



Permit No. WAR007765
 Coverage Effective Date: January 1, 2025
 Permit Issuance Date: December 1, 2024
 Expiration Date: December 31, 2029

THE INDUSTRIAL STORMWATER GENERAL PERMIT MONITORING SUMMARY

Name & Mailing Address

Darrin Moorcroft
 Sierra Pacific Industries
 421 S Front St
 Shelton, WA 98584

Facility Name & Location

BURLINGTON LUMBER FACILITY
 N OF SR 20 & 536
 BURLINGTON, WA 98233

NAICS Codes Representing Activities
 321113

Monitoring Point Information

<u>Feature Name</u>	<u>Monitoring Point Code</u>	<u>Monitoring Point Description</u>	<u>Latitude/ Longitude</u>	<u>NAICS Code(s)</u>	<u>Outfall Type</u>	<u>Name of Surface Waterbody</u>
SWS1	SWS1	Discharge to unnamed stream	48.446110 / -122.433891	321113	Surface Water Body	SURFACE WATER SAMPLING LOCATION 1 NEAR POND
SWS2	SWS2	Discharge to unnamed stream	48.446110 / -122.434998	321113	Surface Water Body	STORMWATER SAMPLING LOCATION 2

Below is a summary of updated monitoring requirements based on the recently reissued ISGP, effective January 1, 2025. Please review this information and contact your permit administrator, Melinda Wilson at MEWI461@ecy.wa.gov or (360) 870-8290, if you have questions or believe any of this information is incorrect.

<u>Parameter</u>	<u>Unit</u>	<u>Value</u>	<u>Method</u>	<u>Quantitation</u>	<u>Frequency</u>
Feature SWS2 Monitoring Point SWS2					
ISGP Western WA - 2025 Permit					
Turbidity	NTU	Benchmark Value: 25	EPA 180.1 Meter	0.5	1/quarter
pH	SU	Benchmark: Between 5 and 9	Calibrated Meter	±0.1	1/quarter
Oil Sheen	Yes / No	No Visible Oil Sheen	N/A	N/A	1/quarter
Copper, Total	µg/L	Benchmark Value: 14	EPA 200.8	2.0	1/quarter

Zinc, Total	µg/L	Benchmark Value: 117	EPA 200.8	2.5	1/quarter
ISGP Timber Product Industry, Paper & Allied Products - 2025 Permit					
COD	mg/L	Benchmark Value: 120	SM5220-D	10	1/quarter
TSS	mg/L	Benchmark Value: 100	SM2540-D	5.0	1/quarter
Feature SWS1 Monitoring Point SWS1					
ISGP Western WA - 2025 Permit					
Turbidity	NTU	Benchmark Value: 25	EPA 180.1 Meter	0.5	1/quarter
pH	SU	Benchmark: Between 5 and 9	Calibrated Meter	±0.1	1/quarter
Oil Sheen	Yes / No	No Visible Oil Sheen	N/A	N/A	1/quarter
Copper, Total	µg/L	Benchmark Value: 14	EPA 200.8	2.0	1/quarter
Zinc, Total	µg/L	Benchmark Value: 117	EPA 200.8	2.5	1/quarter
ISGP Timber Product Industry, Paper & Allied Products - 2025 Permit					
COD	mg/L	Benchmark Value: 120	SM5220-D	10	1/quarter
TSS	mg/L	Benchmark Value: 100	SM2540-D	5.0	1/quarter

Please refer to the permit for all of the details and fine print per parameter.



Jeff Killelea, Manager
Permit and Technical Services Section
Water Quality Program