



Permit No. WAR011142
Coverage Effective Date: January 1, 2025
Permit Issuance Date: December 1, 2024
Expiration Date: December 31, 2029

**THE INDUSTRIAL STORMWATER GENERAL PERMIT
MONITORING SUMMARY**

Name & Mailing Address

Jerry Peterson
Harco Fittings LLC
PO Box 10335
Lynchburg, VA 24506-0335

Facility Name & Location

Harco Fittings LLC
164 W SMITH RD
BELLINGHAM, WA 98226

NAICS Codes Representing Activities
326122

Monitoring Point Information

<u>Feature Name</u>	<u>Monitoring Point Code</u>	<u>Monitoring Point Description</u>	<u>Latitude/ Longitude</u>	<u>NAICS Code(s)</u>	<u>Outfall Type</u>	<u>Name of Surface Waterbody</u>
DP3	001	001	48.836479 / -122.489403	326122	Surface Water Body	Silver Creek

Below is a summary of updated monitoring requirements based on the recently reissued ISGP, effective January 1, 2025. Please review this information and contact your permit administrator, Melinda Wilson at MEWI461@ecy.wa.gov or (360) 870-8290, if you have questions or believe any of this information is incorrect.

Parameter	Unit	Value	Method	Quantitation	Frequency
Feature DP3 Monitoring Point 001					
ISGP Western WA - 2025 Permit					
Turbidity	NTU	Benchmark Value: 25	EPA 180.1 Meter	0.5	1/quarter
pH	SU	Benchmark: Between 5 and 9	Calibrated Meter	±0.1	1/quarter
Oil Sheen	Yes / No	No Visible Oil Sheen	N/A	N/A	1/quarter
Copper, Total	µg/L	Benchmark Value: 14	EPA 200.8	2.0	1/quarter
Zinc, Total	µg/L	Benchmark Value: 117	EPA 200.8	2.5	1/quarter

Please refer to the permit for all of the details and fine print per parameter.

A handwritten signature in black ink, reading "Jeff Killelea". The signature is written in a cursive, flowing style.

Jeff Killelea, Manager
Permit and Technical Services Section
Water Quality Program