



Permit No. WAR000790
 Coverage Effective Date: January 1, 2025
 Permit Issuance Date: December 1, 2024
 Expiration Date: December 31, 2029

**THE INDUSTRIAL STORMWATER GENERAL PERMIT
 MONITORING SUMMARY**

Name & Mailing Address

Phil Steklenski
 Simpson Door Company
 400 W Simpson Ave
 McCleary, WA 98557-9600

Facility Name & Location

SIMPSON DOOR CO
 400 SIMPSON AVE
 MCCLEARY, WA 98557

NAICS Codes Representing Activities

321911

Monitoring Point Information

<u>Feature Name</u>	<u>Monitoring Point Code</u>	<u>Monitoring Point Description</u>	<u>Latitude/ Longitude</u>	<u>NAICS Code(s)</u>	<u>Outfall Type</u>	<u>Name of Surface Waterbody</u>
1	1	OUTFALL 1	47.058479 / -123.271301	321911	Surface Water Body	OUTFALL 1
2	2	OUTFALL 2	47.057571 / -123.270897	321911	Surface Water Body	OUTFALL 2
4	4	OUTFALL 4	47.055679 / -123.269302	321911	Surface Water Body	OUTFALL 4
5	5	OUTFALL 5	47.056179 / -123.268700	321911	Surface Water Body	OUTFALL 5
6	6	OUTFALL 6	47.055698 / -123.268799	321911	Surface Water Body	OUTFALL 6

Below is a summary of updated monitoring requirements based on the recently reissued ISGP, effective January 1, 2025. Please review this information and contact your permit administrator, Max Graham at gram461@ecy.wa.gov or (564) 200-2505, if you have questions or believe any of this information is incorrect.

Parameter	Unit	Value	Method	Quantitation	Frequency
Feature 1 Monitoring Point 1					
ISGP Western WA - 2025 Permit					
Turbidity	NTU	Benchmark Value: 25	EPA 180.1 Meter	0.5	1/quarter

pH	SU	Benchmark: Between 5 and 9	Calibrated Meter	±0.1	1/quarter
Oil Sheen	Yes / No	No Visible Oil Sheen	N/A	N/A	1/quarter
Copper, Total	µg/L	Benchmark Value: 14	EPA 200.8	2.0	1/quarter
Zinc, Total	µg/L	Benchmark Value: 117	EPA 200.8	2.5	1/quarter
ISGP Timber Product Industry, Paper & Allied Products - 2025 Permit					
COD	mg/L	Benchmark Value: 120	SM5220-D	10	1/quarter
TSS	mg/L	Benchmark Value: 100	SM2540-D	5.0	1/quarter
Feature 5 Monitoring Point 5					
ISGP Western WA - 2025 Permit					
Turbidity	NTU	Benchmark Value: 25	EPA 180.1 Meter	0.5	1/quarter
pH	SU	Benchmark: Between 5 and 9	Calibrated Meter	±0.1	1/quarter
Oil Sheen	Yes / No	No Visible Oil Sheen	N/A	N/A	1/quarter
Copper, Total	µg/L	Benchmark Value: 14	EPA 200.8	2.0	1/quarter
Zinc, Total	µg/L	Benchmark Value: 117	EPA 200.8	2.5	1/quarter
ISGP Timber Product Industry, Paper & Allied Products - 2025 Permit					
COD	mg/L	Benchmark Value: 120	SM5220-D	10	1/quarter
TSS	mg/L	Benchmark Value: 100	SM2540-D	5.0	1/quarter

Please refer to the permit for all of the details and fine print per parameter.



Jeff Killelea, Manager
 Permit and Technical Services Section
 Water Quality Program