



Permit No. WAR008687
 Coverage Effective Date: January 1, 2025
 Permit Issuance Date: December 1, 2024
 Expiration Date: December 31, 2029

THE INDUSTRIAL STORMWATER GENERAL PERMIT MONITORING SUMMARY

Name & Mailing Address

Michael Stobbart
 Lister Chain And Forge, Inc.
 3810 Loomis Trail Rd
 Blaine, WA 98230-9106

Facility Name & Location

LISTER CHAIN & FORGE, INC.
 3810 LOOMIS TRAIL RD
 BLAINE, WA 98230

NAICS Codes Representing Activities
 332111

Monitoring Point Information

<u>Feature Name</u>	<u>Monitoring Point Code</u>	<u>Monitoring Point Description</u>	<u>Latitude/ Longitude</u>	<u>NAICS Code(s)</u>	<u>Outfall Type</u>	<u>Name of Surface Waterbody</u>
003	001	OUTFALL 003	48.950134 / -122.689613	332111	Surface Water Body	OUTFALL 003

Below is a summary of updated monitoring requirements based on the recently reissued ISGP, effective January 1, 2025. Please review this information and contact your permit administrator, Melinda Wilson at MEWI461@ecy.wa.gov or (360) 870-8290, if you have questions or believe any of this information is incorrect.

Parameter	Unit	Value	Method	Quantitation	Frequency
Feature 003 Monitoring Point 001					
ISGP Western WA - 2025 Permit					
Turbidity	NTU	Benchmark Value: 25	EPA 180.1 Meter	0.5	1/quarter
pH	SU	Benchmark: Between 5 and 9	Calibrated Meter	±0.1	1/quarter
Oil Sheen	Yes / No	No Visible Oil Sheen	N/A	N/A	1/quarter
Copper, Total	µg/L	Benchmark Value: 14	EPA 200.8	2.0	1/quarter
Zinc, Total	µg/L	Benchmark Value: 117	EPA 200.8	2.5	1/quarter
ISGP Primary Metals, Metals Mining, Auto Scrap Salvage Recycling, Metals Fab - 2025 Permit					
Lead, Total	µg/L	Benchmark Value: 64.6	EPA 200.8	0.5	1/quarter

Petroleum Hydrocarbons (Diesel-range organics and heavy oils)	mg/L	Benchmark Value: 10	NWTPH-Dx	0.25	1/quarter
---	------	---------------------	----------	------	-----------

Please refer to the permit for all of the details and fine print per parameter.

A handwritten signature in black ink, appearing to read "Jeff Killelea". The signature is fluid and cursive, with the first name "Jeff" being more prominent than the last name "Killelea".

Jeff Killelea, Manager
Permit and Technical Services Section
Water Quality Program