



Permit No. WAR011443
 Coverage Effective Date: January 1, 2025
 Permit Issuance Date: December 1, 2024
 Expiration Date: December 31, 2029

THE INDUSTRIAL STORMWATER GENERAL PERMIT MONITORING SUMMARY

Name & Mailing Address

Michael Sorenson
 Milne Fruit Products, Inc.
 108 Blaine Ave
 Sunnyside, WA 98944-1458

Facility Name & Location

Milne Fruit Products
 108 BLAINE AVE
 SUNNYSIDE, WA 98944

NAICS Codes Representing Activities
 311411

Monitoring Point Information

<u>Feature Name</u>	<u>Monitoring Point Code</u>	<u>Monitoring Point Description</u>	<u>Latitude/ Longitude</u>	<u>NAICS Code(s)</u>	<u>Outfall Type</u>	<u>Name of Surface Waterbody</u>
WP2	002	Briner	46.329441 / -120.022202	311411	Surface Water Body	WP2

Below is a summary of updated monitoring requirements based on the recently reissued ISGP, effective January 1, 2025. Please review this information and contact your permit administrator, Collin Smith at cosm461@ecy.wa.gov or (564) 669-9319, if you have questions or believe any of this information is incorrect.

Parameter	Unit	Value	Method	Quantitation	Frequency
Feature WP2 Monitoring Point 002					
ISGP Eastern WA - 2025 Permit					
Turbidity	NTU	Benchmark Value: 25	EPA 180.1 Meter	0.5	1/quarter
pH	SU	Benchmark: Between 5 and 9	Calibrated Meter	±0.1	1/quarter
Oil Sheen	Yes / No	No Visible Oil Sheen	N/A	N/A	1/quarter
Copper, Total	µg/L	Benchmark Value: 32	EPA 200.8	2.0	1/quarter
Zinc, Total	µg/L	Benchmark Value: 117	EPA 200.8	2.5	1/quarter
ISGP Chem, Allied, Food & Kindred - 2025 Permit					
BOD ₅	mg/L	Benchmark Value: 30	SM 5210B	2.0	1/quarter

Nitrate + Nitrite Nitrogen, as N	mg/L	Benchmark Value: 0.68	SM 4500- NO ³ -E/F/H	0.10	1/quarter
Phosphorus, Total	mg/L	Benchmark Value: 2	EPA 365.1	0.01	1/quarter

Please refer to the permit for all of the details and fine print per parameter.



Jeff Killelea, Manager
Permit and Technical Services Section
Water Quality Program