



Permit No. WAR000083
Coverage Effective Date: January 1, 2025
Permit Issuance Date: December 1, 2024
Expiration Date: December 31, 2029

**THE INDUSTRIAL STORMWATER GENERAL PERMIT
MONITORING SUMMARY**

Name & Mailing Address

Jesse Waknitz
Port Of Port Angeles
PO Box 1350
Port Angeles, WA 98362-0251

Facility Name & Location

WM R FAIRCHILD INTL AIRPORT
1402 FAIRCHILD INTERNATIONAL
AIRPORT
PORT ANGELES, WA 98362

NAICS Codes Representating Activities
481112, 481211, 113310, 621910

Monitoring Point Information

<u>Feature Name</u>	<u>Monitoring Point Code</u>	<u>Monitoring Point Description</u>	<u>Latitude/ Longitude</u>	<u>NAICS Code(s)</u>	<u>Outfall Type</u>	<u>Name of Surface Waterbody</u>
A	A	DRY CREEK (DC)	48.122299 / -123.516197	113310, 321999, 481111, 481112, 481211, 621910	Surface Water Body	BASIN A OUTLET
B	B	BASIN B OUTLET	48.127010 / -123.507103	113310, 321999, 481111, 481112, 481211, 621910	Surface Water Body	BASIN B OUTLET

Below is a summary of updated monitoring requirements based on the recently reissued ISGP, effective January 1, 2025. Please review this information and contact your permit administrator, Max Graham at gram461@ecy.wa.gov or (564) 200-2505, if you have questions or believe any of this information is incorrect.

Parameter	Unit	Value	Method	Quantitation	Frequency
-----------	------	-------	--------	--------------	-----------

Feature A Monitoring Point A					
ISGP Western WA - 2025 Permit					
Turbidity	NTU	Benchmark Value: 25	EPA 180.1 Meter	0.5	1/quarter
pH	SU	Benchmark: Between 5 and 9	Calibrated Meter	±0.1	1/quarter
Oil Sheen	Yes / No	No Visible Oil Sheen	N/A	N/A	1/quarter
Copper, Total	µg/L	Benchmark Value: 14	EPA 200.8	2.0	1/quarter
Zinc, Total	µg/L	Benchmark Value: 117	EPA 200.8	2.5	1/quarter
2025 ISGP 6PPDQ Monitoring					
6PPD-quinone	ng/L	Report Only	EPA – Draft Method 1634 or Other EPA or Ecology-approved Method	2.0 ng/L	1/quarter
ISGP Air Transportation - 2025 Permit					
Total Ammonia (as N)	µg/L	Benchmark Value: 2.1	SM4500-NH3-G/H	0.02	1/quarter
BOD ₅	mg/L	Benchmark Value: 30	SM 5210B	2.0	1/quarter
COD	mg/L	Benchmark Value: 120	SM5220-D	10	1/quarter
Nitrate + Nitrite Nitrogen, as N	mg/L	Benchmark Value: 0.68	SM 4500-NO ³ -E/F/H	0.10	1/quarter
Petroleum Hydrocarbons (Diesel-range organics and heavy oils)	mg/L	Benchmark Value: 10	NWTPH-Dx	0.25	1/quarter
PFOA	ng/L	Report Only	EPA 1633	≤ 4.0 ng/L	1/quarter
PFOS	ng/L	Report Only	EPA 1633	≤ 4.0 ng/L	1/quarter
PFHxS	ng/L	Report Only	EPA 1633	≤ 10.0 ng/L	1/quarter
PFNA	ng/L	Report Only	EPA 1633	≤ 10.0 ng/L	1/quarter
HFPO-DA	ng/L	Report Only	EPA 1633	≤ 10.0 ng/L	1/quarter
PFBS	ng/L	Report Only	EPA 1633	≤ 10.0 ng/L	1/quarter
ISGP Timber Product Industry, Paper & Allied Products - 2025 Permit					
COD	mg/L	Benchmark Value: 120	SM5220-D	10	1/quarter
TSS	mg/L	Benchmark Value: 100	SM2540-D	5.0	1/quarter

Please refer to the permit for all of the details and fine print per parameter. 6ppd monitoring is required beginning January 1, 2028.

A handwritten signature in black ink, reading "Jeff Killelea". The signature is written in a cursive, flowing style.

Jeff Killelea, Manager
Permit and Technical Services Section
Water Quality Program