



Permit No. WAR000507
Coverage Effective Date: January 1, 2025
Permit Issuance Date: December 1, 2024
Expiration Date: December 31, 2029

**THE INDUSTRIAL STORMWATER GENERAL PERMIT
MONITORING SUMMARY**

Name & Mailing Address

Richard Guerriero
Ocean Spray Cranberries Inc Aber
1480 State Route 105
Aberdeen, WA 98520-9524

Facility Name & Location

OCEAN SPRAY MARKHAM FACILITY
1480 SR 105
Aberdeen, WA 98520

NAICS Codes Representing Activities
311421

Monitoring Point Information

<u>Feature Name</u>	<u>Monitoring Point Code</u>	<u>Monitoring Point Description</u>	<u>Latitude/ Longitude</u>	<u>NAICS Code(s)</u>	<u>Outfall Type</u>	<u>Name of Surface Waterbody</u>
DBC	DBC	SWDB C Low Area Groundwater	46.905998 / -123.995598	311421	Ground	
SWNO	SWNO	NORTH POND	46.905491 / -123.998802	311421	Surface Water Body	NORTH POND
SWSO	SWSO	DISCHARGE SOUTHWEST STORMWATER OUTFALL	46.902988 / -123.999397	311421	Surface Water Body	DISCHARGE SOUTHWEST STORMWATER OUTFALL

Below is a summary of updated monitoring requirements based on the recently reissued ISGP, effective January 1, 2025. Please review this information and contact your permit administrator, Max Graham at gram461@ecy.wa.gov or (564) 200-2505, if you have questions or believe any of this information is incorrect.

Parameter	Unit	Value	Method	Quantitation	Frequency
Feature DBC Monitoring Point DBC					
ISGP Western WA - 2025 Permit					
Turbidity	NTU	Benchmark Value: 25	EPA 180.1 Meter	0.5	1/quarter
pH	SU	Benchmark: Between 5 and 9	Calibrated Meter	±0.1	1/quarter

Oil Sheen	Yes / No	No Visible Oil Sheen	N/A	N/A	1/quarter
Copper, Total	µg/L	Benchmark Value: 14	EPA 200.8	2.0	1/quarter
Zinc, Total	µg/L	Benchmark Value: 117	EPA 200.8	2.5	1/quarter
ISGP Chem, Allied, Food & Kindred - 2025 Permit					
BOD ₅	mg/L	Benchmark Value: 30	SM 5210B	2.0	1/quarter
Nitrate + Nitrite Nitrogen, as N	mg/L	Benchmark Value: 0.68	SM 4500-NO ³ -E/F/H	0.10	1/quarter
Phosphorus, Total	mg/L	Benchmark Value: 2	EPA 365.1	0.01	1/quarter
Feature SWSO Monitoring Point SWSO					
ISGP Western WA - 2025 Permit					
Turbidity	NTU	Benchmark Value: 25	EPA 180.1 Meter	0.5	1/quarter
pH	SU	Benchmark: Between 5 and 9	Calibrated Meter	±0.1	1/quarter
Oil Sheen	Yes / No	No Visible Oil Sheen	N/A	N/A	1/quarter
Copper, Total	µg/L	Benchmark Value: 14	EPA 200.8	2.0	1/quarter
Zinc, Total	µg/L	Benchmark Value: 117	EPA 200.8	2.5	1/quarter
ISGP Chem, Allied, Food & Kindred - 2025 Permit					
BOD ₅	mg/L	Benchmark Value: 30	SM 5210B	2.0	1/quarter
Nitrate + Nitrite Nitrogen, as N	mg/L	Benchmark Value: 0.68	SM 4500-NO ³ -E/F/H	0.10	1/quarter
Phosphorus, Total	mg/L	Benchmark Value: 2	EPA 365.1	0.01	1/quarter
Feature SWNO Monitoring Point SWNO					
ISGP Western WA - 2025 Permit					
Turbidity	NTU	Benchmark Value: 25	EPA 180.1 Meter	0.5	1/quarter
pH	SU	Benchmark: Between 5 and 9	Calibrated Meter	±0.1	1/quarter
Oil Sheen	Yes / No	No Visible Oil Sheen	N/A	N/A	1/quarter
Copper, Total	µg/L	Benchmark Value: 14	EPA 200.8	2.0	1/quarter
Zinc, Total	µg/L	Benchmark Value: 117	EPA 200.8	2.5	1/quarter
ISGP Chem, Allied, Food & Kindred - 2025 Permit					
BOD ₅	mg/L	Benchmark Value: 30	SM 5210B	2.0	1/quarter
Nitrate + Nitrite Nitrogen, as N	mg/L	Benchmark Value: 0.68	SM 4500-NO ³ -E/F/H	0.10	1/quarter
Phosphorus, Total	mg/L	Benchmark Value: 2	EPA 365.1	0.01	1/quarter

Please refer to the permit for all of the details and fine print per parameter.

A handwritten signature in black ink, reading "Jeff Killelea". The signature is written in a cursive, flowing style.

Jeff Killelea, Manager
Permit and Technical Services Section
Water Quality Program