



Permit No. WAR000840  
 Coverage Effective Date: January 1, 2025  
 Permit Issuance Date: December 1, 2024  
 Expiration Date: December 31, 2029

**THE INDUSTRIAL STORMWATER GENERAL PERMIT  
 MONITORING SUMMARY**

Name & Mailing Address

Joel Larsen  
 Al's Lynnwood Truck Parts  
 13311 Highway 99  
 Everett, WA 98204-5423

Facility Name & Location

ALS LYNNWOOD TRUCK PARTS  
 13311 HWY 99  
 EVERETT, WA 98204-5423

NAICS Codes Representing Activities

441310

**Monitoring Point Information**

<u>Feature Name</u>	<u>Monitoring Point Code</u>	<u>Monitoring Point Description</u>	<u>Latitude/ Longitude</u>	<u>NAICS Code(s)</u>	<u>Outfall Type</u>	<u>Name of Surface Waterbody</u>
SW1	001	SW 3	47.876110 / -122.268097	441310	Surface Water Body	DISCHARGE PT 1

Below is a summary of updated monitoring requirements based on the recently reissued ISGP, effective January 1, 2025. Please review this information and contact your permit administrator, Collin Smith at [cosm461@ecy.wa.gov](mailto:cosm461@ecy.wa.gov) or (564) 669-9319, if you have questions or believe any of this information is incorrect.

<b>Parameter</b>	<b>Unit</b>	<b>Value</b>	<b>Method</b>	<b>Quantitation</b>	<b>Frequency</b>
Feature SW1 Monitoring Point 001					
ISGP Western WA - 2025 Permit					
Turbidity	NTU	Benchmark Value: 25	EPA 180.1 Meter	0.5	1/quarter
pH	SU	Benchmark: Between 5 and 9	Calibrated Meter	±0.1	1/quarter
Oil Sheen	Yes / No	No Visible Oil Sheen	N/A	N/A	1/quarter
Copper, Total	µg/L	Benchmark Value: 14	EPA 200.8	2.0	1/quarter
Zinc, Total	µg/L	Benchmark Value: 117	EPA 200.8	2.5	1/quarter

Please refer to the permit for all of the details and fine print per parameter.

A handwritten signature in black ink, reading "Jeff Killelea". The signature is written in a cursive style with a large, looped initial "J".

Jeff Killelea, Manager  
Permit and Technical Services Section  
Water Quality Program