



Permit No. WAR310172
 Coverage Effective Date: January 1, 2025
 Permit Issuance Date: December 1, 2024
 Expiration Date: December 31, 2029

THE INDUSTRIAL STORMWATER GENERAL PERMIT MONITORING SUMMARY

Name & Mailing Address

Tom Sroufe
 Snoqualmie Mill Ventures, LLC
 249 Main Ave S Ste 107, PMB 364
 North Bend, WA 98045-5016

Facility Name & Location

Snoqualmie Mill Industrial Areas
 SE Stearns Rd & SE Haul Road
 Snoqualmie, WA 98065

NAICS Codes Representing Activities
 532412, 113310

Monitoring Point Information

<u>Feature Name</u>	<u>Monitoring Point Code</u>	<u>Monitoring Point Description</u>	<u>Latitude/ Longitude</u>	<u>NAICS Code(s)</u>	<u>Outfall Type</u>	<u>Name of Surface Waterbody</u>
OF01	DP02	Discharge Point 02	47.543118 / -121.817223	113310, 532412	Surface Water Body	Wetland 6
OF01	SP02	Sampling Point 02	47.543278 / -121.816376	113310, 532412	Surface Water Body	Wetland 6
OF02	DP02	Discharge Point02	47.542660 / -121.815956	113310, 532412	Surface Water Body	Wetland 1
OF03	DP02	Discharge Point 02	47.542751 / -121.817551	113310, 532412	Surface Water Body	Wetland 6
OF04	SP01	Sampling Point 01	47.541943 / -121.817139	113310, 532412	Surface Water Body	Wetland 2
OF5	DP01	Discharge Point 01	47.541115 / -121.817543	113310, 532412	Surface Water Body	Wetland 4
OF5	SP01	Sampling Point 01	47.541092 / -121.817474	113310, 532412	Surface Water Body	Wetland 4

Below is a summary of updated monitoring requirements based on the recently reissued ISGP, effective January 1, 2025. Please review this information and contact your permit administrator, Alyssa Brewer at ALYB461@ecy.wa.gov or (564) 669-4922, if you have questions or believe any of this information is incorrect.

Parameter	Unit	Value	Method	Quantitation	Frequency
Feature OF01 Monitoring Point SP02					
ISGP Western WA - 2025 Permit					
Turbidity	NTU	Benchmark Value: 25	EPA 180.1 Meter	0.5	1/quarter
pH	SU	Benchmark: Between 5 and 9	Calibrated Meter	±0.1	1/quarter
Oil Sheen	Yes / No	No Visible Oil Sheen	N/A	N/A	1/quarter
Copper, Total	µg/L	Benchmark Value: 14	EPA 200.8	2.0	1/quarter
Zinc, Total	µg/L	Benchmark Value: 117	EPA 200.8	2.5	1/quarter
ISGP Timber Product Industry, Paper & Allied Products - 2025 Permit					
COD	mg/L	Benchmark Value: 120	SM5220-D	10	1/quarter
TSS	mg/L	Benchmark Value: 100	SM2540-D	5.0	1/quarter
ISGP Transportation, Petroleum Bulk Stations & Terminals- 2025 Permit					
Petroleum Hydrocarbons (Diesel-range organics and heavy oils)	mg/L	Benchmark Value: 10	NWTPH-Dx	0.25	1/quarter
Feature OF5 Monitoring Point SP01					
ISGP Western WA - 2025 Permit					
Turbidity	NTU	Benchmark Value: 25	EPA 180.1 Meter	0.5	1/quarter
pH	SU	Benchmark: Between 5 and 9	Calibrated Meter	±0.1	1/quarter
Oil Sheen	Yes / No	No Visible Oil Sheen	N/A	N/A	1/quarter
Copper, Total	µg/L	Benchmark Value: 14	EPA 200.8	2.0	1/quarter
Zinc, Total	µg/L	Benchmark Value: 117	EPA 200.8	2.5	1/quarter
ISGP Timber Product Industry, Paper & Allied Products - 2025 Permit					
COD	mg/L	Benchmark Value: 120	SM5220-D	10	1/quarter
TSS	mg/L	Benchmark Value: 100	SM2540-D	5.0	1/quarter
ISGP Transportation, Petroleum Bulk Stations & Terminals- 2025 Permit					
Petroleum Hydrocarbons (Diesel-range organics and heavy oils)	mg/L	Benchmark Value: 10	NWTPH-Dx	0.25	1/quarter

Please refer to the permit for all of the details and fine print per parameter.

A handwritten signature in black ink, reading "Jeff Killelea". The signature is written in a cursive, flowing style.

Jeff Killelea, Manager
Permit and Technical Services Section
Water Quality Program