



Permit No. WAR000727  
Coverage Effective Date: January 1, 2025  
Permit Issuance Date: December 1, 2024  
Expiration Date: December 31, 2029

**THE INDUSTRIAL STORMWATER GENERAL PERMIT  
MONITORING SUMMARY**

Name & Mailing Address

Brandon Smith  
Pierce County Planning and Public Works  
2401 S 35th St Rm 2  
Tacoma, WA 98409-7460

Facility Name & Location

CHAMBERS CREEK WWTP  
10311 CHAMBERS CREEK RD W  
UNIVERSITY PLACE, WA 98467-1040

NAICS Codes Representing Activities  
221320

Monitoring Point Information

<u>Feature Name</u>	<u>Monitoring Point Code</u>	<u>Monitoring Point Description</u>	<u>Latitude/ Longitude</u>	<u>NAICS Code(s)</u>	<u>Outfall Type</u>	<u>Name of Surface Waterbody</u>
SWO	SWO	STORM WATER OUTFALL	47.190460 / -122.575188	221320	Surface Water Body	STORM WATER OUTFALL

Below is a summary of updated monitoring requirements based on the recently reissued ISGP, effective January 1, 2025. Please review this information and contact your permit administrator, Melinda Wilson at MEWI461@ecy.wa.gov or (360) 870-8290, if you have questions or believe any of this information is incorrect.

Parameter	Unit	Value	Method	Quantitation	Frequency
Feature SWO Monitoring Point SWO					
ISGP Western WA - 2025 Permit					
Turbidity	NTU	Benchmark Value: 25	EPA 180.1 Meter	0.5	1/quarter
pH	SU	Benchmark: Between 5 and 9	Calibrated Meter	±0.1	1/quarter
Oil Sheen	Yes / No	No Visible Oil Sheen	N/A	N/A	1/quarter
Copper, Total	µg/L	Benchmark Value: 14	EPA 200.8	2.0	1/quarter
Zinc, Total	µg/L	Benchmark Value: 117	EPA 200.8	2.5	1/quarter

Please refer to the permit for all of the details and fine print per parameter.

A handwritten signature in black ink, reading "Jeff Killelea". The signature is written in a cursive, flowing style.

Jeff Killelea, Manager  
Permit and Technical Services Section  
Water Quality Program