



Permit No. WAR002920  
Coverage Effective Date: January 1, 2025  
Permit Issuance Date: December 1, 2024  
Expiration Date: December 31, 2029

### THE INDUSTRIAL STORMWATER GENERAL PERMIT MONITORING SUMMARY

Name & Mailing Address

Amy Wentworth  
Pacific Shellfish South Bend LLC  
PO Box 97  
Clackamas, OR 97015-0097

Facility Name & Location

Pacific Shellfish South Bend LLC  
1200 ROBERT BUSH DR  
SOUTH BEND, WA 98586-0166

NAICS Codes Representing Activities  
311710

Monitoring Point Information

<u>Feature Name</u>	<u>Monitoring Point Code</u>	<u>Monitoring Point Description</u>	<u>Latitude/ Longitude</u>	<u>NAICS Code(s)</u>	<u>Outfall Type</u>	<u>Name of Surface Waterbody</u>
1	1	DISCHARGE 1	46.667580 / -123.812401	311710	Surface Water Body	DISCHARGE 1
2	OV2	OV2	46.666809 / -123.811798	311710	Surface Water Body	Point 2

Below is a summary of updated monitoring requirements based on the recently reissued ISGP, effective January 1, 2025. Please review this information and contact your permit administrator, Max Graham at [gram461@ecy.wa.gov](mailto:gram461@ecy.wa.gov) or (564) 200-2505, if you have questions or believe any of this information is incorrect.

<u>Parameter</u>	<u>Unit</u>	<u>Value</u>	<u>Method</u>	<u>Quantitation</u>	<u>Frequency</u>
Feature 2 Monitoring Point OV2					
ISGP Western WA - 2025 Permit					
Turbidity	NTU	Benchmark Value: 25	EPA 180.1 Meter	0.5	1/quarter
pH	SU	Benchmark: Between 5 and 9	Calibrated Meter	±0.1	1/quarter
Oil Sheen	Yes / No	No Visible Oil Sheen	N/A	N/A	1/quarter
Copper, Total	µg/L	Benchmark Value: 14	EPA 200.8	2.0	1/quarter
Zinc, Total	µg/L	Benchmark Value: 117	EPA 200.8	2.5	1/quarter

ISGP Chem, Allied, Food & Kindred - 2025 Permit					
BOD <sub>5</sub>	mg/L	Benchmark Value: 30	SM 5210B	2.0	1/quarter
Nitrate + Nitrite Nitrogen, as N	mg/L	Benchmark Value: 0.68	SM 4500-NO <sup>3</sup> -E/F/H	0.10	1/quarter
Phosphorus, Total	mg/L	Benchmark Value: 2	EPA 365.1	0.01	1/quarter
Feature 1 Monitoring Point 1					
ISGP Western WA - 2025 Permit					
Turbidity	NTU	Benchmark Value: 25	EPA 180.1 Meter	0.5	1/quarter
pH	SU	Benchmark: Between 5 and 9	Calibrated Meter	±0.1	1/quarter
Oil Sheen	Yes / No	No Visible Oil Sheen	N/A	N/A	1/quarter
Copper, Total	µg/L	Benchmark Value: 14	EPA 200.8	2.0	1/quarter
Zinc, Total	µg/L	Benchmark Value: 117	EPA 200.8	2.5	1/quarter
ISGP Chem, Allied, Food & Kindred - 2025 Permit					
BOD <sub>5</sub>	mg/L	Benchmark Value: 30	SM 5210B	2.0	1/quarter
Nitrate + Nitrite Nitrogen, as N	mg/L	Benchmark Value: 0.68	SM 4500-NO <sup>3</sup> -E/F/H	0.10	1/quarter
Phosphorus, Total	mg/L	Benchmark Value: 2	EPA 365.1	0.01	1/quarter

Please refer to the permit for all of the details and fine print per parameter.



Jeff Killelea, Manager  
Permit and Technical Services Section  
Water Quality Program