

NUCOR STEEL SEATTLE, INC.

2424 SW Andover Street
Seattle, WA 98106-1100
206.933.2222

April 11, 2025

Jeanne Tran
WA State Dept. of Ecology
P.O. Box 330316
Shoreline, WA 98133-9716

SUBJECT: ADDENDUM - Notice of potential Non-Compliance – Discharge of Contact Cooling Water to Stormwater Drains prior to Treatment System

Dear Ms. Tran:


This letter is a follow-up to the 5-Day Report provided on 4/4/2025 to report a Contact Cooling Water discharge to Stormwater Drains Prior to Treatment System.

Stormwater discharge samples we had taken within an hour of discovery on 3/31/2025, as well as approximately one day later on 4/1/2025. Analysis for both of these samples show typical results for the facility and no exceedances of stormwater permit parameters. These samples will be documented with DMR submittals and are also attached for your review.

Nucor also performed a Root Cause Analysis for the incident. As a result of the conversation, we have added a specific requirement for site personnel to inspect the condition of the drain every 12 hours during system operation. We have also scheduled a contractor to cut a larger opening in the portion of the drain that became clogged (and caused this incident). We are confident these actions will prevent future events in this system.

Please call me on 206-933-2205 if you have any questions or comments.

Respectfully,



Jeffrey Eis
Environmental Engineer
Nucor Steel Seattle, Inc.