



STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY

Central Region Office

1250 West Alder St., Union Gap, WA 98903-0009 • 509-575-2490

April 30, 2025

Brad Long
Long Properties IV, LLC
P.O. Box 9783
Yakima, WA 98909-9783

Sent via email only: bradl@gslong.com

Dear Brad Long,

RE: Discharge Monitoring Report for Long Properties IV, LLC--WAG435186

Ecology has reviewed your [2024](#) annual discharge monitoring reports (DMR's). The table below summarizes the permit violations found. The purpose of this letter is to provide you an opportunity to review these violations and submit corrections if the records are not accurate.

[2024-WAG435186—GS Long Facility](#)

Outfall No(s).	Parameter	Date	Reported Value	Permit Limit
001	<u>Missing Analysis Violations*</u> pH Standard Units (SU); Total Residual Chlorine, mg/L; Total Suspended Solids (TSS), mg/L; Chloride, mg/L; Temperature, °C; Biochemical Oxygen Demand (BOD), mg/L	Three Quarters	No reported value	Once per quarter required
003	<u>Numeric Effluent Violations</u> Total Residual Chlorine, mg/L	01/04/2024 04/09/2024 09/18/2024 12/16/2024	0.14 0.13 0.12 0.16	<0.05 <0.05 <0.05 <0.05
004	<u>Missing Analysis Violations*</u> pH, SU; Total Residual Chlorine, mg/L; TSS, mg/L; Chloride, mg/L; Temperature, °C; BOD, mg/L	Three Quarters	No reported value	Once per quarter required

Brad Long
April 30, 2025
Page 2

006	<u>Numeric Effluent Violations</u> pH, SU	12/16/2024	9.65	6.00-9.00
-----	--	------------	------	-----------

*These may be reporting errors. Please call for instructions on how to properly fill out DMR's.

Reduce the amount of additives in your discharge for outfall 003 or use a dichlorination agent in the discharge. Please correct that for the 2025 reporting year.

If you have any questions or concerns, please contact me at 509-406-6624 (cell), or email marcia.porter@ecy.wa.gov.

Sincerely,



Marcia Porter
Fresh Fruit Packing General Permit Manager
Dept. of Ecology

e.c. Nick Longmire, Long Properties IV, LLC. nickl@gslong.com
Robert Busch, Long Properties IV, LLC robertb@gslong.com