

Reporting Jurisdiction Name, Address

Ecology ERTS #: 739094

LOTT Incident #:

SSO - SANITARY SEWER OVERFLOW REPORTING AND INFORMATION SHEET

Call made to LOTT by: Sydney Pype

Time call was placed:

E-Mailed reporting time: 3:40 PM

Today's Date: 5/27/2025

<input checked="" type="checkbox"/>
<input type="checkbox"/>
<input type="checkbox"/>
<input type="checkbox"/>

INITIAL REPORT

FOLLOW-UP REPORT

ON-GOING INCIDENT

OTHER

Name: Sydney Pype of City of Olympia Phone: 360-628-0589
Person reporting the spill to LOTT Agency

Spill began: 5/27/2025 at 10:45 AM Spill stopped: 5/27/2025 at 1:00 PM
Date Time Date Time

Gallons spilled: 100-500 Material spilled: SSO - Raw Sewage / STEP

Spill Location: 1319 14th Ave SW
Address, manhole, nearest intersection or other identifiable location

Spilled to: ☐ ground, no run-off includes storm ponds ☒ Run-off to: Street, catch basin, storm pond
Street, catch basin, storm sewer

Reached the Waters of the State

☐ Yes ☒ No

Bodies of Water
Name of stream or water body

Cause of spill: Line blockage
Line blockage, CSO, STEP system malfunction, etc.

Clean-up & disposal: clean-up by Olympia O&M staff
Actions taken & by whom

Prevention: Staff did not give details on prevention
Actions taken to prevent re-occurrence (clean line, replace equipment, etc.)

Notifications by EMAIL or PHONE

NAME	CALLED (TIME, DATE & INITIALS)	EMAILED (TIME, DATE & INITIALS)
Department of Ecology - 360.407.6300	1:02 PM, 5-27-25, SP	
Thurston County Health 360.968.4346 (Tristen P.) or 360.867.2535 (Stuart W.) emwebmaster@co.thurston.wa.us	n/a	

Dept. of Health - Shellfish - 360.236.3330 - 360.789.8962	n/a	
LOTT - 360.528.5700		EMAILED (TIME, DATE & INITIALS)
Operations and Facilities		0800, 5-28-25, MJV
Environmental Planning & Communications Dir		0800, 5-28-25, MJV
Process Control Sup.		
Operations Supervisor		

