



---

THIS REPORT HAS BEEN FINALIZED AND CAN BE RELEASED.

**LOTT ALLIANCE**  
**SANITARY SEWER OVERFLOW INCIDENT REPORT**

**WASHINGTON STATE DEPARTMENT OF ECOLOGY:**

24-Hour Spill Hotline Number	360-407-6300
Dave Dougherty, NPDES Permit Manager	360-407-6278

**Initial SSO Report** received or witnessed by: Sydney Pype, City of Olympia  
Date / Time: 5/27/25 @ 1045

**Investigation** dispatched to, or conducted by: Matt Valenta, LOTT Clean Water Alliance  
Date / Time: 5/27/25 @ 1540 (email)  
Field person in charge: Sydney Pype, City of Olympia

**Location** of overflow: 1319 14<sup>th</sup> Ave SW, Olympia  
Material discharged (i.e. raw sewage, etc.): Sewage  
Area affected by discharge (i.e. storm sewer, surface water, etc.): Sewage spill was due to a line blockage

**Time** overflow started: 5/27/25 @ 1045  
Time overflow stopped: 5/27/25 @ 1300  
Estimate volume discharged (gal.): 100-500 gallons  
How was this volume determined? (i.e. meter, calculation, estimation, etc.) Staff calculated volume using eyeball estimation of area where event is occurring.

**Ecology 24-Hour Spill Hotline** notified at: 5/27/25  
LOTT Spill No: n/a Ecology ERTS No: 739094 WA Emergency Mgmt. n/a


**Ecology verbal notification details:**  
(exactly what information was conveyed to spill hotline dispatcher, i.e. start/stop times, volume, location, area affected, etc.) A sewage spill occurred at the above address due to a line blockage. 100 – 500 gallons spilled to the street, catch basin and storm pond.

**Overflow details** caused by: (briefly describe what caused overflow to occur, and what was done to stop overflow) Sewage spill was due to contractor boring through sewer main. City staff cleaned SSO residual around area where event occurred.

**Action taken:**

(what has been or will be done to prevent a reoccurrence of this event)  
No additional details were provided.

For more information contact: Matt Valenta, Plant Manager LOTT Clean Water Alliance

Signature: 

Matt Valenta  
Phone Number: 360-528-5724

---

Photos:

THIS REPORT HAS BEEN FINALIZED AND CAN BE RELEASED.