

Reporting Jurisdiction Name, Address

Ecology ERTS #: 739309

SSO - SANITARY SEWER OVERFLOW REPORTING AND INFORMATION SHEET

Call made to LOTT by: Sydney Pype

Time call was placed: _____

E-Mailed reporting time: 12:00

Today's Date: 6/5/2025

<input checked="" type="checkbox"/>	INITIAL REPORT
<input type="checkbox"/>	FOLLOW-UP REPORT
<input type="checkbox"/>	ON-GOING INCIDENT
<input type="checkbox"/>	OTHER _____

Name: Sydney Pype of City of Olympia Phone: 360-628-0589
Person reporting the spill to LOTT Agency

Spill began: 6/4/2025 at n/a Spill stopped: 6/5/2025 at n/a
Date Time Date Time

Gallons spilled: n/a Material spilled: SSO - Raw Sewage / STEP

Spill Location: 1903 16th Ave SE, Olympia
Address, manhole, nearest intersection or other identifiable location

Spilled to: ☒ ground, no run-off ☐ Run-off to: _____
includes storm ponds Street, catch basin, storm sewer

Reached the Waters of the State

☒ Yes ☐ No Bodies of Water Indian/Moxlie Creek
Name of stream or water body

Cause of spill: Private property - Grinder Pump system failed
Line blockage, CSO, STEP system malfunction, etc.

Clean-up & disposal: Private property, property owner will be responsible for fixing the infrastructure on their property. The spill is non-recoverable due to no surface flow.
Actions taken & by whom

Prevention: Staff did not provide details on prevention
Actions taken to prevent re-occurrence (clean line, replace equipment, etc.)

Notifications by EMAIL or PHONE

NAME	CALLED (TIME, DATE & INITIALS)	EMAILED (TIME, DATE & INITIALS)
Department of Ecology - 360.407.6300	1021_6/5/25_SP	
Thurston County Health 360.968.4346 (Tristen P.) or 360.867.2535 (Stuart W.) emwebmaster@co.thurston.wa.u	0615_6/6/25_msg	

Dept. of Health - Shellfish - 360.236.3330 - 360.789.8962	n/a	
LOTT - 360.528.5700		EMAILED (TIME, DATE & INITIALS)
Operations and Facilities		0620_6/6/25_map
Environmental Planning & Communications Dir		0620_6/6/25_map
Process Control Sup.		0620_6/6/25_map
Operations Superviror		0620_6/6/25_map

