



THIS REPORT HAS BEEN FINALIZED AND CAN BE RELEASED.

LOTT ALLIANCE
SANITARY SEWER OVERFLOW INCIDENT REPORT

WASHINGTON STATE DEPARTMENT OF ECOLOGY:

24-Hour Spill Hotline Number	360-407-6300
Dave Dougherty, NPDES Permit Manager	360-407-6278

Initial SSO Report received or witnessed by: Sydney Pype, City of Olympia
Date / Time: 6/15/25 @ 1030

Investigation dispatched to, or conducted by: Mark Petrie, LOTT Clean Water Alliance
Date / Time: 6/16/25 @ 1450 (email)
Field person in charge: Sydney Pype, City of Olympia

Location of overflow: 1102 Legion Way SE, Olympia
Material discharged (i.e. raw sewage, etc.): Sewage
Area affected by discharge (i.e. storm sewer, surface water, etc.): Sewage spill was due to a blockage in private sewer lateral.

Time overflow started: 6/15/25 @ 1030
Time overflow stopped: 6/15/25 @ 1112
Estimate volume discharged (gal.): 25-50 gallon SSO event
How was this volume determined? (i.e. meter, calculation, estimation, etc.) visual estimation

Ecology 24-Hour Spill Hotline notified at: 6/15/25
LOTT Spill No: n/a Ecology ERTS No: 739501 WA Emergency Mgmt. n/a

Ecology verbal notification details:
(exactly what information was conveyed to spill hotline dispatcher, i.e. start/stop times, volume, location, area affected, etc.) A sewage spill occurred at the above address due to a blockage in a private sewer lateral.

Overflow details caused by: (briefly describe what caused overflow to occur, and what was done to stop overflow) Sewage spill was due to blockage in a private sewer lateral. City staff responded to area, used vactor truck to remove SSO residual from roadway and catch basin, no sewage residual reached the waters of the State.

Action taken:

(what has been or will be done to prevent a reoccurrence of this event)
Staff informed property owner to ensure side lateral stays clear.

For more information contact: Matt Valenta, Plant Manager LOTT Clean Water Alliance

Signature: 

Matt Valenta
Phone Number: 360-528-5724

Photos:

THIS REPORT HAS BEEN FINALIZED AND CAN BE RELEASED.