

Ecology ERTS #: 739501

Reporting Jurisdiction Name, Address

SSO - SANITARY SEWER OVERFLOW REPORTING AND INFORMATION SHEET

Call made to LOTT by: Sydney Pype

Time call was placed:

E-Mailed reporting time: 14:50

Today's Date: 6/16/2025

<input checked="" type="checkbox"/>	INITIAL REPORT
<input type="checkbox"/>	FOLLOW-UP REPORT
<input type="checkbox"/>	ON-GOING INCIDENT
<input type="checkbox"/>	OTHER _____

Name: Sydney Pype of City of Olympia Phone: 360-628-0589
Person reporting the spill to LOTT Agency

Spill began: 6/15/2025 at 1030 Spill stopped: 6/15/2025 at 1112
Date Time Date Time

Gallons spilled: 25-50 Material spilled: SSO - Raw Sewage / STEP

Spill Location: 1102 Legion Way SE, Olympia
Address, manhole, nearest intersection or other identifiable location

Spilled to: [] ground, no run-off [X] Run-off to: street, catch basin
includes storm ponds Street, catch basin, storm sewer

Reached the Waters of the State Bodies of Water
[] Yes [X] No Name of stream or water body

Cause of spill: Blockage in private sewer lateral
Line blockage, CSO, STEP system malfunction, etc.

Clean-up & disposal: City of Olympia staff vactored SSO residual from street area and catch basin. Line blockage was cleared
Actions taken & by whom

Prevention: Private lateral blockage, staff informed property owner to ensure line stays clear
Actions taken to prevent re-occurrence (clean line, replace equipment, etc.)

Notifications by EMAIL or PHONE

NAME	CALLED (TIME, DATE & INITIALS)	EMAILED (TIME, DATE & INITIALS)
Department of Ecology - 360.407.6300	1205_ PM_6/15/23_LL	
Thurston County Health 360.968.4346 (Tristen P.) or 360.867.2535 (Stuart W.) emwebmaster@co.thurston.wa.u	n/a	

Dept. of Health - Shellfish - 360.236.3330 - 360.789.8962	n/a	
LOTT - 360.528.5700		EMAILED (TIME, DATE & INITIALS)
Operations and Facilities		0645_6/16/25_map
Environmental Planning & Communications Dir		0645_6/16/25_map
Process Control Sup.		0645_6/16/25_map
Operations SupervirSOR		0645_6/16/25_map

