



June 19, 2025

Water Quality Permit Coordinator
State of Washington - Department of Ecology
Southwest Regional office
PO Box 47775
Olympia, WA 98504-7775

RE: Pacific Seafood – Woodland, LLC Permit No. ST0006222 May 2025 Noncompliance Notification

Dear Sir or Madam,

The discharge monitoring report (DMR) for May 2025 reported one (1) violation during the reporting period. The DMR reported one (1) total suspended solids (TSS) daily max exceedance.

After becoming aware of the exceedance of the TSS from the sample collected on April 16, we immediately started our internal investigation into the cause of the violation. We discovered that the rotary screen was not operating optimally on May 20th, 2025. Subsequently, May 22nd was the next sampling event, which was the day of the TSS exceedance in the May reporting period. Given this timeline, it was likely that the full implementation of repairs and updates that have since been made to the system was not yet completed prior to the May 22nd sampling event.

Now that we have identified and addressed the root cause of the April, and now May exceedances, the Facility's treatment system is now resuming proper operation, and is shown by the first June sampling event collected on the 5th which yielded TSS results of 160 mg/L. After receiving these sample results, and as we continue to monitor the rotary screen, we do not anticipate generating another TSS Exceedance during the June reporting period.

Please reach out to me if you have any further questions.

June 19, 2025

Sincerely,

Ben Mitchell
Environmental Manager
Pacific Seafood
T: 503.905.4264
Bmitchell@pacificseafood.com