



Issuance Date: \_\_?\_\_

Effective Date: \_\_?\_\_

Expiration Date: \_\_?\_\_

**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM  
WASTE DISCHARGE PERMIT WA0022365**

**State of Washington  
DEPARTMENT OF ECOLOGY**

Central Regional Office  
1250 West Alder Street  
Union Gap WA 98903

In compliance with the provisions of  
The State of Washington Water Pollution Control Law  
Chapter 90.48 Revised Code of Washington  
and

The Federal Water Pollution Control Act  
(The Clean Water Act)  
Title 33 United States Code, Section 1342 et seq

City of Okanogan Publicly Owned Treatment Works  
PO Box 752  
Okanogan, WA, 98840

is authorized to discharge in accordance with the Special and General Conditions that follow.

Facility Location: 1610 South 1<sup>st</sup> Avenue, Okanogan, WA 98840

Treatment Type: Class II Rotating Biological Contractor with Ultraviolet Disinfection

Receiving Water: Okanogan River, River Mile 24.

---

Damon G. Roberts  
Water Quality Section Manager  
Central Regional Office  
Washington State Department of Ecology

<b>National Pollutant Discharge Elimination System Waste Discharge Permit WA0022365 .....</b>	<b>1</b>
<b>SUMMARY OF PERMIT SUBMITTALS.....</b>	<b>5</b>
<b>SPECIAL CONDITIONS.....</b>	<b>6</b>
S1. Discharge limits.....	6
S1.A. Effluent limits.....	6
S1.B. Mixing zone authorization .....	7
S2. Monitoring requirements .....	8
S2.A. Monitoring schedule .....	8
S2.B. DDT/PCB Analysis for TMDL Wasteload Allocation Compliance Verification.....	10
S2.C. Sampling and analytical procedures .....	10
S2.D. Flow measurement, field measurement, and continuous monitoring devices .....	11
S2.E. Laboratory accreditation.....	11
S2.F. Request for reduction in monitoring .....	12
S3. Reporting and recording requirements.....	12
S3.A. Discharge Monitoring Reports.....	12
S3.B. Permit submittals and schedules.....	13
S3.C. Records retention.....	14
S3.D. Recording of results .....	14
S3.E. Additional monitoring by the Permittee.....	14
S3.F. Reporting permit violations.....	14
S3.G. Other reporting.....	17
S3.H. Maintaining a copy of this permit.....	17
S4. Facility loading .....	17
S4.A. Design criteria .....	17
S4.B. Plans for maintaining adequate capacity.....	17
S4.C. Duty to mitigate .....	18
S4.D. Notification of new or altered sources .....	18
S4.E. Infiltration and inflow evaluation .....	18
S4.F. Wasteload assessment.....	19
S5. Operation and maintenance.....	19
S5.A. Certified operator .....	19
S5.B. Operation and maintenance program.....	19
S5.C. Short-term reduction .....	20
S5.D. Electrical power failure .....	20
S5.E. Prevent connection of inflow .....	20
S5.F. Bypass procedures .....	21
S5.G. Operations and maintenance (O&M) manual.....	22
S6. Pretreatment .....	23
S6.A. Duty to enforce discharge prohibitions .....	23

S6.B. Identification of new industrial wastewater sources and notification of permit requirements.....	24
S6.C. Industrial user survey .....	25
S7. Solid wastes.....	26
S7.A. Solid waste handling .....	26
S7.B. Leachate .....	26
S8. Application for permit renewal or modification for facility changes .....	26
S9. Spill control plan.....	26
S9.A. Spill control plan submittals and requirements .....	26
S9.B. Spill control plan components .....	26
<b>REFERENCES .....</b>	<b>28</b>
<b>GENERAL CONDITIONS.....</b>	<b>30</b>
G1. Signatory requirements.....	30
G2. Right of inspection and entry .....	31
G3. Permit actions .....	31
G4. Reporting planned changes.....	32
G5. Plan review required .....	33
G6. Compliance with other laws and statutes.....	33
G7. Transfer of this permit.....	33
G8. Reduced production for compliance .....	34
G9. Removed substances .....	34
G10. Duty to provide information.....	34
G11. Other requirements of 40 CFR .....	34
G12. Additional monitoring .....	34
G13. Payment of fees.....	34
G14. Penalties for violating permit conditions.....	34
G15. Upset .....	35
G16. Property rights .....	35
G17. Duty to comply.....	35
G18. Toxic pollutants.....	35
G19. Penalties for tampering.....	36
G20. Compliance schedules.....	36
G21. Service agreement review .....	36
<b>APPENDIX A – List of Pollutants, Analytical Methods, Detection Levels and Quantitation Levels .....</b>	<b>37</b>
Table 1 - Summary of permit submittals.....	5
Table 2 – Effluent limits: Outfall 001.....	6
Table 3 – Dilution factors.....	8
Table 4 – Wastewater influent.....	8
Table 5 – Final wastewater effluent.....	8
Table 6 – Permit renewal application requirements, final wastewater effluent .....	9

**May 2024**

NPDES Permit Domestic Wastewater

Table 7 – Additional monitoring .....	9
Table 8 - Design criteria .....	17

DRAFT

## SUMMARY OF PERMIT SUBMITTALS

Refer to the Special and General Conditions of this permit for additional submittal requirements.

**Table 1 - Summary of permit submittals**

Permit section	Submittal	Frequency	First submittal date
S2.B	DDT/PCB Analysis for TMDL Wasteload Allocation Compliance Verification	As Necessary	
S3.A	Monthly Discharge Monitoring Report (DMR)	Monthly	Enter a specific date
S3.A	Permit renewal application monitoring data	Annually	Enter a specific date
S3.F	Reporting permit violations	As necessary	
S4.B	Plans for maintaining adequate capacity	As necessary	
S4.D	Notification of new or altered sources	As necessary	
S4.E	Infiltration and Inflow evaluation	1/Permit Cycle	Enter a specific date
S4.F	Wasteload assessment	Annually	Enter a specific date
S5.F	Bypass notification	As necessary	
S5.G	Operations and maintenance manual review confirmation letter	Annually	Enter a specific date
S6.C	Industrial User Survey	1/Permit Cycle	Enter a specific date
S8	Application for permit renewal	1/Permit Cycle	Insert date from S8
S9	Spill control plan submittal	1/Permit Cycle	Enter a specific date
G1	Notice of change in authorization	As necessary	
G4	Reporting planned changes	As necessary	
G5	Engineering report for construction or modification activities	As necessary	
G7	Notice of permit transfer	As necessary	
G10	Duty to provide information	As necessary	
G20	Compliance schedules	As necessary	
G21	Contract submittal	As necessary	

**May 2024**

NPDES Permit Domestic Wastewater

## SPECIAL CONDITIONS

### S1. Discharge limits

#### S1.A. Effluent limits

All discharges and activities authorized by this permit must comply with the terms and conditions of this permit. The discharge of any of the following pollutants more frequently than, or at a level in excess of, that identified and authorized by this permit violates the terms and conditions of this permit.

Beginning on the effective date of this permit, the Permittee may discharge treated domestic wastewater to the Okanogan River at the permitted location subject to compliance with the following limits:

**Table 2 – Effluent limits: Outfall 001**

Latitude: 48.353111 Longitude: -119.596096

Parameter	Average Monthly <sup>a</sup>	Average Weekly <sup>b</sup>
Biochemical Oxygen Demand (5-day) (BOD <sub>5</sub> )	30 mg/L	45 mg/L
BOD <sub>5</sub>	135 lbs/day	203 lbs/day
BOD <sub>5</sub>	85% removal of influent BOD <sub>5</sub>	N/A
Total Suspended Solids (TSS)	30 mg/L	45 mg/L
TSS	135 lbs/day	203 lbs/day
TSS	85% removal of influent TSS	N/A

Parameter	Minimum	Maximum
pH	6.0 standard units	9.0 standard units

Parameter	Monthly Geometric Mean	Weekly Geometric Mean
Fecal Coliform Bacteria <sup>c</sup>	200 CFUs/100 mL	400 CFUs/100 mL

Parameter	Average Monthly	Maximum Daily <sup>d</sup>
4,4'-DDE <sup>e</sup>	N/A	1.2 mg/Day
4,4'-DDD <sup>f</sup>	N/A	1.7 mg/Day
4,4'-DDT <sup>g</sup>	N/A	1.2 mg/Day
t-DDT <sup>h</sup>	N/A	2.0 mg/Day
t-PCBs <sup>i</sup>	N/A	0.30 mg/Day
Temperature	N/A	27.5 °C

<sup>a</sup> Average monthly effluent limit means the highest allowable average of daily discharges over a calendar month. To calculate the discharge value to compare to the

**May 2024**

NPDES Permit Domestic Wastewater

limit, you add the value of each daily discharge measured during a calendar month and divide this sum by the total number of daily discharges measured.

<sup>b</sup> Average weekly discharge limit means the highest allowable average of daily discharges over a calendar week, calculated as the sum of all daily discharges measured during a calendar week divided by the number of daily discharges' measured during that week. See footnote c for bacteria calculations.

<sup>c</sup> Ecology provides directions to calculate the monthly and the 7-day geometric mean in the *Information Manual for Treatment Plant Operators* (Ecology, 2004).

<sup>d</sup> Maximum daily effluent limit is the highest allowable daily discharge. The daily discharge is the average discharge of a pollutant measured during a calendar day. For pollutants with limits expressed in units of mass, calculate the daily discharge as the total mass of the pollutant discharged over the day. The average daily measurement does not apply to pH or temperature.

<sup>e</sup> 4,4' DDE means 1, 1'-(Dichloroethenyldiene)bis[4-chlorobenzene]:: CAS Number 72-55

<sup>f</sup> 4,4' DDD 1,1'-(2,2-Dichloroethenyldiene)bis(4-chlorobenzene):: CAS Number 72-54-8

<sup>g</sup> 4,4'-DDT means 1,1,1-Trichloro-2,2-bis(p-chlorophenyl)ethane:: CAS Number 50-29-3

<sup>h</sup> t-DDT is the sum of 4,4'-DDT + 4,4'-DDE + 4,4'-DDD

<sup>i</sup> t-PCB is the sum of PCB Aroclors 1268, 1262, 1260, 1254, 1248, 1242, 1232, 1221, and 1016

### **S1.B. Mixing zone authorization**

Mixing zone for Outfall 001

The following paragraphs define the maximum boundaries of the mixing zones.

#### **Chronic mixing zone**

The width of the chronic mixing zone is limited to a distance of 8 feet (2.44 meters). The length of the chronic mixing zone extends 20 feet (6.1 meters) upstream and 310 feet (94.5 meters) downstream of the outfall. The mixing zone extends from the bottom to the top of the water column. The mixing zone must not utilize greater than 25% of the flow. The concentration of pollutants at the edge of the chronic zone must meet chronic aquatic life criteria and human health criteria.

#### **Acute mixing zone**

The width of the acute mixing zone is limited to a distance of 2.62 feet (0.8 meters). The length of the acute mixing zone extends 10 feet (3.05 meters) upstream and 31 feet (9.4 meters) downstream of the outfall. The mixing zone extends from the bottom to the top of the water column. The acute mixing zone must not utilize

**May 2024**

NPDES Permit Domestic Wastewater

greater than 2.5% of the flow. The concentration of pollutants at the edge of the acute zone must meet acute aquatic life criteria.

**Table 3 – Dilution factors**

Criteria	Dilution factor
Acute Aquatic Life Criteria	9.0
Chronic Aquatic Life Criteria	122.1

## S2. Monitoring requirements

### S2.A. Monitoring schedule

The Permittee must monitor in accordance with the following schedule and the requirements specified in Appendix A.

**Table 4 – Wastewater influent**

Wastewater influent means the raw sewage flow from the collection system into the treatment facility. Sample the wastewater entering the headworks of the treatment plant excluding any side-stream returns from inside the plant.

Parameter	Units & speciation	Minimum sampling frequency	Sample type
BOD <sub>5</sub>	mg/L	1/week	Composite Sample (24 hour) <sup>a</sup>
BOD <sub>5</sub>	lbs/day	1/week	Calculated <sup>b</sup>
TSS	mg/L	1/week	Composite Sample (24 hour)
TSS	lbs/day	1/week	Calculated

**Table 5 – Final wastewater effluent**

Final wastewater effluent means wastewater exiting the last treatment process or operation. Typically, this is after or at the exit from the chlorine contact chamber or other disinfection process. The Permittee may take effluent samples for the BOD<sub>5</sub> analysis before or after the disinfection process. If taken after, the Permittee must dechlorinate and reseed the sample.

Parameter	Units & speciation	Minimum sampling frequency	Sample type
Flow	MGD	Continuous <sup>c</sup>	Metered/Recorded
BOD <sub>5</sub>	mg/L	1/week	Composite Sample (24 hour)
BOD <sub>5</sub>	lbs/day	1/week	Calculated
BOD <sub>5</sub>	% removal	1/week	Calculated <sup>d</sup>
TSS	mg/L	1/week	Composite Sample (24 hour)

**May 2024**

NPDES Permit Domestic Wastewater

Parameter	Units & speciation	Minimum sampling frequency	Sample type
TSS	lbs/day	1/week	Calculated
TSS	% removal	1/week	Calculated
Fecal Coliform <sup>e</sup>	#cfu /100 ml	2/week	Grab <sup>f</sup>
pH <sup>g</sup>	standard units	5/week	Grab
Temperature <sup>h</sup>	°C	Daily	Measurement
Total Ammonia	mg/L as N	1/month	Composite Sample (24 hour)
Total Ammonia	Lbs/day	1/month	Calculation
Dissolved Oxygen	mg/L	2/week	Grab

**Table 6 – Permit renewal application requirements, final wastewater effluent**

The Permittee must record and report the wastewater treatment plant flow discharged on the day it collects the sample for priority pollutant testing with the discharge monitoring report.

Parameter	Units & speciation	Minimum sampling frequency	Sample type
E.coli <sup>i</sup>	MPN /100ml	Once per year	Grab
Total Kjeldahl Nitrogen	mg/L as N	Once per year	24-Hour Composite
Nitrate plus Nitrite	mg/L as N	Once per year	24-Hour Composite
Oil and Grease	mg/L	Once per year	24-Hour Composite
Ortho-Phosphorus	mg/L as P	Once per year	24-Hour Composite

**Table 7 – Additional monitoring**

Monitoring type	Description
DDT/PCB Analysis for TMDL Wasteload Allocation Compliance Verification	As specified in condition S2.B

Footnotes:

<sup>a</sup> Twenty-four (24)-hour composite means a series of individual samples collected over a 24-hour period into a single container and analyzed as one sample.

<sup>b</sup> Calculated means figured concurrently with the respective sample, using the following formula: Concentration (in mg/L) X Flow (in MGD) X Conversion Factor (8.34) = lbs/day

<sup>c</sup> Continuous means uninterrupted except for brief lengths of time for calibration, power failure, or unanticipated equipment repair or maintenance. The time interval for the associated data logger must be no greater than 30 minutes. Sample daily when continuous monitoring is not possible.

<sup>d</sup> Calculate the percent removal of BOD<sub>5</sub> and TSS as follows: Percent (%) removal = [(Influent concentration (mg/L) – Effluent concentration (mg/L)]/[Influent concentration (mg/L)] x 100%

**May 2024**

NPDES Permit Domestic Wastewater

<sup>e</sup> Report a numeric value for fecal coliforms following the procedures in the Information Manual for Wastewater Treatment Plant Operators, Publication 04-10-020 (Ecology, 2004). Do not report a result as Too Numerous To Count (TNTC).

<sup>f</sup> Grab means an individual sample collected over a fifteen (15) minute, or less, period.

<sup>g</sup> Report the daily pH and the minimum and maximum for the monitoring period.

<sup>h</sup> Conduct temperature grab sampling when the effluent is at or near its daily maximum temperature, which usually occurs in the late afternoon. If measuring temperature continuously, report a daily maximum from half-hour measurements over a 24-hour period. Continuous monitoring instruments must achieve an accuracy of 0.2 degrees C and the Permittee must verify accuracy annually.

<sup>i</sup> The permittee is required to monitor for both fecal coliform and *E.coli* for development of site specific correlation. The grab sample for *E.coli* must be sampled and analyzed at the same time as a grab sample for fecal coliform.

## **S2.B. DDT/PCB Analysis for TMDL Wasteload Allocation Compliance Verification**

Should the POTW effluent reach 85% of its flow design capacity (0.460 MGD) for three consecutive months, Ecology requires the POTW to analyze its wastewater for 4,4'-DDT, 4,4'-DDE, t-DD, and the PCB Aroclors 1260, 1254, 1248, 1242, 1232, 1221 and 1016. Ecology requires submittal of analytical results no more than 45 days following the third month with Flow, BOD, or TSS loadings at 85% or greater than the facility design capacity.

Should an analytical method capable of detecting extremely low concentrations of DDT and DDT products contained in wastewater treatment effluent not be available, Ecology may require additional testing of effluent for DDT and DDT daughter products. An analysis of effluent prior to the 85% of design flow will render the special condition as conducted and complete.

## **S2.C. Sampling and analytical procedures**

Samples and measurements taken to meet the requirements of this permit must represent the volume and nature of the monitored parameters, including representative sampling of any unusual discharge or discharge condition, including bypasses, upsets, and maintenance-related conditions affecting effluent quality.

Sampling and analytical methods used to meet the monitoring requirements specified in this permit must conform to the *Guidelines Establishing Test Procedures for the Analysis of Pollutants* contained in 40 CFR Part 136 (or as applicable in 40 CFR subchapter N [Parts 400–471] or 40 CFR subchapter O [Parts 501-503]) unless otherwise specified in this permit. Ecology may specify alternative methods for parameters without limits and for those parameters without an EPA approved test method in 40 CFR Part 136.

**S2.D. Flow measurement, field measurement, and continuous monitoring devices**

The Permittee must:

1. Select and use appropriate flow measurement, field measurement, and continuous monitoring devices and methods consistent with accepted scientific practices.
2. Install, calibrate, and maintain these devices to ensure the accuracy of the measurements is consistent with the accepted industry standard, the manufacturer's recommendation, and approved O&M manual procedures for the device and the wastestream.
3. Calibrate continuous monitoring instruments weekly unless it can demonstrate a longer period is sufficient based on monitoring records. The Permittee:
  - a. May calibrate apparatus for continuous monitoring of dissolved oxygen by air calibration.
  - b. Must calibrate continuous pH measurement instruments according to the manufacturer's requirements.
  - c. Must calibrate continuous chlorine measurement instruments using a grab sample analyzed in the laboratory within 15 minutes of sampling.
4. Calibrate micro-recording temperature devices, known as thermistors, using protocols from *Standard Operating Procedure EAP080, Version 2.2, Continuous Temperature Monitoring of Freshwater Rivers and Streams* (Ecology, 2022). Calibration as specified in this document is not required if the Permittee uses recording devices certified by the manufacturer.
5. Use field measurement devices as directed by the manufacturer and do not use reagents beyond their expiration dates.
6. Establish a calibration frequency for each device or instrument in the O&M manual that conforms to the frequency recommended by the manufacturer.
7. Calibrate flow-monitoring devices at a minimum frequency of at least one calibration per year.
8. Maintain calibration records for at least three years.

**S2.E. Laboratory accreditation**

The Permittee must ensure that all monitoring data required by Ecology for permit specified parameters is prepared by a laboratory registered or accredited under the provisions of Chapter 173-50 Washington Administrative Code (WAC), Accreditation of Environmental Laboratories. Flow, temperature, settleable solids, conductivity, pH, and internal process control parameters are exempt from this requirement. The Permittee must obtain accreditation for conductivity and pH if it must receive accreditation or registration for other parameters.

### **S2.F. Request for reduction in monitoring**

The Permittee may request a reduction of the sampling frequency after twelve (12) months of monitoring. Ecology will review each request and at its discretion grant the request when it reissues the permit or by a permit modification.

The Permittee must:

1. Provide a written request.
2. Clearly state the parameters for which it is requesting reduced monitoring.
3. Clearly state the justification for the reduction.

### **S3. Reporting and recording requirements**

The Permittee must monitor and report in accordance with the following conditions. Falsification of information submitted to Ecology is a violation of the terms and conditions of this permit.

#### **S3.A. Discharge Monitoring Reports**

The first monitoring period begins on the effective date of the permit (unless otherwise specified). The Permittee must:

1. Summarize, report, and submit monitoring data obtained during each monitoring period on the electronic Discharge Monitoring Report (DMR) form provided by Ecology within the [Water Quality Permitting Portal](#)<sup>1</sup>. Include data for each of the parameters tabulated in Special Conditions S2 and as required by the form. Report a value for each day sampling occurred (unless specifically exempted in the permit) and for the summary values (when applicable) included on the electronic form.
2. Submit DMRs no later than the dates specified below, unless otherwise specified in this permit.
3. Submit DMRs for parameters with the monitoring frequencies specified in S2 (monthly, quarterly, annual, etc.) at the reporting schedule identified below.  
The Permittee must:
  - a. Submit **monthly** DMRs by the 15th day of the following month.
  - b. Submit **permit renewal application monitoring data** in WQWebDMR, as required in Special Condition S2, by **DATE**.
4. Enter the "No Discharge" reporting code for an entire DMR, for a specific monitoring point, or a specific parameter as appropriate, if the Permittee did not discharge wastewater or a specific pollutant during a given monitoring period.
5. Report single analytical values below detection as "less than the Detection Level (DL)" by entering the < followed by the numeric value of the detection level (e.g. < 2.0) on the DMR. If the method used did not meet the minimum

---

<sup>1</sup> <https://ecology.wa.gov/Regulations-Permits/Guidance-technical-assistance/Water-quality-permits-guidance/WQWebPortal-guidance>

- DL and Quantitation Level (QL) identified in the permit report the actual QL and DL in the comments or in the location provided.
6. Report single analytical values between the DL and the QL by entering the estimated value, the code for estimated value/below quantitation limit (J) and any additional information in the comments.
  7. When an outside laboratory performs the analysis, submit a copy of the laboratory report as an attachment using WQWebDMR. Contract laboratory reports must include the chain of custody and QA/QC results.
  8. Submit bacteria monitoring results as follows:
    - a. Do not report zero for bacterial monitoring. Report as required by the laboratory method.
    - b. Calculate and report an arithmetic average value for each day for bacteria if multiple samples were taken in one day.
    - c. Calculate the geometric mean values for bacteria (unless otherwise specified in the permit) using the reported numeric value for all bacteria samples measured above the detection value except when it took multiple samples in one day. If multiple samples are taken in one day, use the arithmetic average for the day in the geometric mean calculation. Use the detection value for those samples measured below detection.
  9. Report the test method used for analysis in the comments if the laboratory used an alternative method not specified in the permit and as allowed in Appendix A.
  10. Calculate average values and calculated total values (unless otherwise specified in the permit) using:
    - a. The reported numeric value for all parameters measured between the detection value and the quantitation value for the sample analysis.
    - b. One-half (1/2) the detection value (for values reported below detection) if the lab detected the parameter in another sample from the same monitoring point for the reporting period.
    - c. Zero (for values reported below detection) if the lab did not detect the parameter in another sample for reporting period.
  11. Report single-sample grouped parameters (for example: priority pollutants, PAHs, pulp and paper chlorophenolics, TTOs) on the WQWebDMR form and include: sample date, concentration detection, DL (as necessary), and laboratory QL (as necessary).

### **S3.B. Permit submittals and schedules**

The Permittee must use the Water Quality Permitting Portal – Permit Submittals application (unless otherwise specified in the permit) to submit all permit-required reports by the date specified in the permit.

When another permit condition requires submittal of a paper (hard copy) report, the Permittee must ensure that it is postmarked or received by Ecology no later than the dates specified by this permit. Send these paper reports to Ecology at:

**May 2024**

NPDES Permit Domestic Wastewater

Water Quality Permit Coordinator  
Department of Ecology  
Central Regional Office  
1250 West Alder Street  
Union Gap, WA 98903

**S3.C. Records retention**

The Permittee must retain records of all monitoring information for a minimum of three years. Such information must include all calibration and maintenance records and all original recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit. The Permittee must extend this period of retention during any unresolved litigation regarding the discharge of pollutants by the Permittee or when requested by Ecology.

**S3.D. Recording of results**

For each measurement or sample taken, the Permittee must record the following information:

1. The date, exact place, method, and time of sampling or measurement.
2. The individual who performed the sampling or measurement.
3. The date and time the analysis was performed.
4. The individual who performed the analysis.
5. The analytical technique or method used.
6. The results of all analyses.

**S3.E. Additional monitoring by the Permittee**

If the Permittee monitors any pollutant more frequently than required by Special Condition S2 of this permit, then the Permittee must include the results of such monitoring in the calculation and reporting of the data submitted in the Permittee's DMR unless otherwise specified by Special Condition S2.

**S3.F. Reporting permit violations**

The Permittee must take the following actions when it violates or is unable to comply with any permit condition:

1. Immediately take action to stop, contain, and cleanup unauthorized discharges or otherwise stop the noncompliance and correct the problem.

The permittee must make reasonable attempts to collect a sample of any unusual discharge or discharge condition including prohibited bypasses, upsets, and maintenance-related conditions affecting effluent quality. The sample must be representative of the volume and nature of the uncharacteristic discharge and must represent a relevant subset of parameters required to be monitored under section S2.A. The additional monitoring results must be reported on the monthly DMR, along with a note of explanation. Refer to the Information Manual for

Treatment Plant Operators, Publication 04-10-020 (Ecology, 2004), for guidance on incorporating extra sampling results into DMR calculations.

## 2. Immediate reporting

The Permittee must immediately report (see definition of “immediate reporting” in Appendix C of the Fact Sheet) to Ecology and the local health jurisdiction at the numbers listed below, all:

- Failures of the disinfection system.
- Plant bypasses resulting in a discharge to a waterbody.
- Any upset that causes an exceedance of an effluent limit in the permit (See G.15, "Upset").
- Collection system overflows.
- Any other failures of the sewage system (pipe breaks, etc.).

Central Regional Office	509-575-2490
Okanogan Health District	509-422-7140
Okanogan Irrigation District	509-826-1250

The Permittee must also immediately report to the Department of Health Drinking Water Program at the numbers listed below:

### Department of Health Drinking Water Program

- 800-521-0323 (business hours)
- 877-481-4901 (after business hours)

## 3. Twenty-four (24) hour reporting

The Permittee must report the following to Ecology at the telephone number listed in S3.F.3, within 24 hours from the time the Permittee becomes aware of any of the following:

- Any violation of a maximum daily or instantaneous maximum discharge limit for any of the pollutants in Special Condition S1.A of this permit.
- Any noncompliance that may endanger health or the environment, unless previously reported under immediate reporting requirements.

## 4. Five-day follow up report

The Permittee must also submit a written report within five days of the time that the Permittee becomes aware of any reportable event under S3.F.3 or S3.F.4. (See definition of “Days (compliance period interval)” in Appendix C of the Fact Sheet.)

Submit the written report electronically using the Water Quality Permitting Portal – Permit Submittals application.

The permittee may use any reporting form that includes all the required content listed in this section.

The report must contain:

- a. A description of the noncompliance and its cause.
- b. The period of noncompliance, including exact dates and times.
- c. The estimated time the Permittee expects the noncompliance to continue if not yet corrected.
- d. Steps taken or planned to reduce, eliminate, and prevent recurrence of the noncompliance.
- e. If the noncompliance involves an overflow prior to the treatment works:
  - (i) Indicate the type of event (e.g., combined sewer overflow, sanitary sewer overflow, or bypass event).
  - (ii) Indicate the type of sewer overflow structure (e.g., manhole, combined sewer overflow outfall).
  - (iii) Estimate the quantity (in gallons) of the untreated overflow.
  - (iv) Indicate whether the noncompliance was related to wet weather; and
  - (v) Indicate the types of human health and environmental impacts of the event.
- f. Include a description of actions taken to stop, contain, and cleanup unauthorized discharges and to mitigate any associated environmental impacts.
- g. If an ERTS number was assigned to the event when it was initially reported, include this number in the five-day follow up report for reference.
- h. Identification of other agencies contacted per the emergency notification call list in S3.F.3.
- i. If samples were taken to characterize the event, provide any analytical results that are available with the five-day report. If the data was collected at the same monitoring points and for parameters specified on the DMR, the sample results must also be reported on the DMR.

#### 5. Waiver of written reports

Ecology may waive the report required in S3.F.4 on a case-by-case basis if the Permittee has submitted a timely oral report. If a waiver is requested, the Permittee must obtain documentation of this waiver in writing or email from Ecology.

#### 6. All other permit violation reporting

The Permittee must report all other permit violations when they submit monitoring reports under Special Condition S3.A. (Reporting). The reports

must contain the information listed in S3.F.4 Compliance with these requirements does not relieve the Permittee from responsibility to maintain continuous compliance with the terms and conditions of this permit or from the resulting liability for failure to comply.

### **S3.G. Other reporting**

1. Spills of oil or hazardous materials

In addition to the requirements in S3.F, the Permittee must report a spill of oil or hazardous materials in accordance with the requirements of Revised Code of Washington (RCW) 90.56.280 and WAC 173-303-145. Visit the website [How to Report a Spill](#)<sup>2</sup> for further instructions.

2. Failure to submit relevant or correct facts

Where the Permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application, or in any report to Ecology, it must submit such facts or information promptly.

### **S3.H. Maintaining a copy of this permit**

The Permittee must keep a copy of this permit at the facility and make it available upon request to Ecology inspectors.

## **S4. Facility loading**

### **S4.A. Design criteria**

The flows or waste loads for the permitted facility must not exceed the following design criteria:

**Table 8 - Design criteria**

Parameter	Unit
Maximum Month Design Flow (MMDF)	0.54 MGD
BOD5 Influent Loading for Maximum Month	1,007 lb/day
TSS Influent Loading for Maximum Month	1,056 lb/day

### **S4.B. Plans for maintaining adequate capacity**

1. The Permittee must submit a plan and a schedule for continuing to maintain capacity to Ecology when:
  - a. The actual flow or waste load reaches 85 percent of any one of the design criteria in S4.A for three consecutive months.
  - b. The projected plant flow or loading would reach design capacity within five years.
2. The plan and schedule must identify the actions necessary to maintain adequate capacity for the expected population growth and to meet the limits

<sup>2</sup> <https://ecology.wa.gov/About-us/Get-involved/Report-an-environmental-issue/Report-a-spill>

and requirements of the permit. The Permittee must consider the following topics and actions in its plan:

- a. Analysis of the present design and proposed process modifications.
- b. Reduction or elimination of excessive infiltration and inflow of uncontaminated ground and surface water into the sewer system.
- c. Limits on future sewer extensions or connections or additional waste loads.
- d. Modification or expansion of facilities.
- e. Reduction of industrial or commercial flows or waste loads.

Engineering documents associated with the plan must meet the requirements of WAC 173-240-060, "Engineering Report," and must be approved by Ecology prior to any construction.

**S4.C. Duty to mitigate**

The Permittee must take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this permit that has a reasonable likelihood of adversely affecting human health or the environment.

**S4.D. Notification of new or altered sources**

1. The Permittee must submit written notice to Ecology whenever any new discharge or a substantial change in volume or character of an existing discharge into the wastewater treatment plant is proposed which:
  - a. Would interfere with the operation of, or exceed the design capacity of, any portion of the wastewater treatment plant.
  - b. Is not part of an approved general sewer plan or approved plans and specifications.
  - c. Is subject to pretreatment standards under 40 CFR Part 403 and Section 307(b) of the Clean Water Act.
2. This notice must include an evaluation of the wastewater treatment plant's ability to adequately transport and treat the added flow and/or waste load, the quality and volume of effluent to be discharged to the treatment plant, and the anticipated impact on the Permittee's effluent [40 CFR 122.42 (b)].

**S4.E. Infiltration and inflow evaluation**

1. The Permittee must conduct an infiltration and inflow evaluation. Refer to the publication *I/I Analysis and Project Certification* (USEPA, 1985), available as Ecology Publication 97-03.
2. The Permittee may use monitoring records to assess measurable infiltration and inflow.
3. The Permittee must prepare a report summarizing any measurable infiltration and inflow. If infiltration and inflow have increased by more than 15 percent from that found in the previous report based on equivalent rainfall, the report must contain a plan and a schedule to locate the sources of infiltration and inflow and to correct the problem.

4. The Permittee must submit a report summarizing the results of the evaluation and any recommendations for corrective actions by **DATE**

#### **S4.F. Wasteload assessment**

The Permittee must conduct an annual assessment of its influent flow and waste load and submit a report to Ecology by **DATE** and every year thereafter. The report must contain:

1. A description of compliance or noncompliance with the permit effluent limits.
2. A comparison between the existing and design:
  - a. Monthly average dry weather and wet weather flows.
  - b. Peak flows.
  - c. BOD<sub>5</sub> loading.
  - d. Total suspended solids loadings.
3. The percent change in the above parameters since the previous report (except for the first report).
4. The present and design population or population equivalent.
5. The projected population growth rate.
6. The estimated date upon which the Permittee expects the wastewater treatment plant to reach design capacity, according to the most restrictive of the parameters above.

Ecology may modify the interval for review and reporting if it determines that a different frequency is sufficient.

#### **S5. Operation and maintenance**

The Permittee must at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances), which are installed to achieve compliance with the terms and conditions of this permit. Proper operation and maintenance also includes keeping a daily operation logbook (paper or electronic), adequate laboratory controls, and appropriate quality assurance procedures. This provision of the permit requires the Permittee to operate backup or auxiliary facilities or similar systems only when the operation is necessary to achieve compliance with the conditions of this permit.

##### **S5.A. Certified operator**

This permitted facility must be operated by an operator certified by the state of Washington for at least a Class II plant. This operator must be in responsible charge of the day-to-day operation of the wastewater treatment plant. An operator certified for at least a Class I plant must be in charge during all regularly scheduled shifts. The Permittee must notify Ecology when the operator in charge at the facility changes. It must provide the new operator's name and certification level and provide the name of the operator leaving the facility.

##### **S5.B. Operation and maintenance program**

The Permittee must:

**May 2024**

NPDES Permit Domestic Wastewater

1. Institute an adequate operation and maintenance program for the entire sewage system.
2. Keep maintenance records on all major electrical and mechanical components of the treatment plant, as well as the sewage system and pumping stations. Such records must clearly specify the frequency and type of maintenance recommended by the manufacturer and must show the frequency and type of maintenance performed.
3. Make maintenance records available for inspection at all times.

**S5.C. Short-term reduction**

The Permittee must schedule any facility maintenance, which might require interruption of wastewater treatment and degrade effluent quality, during non-critical water quality periods and carry this maintenance out according to the approved O&M manual or as otherwise approved by Ecology.

If a Permittee contemplates a reduction in the level of treatment that would cause a violation of permit discharge limits on a short-term basis for any reason, and such reduction cannot be avoided, the Permittee must:

1. Give written notification to Ecology, if possible, thirty (30) days prior to such activities.
2. Detail the reasons for, length of time of, and the potential effects of the reduced level of treatment.

This notification does not relieve the Permittee of its obligations under this permit.

**S5.D. Electrical power failure**

The Permittee must ensure that adequate safeguards prevent the discharge of untreated wastes or wastes not treated in accordance with the requirements of this permit during electrical power failure at the treatment plant and/or sewage lift stations. Adequate safeguards include, but are not limited to, alternate power sources, standby generator(s), or retention of inadequately treated wastes.

The Permittee must maintain Reliability Class II (EPA 430-99-74-001) at the wastewater treatment plant. Reliability Class II requires a backup power source sufficient to operate all vital components and critical lighting and ventilation during peak wastewater flow conditions. Vital components used to support the secondary processes (i.e., mechanical aerators or aeration basin air compressors) need not be operable to full levels of treatment, but must be sufficient to maintain the biota.

**S5.E. Prevent connection of inflow**

The Permittee must strictly enforce its sewer ordinances and not allow the connection of inflow (roof drains, foundation drains, etc.) to the sanitary sewer system.

**S5.F. Bypass procedures**

A bypass is the intentional diversion of waste streams from any portion of a treatment facility. This permit prohibits all bypasses except when the bypass is for essential maintenance, as authorized in special condition S5.F.1, or is approved by Ecology as an anticipated bypass following the procedures in S5.F.2.

1. Bypass for essential maintenance without the potential to cause violation of permit limits or conditions: This permit allows bypasses for essential maintenance of the treatment system when necessary to ensure efficient operation of the system. The Permittee may bypass the treatment system for essential maintenance only if doing so does not cause violations of effluent limits. The Permittee is not required to notify Ecology when bypassing for essential maintenance. However, the Permittee must comply with the monitoring requirements specified in special condition S2.B.
2. Anticipated bypasses for non-essential maintenance: Ecology may approve an anticipated bypass under the conditions listed below. This permit prohibits any anticipated bypass that is not approved through the following process.
  - a. If a bypass is for non-essential maintenance, the Permittee must notify Ecology, if possible, at least ten (10) days before the planned date of bypass. The notice must contain:
    - A description of the bypass and the reason the bypass is necessary.
    - An analysis of all known alternatives which would eliminate, reduce, or mitigate the potential impacts from the proposed bypass.
    - A cost-effectiveness analysis of alternatives.
    - The minimum and maximum duration of bypass under each alternative.
    - A recommendation as to the preferred alternative for conducting the bypass.
    - The projected date of bypass initiation.
    - A statement of compliance with SEPA.
    - A request for modification of water quality standards as provided for in WAC 173-201A-410, if an exceedance of any water quality standard is anticipated.
    - Details of the steps taken or planned to reduce, eliminate, and prevent recurrence of the bypass.
  - b. For probable construction bypasses, the Permittee must notify Ecology of the need to bypass as early in the planning process as possible. The Permittee must consider the analysis required above during the project planning and design process. The project-specific engineering report as well as the plans and specifications must include details of probable construction bypasses to the extent practical. In cases where the

Permittee determines the probable need to bypass early, the Permittee must continue to analyze conditions up to and including the construction period in an effort to minimize or eliminate the bypass.

- c. Ecology will determine if the Permittee has met the conditions of special condition S5.F.2 a and b and consider the following prior to issuing a determination letter, an administrative order, or a permit modification as appropriate for an anticipated bypass:
  - If the Permittee planned and scheduled the bypass to minimize adverse effects on the public and the environment.
  - If the bypass is unavoidable to prevent loss of life, personal injury, or severe property damage. "Severe property damage" means substantial physical damage to property, damage to the treatment facilities which would cause them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass.
  - If feasible alternatives to the bypass exist, such as:
    - The use of auxiliary treatment facilities.
    - Retention of untreated wastes.
    - Stopping production.
    - Maintenance during normal periods of equipment downtime, but not if the Permittee should have installed adequate backup equipment in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventative maintenance.
    - Transport of untreated wastes to another treatment facility.

**S5.G. Operations and maintenance (O&M) manual**

1. The Permittee must:
  - a. Review the O&M Manual at least annually and confirm this review by letter to Ecology by **DATE** of each year.
  - b. Submit to Ecology for review substantial changes or updates to the O&M Manual.
  - c. Keep the approved O&M Manual at the permitted facility.
  - d. Follow the instructions and procedures of this manual.
2. In addition to the requirements of WAC 173-240-080(1) through (5), the O&M Manual must be consistent with the guidance in Section G1-4.4 in the *Criteria for Sewage Works Design (Orange Book)* (Ecology, 2023). The O&M Manual must include:
  - a. Emergency procedures for cleanup in the event of wastewater system upset or failure.

- b. A review of system components which if failed could pollute surface water or could impact human health. Provide a procedure for a routine schedule of checking the function of these components.
- c. Wastewater system maintenance procedures that contribute to the generation of process wastewater.
- d. Reporting protocols for submitting reports to Ecology to comply with the reporting requirements in the discharge permit.
- e. Any directions to maintenance staff when cleaning or maintaining other equipment or performing other tasks which are necessary to protect the operation of the wastewater system (for example, defining maximum allowable discharge rate for draining a tank, blocking all floor drains before beginning the overhaul of a stationary engine).
- f. The treatment plant process control monitoring schedule.
- g. Minimum staffing adequate to operate and maintain the treatment processes and carry out compliance monitoring required by the permit.
- h. Specify other items on case-by-case basis such as O&M for collection systems pump stations, lagoon liners, etc.

#### **S6. Pretreatment**

The Permittee must work with Ecology to ensure that all industrial users (see “industrial user” and “industrial wastewater” definitions in the fact sheet glossary) of the publicly owned treatment works (POTW) comply with the pretreatment requirements of the federal Clean Water Act, Washington state law and the federal General Pretreatment Regulations. Pretreatment requirements apply to sewers, pipes, and other conveyances in addition to devices and systems used in the storage, treatment, recycling and reclamation of municipal sewage or industrial wastes of a liquid nature (see “POTW” definition in the fact sheet glossary).

##### **S6.A. Duty to enforce discharge prohibitions**

The Permittee must notify Ecology, within 30 days of becoming aware, if any industrial user violates the following discharge prohibitions and initiate enforcement action to promptly curtail any such discharge.

- 1. The Permittee must not authorize or knowingly allow the discharge of any pollutants into its POTW which may be reasonably expected to cause pass through or interference.
- 2. The Permittee must not authorize or knowingly allow the introduction of any of the following into their treatment works:
  - a. Pollutants which create a fire or explosion hazard in the POTW (including, but not limited to waste streams with a closed cup flashpoint of less than 140 degrees Fahrenheit or 60 degrees Centigrade using the test methods specified in 40 CFR 261.21).
  - b. Pollutants which will cause corrosive structural damage to the POTW, but in no case discharges with pH lower than 5.0, or greater than 11.0

standard units, unless the works are specifically designed to accommodate such discharges.

- c. Solid or viscous pollutants in amounts that could cause obstruction to the flow in the collection system or otherwise cause interference with the POTW.
  - d. Any pollutant, including oxygen-demanding pollutants, (BOD<sub>5</sub>, etc.) released in a discharge at a flow rate and/or pollutant concentration which will cause interference with the POTW.
  - e. Petroleum oil, non-biodegradable cutting oil, or products of mineral origin in amounts that will cause interference or pass through.
  - f. Pollutants which result in the presence of toxic gases, vapors, or fumes within the POTW in a quantity which may cause acute worker health and safety problems.
  - g. Heat in amounts that will inhibit biological activity in the POTW resulting in interference but in no case heat in such quantities that the temperature at the POTW headworks exceeds 40 degrees Celsius (104 degrees Fahrenheit) unless Ecology, upon request of the Permittee, approves alternate temperature limits in writing.
  - h. Any trucked or hauled pollutants, except at discharge points designated by the Permittee.
  - i. Wastewaters prohibited to be discharged to the POTW by the Dangerous Waste Regulations (chapter 173-303 WAC), unless authorized under the Domestic Sewage Exclusion (WAC 173-303-071).
3. The Permittee must not allow the following discharges to the POTW unless approved in writing by Ecology:
- a. Noncontact cooling water in significant volumes.
  - b. Stormwater and other direct inflow sources.
  - c. Wastewaters significantly affecting system hydraulic loading, which do not require treatment, or would not be afforded a significant degree of treatment by the system.

**S6.B. Identification of new industrial wastewater sources and notification of permit requirements**

The Permittee must establish a process for authorizing industrial wastewater discharges.

The Permittee must:

1. Immediately notify Ecology of any proposed industrial wastewater discharges from a source which is or may be a significant industrial user (SIU).
2. Within 30 days of becoming aware, notify Ecology of existing industrial users which change operations or increase wastewater discharge volume in a manner which makes them an SIU.

3. Within 30 days of becoming aware, notify Ecology of existing, unpermitted industrial users that are an SIU.
4. Require all SIUs to obtain a state waste discharge permit (SWDP) from Ecology prior to accepting or as a condition of continuing to accept their industrial wastewater.

**S6.C. Industrial user survey**

The Permittee must complete an industrial user survey and must submit a report of the survey to Ecology by **[Enter Date]**. The Permittee should use Ecology's "Guidance Manual for Performing an Industrial User Survey" to develop and compile the survey. In addition to identifying new industrial users, the Permittee must reevaluate existing nondomestic users identified in previous surveys for significantly altered processes or discharge practices. The intent of the industrial user survey is to compile a master list of nondomestic users (commercial and industrial, including hauled waste) introducing pollutants to the POTW and identify significant industrial users. The survey must capture nondomestic users in the entire sewershed of the receiving POTW. If the Permittee receives wastewater to the POTW from other jurisdictions, the Permittee must identify nondomestic users in those jurisdictions as well.

The survey report must include:

1. A description of the survey procedures (information gathering methods) the Permittee used to develop the master list of nondomestic users.
2. Identification of other jurisdictions that contribute wastewater to the POTW, as well as the process used to identify nondomestic users in those jurisdictions.
3. Example survey forms.
4. A master list of nondomestic users. The master list must include:
  - a. Names and addresses of all nondomestic users.
  - b. A description of the processes that affect or contribute to the user's wastewater.
  - c. The principal products and raw materials of each user that affects or contributes to the user's wastewater.
  - d. The average daily volume of wastewater discharged by each user, indicating the estimated amount attributable to process wastewater.
  - e. A statement of whether the user is subject to one or more categorical standards, and if so, under which category and subcategory.
  - f. A statement of whether the user is a significant industrial user and why (i.e. hydraulic or organic loading, categorical standards).
  - g. A statement whether the user is subject to local restrictions or requirements.
  - h. A statement whether any problems at the POTW, including upset, pass through, or interference, have been attributed to the user in the past 4.5 years.

## **S7. Solid wastes**

### **S7.A. Solid waste handling**

The Permittee must handle and dispose of all solid waste material in such a manner as to prevent its entry into state ground or surface water.

### **S7.B. Leachate**

The Permittee must not allow leachate from its solid waste material to enter state waters without providing all known, available, and reasonable methods of treatment, nor allow such leachate to cause violations of the State Surface Water Quality Standards, Chapter 173-201A WAC, or the State Ground Water Quality Standards, Chapter 173-200 WAC. The Permittee must apply for a permit or permit modification as may be required for such discharges to state ground or surface waters

## **S8. Application for permit renewal or modification for facility changes**

The Permittee must submit an application for renewal of this permit by **[DATE]**.

The Permittee must also submit a new application or addendum at least one hundred eighty (180) days prior to commencement of discharges, resulting from the activities listed below, which may result in permit violations. These activities include any facility expansions, production increases, or other planned changes, such as process modifications, in the permitted facility.

## **S9. Spill control plan**

### **S9.A. Spill control plan submittals and requirements**

The Permittee must:

1. Submit to Ecology a spill control plan for the prevention, containment, and control of spills or unplanned releases of pollutants by **[DATE]**.
2. Review the plan at least annually and update the spill plan as needed.
3. Send changes to the plan to Ecology.
4. Follow the plan and any supplements throughout the term of the permit.

### **S9.B. Spill control plan components**

The spill control plan must include the following:

1. A list of all oil and petroleum products and other materials used and/or stored on-site, which when spilled, or otherwise released into the environment, designate as Dangerous Waste (DW) or Extremely Hazardous Waste (EHW) by the procedures set forth in WAC 173-303-070. Include other materials used and/or stored on-site which may become pollutants or cause pollution upon reaching state's waters.
2. A description of preventive measures and facilities (including an overall facility plot showing drainage patterns) which prevent, contain, or treat spills of these materials.

3. A description of the reporting system the Permittee will use to alert responsible managers and legal authorities in the event of a spill.
4. A description of operator training to implement the plan.

The Permittee may submit plans and manuals required by 40 CFR Part 112, contingency plans required by Chapter 173-303 WAC, or other plans required by other agencies, which meet the intent of this section.

DRAFT

## REFERENCES

- Doneker, R. L., & Jirka, G. H. (2007). *CORMIX User Manual: A Hydrodynamic Mixing Zone Model and Decision Support System for Pollutant Discharges into Surface Waters, EPA-823-K-07-001*. Retrieved from <http://www.mixzon.com/downloads/>
- Ecology. (2004). *Information Manual for Treatment Plant Operators, Publication 04-10-020*. Retrieved from <https://apps.ecology.wa.gov/publications/SummaryPages/0410020.html>
- Ecology. (2016). *Guidelines for Preparing Quality Assurance Project Plans for Environmental Studies*. Retrieved from <https://apps.ecology.wa.gov/publications/summarypages/0403030.html>
- Ecology. (2016). *Laboratory Guidance and Whole Effluent Toxicity Test Review Criteria (Publication 95-80)*. Retrieved from <https://apps.ecology.wa.gov/publications/SummaryPages/9580.html>
- Ecology. (2018). *Water Quality Program Permit Writer's Manual, Publication 92-109*. Retrieved from <https://apps.ecology.wa.gov/publications/summarypages/92109.html>
- Ecology. (2021). *Sediment Cleanup User's Manual SCUM*. Retrieved from <https://apps.ecology.wa.gov/publications/SummaryPages/1209057.html>
- Ecology. (2022). *Standard Operating Procedure EAP080, Version 2.2: Continuous Temperature Monitoring of Freshwater Rivers and Streams, Publication 22-03-216*. Retrieved from <https://apps.ecology.wa.gov/publications/SummaryPages/2203216.html>
- Ecology. (2023). *Criteria for Sewage Works Design, Publication 98-37 (Orange Book)*. Retrieved from <https://apps.ecology.wa.gov/publications/SummaryPages/9837.html>
- Ecology and Department of Health. (2019). *Reclaimed Water Facilities Manual: The Purple Book*. Retrieved from <https://apps.ecology.wa.gov/publications/SummaryPages/1510024.html>
- Frick, W. E., Roberts, P. J., Davis, L. R., Keyes, D. J., & Baumgartner, G. K. (2003). *Dilution Models for Effluent Discharges, 4th Edition (Visual Plumes)*. Athens, GA: Ecosystems Research Division, USEPA. Retrieved from <https://www.epa.gov/sites/production/files/documents/VP-Manual.pdf>
- Kilpatrick, F. A., & Cobb, E. D. (1985). *Measurement of Discharge Using Tracers, Chapter A16, Techniques of Water-Resources Investigations of the USGS, Book 3, Application of Hydraulics*. Reston VA: USGS. Retrieved from [https://pubs.usgs.gov/twri/twri3-a16/pdf/TWRI\\_3-A16.pdf](https://pubs.usgs.gov/twri/twri3-a16/pdf/TWRI_3-A16.pdf)

- USEPA. (1985). *Infiltration/Inflow: I/I Analysis and Project Certification*. Retrieved from <https://apps.ecology.wa.gov/publications/SummaryPages/9703.html>
- USEPA. (1996). *Method 1669: Sampling Ambient Water for Trace Metals at EPA Water Quality Criteria Levels*. Retrieved from [https://www.epa.gov/sites/default/files/2015-10/documents/method\\_1669\\_1996.pdf](https://www.epa.gov/sites/default/files/2015-10/documents/method_1669_1996.pdf)
- Wilson, J. F., Cobb, E. D., & Kilpatrick, F. A. (1986). *Fluorometric Procedures for Dye Tracing, Chapter A12. Techniques of Water-Resources Investigations of the USGS, Book 3, Application of Hydraulics*. Reston, VA: USGS. Retrieved from [https://pubs.usgs.gov/twri/twri3-a12/pdf/TWRI\\_3-A12.pdf](https://pubs.usgs.gov/twri/twri3-a12/pdf/TWRI_3-A12.pdf)

## GENERAL CONDITIONS

### G1. Signatory requirements

1. All applications submitted to Ecology must be signed and certified.
  - a. In the case of corporations, by a responsible corporate officer. For the purpose of this section, a responsible corporate officer means:
    - A president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision-making functions for the corporation, or
    - The manager of one or more manufacturing, production, or operating facilities, provided, the manager is authorized to make management decisions which govern the operation of the regulated facility including having the explicit or implicit duty of making major capital investment recommendations, and initiating and directing other comprehensive measures to assure long-term environmental compliance with environmental laws and regulations; the manager can ensure that the necessary systems are established or actions taken to gather complete and accurate information for permit application requirements; and where authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures.
  - b. In the case of a partnership, by a general partner.
  - c. In the case of sole proprietorship, by the proprietor.
  - d. In the case of a municipal, state, or other public facility, by either a principal executive officer or ranking elected official.

Applications for permits for domestic wastewater facilities that are either owned or operated by, or under contract to, a public entity shall be submitted by the public entity.

2. All reports required by this permit and other information requested by Ecology must be signed by a person described above or by a duly authorized representative of that person. A person is a duly authorized representative only if:
  - a. The authorization is made in writing by a person described above and submitted to Ecology.
  - b. The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility, such as the position of plant manager, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters. (A duly authorized representative may thus be either a named individual or any individual occupying a named position.)

3. Changes to authorization. If an authorization under paragraph G1.2, above, is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of paragraph G1.2, above, must be submitted to Ecology prior to or together with any reports, information, or applications to be signed by an authorized representative.
4. Certification. Any person signing a document under this section must make the following certification:

"I certify under penalty of law, that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

## **G2. Right of inspection and entry**

The Permittee must allow an authorized representative of Ecology, upon the presentation of credentials and such other documents as may be required by law:

1. To enter upon the premises where a discharge is located or where any records must be kept under the terms and conditions of this permit.
2. To have access to and copy, at reasonable times and at reasonable cost, any records required to be kept under the terms and conditions of this permit.
3. To inspect, at reasonable times, any facilities, equipment (including monitoring and control equipment), practices, methods, or operations regulated or required under this permit.
4. To sample or monitor, at reasonable times, any substances or parameters at any location for purposes of assuring permit compliance or as otherwise authorized by the Clean Water Act.

## **G3. Permit actions**

This permit may be modified, revoked and reissued, or terminated either at the request of any interested person (including the permittee) or upon Ecology's initiative. However, the permit may only be modified, revoked and reissued, or terminated for the reasons specified in 40 CFR 122.62, 40 CFR 122.64 or WAC 173-220-150 according to the procedures of 40 CFR 124.5.

1. The following are causes for terminating this permit during its term, or for denying a permit renewal application:
  - a. Violation of any permit term or condition.

- b. Obtaining a permit by misrepresentation or failure to disclose all relevant facts.
  - c. A material change in quantity or type of waste disposal.
  - d. A determination that the permitted activity endangers human health or the environment, or contributes to water quality standards violations and can only be regulated to acceptable levels by permit modification or termination.
  - e. A change in any condition that requires either a temporary or permanent reduction, or elimination of any discharge or sludge use or disposal practice controlled by the permit.
  - f. Nonpayment of fees assessed pursuant to RCW 90.48.465.
  - g. Failure or refusal of the Permittee to allow entry as required in RCW 90.48.090.
2. The following are causes for modification but not revocation and reissuance except when the Permittee requests or agrees:
- a. A material change in the condition of the waters of the state.
  - b. New information not available at the time of permit issuance that would have justified the application of different permit conditions.
  - c. Material and substantial alterations or additions to the permitted facility or activities which occurred after this permit issuance.
  - d. Promulgation of new or amended standards or regulations having a direct bearing upon permit conditions, or requiring permit revision.
  - e. The Permittee has requested a modification based on other rationale meeting the criteria of 40 CFR Part 122.62.
  - f. Ecology has determined that good cause exists for modification of a compliance schedule, and the modification will not violate statutory deadlines.
  - g. Incorporation of an approved local pretreatment program into a municipality's permit.
3. The following are causes for modification or alternatively revocation and reissuance:
- a. When cause exists for termination for reasons listed in 1.a through 1.g of this section, and Ecology determines that modification or revocation and reissuance is appropriate.
  - b. When Ecology has received notification of a proposed transfer of the permit. A permit may also be modified to reflect a transfer after the effective date of an automatic transfer (General Condition G7) but will not be revoked and reissued after the effective date of the transfer except upon the request of the new Permittee.

#### **G4. Reporting planned changes**

The Permittee must, as soon as possible, but no later than one hundred eighty (180) days prior to the proposed changes, give notice to Ecology of planned physical

alterations or additions to the permitted facility, production increases, or process modification which will result in:

1. The permitted facility being determined to be a new source pursuant to 40 CFR 122.29(b).
2. A significant change in the nature or an increase in quantity of pollutants discharged.
3. A significant change in the Permittee's sludge use or disposal practices.

Following such notice, and the submittal of a new application or supplement to the existing application, along with required engineering plans and reports, this permit may be modified, or revoked and reissued pursuant to 40 CFR 122.62(a) to specify and limit any pollutants not previously limited. Until such modification is effective, any new or increased discharge in excess of permit limits or not specifically authorized by this permit constitutes a violation.

**G5. Plan review required**

Prior to constructing or modifying any wastewater control facilities, an engineering report and detailed plans and specifications must be submitted to Ecology for approval in accordance with chapter 173-240 WAC. Engineering reports, plans, and specifications must be submitted at least one hundred eighty (180) days prior to the planned start of construction unless a shorter time is approved by Ecology. Facilities must be constructed and operated in accordance with the approved plans.

**G6. Compliance with other laws and statutes**

Nothing in this permit excuses the Permittee from compliance with any applicable federal, state, or local statutes, ordinances, or regulations.

**G7. Transfer of this permit**

In the event of any change in control or ownership of facilities from which the authorized discharge emanates, the Permittee must notify the succeeding owner or controller of the existence of this permit by letter, a copy of which must be forwarded to Ecology.

1. Transfers by Modification

Except as provided in paragraph (2) below, this permit may be transferred by the Permittee to a new owner or operator only if this permit has been modified or revoked and reissued under 40 CFR 122.62(b)(2), or a minor modification made under 40 CFR 122.63(d), to identify the new Permittee and incorporate such other requirements as may be necessary under the Clean Water Act.

2. Automatic Transfers

This permit may be automatically transferred to a new Permittee if:

- a. The Permittee notifies Ecology at least thirty (30) days in advance of the proposed transfer date.

- b. The notice includes a written agreement between the existing and new Permittees containing a specific date transfer of permit responsibility, coverage, and liability between them.
- c. Ecology does not notify the existing Permittee and the proposed new Permittee of its intent to modify or revoke and reissue this permit. A modification under this subparagraph may also be minor modification under 40 CFR 122.63. If this notice is not received, the transfer is effective on the date specified in the written agreement.

**G8. Reduced production for compliance**

The Permittee, in order to maintain compliance with its permit, must control production and/or all discharges upon reduction, loss, failure, or bypass of the treatment facility until the facility is restored or an alternative method of treatment is provided. This requirement applies in the situation where, among other things, the primary source of power of the treatment facility is reduced, lost, or fails.

**G9. Removed substances**

Collected screenings, grit, solids, sludges, filter backwash, or other pollutants removed in the course of treatment or control of wastewaters must not be resuspended or reintroduced to the final effluent stream for discharge to state waters.

**G10. Duty to provide information**

The Permittee must submit to Ecology, within a reasonable time, all information which Ecology may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit or to determine compliance with this permit. The Permittee must also submit to Ecology upon request, copies of records required to be kept by this permit.

**G11. Other requirements of 40 CFR**

All other requirements of 40 CFR 122.41 and 40 CFR 122.42 are incorporated in this permit by reference.

**G12. Additional monitoring**

Ecology may establish specific monitoring requirements in addition to those contained in this permit by administrative order or permit modification.

**G13. Payment of fees**

The Permittee must submit payment of fees associated with this permit as assessed by Ecology.

**G14. Penalties for violating permit conditions**

Any person who is found guilty of willfully violating the terms and conditions of this permit is deemed guilty of a crime, and upon conviction thereof shall be punished by a fine of up to ten thousand dollars (\$10,000) and costs of prosecution, or by imprisonment in the discretion of the court. Each day upon which a willful violation occurs may be deemed a separate and additional violation.

**May 2024**

NPDES Permit Domestic Wastewater

Any person who violates the terms and conditions of a waste discharge permit may incur, in addition to any other penalty as provided by law, a civil penalty in the amount of up to ten thousand dollars (\$10,000) for every such violation. Each and every such violation is a separate and distinct offense, and in case of a continuing violation, every day's continuance is deemed to be a separate and distinct violation.

#### **G15. Upset**

Definition – “Upset” means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limits because of factors beyond the reasonable control of the Permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.

An upset constitutes an affirmative defense to an action brought for noncompliance with such technology-based permit effluent limits if the requirements of the following paragraph are met.

A Permittee who wishes to establish the affirmative defense of upset must demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:

1. An upset occurred and that the Permittee can identify the cause(s) of the upset.
2. The permitted facility was being properly operated at the time of the upset.
3. The Permittee submitted notice of the upset as required in Special Condition S3.F.
4. The Permittee complied with any remedial measures required under S3.F of this permit.

In any enforcement action the Permittee seeking to establish the occurrence of an upset has the burden of proof.

#### **G16. Property rights**

This permit does not convey any property rights of any sort, or any exclusive privilege.

#### **G17. Duty to comply**

The Permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Clean Water Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or denial of a permit renewal application.

#### **G18. Toxic pollutants**

The Permittee must comply with effluent standards or prohibitions established under Section 307(a) of the Clean Water Act for toxic pollutants within the time provided in the regulations that establish those standards or prohibitions, even if this permit has not yet been modified to incorporate the requirement.

**May 2024**

NPDES Permit Domestic Wastewater

**G19. Penalties for tampering**

The Clean Water Act provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than two (2) years per violation, or by both. If a conviction of a person is for a violation committed after a first conviction of such person under this condition, punishment shall be a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than four (4) years, or by both.

**G20. Compliance schedules**

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit must be submitted no later than fourteen (14) days following each schedule date.

**G21. Service agreement review**

The Permittee must submit to Ecology any proposed service agreements and proposed revisions or updates to existing agreements for the operation of any wastewater treatment facility covered by this permit. The review is to ensure consistency with chapters 90.46 and 90.48 RCW as required by RCW 70.150.040(9). In the event that Ecology does not comment within a thirty-day (30) period, the Permittee may assume consistency and proceed with the service agreement or the revised/updated service agreement.

## APPENDIX A – List of Pollutants, Analytical Methods, Detection Levels and Quantitation Levels

The Permittee must use the specified analytical methods, detection levels (DLs) <sup>1</sup> and quantitation levels (QLs) <sup>2</sup> in the following table for permit and application required monitoring unless:

- Another permit condition specifies other methods, detection levels, or quantitation levels.
- The method used produces measurable results in the sample and EPA has listed it as an EPA-approved method in 40 CFR Part 136.

If the Permittee uses an alternative method, not specified in the permit, and as allowed above, it must report the test method, DL, and QL on the discharge monitoring report or in the required report.

If the Permittee is unable to obtain the required DL and QL in its effluent due to matrix effects, the Permittee must submit a matrix-specific detection level (MDL) and a quantitation level (QL) to Ecology with appropriate laboratory documentation when the detection levels are too high to provide results near or below criteria (or applicable permit limits).

The lists below include conventional pollutants (as defined in CWA section 502(6) and 40 CFR Part 122), toxic or priority pollutants as defined in CWA section 307(a)(1) and listed in 40 CFR Part 122 Appendix D, 40 CFR Part 401.15 and 40 CFR Part 423 Appendix A), and nonconventionals. 40 CFR Part 122 Appendix D (Table V) also identifies toxic pollutants and hazardous substances which are required to be reported by dischargers if expected to be present. This permit appendix A list does not include those parameters.

The list also includes:

- Pulp and paper pollutants identified in 40 CFR Part 430.
- Dioxin and furan congeners identified using EPA Method 1613.
- Per- and polyfluoroalkyl substances (PFAS) identified using EPA Method 1633.

**Appendix A Table 1 – Conventional pollutants**

Pollutant	CAS number (if available)	Recommended analytical protocol	Detection level (DL) <sup>1</sup> µg/L unless specified	Quantitation level (QL) <sup>2</sup> µg/L unless specified
Biochemical Oxygen Demand		SM5210-B		2 mg/L
Biochemical Oxygen Demand, Soluble		SM5210-B <sup>3</sup>		2 mg/L

**May 2024**

NPDES Permit Domestic Wastewater

Pollutant	CAS number (if available)	Recommended analytical protocol	Detection level (DL) <sup>1</sup> µg/L unless specified	Quantitation level (QL) <sup>2</sup> µg/L unless specified
Fecal Coliform		SM 9221E, 9221F SM 9222D	N/A	Specified in method sample aliquot dependent
Oil and Grease (HEM) (Hexane Extractable Material)		1664 A or B	1,400	5,000
pH		SM4500-H+ B	N/A	N/A
Total Suspended Solids		SM2540-D		5 mg/L

**Appendix A Table 2 - Nonconventional pollutants**

Pollutant	CAS number (if available)	Recommended analytical protocol	Detection level (DL) <sup>1</sup> µg/L unless specified	Quantitation level (QL) <sup>2</sup> µg/L unless specified
Alkalinity, Total		SM2320-B		5 mg/L as CaCO <sub>3</sub>
Aluminum, Total	7429-90-5	200.8	2.0	10
Ammonia, Total (as N)		SM4500-NH3-B and C/D/E/G/H		20
Barium Total	7440-39-3	200.8	0.5	2.0
BTEX (benzene +toluene + ethylbenzene + m,o,p xylenes)		EPA SW 846 8021/8260	1	2
Boron, Total	7440-42-8	200.8	2.0	10.0
Chemical Oxygen Demand		SM5220-D		10 mg/L
Chloride		SM4500-Cl B/C/D/E and SM4110 B		Sample and limit dependent
Chlorine, Total Residual		SM4500 Cl G	10	50
Cobalt, Total	7440-48-4	200.8	0.05	0.25
Color		SM2120 B/C/E		10 color units
Dissolved oxygen		SM4500-OC/OG		0.2 mg/L

Pollutant	CAS number (if available)	Recommended analytical protocol	Detection level (DL) <sup>1</sup> µg/L unless specified	Quantitation level (QL) <sup>2</sup> µg/L unless specified
E.coli		SM 9221B, 9221F, 9223B	N/A	Specified in method; sample aliquot dependent
Enterococci		EPA 1600 SM 9230B, 9230C, 9230D,	N/A	Specified in method; sample aliquot dependent
Flow		Calibrated device		
Fluoride	16984-48-8	SM4500-F E	25	100
Hardness, Total		SM2340B		200 as CaCO <sub>3</sub>
Iron, Total	7439-89-6	200.7	12.5	50
Magnesium, Total	7439-95-4	200.7	10	50
Manganese, Total	7439-96-5	200.8	0.1	0.5
Molybdenum, Total	7439-98-7	200.8	0.1	0.5
Nitrate + Nitrite Nitrogen (as N)		SM4500-NO <sub>3</sub> - E/F/H		100
Nitrogen, Total Kjeldahl (as N)		SM4500-N <sub>org</sub> B/C and SM4500NH <sub>3</sub> - B/C/D/EF/G/H		300
NWTPH Dx <sup>4</sup>		Ecology NWTPH Dx	250	250
NWTPH Gx <sup>5</sup>		Ecology NWTPH Gx	250	250
Phosphorus, Total (as P)		SM4500 PB followed by SM4500-PE/PF	3	10
Salinity		SM2520-B		3 practical salinity units or scale (PSU or PSS)
Settleable Solids		SM2540 -F		Sample and limit dependent
Soluble Reactive Phosphorus (as P)		SM4500-P E/F/G	3	10
Sulfate (as mg/L SO <sub>4</sub> )		SM4110-B		0.2 mg/L
Sulfide (as mg/L S)		SM4500-S2F/D/G		0.2 mg/L
Sulfite (as mg/L SO <sub>3</sub> )		SM4500-SO3B		2 mg/L

**May 2024**

NPDES Permit Domestic Wastewater

Pollutant	CAS number (if available)	Recommended analytical protocol	Detection level (DL) <sup>1</sup> µg/L unless specified	Quantitation level (QL) <sup>2</sup> µg/L unless specified
Temperature		Analog recorder or micro-recording devices (thermistors)		0.2°C
Tin, Total	7440-31-5	200.8	0.3	1.5
Titanium, Total	7440-32-6	200.8	0.5	2.5
Total Coliform		SM 9221B SM 9222B	N/A	Specified in method; sample aliquot dependent
Total Organic Carbon		SM5310-B/C/D		1 mg/L
Total Dissolved solids		SM2540 C		20 mg/L

**Appendix A Table 3 - Priority pollutants: Metals, chromium (hex), cyanide & total phenols**

Priority pollutants	PP #	CAS number (if available)	Recommended analytical protocol	Detection level (DL) <sup>1</sup> µg/L unless specified	Quantitation level (QL) <sup>2</sup> µg/L unless specified
Antimony, Total	114	7440-36-0	200.8	0.3	1.0
Arsenic, Total	115	7440-38-2	200.8	0.1	0.5
Beryllium, Total	117	7440-41-7	200.8	0.1	0.5
Cadmium, Total	118	7440-43-9	200.8	0.05	0.25
Chromium (hex) dissolved	119	18540-29-9	SM3500-Cr C	0.3	1.2
Chromium, Total	119	7440-47-3	200.8	0.2	1.0
Copper, Total	120	7440-50-8	200.8	0.4	2.0
Lead, Total	122	7439-92-1	200.8	0.1	0.5
Mercury, Total	123	7439-97-6	1631E	0.0002	0.0005
Nickel, Total	124	7440-02-0	200.8	0.1	0.5
Selenium, Total	125	7782-49-2	200.8	1.0	1.0
Silver, Total	126	7440-22-4	200.8	0.04	0.2
Thallium, Total	127	7440-28-0	200.8	0.09	0.36
Zinc, Total	128	7440-66-6	200.8	0.5	2.5

**May 2024**

NPDES Permit Domestic Wastewater

Priority pollutants	PP #	CAS number (if available)	Recommended analytical protocol	Detection level (DL) <sup>1</sup> µg/L unless specified	Quantitation level (QL) <sup>2</sup> µg/L unless specified
Cyanide, Total	121	57-12-5	335.4	5	10
Cyanide, Weak Acid Dissociable	121		SM4500-CN I	5	10
Cyanide, Free Amenable to Chlorination (Available Cyanide)	121		SM4500-CN G	5	10
Phenols, Total	65		EPA 420.1		50

**Appendix A Table 4 - Priority pollutants: Acid compounds**

Priority pollutants	PP #	CAS number (if available)	Recommended analytical protocol	Detection level (DL) <sup>1</sup> µg/L unless specified	Quantitation level (QL) <sup>2</sup> µg/L unless specified
2-Chlorophenol	24	95-57-8	625.1	3.3	9.9
2,4-Dichlorophenol	31	120-83-2	625.1	2.7	8.1
2,4-Dimethylphenol	34	105-67-9	625.1	2.7	8.1
4,6-dinitro-o-cresol (2-methyl-4,6,- dinitrophenol)	60	534-52-1	625.1/1625B	24	72
2,4 dinitrophenol	59	51-28-5	625.1	42	126
2-Nitrophenol	57	88-75-5	625.1	3.6	10.8
4-Nitrophenol	58	100-02-7	625.1	2.4	7.2
Parachlorometa cresol (4-chloro-3- methylphenol)	22	59-50-7	625.1	3.0	9.0
Pentachlorophenol	64	87-86-5	625.1	3.6	10.8
Phenol	65	108-95-2	625.1	1.5	4.5
2,4,6-Trichlorophenol	21	88-06-2	625.1	2.7	8.1

**Appendix A Table 5 - Priority pollutants: Volatile compounds**

**May 2024**

NPDES Permit Domestic Wastewater

Priority pollutants	PP #	CAS number (if available)	Recommended analytical protocol	Detection level (DL) <sup>1</sup> µg/L unless specified	Quantitation level (QL) <sup>2</sup> µg/L unless specified
Acrolein	2	107-02-8	624.1	5	10
Acrylonitrile	3	107-13-1	624.1	1.0	2.0
Benzene	4	71-43-2	624.1	4.4	13.2
Bromoform	47	75-25-2	624.1	4.7	14.1
Carbon tetrachloride	6	56-23-5	624.1/601 or SM6230B	2.8	8.4
Chlorobenzene	7	108-90-7	624.1	6.0	18.0
Chloroethane	16	75-00-3	624/601	1.0	2.0
2-Chloroethylvinyl Ether	19	110-75-8	624.1	1.0	2.0
Chloroform	23	67-66-3	624.1 or SM6210B	1.6	4.8
Dibromochloromethane (chlordibromomethane)	51	124-48-1	624.1	3.1	9.3
1,2-Dichlorobenzene	25	95-50-1	624.1	1.9	7.6
1,3-Dichlorobenzene	26	541-73-1	624.1	1.9	7.6
1,4-Dichlorobenzene	27	106-46-7	624.1	4.4	17.6
Dichlorobromomethane	48	75-27-4	624.1	2.2	6.6
1,1-Dichloroethane	13	75-34-3	624.1	4.7	14.1
1,2-Dichloroethane	10	107-06-2	624.1	2.8	8.4
1,1-Dichloroethylene	29	75-35-4	624.1	2.8	8.4
1,2-Dichloropropane	32	78-87-5	624.1	6.0	18.0
1,3-dichloropropene (mixed isomers) (1,2-dichloropropylene)6	33	542-75-6	624.1	5.0	15.0
Ethylbenzene	38	100-41-4	624.1	7.2	21.6
Methyl bromide (Bromomethane)	46	74-83-9	624/601	5.0	10.0
Methyl chloride (Chloromethane)	45	74-87-3	624.1	1.0	2.0
Methylene chloride	44	75-09-2	624.1	2.8	8.4
1,1,2,2-Tetrachloroethane	15	79-34-5	624.1	6.9	20.7
Tetrachloroethylene	85	127-18-4	624.1	4.1	12.3
Toluene	86	108-88-3	624.1	6.0	18.0

**May 2024**

NPDES Permit Domestic Wastewater

Priority pollutants	PP #	CAS number (if available)	Recommended analytical protocol	Detection level (DL) <sup>1</sup> µg/L unless specified	Quantitation level (QL) <sup>2</sup> µg/L unless specified
1,2-Trans-Dichloroethylene (Ethylene dichloride)	30	156-60-5	624.1	1.6	4.8
1,1,1-Trichloroethane	11	71-55-6	624.1	3.8	11.4
1,1,2-Trichloroethane	14	79-00-5	624.1	5.0	15.0
Trichloroethylene	87	79-01-6	624.1	1.9	5.7
Vinyl chloride	88	75-01-4	624/SM6200B	1.0	2.0

**Appendix A Table 6 - Priority pollutants: Base/neutral compounds**

Priority pollutants	PP #	CAS number (if available)	Recommended analytical Protocol	Detection level (DL) <sup>1</sup> µg/L unless specified	Quantitation level (QL) <sup>2</sup> µg/L unless specified
Acenaphthene	1	83-32-9	625.1	1.9	5.7
Acenaphthylene	77	208-96-8	625.1	3.5	10.5
Anthracene	78	120-12-7	625.1	1.9	5.7
Benzidine	5	92-87-5	625.1	44	132
Benzyl butyl phthalate	67	85-68-7	625.1	2.5	7.5
Benzo(a)anthracene	72	56-55-3	625.1	7.8	23.4
Benzo(b)fluoranthene (3,4- benzofluoranthene) <sup>7</sup>	74	205-99-2	610/625.1	4.8	14.4
Benzo(k)fluoranthene (11,12- benzofluoranthene) <sup>7</sup>	75	207-08-9	610/625.1	2.5	7.5
Benzo(a)pyrene	73	50-32-8	610/625.1	2.5	7.5
Benzo(ghi)Perylene	79	191-24-2	610/625.1	4.1	12.3
Bis(2-chloroethoxy)methane	43	111-91-1	625.1	5.3	15.9
Bis(2-chloroethyl)ether	18	111-44-4	611/625.1	5.7	17.1
Bis(2-chloro-1-methylethyl)Ether (Bis(2-chloroisopropyl)ether) <sup>8</sup>	42	108-60-1	625.1	5.7	17.1
Bis(2-ethylhexyl)phthalate	66	117-81-7	625.1	2.5	7.5
4-Bromophenyl phenyl ether	41	101-55-3	625.1	1.9	5.7

**May 2024**

NPDES Permit Domestic Wastewater

Priority pollutants	PP #	CAS number (if available)	Recommended analytical Protocol	Detection level (DL) <sup>1</sup> µg/L unless specified	Quantitation level (QL) <sup>2</sup> µg/L unless specified
2-Chloronaphthalene	20	91-58-7	625.1	1.9	5.7
4-Chlorophenyl phenyl ether	40	7005-72-3	625.1	4.2	12.6
Chrysene	76	218-01-9	610/625.1	2.5	7.5
Dibenzo(a-h)anthracene (1,2,5,6-dibenzanthracene)	82	53-70-3	625.1	2.5	7.5
3,3-Dichlorobenzidine	28	91-94-1	605/625.1	16.5	49.5
Diethyl phthalate	70	84-66-2	625.1	1.9	5.7
Dimethyl phthalate	71	131-11-3	625.1	1.6	4.8
Di-n-butyl phthalate	68	84-74-2	625.1	2.5	7.5
2,4-dinitrotoluene	35	121-14-2	609/625.1	5.7	17.1
2,6-dinitrotoluene	36	606-20-2	609/625.1	1.9	5.7
Di-n-octyl phthalate	69	117-84-0	625.1	2.5	7.5
1,2-Diphenylhydrazine (as Azobenzene)	37	122-66-7	1625B/625.1	5.0	20
Fluoranthene	39	206-44-0	625.1	2.2	6.6
Fluorene	80	86-73-7	625.1	1.9	5.7
Hexachlorobenzene	9	118-74-1	612/625.1	1.9	5.7
Hexachlorobutadiene	52	87-68-3	625.1	0.9	2.7
Hexachlorocyclopentadiene	53	77-47-4	1625B/625.1	2.0	4.0
Hexachloroethane	12	67-72-1	625.1	1.6	4.8
Indeno(1,2,3-cd)Pyrene	83	193-39-5	610/625.1	3.7	11.1
Isophorone	54	78-59-1	625.1	2.2	6.6
Naphthalene	55	91-20-3	625.1	1.6	4.8
Nitrobenzene	56	98-95-3	625.1	1.9	5.7
N-Nitrosodimethylamine	61	62-75-9	607/625.1	2.0	4.0
N-Nitrosodi-n-propylamine	63	621-64-7	607/625.1	0.5	1.0
N-Nitrosodiphenylamine	62	86-30-6	625.1	1.0	2.0
Phenanthrene	81	85-01-8	625.1	5.4	16.2
Pyrene	84	129-00-0	625.1	1.9	5.7
1,2,4-Trichlorobenzene	8	120-82-1	625.1	1.9	5.7

**May 2024**

NPDES Permit Domestic Wastewater

**Appendix A Table 7 - Base/neutral compounds – Ecology PBTs**

Pollutant	CAS number (if available)	Recommended analytical protocol	Detection level (DL) <sup>1</sup> µg/L unless specified	Quantitation level (QL) <sup>2</sup> µg/L unless specified
Benzo(j)fluoranthene <sup>7</sup>	205-82-3	625	0.5	1.0
Benzo(r,s,t)pentaphene	189-55-9	625	1.3	5.0
Dibenzo (a,h)acridine	226-36-8	610M/625M	2.5	10.0
Dibenzo (a,j)acridine	224-42-0	610M/625M	2.5	10.0
Dibenzo(a,e)pyrene	192-65-4	610M/625M	2.5	10.0
Dibenzo(a,h)pyrene	189-64-0	625M	2.5	10.0
3-Methyl cholanthrene	56-49-5	625	2.0	8.0
Perylene	198-55-0	625	1.9	7.6

**Appendix A Table 8 - Dioxin**

Priority pollutant	PP #	CAS number (if available)	Recommended analytical protocol	Detection level (DL) <sup>1</sup> µg/L unless specified	Quantitation level (QL) <sup>2</sup> µg/L unless specified
2,3,7,8-Tetra-Chlorodibenzo-P-Dioxin (2,3,7,8 TCDD)	129	1746-01-6	1613B	1.3 pg/L	5 pg/L

**Appendix A Table 9 - Pesticides and PCBs**

Priority pollutants	PP #	CAS number (if available)	Recommended analytical protocol	Detection level (DL) <sup>1</sup> µg/L unless specified	Quantitation level (QL) <sup>2</sup> µg/L unless specified
Aldrin	89	309-00-2	608.3	4.0 ng/L	12 ng/L
alpha-BHC	102	319-84-6	608.3	3.0 ng/L	9.0 ng/L
beta-BHC	103	319-85-7	608.3	6.0 ng/L	18 ng/L
gamma-BHC (Lindane)	104	58-89-9	608.3	4.0 ng/L	12 ng/L

**May 2024**

NPDES Permit Domestic Wastewater

delta-BHC	105	319-86-8	608.3	9.0 ng/L	27 ng/L
Chlordane <sup>9</sup>	91	57-74-9	608.3	14 ng/L	42 ng/L
4,4'-DDT	92	50-29-3	608.3	12 ng/L	36 ng/L
4,4'-DDE	93	72-55-9	608.3	4.0 ng/L	12 ng/L
4,4' DDD	94	72-54-8	608.3	11ng/L	33 ng/L
Dieldrin	90	60-57-1	608.3	2.0 ng/L	6.0 ng/L
alpha-Endosulfan	95	959-98-8	608.3	14 ng/L	42 ng/L
beta-Endosulfan	96	33213-65-9	608.3	4.0 ng/L	12 ng/L
Endosulfan Sulfate	97	1031-07-8	608.3	66 ng/L	198 ng/L
Endrin	98	72-20-8	608.3	6.0 ng/L	18 ng/L
Endrin Aldehyde	99	7421-93-4	608.3	23 ng/L	70 ng/L
Heptachlor	100	76-44-8	608.3	3.0 ng/L	9.0 ng/L
Heptachlor Epoxide	101	1024-57-3	608.3	83 ng/L	249 ng/L
PCB-1242 <sup>10</sup>	106	53469-21-9	608.3	0.065	0.195
PCB-1254	107	11097-69-1	608.3	0.065	0.195
PCB-1221	108	11104-28-2	608.3	0.065	0.195
PCB-1232	109	11141-16-5	608.3	0.065	0.195
PCB-1248	110	12672-29-6	608.3	0.065	0.195
PCB-1260	111	11096-82-5	608.3	0.065	0.195
PCB-1016 <sup>10</sup>	112	12674-11-2	608.3	0.065	0.195
Toxaphene	113	8001-35-2	608.3	240 ng/L	720 ng/L

**Appendix A Table 10 - Pulp & paper pollutants (40CFR Part 430)**

Pollutant	CAS number (if available)	Recommended analytical protocol	Detection level (DL) <sup>1</sup> µg/L unless specified	Quantitation level (QL) <sup>2</sup> µg/L unless specified
Adsorbable Organic Halides (AOX)		EPA 1650		20
2,3,7,8- Tetrachlorodibenzo-p-dioxin (TCDD) (this is a priority pollutant also listed in Table 8)	1746-01-6	EPA 1613	1.3 pg/L	5 pg/L
2,3,7,8- Tetrachlorodibenzofuran (TCDF)	51207-31-9	EPA 1613	1.3 pg/L	5 pg/L
Trichlorosyringol		EPA 1653		2.5

**May 2024**

NPDES Permit Domestic Wastewater

Pollutant	CAS number (if available)	Recommended analytical protocol	Detection level (DL) <sup>1</sup> µg/L unless specified	Quantitation level (QL) <sup>2</sup> µg/L unless specified
3,4,5-Trichlorocatechol		EPA 1653		5.0
3,4,6-Trichlorocatechol		EPA 1653		5.0
3,4,5-Trichloroguaiacol		EPA 1653		2.5
3,4,6-Trichloroguaiacol		EPA 1653		2.5
4,5,6-Trichloroguaiacol		EPA 1653		2.5
2,4,5-Trichlorophenol		EPA 1653		2.5
2,4,6-Trichlorophenol		EPA 1653		2.5
Tetrachlorocatechol		EPA 1653		5.0
Tetrachloroguaiacol		EPA 1653		5.0
2,3,4,6-Tetrachlorophenol		EPA 1653		2.5
Pentachlorophenol (this is also a priority pollutant listed in Table 4)		EPA 1653		5.0

**Appendix A Table 11 - Nonconventionals – dioxin & furan congeners**

Pollutant	CAS number (if available)	Recommended analytical protocol	Detection level (DL) <sup>1</sup> µg/L unless specified	Quantitation level (QL) <sup>2</sup> µg/L unless specified
2,3,7,8- Tetrachlorodibenzo-p-dioxin (TCDD) (this is a priority pollutant also listed in Table 8)	1746-01-6	EPA 1613	1.3 pg/L	5 pg/L
Total TCDD	41903-57-5			
2,3,7,8- Tetrachlorodibenzofuran (TCDF)	51207-31-9		1.3 pg/L	5 pg/L
Total-TCDF	55722-27-5			
1,2,3,7,8- Pentachlorodibenzo-p-dioxin (PeCDD)	40321-76-4			
Total-PeCDD	36088-22-9			
1,2,3,7,8- Pentachlorodibenzofuran (PeCDF)	57117-41-6			
2,3,4,7,8-PeCDF	57117-31-4			
Total-PeCDF	30402-15-4			

**May 2024**

NPDES Permit Domestic Wastewater

Pollutant	CAS number (if available)	Recommended analytical protocol	Detection level (DL) <sup>1</sup> µg/L unless specified	Quantitation level (QL) <sup>2</sup> µg/L unless specified
1,2,3,4,7,8- Hexachlorodibenzo-p-dioxin (HxCDD)	39227-28-6			
1,2,3,6,7,8-HxCDD	57653-85-7			
1,2,3,7,8,9-HxCDD	19408-74-3			
Total-HxCDD	34465-46-8			
1,2,3,4,7,8- Hexachlorodibenzofuran (HxCDF)	70648-26-9			
1,2,3,6,7,8-HxCDF	57117-44-9			
1,2,3,7,8,9-HxCDF	72918-21-9			
2,3,4,6,7,8-HxCDF	60851-34-5			
Total-HxCDF	55684-94-1			
1,2,3,4,6,7,8- Heptachlorodibenzo-p-dioxin (HpCDD )	35822-46-9			
Total-HpCDD	37871-00-4			
1,2,3,4,6,7,8- Heptachlorodibenzofuran (HpCDF)	67562-39-4			
1,2,3,4,7,8,9-HpCDF	55673-89-7			
Total-HpCDF	38998-75-3			
Octachlorodibenzo-p-dioxin (OCDD )	3268-87-9			
Octachlorodibenzofuran (OCDF)	39001-02-0			

**Appendix A Table 12 - Per- and polyfluoroalkyl substances (PFAS) 11**

Pollutant	CAS number (if available)	Recommended analytical protocol	Detection level (DL) <sup>1</sup> µg/L unless specified	Quantitation level (QL) <sup>2</sup> µg/L unless specified
Perfluorobutanoic acid (PFBA)	375-22-4	1633	0.330 ng/L	6.4 ng/L
Perfluoropentanoic acid (PFPeA)	2706-90-3	1633	0.196 ng/L	3.2 ng/L
Perfluorohexanoic acid (PFHxA)	307-24-4	1633	0.318 ng/L	1.6 ng/L
Perfluoroheptanoic acid (PFHpA)	375-85-9	1633	0.221 ng/L	1.6 ng/L

**May 2024**

NPDES Permit Domestic Wastewater

Pollutant	CAS number (if available)	Recommended analytical protocol	Detection level (DL) <sup>1</sup> µg/L unless specified	Quantitation level (QL) <sup>2</sup> µg/L unless specified
Perfluorooctanoic acid (PFOA)	335-67-1	1633	0.302 ng/L	1.6 ng/L
Perfluorononanoic acid (PFNA)	375-95-1	1633	0.221 ng/L	1.6 ng/L
Perfluorodecanoic acid (PFDA)	335-76-2	1633	0.333 ng/L	1.6 ng/L
Perfluoroundecanoic acid (PFUnA)	2058-94-8	1633	0.264 ng/L	1.6 ng/L
Perfluorododecanoic acid (PFDoA)	307-55-1	1633	0.379 ng/L	1.6 ng/L
Perfluorotridecanoic acid (PFTrDA)	72629-94-8	1633	0.238 ng/L	1.6 ng/L
Perfluorotetradecanoic acid (PFTeDA)	376-06-7	1633	0.264 ng/L	1.6 ng/L
Perfluorobutanesulfonic acid (PFBS)	375-73-5	1633	0.245 ng/L	1.6 ng/L
Perfluoropentanesulfonic acid (PFPeS)	2706-91-4	1633	0.204 ng/L	1.6 ng/L
Perfluorohexanesulfonic acid (PFHxS)	355-46-4	1633	0.217 ng/L	1.6 ng/L
Perfluoroheptanesulfonic acid (PFHpS)	375-92-8	1633	0.137 ng/L	1.6 ng/L
Perfluorooctanesulfonic acid (PFOS)	1763-23-1	1633	0.327 ng/L	1.6 ng/L
Perfluorononanesulfonic acid (PFNS)	68259-12-1	1633	0.303 ng/L	1.6 ng/L
Perfluorodecanesulfonic acid (PFDS)	335-77-3	1633	0.334 ng/L	1.6 ng/L
Perfluorododecanesulfonic acid (PFDoS)	79780-39-5	1633	0.179 ng/L	1.6 ng/L
1H,1H,2H,2H-Perfluorohexanesulfonic acid (4:2FTS)	757124-72-4	1633	2.281 ng/L	6.4 ng/L
1H,1H,2H,2H-Perfluorooctanesulfonic acid (6:2FTS)	27619-97-2	1633	3.973 ng/L	6.4 ng/L
1H,1H,2H,2H-Perfluorodecanesulfonic acid (8:2FTS)	39108-34-4	1633	1.566 ng/L	6.4 ng/L
Perfluorooctanesulfonamide (PFOSA)	754-91-6	1633	0.227 ng/L	1.6 ng/L
N-methyl perfluorooctanesulfonamine (NMeFOSA)	31506-32-8	1633	0.196 ng/L	1.6 ng/L
N-ethyl perfluorooctanesulfonamide (NEtFOSA)	4151-50-2	1633	0.585 ng/L	1.6 ng/L
N-methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	2355-31-9	1633	0.586 ng/L	1.6 ng/L
N-ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	2991-50-6	1633	0.324 ng/L	1.6 ng/L

**May 2024**

NPDES Permit Domestic Wastewater

Pollutant	CAS number (if available)	Recommended analytical protocol	Detection level (DL) <sup>1</sup> µg/L unless specified	Quantitation level (QL) <sup>2</sup> µg/L unless specified
N-methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	24448-09-7	1633	1.191 ng/L	16 ng/L
N-ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	1691-99-2	1633	1.022 ng/L	16 ng/L
Hexafluoropropylene oxide dimer acid (HFPO-DA)	13252-13-6	1633	0.406 ng/L	6.4 ng/L
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	919005-14-4	1633	0.779 ng/L	6.4 ng/L
Perfluoro(2-ethoxyethane) sulfonic acid (PFEEESA)	113507-82-7	1633	0.137 ng/L	3.2 ng/L
Perfluoro-3-methoxypropanoic acid (PFMPA)	377-73-1	1633	0.177 ng/L	3.2 ng/L
Perfluoro-4-methoxybutanoic acid (PFMBA)	863090-89-5	1633	0.117 ng/L	3.2 ng/L
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	151772-58-6	1633	1.384 ng/L	3.2 ng/L
9-Chlorohexadecafluoro-3-oxaundecane-1-sulfonic acid (9CL-PF3ONS)	756426-58-1	1633	0.871 ng/L	6.4 ng/L
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11CL-PF3OUNDS)	763051-92-9	1633	0.819 ng/L	6.4 ng/L
3-Perfluoropropyl propanoic acid (3:3FTCA)	356-02-5	1633	0.721 ng/L	8.0 ng/L
2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	914637-49-3	1633	5.066 ng/L	40 ng/L
3-Perfluoroheptyl propanoic acid (7:3FTCA)	812-70-4	1633	5.942 ng/L	40 ng/L

## Footnotes

<sup>1</sup> Detection level (DL) – or method detection limit means the minimum concentration of an analyte (substance) that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results as determined by the procedure given in 40 CFR part 136, Appendix B.

**May 2024**

NPDES Permit Domestic Wastewater

<sup>2</sup> Quantitation Level (QL) – also known as Minimum Level (ML) – The term “minimum level” refers to either the sample concentration equivalent to the lowest calibration point in a method or a multiple of the method detection limit (DL), whichever is higher. Minimum levels may be obtained in several ways: They may be published in a method; they may be based on the lowest acceptable calibration point used by a laboratory; or they may be calculated by multiplying the DL in a method, or the DL determined by a laboratory, by a factor of 3. For the purposes of NPDES compliance monitoring, EPA considers the following terms to be synonymous: “quantitation limit,” “reporting limit,” and “minimum level”.

<sup>3</sup> Soluble Biochemical Oxygen Demand – method note: First, filter the sample through a Millipore Nylon filter (or equivalent) - pore size of 0.45-0.50 um (prep all filters by filtering 250 ml of laboratory grade deionized water through the filter and discard). Then, analyze sample as per method 5210-B.

<sup>4</sup> Northwest Total Petroleum Hydrocarbons Diesel Extended Range OR NWTPH Dx – Analytical Methods for Petroleum Hydrocarbons <https://apps.ecology.wa.gov/publications/documents/97602.pdf>

<sup>5</sup> Northwest Total Petroleum Hydrocarbons Gasoline Extended Range OR NWTPH Gx – Analytical Methods for Petroleum Hydrocarbons <https://apps.ecology.wa.gov/publications/documents/97602.pdf>

<sup>6</sup> 1, 3-dichloropropylene (mixed isomers) – You may report this parameter as two separate parameters: cis-1, 3-dichloropropene (10061-01-5) and trans-1, 3-dichloropropene (10061-02-6).

<sup>7</sup> Total Benzofluoranthenes – Because Benzo(b)fluoranthene, Benzo(j)fluoranthene and Benzo(k)fluoranthene co-elute you may report these three isomers as total benzofluoranthenes.

<sup>8</sup> Bis(2-Chloro-1-Methylethyl) Ether – This compound was previously listed as Bis(2-Chloroisopropyl) Ether (39638-32-9)

<sup>9</sup> Chlordane – You may report alpha-chlordane (5103-71-9) and gamma-chlordane (5103-74-2) in place of chlordane (57-74-9). If you report alpha and gamma-chlordane, the DL/PQLs that apply are 14/42 ng/L.

<sup>10</sup> PCB 1016 & PCB 1242 – You may report these two PCB compounds as one parameter called PCB 1016/1242.

11 Prior to approval of analytical methods for PFAS chemicals under 40 CFR 136, the permittee must use the latest revision of EPA Method 1633. After analytical methods for PFAS chemicals are approved under 40 CFR 136, the permittee may use any sufficiently sensitive approved analytical method. If a laboratory that can analyze PFAS chemicals via Method 1633 is not reasonably available, the permittee may request use of an alternate method and Ecology can approve the alternative method by email.

**May 2024**

NPDES Permit Domestic Wastewater