

Reporting Jurisdiction Name, Address

Ecology ERTS #: 739309

## SSO - SANITARY SEWER OVERFLOW REPORTING AND INFORMATION SHEET

Call made to LOTT by: Sydney Pype

Time call was placed:

E-Mailed reporting time: 15:57

Today's Date: 6/26/2025

<input type="checkbox"/>
<input checked="" type="checkbox"/>
<input checked="" type="checkbox"/>
<input type="checkbox"/>

INITIAL REPORT

FOLLOW-UP REPORT

ON-GOING INCIDENT

OTHER \_\_\_\_\_

Name: Sydney Pype of City of Olympia Phone: 360-628-0589  
Person reporting the spill to LOTT Agency

Spill began: 6/4/2025 at n/a Spill stopped: 6/5/2025 at n/a  
Date Time Date Time

Gallons spilled: 480+ Material spilled: SSO - Raw Sewage / STEP

Spill Location: 1903 16th Ave SE, Olympia  
Address, manhole, nearest intersection or other identifiable location

Spilled to: ☒ ground, no run-off ☐ Run-off to: \_\_\_\_\_  
includes storm ponds Street, catch basin, storm sewer

Reached the Waters of the State

☒ Yes ☐ No

Bodies of Water Indian/Moxlie Creek  
Name of stream or water body

Cause of spill: Private property - Grinder Pump system failed  
Line blockage, CSO, STEP system malfunction, etc.

Private property, property owner will be responsible for fixing the infrastructure on their  
Clean-up & disposal: property. The spill is non-recoverable due to no surface flow.  
Actions taken & by whom

Staff did not provide details on prevention **\*\*FOLLOW-UP\*\*** *City of Olympia provided an update on this SSO event. Property has not made repairs as of this date, SSO event is ongoing with approx. flow of 20 GPD to Indian / Moxlie Creek. Thurston County Helath has moved onto civil penalties to property owners, issuing an emergency order.*

Prevention: order.  
Actions taken to prevent re-occurrence (clean line, replace equipment, etc.)

Notifications by EMAIL or PHONE

NAME	CALLED (TIME, DATE & INITIALS)	EMAILED (TIME, DATE & INITIALS)
Department of Ecology - 360.407.6300	1021_6/5/25_SP	
Thurston County Health 360.968.4346 (Tristen P.) or 360.867.2535 (Stuart W.) emwebmaster@co.thurston.wa.u	0615_6/6/25_msg	

<b>Dept. of Health - Shellfish - 360.236.3330 - 360.789.8962</b>	n/a	
<b>LOTT - 360.528.5700</b>		<b>EMAILED (TIME, DATE &amp; INITIALS)</b>
Operations and Facilities		1255_6/30/25_map
Environmental Planning & Communications Dir		1255_6/30/25_map
Process Control Sup.		1255_6/30/25_map
Operations Superviror		1255_6/30/25_map



