

**City of Dayton Public Works**  
**Sanitary Sewer Overflow, By-Pass or Illegal Discharge Field Report**

DOE ERTS No: (Ecology enters this #) #640183

\* indicates Required fields

* Event:	<input type="checkbox"/> Sanitary Sewer Overflow to surface water <input checked="" type="checkbox"/> Sanitary Sewer Overflow to ground <input type="checkbox"/> By-Pass (discharge to receiving water with any part of treatment process inoperable)
----------	---

**Reported By**

*Name:	Michael Bowhay	*Business Name:	Dayton WWTP
*Email:	wwtpdayton@hotmail.com	*Phone Number:	(509)382-2937
*Report Date:	3/26/2013	*Time:	10:00 AM

**Discharge Information**

*Date Discharge Discovered:	3/25/2013	Time:	9:45 AM
*Location Address:	Dayton WWTP, 800 Stockton Rd		
	City:	Dayton	State: WA

**Description of Discharge**

*Medium:	Lawn dirt and gravel / dirt mix
*Material:	Thickened sludge
*Source:	Digester overflow
Cause:	Plugged crossover pipe from primary to secondary digester

*Receiving Water (if applicable):	None of the spill went in any surface water. Stopped at least 75 yards from the River.
-----------------------------------	--

Duration of Overflow:	10-15 min.
-----------------------	------------

Volume of Overflow:	800-1200 gallons
---------------------	------------------

Other Comments:	Ended in depression 30FT x10ft x .25 ft on City property only.
-----------------	--

**Notifications**

Columbia County Environmental Health Dept Joseph Siumara ph: 509 520-5907 fax: 509-397-6239, email: jfiumara@co.walla-walla.wa.us	Date:	3/26/2013
WWTP Permit (Patrick McGuire) ph: 509-3293567 fax: 509-329-3470, email: pmcg461@ecy.wa.gov	Date:	3/25/2013
DOE (Mike Hepp) ph: 509-329-3536, fax: 509-329-3570, email: mhpe461@ecy.wa.gov	Date:	3/26/2013

**NOTE: Mike Hepp will log this event into the ERTS system and notify the City of the assigned ERTS number.**

**Response (include additional pages if necessary)**

Cleanup Method:	Vacuumed with vac trailer emptied into drying bed along with wash. Area covered with 6in of dirty sand mix. Liquid spill waste returned to headworks.
-----------------	---

Steps to prevent reoccurrence:	Will visually check crossover pipe for plug before pumping thickened sludge from thickener to primary digester.
--------------------------------	---