

POSTED
DATE: 05/14/07
INITIALS: JIC

DEPARTMENT OF ECOLOGY

MAY 11 2007

WATER QUALITY PROGRAM

SO3-001641D

INDUSTRIAL STORMWATER GENERAL PERMIT
DISCHARGE MONITORING REPORT

MONITORING PERIOD for (year/quarter): 2007 ☒ Jan/Feb/Mar ☐ Apr/May/Jun ☐ Jul/Aug/Sep ☐ Oct/Nov/Dec
year

Facility/Site Information

FRED TEBB AND SONS INC
Location: 1906 E MARC ST
County: PIERCE

Mailing Information

FRED TEBB AND SONS INC
PO BOX 2235
TACOMA WA 98401-2235

Primary SIC Code: 2411

You must send a Discharge Monitoring Report (DMR) to Ecology every quarter. If there was no discharge or you have suspended sampling because of consistent attainment of benchmark values, mark the appropriate boxes and send the DMR to Ecology. Please read the instructions before completing the DMR.

Discharge Point Sample Point A

☐ There was no qualifying storm event this quarter so no values are entered below (see explanation)

Quarterly Monitoring		AVERAGE	MAXIMUM	UNITS	Sample Type	Events Sampled
Turbidity	<input type="checkbox"/> Consistent Attainment		—	NTU		
pH	<input type="checkbox"/> Consistent Attainment		—	Standard Units		
Zinc (total)	<input type="checkbox"/> Consistent Attainment		—	µg/L		
Oil & Grease	<input type="checkbox"/> Consistent Attainment		—	mg/L	Grab	
Copper	<input type="checkbox"/> Consistent Attainment		—	µg/L		
Lead	<input type="checkbox"/> Consistent Attainment		—	µg/L		
Hardness	Include if sampling for zinc, copper, or lead		—	mg/L (as CaCO ₃)		
BOD5	<input type="checkbox"/> Consistent Attainment		—	mg/L		

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 USC § 1001 AND 33 USC § 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000.00 AND OR MAXIMUM IMPRISONMENT OF BETWEEN SIX MONTHS AND FIVE YEARS.)

JOHN TEBB, VICE PRESIDENT

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER (TYPED OR PRINTED)

MAY 10, 2007

DATE: MO DAY YEAR

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

253-272-4107

TELEPHONE NUMBER

COMMENTS / EXPLANATIONS

Due to high water levels in the receiving drain ditch, it is not possible to safely sample the storm water at sample point A. The city of Tacoma has plans to clean the ditch within the next two years.

POSTED
DATE: 05/10/07
INITIALS: JK

SO3-001641D

DEPT. OF ECOL. & ENV.
MAY 11 2007
WASHINGTON STATE DEPT. OF ECOL. & ENV.

INDUSTRIAL STORMWATER GENERAL PERMIT
DISCHARGE MONITORING REPORT

MONITORING PERIOD for (year/quarter): 2007 ☒ Jan/Feb/Mar ☐ Apr/May/Jun ☐ Jul/Aug/Sep ☐ Oct/Nov/Dec
year

Facility/Site Information

FRED TEBB AND SONS INC
Location: 1906 E MARC ST
County: PIERCE

Mailing Information

FRED TEBB AND SONS INC
PO BOX 2235
TACOMA WA 98401-2235

Primary SIC Code: 2411

You must send a Discharge Monitoring Report (DMR) to Ecology every quarter. If there was no discharge or you have suspended sampling because of consistent attainment of benchmark values, mark the appropriate boxes and send the DMR to Ecology. Please read the instructions before completing the DMR.

Discharge Point <u>Sample Point C</u>						
<input type="checkbox"/> There was no qualifying storm event this quarter so no values are entered below (see explanation)						
Quarterly Monitoring		AVERAGE	MAXIMUM	UNITS	Sample Type	Events Sampled
Turbidity	<input type="checkbox"/> Consistent Attainment		28	NTU	Grab	3/19/2007
pH	<input type="checkbox"/> Consistent Attainment		5.88	Standard Units	"	"
Zinc (total)	<input type="checkbox"/> Consistent Attainment		ND	µg/L	"	"
Oil & Grease	<input type="checkbox"/> Consistent Attainment		8.2	mg/L	Grab	"
Copper	<input type="checkbox"/> Consistent Attainment		ND	µg/L	"	"
Lead	<input type="checkbox"/> Consistent Attainment		ND	µg/L	"	"
Hardness	Include if sampling for zinc, copper, or lead		9.0	mg/L (as CaCO ₃)	"	"
BOD5	<input type="checkbox"/> Consistent Attainment		6.5	mg/L	"	"

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 USC § 1001 AND 33 USC § 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000.00 AND OR MAXIMUM IMPRISONMENT OF BETWEEN SIX MONTHS AND FIVE YEARS.)

JOHN TEBB, VICE PRESIDENT

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER (TYPED OR PRINTED)

MAY 10, 2007

DATE: MO DAY YEAR

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

253-272-4107

TELEPHONE NUMBER

COMMENTS/EXPLANATIONS

Level One Response for Low pH and Turbidity

Testing with pH strips in various areas that drain into sample point C revealed no low pH levels. A more accurate meter was purchased and will be used to monitor pH in this area.

During time of sampling the storm water was noted to be slightly cloudy. Upon inspection it was determined that the source was from a dirt and beauty bark area near a catch basin. This area will be paved during annual yard maintenance this summer.

POSTED
DATE: 08/14/07
INITIALS: JK

SO3-001641D

INDUSTRIAL STORMWATER GENERAL PERMIT
DISCHARGE MONITORING REPORT

MONITORING PERIOD for (year/quarter): 2007 ☒ Jan/Feb/Mar ☐ Apr/May/Jun ☐ Jul/Aug/Sep ☐ Oct/Nov/Dec
year

Facility/Site Information

FRED TEBB AND SONS INC
Location: 1906 E MARC ST
County: PIERCE

Mailing Information

FRED TEBB AND SONS INC
PO BOX 2235
TACOMA WA 98401-2235

Primary SIC Code: 2411

You must send a Discharge Monitoring Report (DMR) to Ecology every quarter. If there was no discharge or you have suspended sampling because of consistent attainment of benchmark values, mark the appropriate boxes and send the DMR to Ecology. Please read the instructions before completing the DMR.

Discharge Point <u>Sample Point G</u>						
<input type="checkbox"/> There was no qualifying storm event this quarter so no values are entered below (see explanation)						
Quarterly Monitoring		AVERAGE	MAXIMUM	UNITS	Sample Type	Events Sampled
Turbidity	<input type="checkbox"/> Consistent Attainment		52	NTU	Grab	3/19/2007
pH	<input type="checkbox"/> Consistent Attainment		6.17	Standard Units	"	"
Zinc (total)	<input type="checkbox"/> Consistent Attainment		110	µg/L	"	"
Oil & Grease	<input type="checkbox"/> Consistent Attainment		5.1	mg/L	Grab	"
Copper	<input type="checkbox"/> Consistent Attainment		12	µg/L	"	"
Lead	<input type="checkbox"/> Consistent Attainment		ND	µg/L	"	"
Hardness	Include if sampling for zinc, copper, or lead		17	mg/L (as CaCO ₃)	"	"
BOD5	<input type="checkbox"/> Consistent Attainment		8.4	mg/L	"	"

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 USC § 1001 AND 33 USC § 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000.00 AND OR MAXIMUM IMPRISONMENT OF BETWEEN SIX MONTHS AND FIVE YEARS.)

JOHN TEBB, VICE PRESIDENT

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER (TYPED OR PRINTED)

MAY 10, 2007

DATE: MO DAY YEAR

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

253-272-4107

TELEPHONE NUMBER

COMMENTS / EXPLANATIONS

Level One Response for Turbidity

After inspection around the area of sample point G, it was determined that more frequent housekeeping and sweeping were necessary in this area. This step will be implemented immediately.