



DEPARTMENT OF
ECOLOGY
State of Washington

Washington Regional Haze Reasonably Available Control Technology Analysis for Pulp and Paper Mills

November 2016
Publication no. 16-02-023

Publication and Contact Information

This report is available on the Department of Ecology's website at <https://fortress.wa.gov/ecy/publications/SummaryPages/1602023.html>

For more information contact:

Air Quality Program
P.O. Box 47600
Olympia, WA 98504-7600

Phone: 360-407-6800

Washington State Department of Ecology - www.ecy.wa.gov

- Headquarters, Olympia 360-407-6000
- Northwest Regional Office, Bellevue 425-649-7000
- Southwest Regional Office, Olympia 360-407-6300
- Central Regional Office, Yakima 509-575-2490
- Eastern Regional Office, Spokane 509-329-3400

For special accommodations or documents in alternate format, call (360) 407-6800, 711 (relay service), or 877-833-6341 (TTY).

Washington Regional Haze RACT Analysis for Pulp and Paper Mills

*By
Gary Huitsing*

Air Quality Program
Washington State Department of Ecology
Olympia, Washington

Table of Contents

	<u>Page</u>
List of Figures and Tables.....	iii
Figures.....	iii
Tables.....	iii
Acknowledgements.....	v
Abstract/Executive Summary	vi
Acronyms, Abbreviations, and Terms	vii
1. Overview	1
1.1. Background.....	1
1.2. RACT in Washington State	4
1.2.1. RACT implementation in Washington State	5
1.3. Source impacts on visibility.....	6
2. Availability of Additional Controls.....	7
3. Demonstrated Emission Limits for Recovery Furnaces and Lime Kilns	14
3.1. Demonstrated PM emission limits for recovery furnaces and lime kilns	14
3.2. Demonstrated SO ₂ emission limits for recovery furnaces and lime kilns	20
3.3. Demonstrated NO _x emission limits for recovery furnaces and lime kilns	27
4. Estimated Emission Reductions Achievable	33
4.1. Estimated emission reductions achievable (by facility).....	33
4.1.1. PTPC estimated emission reductions.....	34
4.1.2. WestRock estimated emission reductions.....	37
4.1.3. Weyerhaeuser estimated emission reductions	40
4.1.4. GP Camas estimated emission reductions	42
4.1.5. KapStone estimated emission reductions.....	45
4.1.6. Boise White Wallula estimated emission reductions.....	51
4.1.7. Cosmo estimated emission reductions	54
4.1.8. Graymont estimated emission reductions	55
4.2. Estimated emission reductions for recovery furnaces achievable (cumulative data)	56
4.3. Estimated emission reductions for lime kilns achievable (cumulative data)	59
4.4. Discussion of estimated potential emission reductions	61
4.4.1.Discussion of estimated potential emission reductions for recovery furnaces	61
4.4.2. Discussion of estimated potential emission reductions for lime kilns	63
5. Impacts of Controls on Visibility	64
5.1. Impacts of pulp and paper mills on visibility (BART modeling analysis)	64
5.2. Impacts of pulp and paper mills on visibility (RACT modeling analysis)	66
5.2.1. Modeling results.....	67
5.2.2. Additional modeling scenarios	68

6.	Estimated Costs	69
6.1.	Capital and operating costs	69
7.	Conclusions	73
7.1.	PTPC conclusions	74
7.2.	WestRock conclusions	74
7.3.	Weyerhaeuser conclusions.....	74
7.4.	GP Camas conclusions.....	74
7.5.	KapStone conclusions	74
7.6.	Boise White Wallula Mill conclusions	74
7.7.	Cosmo specialty fiber mill conclusions	75
7.8.	Graymont lime kiln conclusions	75
	Appendices.....	76
	Appendix A. Unit Conversions and Permit Limit Information	77
	Appendix B. Facility Operating and Emissions Data	109
	Appendix C. WSU Report	134
	Appendix D. Cost Estimates	171

List of Figures and Tables

Page

Figures

Figure 1. Class I areas in Washington State	3
Figure 2. Estimated potential PM emission reductions for recovery furnaces	57
Figure 3. Estimated potential SO ₂ emission reductions for recovery furnaces.....	57
Figure 4. Estimated potential NO _x emission reductions for recovery furnaces	58
Figure 5. Estimated potential PM emission reductions for lime kilns.....	60
Figure 6. Estimated potential SO ₂ emission reductions for lime kilns	60
Figure 7. Estimated potential NO _x emission reductions for lime kilns.....	61

Tables

Table 1. Washington State Chemical Pulp and Paper Mills	2
Table 2. Mandatory Federal Class I Areas in Washington State ¹	3
Table 3. PM Control Technologies Available for Recovery Furnaces and Lime Kilns	7
Table 4. SO ₂ Control Technologies Available for Recovery Furnaces and Lime Kilns	9
Table 5. NO _x Control Technologies Available for Recovery Furnaces and Lime Kilns	10
Table 6. Demonstrated PM Emission Limits at Recovery Furnaces	15
Table 7. Demonstrated PM Emission Limits at Lime Kilns	18
Table 8. SO ₂ Emission Limits ¹ Demonstrated at Recovery Furnaces	20
Table 9. SO ₂ Emission Limits ¹ Demonstrated at Lime Kilns.....	24
Table 10. NO _x Emission Limits ¹ Demonstrated at Recovery Furnaces	27
Table 11. NO _x Emission Limits ¹ Demonstrated at Lime Kilns.....	30
Table 12. PTPC RF Emission Reductions	35
Table 13. PTPC Lime Kiln Emission Reductions	36
Table 14. WestRock Recovery Furnace (No. 4) Emission Reductions	37
Table 15. WestRock Lime Kiln (No. 1) Emission Reductions.....	38
Table 16. WestRock Lime Kiln (No. 2) Emission Reductions.....	39
Table 17. Weyerhaeuser Recovery Furnace (No. 10) Emission Reductions.....	40

Table 18. Weyerhaeuser Lime Kiln (No. 4) Emission Reductions.....	41
Table 19. GP Camas Recovery Furnace (No. 3) Emission Reductions.....	42
Table 20. GP Camas Recovery Furnace (No. 4) Emission Reductions.....	43
Table 21. GP Camas Lime Kiln (No. 4) Emission Reductions	44
Table 22. KapStone Recovery Furnace (No. 18) Emission Reductions	45
Table 23. KapStone Recovery Furnace (No. 19) Emission Reductions	46
Table 24. KapStone Recovery Furnace (No. 22) Emission Reductions	47
Table 25. KapStone Lime Kiln (No. 3) Emission Reductions.....	48
Table 26. KapStone Lime Kiln (No. 4) Emission Reductions.....	49
Table 27. KapStone Lime Kiln (No. 5) Emission Reductions.....	50
Table 28. Boise White Wallula Recovery Furnace (No. 2) Emission Reductions	51
Table 29. Boise White Wallula Recovery Furnace (No. 3) Emission Reductions	52
Table 30. Boise White Wallula Lime Kiln Emission Reductions	53
Table 31. Cosmo Recovery Furnace Emission Reductions	54
Table 32. Graymont Calcining Lime Kiln (CLK) Emission Reductions.....	55
Table 33. Tons of Potential Pollutant Reduction Based on Proposed RACT Limit Options for Recovery Furnaces.....	56
Table 34. Tons of Potential Pollutant Reduction Based on Proposed RACT Limit Options for Lime Kilns	59
Table 35. Visibility Modeling Results: 22nd Highest Delta dv, 2003–2005 (98th Percentile) ...	65
Table 36. Visibility Modeling Results: 8th Highest Delta dv, (98th Percentile).....	67
Table 37. Recovery Furnace Estimated Control Costs	69
Table 38. Lime Kiln Estimated Control Costs.....	72

Acknowledgements

The authors of this report would like to thank the following individuals for their contribution and assistance in preparing this RACT analysis:

- Brian Lamb, Washington State University
- Ravi Vikram, Washington State University
- Serena Chung, Washington State University
- Joseph Vaughan, Washington State University
- Steven J. Gorg, Minnesota Pollution Control Agency (MPCA)
- Eric Kennedy, Maine Department of Environmental Protection (MDEP)
- Gerry Pade, Puget Sound Clean Air Agency (PSCAA)
- Brian Renninger, Puget Sound Clean Air Agency (PSCAA)
- Ann Ingram, Lockheed Martin, EPA Contractor, Info Clearinghouse for Inventories & Emissions Factors (CHIEF) Help Desk Supporting EPA's Measurement Policy Group

The Principle Contributors from Ecology's Staff were:

- Gary Huitsing, Environmental Engineer
- Alan Newman, Environmental Engineer
- Ranil Dhammapala, Acting Science & Engineering Manager (3/14/2015–8/31/2015), Atmospheric Scientist
- Clint Bowman, Air Dispersion Modeler (through 8/31/2016)
- Anya Caudill, Acting Rules and Planning Unit Manager (through 1/31/2016)
- Jeff Johnston, Science & Engineering Manager (through 3/13/2015)

The following Ecology staff also made significant contributions:

- Tina Ebio, Administrative Assistant
- Stephanie Ogle, Waste to Resources Industrial Pulp and Paper Unit Supervisor
- Shingo Yamazaki, Waste to Resources Industrial Pulp and Paper
- Ha Tran, Waste to Resources Industrial Pulp and Paper
- Teddy Le, Waste to Resources Pulp and Paper Unit Supervisor (through 5/31/2016)
- Robert Carruthers, Waste to Resources Industrial Pulp and Paper
- Nancy Lowe, Waste to Resources Industrial Pulp and Paper (through 5/31/2016)
- Marc Heffner, Waste to Resources Industrial Pulp and Paper (through 6/30/2013)
- Nancy Pritchett, Program Development Section Manager
- Rich Hibbard, Environmental Engineer, Program Development Section (through 6/30/2016)
- Bob Burmark, Environmental Engineer, Science & Engineering Section (through 4/1/2016)
- Marc Crooks, Environmental Engineer
- Sally Otterson, Emission Inventory
- Farren Herron-Thorpe, Emission Inventory
- Stephanie Summers, Emission Inventory
- Donna Seegmueller, Admin Services - Records/Library
- Carol Johnston, Agency Ops

Abstract/Executive Summary

This report is a follow-up as required in the 2010 Washington Regional Haze State Implementation Plan. Ecology evaluated emission controls applicable to recovery processes at pulp mills. This report also analyzed visibility improvement in federal Class I areas (national parks and certain wilderness areas) that might occur if additional emission controls were required at pulp mills.

Ecology performed the following:

- Evaluated emission limitations and control technologies used worldwide on pulp mills (recovery furnaces/boilers and lime kilns). We found several promising add-on control technologies. We also looked at emission limits in Washington and found that some emission limits were less protective compared to other pulp mills in Washington and in other states.
- Analyzed revised emission limits for each pulp mill.
- Provided achievable visibility improvements based on the revised emission rates. Modeling indicates that if Reasonably Available Control Technology (RACT – additional air pollution controls) were required, visibility would potentially be improved at the Alpine Lakes and Goat Rocks Wildernesses (0.13 deciview and 0.12 deciview, respectively). No other Class I area showed a cumulative improvement of more than 0.1 deciview.

Ecology concluded that the actual emission reductions from the individual pulp mills and the industry as a whole would be relatively costly to implement and visibility improvements in the federal Class I areas would not be observable.

We do not recommend further work to evaluate or require additional air pollution controls for pulp mills in Washington.

Acronyms, Abbreviations, and Terms

A	Stack Area
Acf	Actual Stack Gas Flow Rate
ACFM	Actual Cubic Feet per Minute
acfs	Actual Cubic Feet per Second
ADT	Air Dried Pulp
AIRNOW	Non-IMPROVE sites; a website which provide visual depictions of current and forecast air quality nationwide.
AIRPACT	AIRPACT is a computerized system for predicting air quality (AQ) for the immediate future of one to three days for ID, OR and WA.
An	Sample Nozzle Cross Section
APTI	Air Pollution Training Institute
ATM	Atmosphere (unit of pressure)
BACT	Best Available Control Technology
BART	Best Available Retrofit Technology
BAT	Best Available Techniques in the [Kraft] Pulp and Paper Industry, December 2001, European Commission. BATs are not permit limits, but are based on guidance documents called BREFs (BAT Reference document)
BLS	Black Liquor Solids
BPT	Best Practical Treatment
Bray	Rayleigh Extinction Coefficient
BREF	BAT Reference document
Btu	British thermal unit
Bws	Stack Gas Moisture Fraction
CAA	Clean Air Act
CaCO ₃	Calcium Carbonate
CALMET	California Meteorological Model; a diagnostic 3-dimensional meteorological model
CALPUFF	California Puff Model; an air quality dispersion model
CAMx	Comprehensive Air Quality Model with Extensions
CEMS	Continuous Emissions Monitoring Systems

CFR	Code of Federal Regulations
CM	Coarse Matter
CM	Coarse Matter
CMAQ	Community Multi-Scale Air Quality Model
CO	Carbon Monoxide
COGO1	Local Air Monitor Site Abbreviation for Columbia River Gorge at Mt Zion
CORII	Local Air Monitor Site Abbreviation for Columbia River Gorge at Wishram
Cp	Pitot tube calibration coefficient
D	Diameter of stack
DBA	Doing Business As
Delta dv	Change in deciview
dH	Meter Orifice Pressure
dP	Differential Pressure
dP	Stack Gas Velocity Head
dP ^{.5}	Stack Gas Velocity Head
dv	Deciview; a measure of light extinction
EC	Elemental Carbon
EGF	Electrified Gravel Bed Filter
EI	Emission Inventory
EPA	Environmental Protection Agency
ESP	Electrostatic Precipitator
F1	Conversion Factor
F2	Conversion Factor
F3	Conversion Factor
F4	Conversion Factor
F5	Conversion Factor
FB	Fractional Bias
FE	Fractional Error
FGD	Flue Gas Desulfurization

FIP	Federal Implementation Plan
FLM	Federal Land Manager
FNA	Formerly Known As
FS	Forest Service
ft ²	Square Feet
g	Gram
GED	Good Equipment Design
GPM	Gallons Per Minute
gr/dscf	Grains per dry standard cubic feet
H ₂ O/gm	H ₂ O per gram
H ₂ O ₂	Hydrogen Peroxide
H ₂ S	Hydrogen Sulfide
HAP	Hazardous Air Pollutant
HAPs	Hazardous Air Pollutants
HERB	High Energy Recovery Boiler
HG	Mercury
Ht	Stack Height
HVLC	High Volume Low Concentration
I	Isokinetic percent
ICCP	Integrated Pollution Prevention Control (ICCP), a reference document on Best Available Techniques [BAT] in the [kraft] Pulp and Paper Industry, December 2001, European Commission
IMPROVE	Interagency Monitoring of Protected Visual Environments
in	Inches
Kg	Kilogram
Kp	Pitot tube constant
KPa	Kilo Pascal
Kraft	Type of chemical pulp and paper mill processes using sulfate. Can be divided into three areas: the making of pulp, recovery of cooking materials, the bleaching of pulp
LAER	Lowest Achievable Emission Rate

Lb/hr	Pounds per hour
Lbmol	Pound Mole
LCPD	Large Combustion Plant Directive of the European Commission.
LEA	Low Excess Air
LK	Lime Kiln
LKEU	Lime Kiln Emission Unit
LNB	Low NO _x Burner
M3	Cubic Meters
MACT	Maximum Achievable Control Technology
MCIP	Meteorology-Chemistry Interface Processor
Md	Stack Gas Mole weight dry
Mf	Mass of particulate: filter
MFB	Mean Fractional Bias
MFE	Mean Fractional Error
mg	milligram
mg/dscf	Milligrams per dry standard cubic feet
MH20	MW of water
MM	Million
Mm-1	Inverse mega meter; a measure of particle extinction
MM5	Meteorological Mesoscale 5
Mn	Mass of particulate: combined samples
MORA1	Local Air Monitor Site Abbreviation for Mt. Rainier National Park
Mp	Mass of particulate: probe wash
Ms	Stack Gas Mole weight wet
MW	Megawatt
MW	Molecular Weight
N ₂	Nitrogen
N/A	Not Applicable or Not Available
NCAC	North Carolina Administrative Code

NCASI	National Council of Air and Stream Improvement
NCG	Non Condensable Gases
NESHAP	National Emission Standards for Hazardous Air Pollutants
NG	Natural Gas
NH ₃	Ammonia
(NH ₄) ₂ SO ₄	Ammonium Sulfate
NH ₄	Ammonium
Nm ³	Newton – Meters cubed
NO	Nitric oxide
NO ₂	Nitrogen dioxide
NO ₃	Ammonium Nitrate or NH ₄ NO ₃
NOCA1	Local Air Monitor Site Abbreviation for Glacier Peak Wilderness and North Cascades National Park
NO _x	Nitrogen Oxides
NPS	National Park Service
NSCR	Non-Selective Catalytic Reduction
NSPS	New Source Performance Standards
NSR	New Source Review
NW AIRQUEST	A virtual air quality science center made up of various air quality agencies, tribes, and universities of the Pacific Northwest
NWCAA	Northwest Clean Air Agency
O&M	Operations and Maintenance
O/R	Oxidation/Reduction
O ₂	Oxygen
O ₃	Ozone
OBS	Observed
OC	Organic Carbon
OLYM1	Local Air Monitor Site Abbreviation for Olympic National Park
OM	Organic Matter
OMC	Organic Mass Carbon

Pa	Pascal
Pa	Pressure (stack)
PAN	Peroxyacetylnitrate
PASA1	Local Air Monitor Site Abbreviation for Pasayten Wilderness
Pbar	Pressure (barometric)
PCT	Proper Combustion Techniques
PICs	Products of Incomplete Combustion
PKA	Previously Known As
PM	Particulate Matter
PM ₁₀	Coarse Particle Matter or Particulate Matter; with an aerodynamic diameter of 10 micrometers or less
PM _{2.5}	Fine Particles or Particulate Matter; with an aerodynamic diameter of 2.5 micrometers or less
PNW	Pacific Northwest
POA	Primary Organic Aerosol
ppm	parts per million
ppmv	parts per million by volume
ppmvd	parts per million by dry volume
PRP	Preliminary Reasonable Progress
PSAT	Particulate Matter Source Apportionment Technology
PSCAA	Puget Sound Clean Air Agency
PSD	Prevention of Significant Deterioration
Pstd	Pressure at STP
PTPC	Port Townsend Paper Company
Qstd	Dry Stack gas flow rate at STP
R	Ideal gas constant
RACT	Reasonably Available Control Technology
RAVI	Reasonably Attributable Visibility Impairment
RF	Recovery Furnace
RFEU	Recovery Furnace Emission Unit

RH	Regional Haze
RHR	Regional Haze Rule
RMC	WRAP's Regional Modeling Center
RPG	Reasonable Progress Goal
RRF	Relative Response Factors
S Content	Sulfur Content
sat vap press	Saturation Vapor Pressure
SBws	Saturation Moisture Fraction at STP
SCFM	Standard Cubic Feet per Minute
SCR	Selective Catalytic Reduction
SIP	State Implementation Plan
SMOKE	Sparse Matrix Operator Kernel Emissions
SNCR	Selective Non-Catalytic Reduction
SNPA1	Local Air Monitor Site Abbreviation for Alpine Lakes Wilderness
SO ₂	Sulfur Dioxide
SO ₄	Ammonium Sulfate or (NH ₄) ₂ SO ₄
SOIL	Fine Soil
SO _x	Sulfur Oxides
STP	Standard Temperature and Pressure
Sulfite chemical pulp and paper process	Similar to Kraft process except that sulfurous acid is used as cooking chemicals instead of sodium hydroxide and sodium sulfide, and a cooking buffer of bisulfite is used with one of four bases (ammonium, calcium, magnesium, or sodium).
Tabs	Temperature absolute
TAPs	Toxic Air Pollutants
TCaO/day	Tons Calcium Oxide per Day
Tm	Dry Gas Meter Temperature
TPH	Tons Per Hour
TPY	Tons Per Year
TRS	Total Reduced Sulfur

Ts	Stack gas temp
TSP	Total Suspended Particulate
Tstd	Temperature at STP
USDA	U.S. Department of Agriculture
USDA – FS	U.S. Department of Agriculture – Forest Service
USDI	U.S. Department of the Interior
USDI – FWS	U.S. Department of the Interior – Fish & Wildlife Service
USDI – NPS	U.S. Department of the Interior – National Park Service
USGS	U.S. Geological Survey
UW	University of Washington
Vi	Impinger 1
IEWS	Visibility Information Exchange Web System
Vii	Impinger 2
Viii	Impinger 3
Visibility SIP	Visibility Protection
Viv	Impinger 4
Vm	Sample Volume from meter
Vmstd	Sample Volume
VOC	Volatile Organic Content
Vs	Stack Gas Velocity
Vw	Total Water Volume Condensed
Vwstd	Total Water Volume Condensed at STP
WA	Washington
WAC	Washington Administrative Code
WEP	Weighted Emissions Potential
WESP	Wet Electrostatic Precipitator
WESTAR	Western States Air Resources Council
WHPA1	Local Air Monitor Site Abbreviation for Goat Rocks Wilderness and Mt. Adams Wilderness areas

WHR	Wet Heat Recovery
WRAP	Western Regional Air Partnership
WRF Smoke SMAQ	Weather Research and Forecasting Model Sparse Matrix Operator Kernel Emissions (SMOKE) Modeling System Satellite-Assisted Management Of Air Quality
WSU	Washington State University
Y	Dry Gas Meter Calibration factor

1. Overview

1.1. Background

This Reasonably Available Control Technology (RACT) analysis addressing regional haze (RH), is prepared to fulfill a commitment in the Washington State Department of Ecology (Ecology) Regional Haze State Implementation Plan (SIP) prepared in December of 2010.

Ecology was required to prepare a RH SIP as part of EPA's phase II 1999 visibility rules called the Regional Haze Rule (RHR). This rule focuses on improving visibility in mandatory Class I federal areas. These lands are identified in the Clean Air Act Amendments of 1977, and afforded the highest level of protection from air pollutants. There are 156 of these Class I areas nationwide and include national parks, wilderness areas, and wildlife refuges. All other federal lands in the nation are designated as Class II areas. Washington's eight mandatory federal Class I areas are shown in Figure 1 and listed in Table 2.

One element of the RHR required the state to include a Four-Factor Analysis of emission reduction potential from non-Best Available Retrofit Technology (BART) sources to be used in developing the Reasonable Progress Goals (RPGs) for each Class I area. The four factors to be considered in these analyses are:

- Cost of compliance
- Time necessary for compliance
- Energy and non-air quality impacts of compliance
- Remaining useful life of any potential affected sources

Ecology and the Western Regional Air Partnership (WRAP) developed analyses for point sources of pollutants in Washington to meet the Four-Factor Analysis requirement for non-BART sources in the RHR. This analysis and its result were included in the state's RH SIP.

The analyses in the RH SIP identified specific industries including "pulp and paper and wood products" (pulp & paper mills), as significant emitters of pollutants known to contribute to RH and that have opportunities for emission reductions that could improve visibility in Class I areas.

The pollutants emitted by the pulp and paper and wood products industry in Washington includes sulfur dioxide (SO₂) and oxides of nitrogen (NO_x) (including nitric oxide (NO) and nitrogen dioxide (NO₂) compounds), volatile organic compounds (VOCs), and directly emitted particulate matter (PM). These air pollutants contribute to RH in the following ways:

- Both SO₂ and NO_x gases can form sulfate and nitrate particulate matter, which, as with particulate matter in general, impair visibility.
- VOCs can either condense to form PM or can react with NO_x.

- NO_x is a precursor chemical for peroxyacetyl nitrate (PAN), which is a secondary pollutant present in photochemical smog.

Of the air pollutants emitted from the pulp, paper, and wood products industry, SO₂ and NO_x are the dominant pollutants that contribute to RH in Washington’s Class I areas.

As noted in the RH SIP, by identifying individual sources of SO₂ and NO_x (and PM) that impair visibility, the RH SIP sets the stage for assessing the effects of potential new emissions limitations for those sources. One of the mechanisms that can be used for assessing emission limits, includes determining and implementing RACT to potentially provide further progress toward meeting the visibility goal.


This RH RACT analysis focuses emissions from pulp and paper mill recovery furnaces and lime kilns. These combustion units emit SO₂, NO_x, and PM. At the time of this analysis, there are seven chemical pulp and paper mills in operation in Washington: six sulfate (Kraft) mills and one sulfite mill. The current names of the mills at the time of this analysis, as well as the abbreviated facility names that will be used throughout this analysis are listed in Table 1.

Table 1. Washington State Chemical Pulp and Paper Mills		
Full Name	Mill Type	Abbreviated Name for this Analysis
Longview Fibre Paper and Packaging, Inc. dba KapStone Kraft Paper Corporation	Kraft	KapStone
Weyerhaeuser Longview Liquid Packaging	Kraft	Weyerhaeuser
WestRock CP, LLC	Kraft	WestRock
Port Townsend Paper Corporation	Kraft	PTPC
Boise White Paper, LLC	Kraft	Boise White Wallula
Georgia Pacific Consumer Products (Camas) LLC	Kraft	GP Camas
Cosmo Specialty Fibers Inc.	Sulfite	Cosmo

While not at a pulp and paper mill, the lime kiln at the Graymont Western U.S. Inc., (Tacoma Division) (Graymont) facility is included in this analysis due to its similarity to the pulp mill lime kilns. Graymont consists of a lime manufacturing plant and two precipitated calcium carbonate plants. Both of these products are utilized in the manufacture of paper.

A definition of RACT, and how it is implemented in Washington State is included in Section 1.2.

The Class I areas in Washington are shown on Figure 1 and additional details for the mandatory federal Class I areas is included in Table 2. Figure 1 also shows the locations of Graymont and the seven chemical pulp and paper mills currently in operation in Washington.



Native American Class I Areas ^{(1),(2)}
 National Park Service Class I Areas ^{(1),(2),(3)}
 U.S. Forest Service Class I Areas ^{(1),(2),(3)}

1. Class I areas are granted special air quality protection under the federal Clean Air Act and state rules. National parks and certain wilderness areas are designated as mandatory Class I federal areas under the federal Clean Air Act. EPA may designate other areas as Class I areas upon request. The Spokane Indian Reservation was designated a Class I area in 1991 based on a request from the Spokane Tribal Council. The operator of any new major stationary source or major modification that may affect air quality in a Class I area should contact the Ecology's Air Quality Program (AQP) for further information.
2. These areas receive special air quality considerations under the Prevention of Significant Deterioration (PSD) Permit Program.
3. These areas are mandatory federal Class I areas that receive visibility protection under the RH Program.

Figure 1. Class I areas in Washington State

Mandatory Class I Area²	Site Abbreviation (local air monitor)³	Acreage	FLM
Alpine Lakes Wilderness	SNPA1	303,508	USDA-FS
Glacier Peak Wilderness	NOCA1	464,258	USDA-FS
North Cascades National Park	NOCA1	503,277	USDI-NPS
Goat Rocks Wilderness	WHPA1	82,680	USDA-FS

Table 2. Mandatory Federal Class I Areas in Washington State¹			
Mandatory Class I Area²	Site Abbreviation (local air monitor)³	Acreage	FLM
Mt. Adams Wilderness	WHPA1	32,356	USDA-FS
Mt. Rainier National Park	MORA1	235,239	USDI-NPS
Pasayten Wilderness	PASA1	505,524	USDA-FS
Olympic National Park	OLYM1	892,578	USDI-NPS
Total Acres		3,019,420	

¹ The USFS is the federal land manager for national wildlife refuges. However, of the 23 national wildlife refuges in Washington State, none of them are part of the group of 21 national wildlife refuges located throughout the other 49 states, which are designated as Class I areas.
<<http://www.fws.gov/refuges/refugeLocatorMaps/washington.html>> and <<http://www.fws.gov/refuges/AirQuality/areas.html>>

² Columbia River Gorge, managed by the forest service, is not a Class I area, but is included in regional haze considerations by request of the FLMs. Another Class I area in the state, the Spokane Indian Reservation, is not included in this table because it is not a mandatory Class I area.

³ The two monitoring sites near the Columbia River Gorge are at Wishram and Mt. Zion and are referred to as COR11 and COGO1, respectively.

1.2. RACT in Washington State

RACT is defined in the Revised Code of Washington (RCW) 70.94.030(20) as:

“...the lowest emission limit that a particular source or source category is capable of meeting by the application of control technology that is reasonably available considering technological and economic feasibility. RACT is determined on a case-by-case basis for an individual source or source category taking into account:

- The impact of the source upon air quality,
- The availability of additional controls,
- The emission reduction to be achieved by additional controls,
- The impact of additional controls on air quality, and
- The capital and operating costs of the additional controls.

RACT requirements for a source or source category shall be adopted only after notice and opportunity for comment are afforded.”

While RACT, the acronym, includes the words “control technology,” RACT is defined in RCW 70.94.030(20) as an “emission limit” based on the application of additional controls.

Other states and the federal Clean Air Act (CAA) may implement RACT differently from the state of Washington (such as limiting it to nonattainment areas). As noted in the RH SIP, however, “a provision of Washington’s CAA (RCW 70.94.154) requires existing sources to use

RACT.” This requirement then applies to existing sources in attainment areas, nonattainment, and unclassifiable areas.

RACT is implemented in Washington State according to the process described in Section 1.2.1, which lists verbatim key portions from RCW 70.94.154.

1.2.1. RACT implementation in Washington State

RCW 70.94.154 contains the implementing provisions for the RACT process in Washington. Specific to determining RACT, this section of law says:

- (1) RACT as defined in RCW 70.94.030 is required for existing sources except as otherwise provided in RCW 70.94.331(9).
- (2) RACT for each source category containing three or more sources shall be determined by rule except as provided in subsection (3) of this section.
- (3) Source-specific RACT determinations may be performed under any of the following circumstances:
 - (a) As authorized by RCW 70.94.153;
 - (b) When required by the federal clean air act;
 - (c) For sources in source categories containing fewer than three sources;
 - (d) When an air quality problem, for which the source is a contributor, justifies a source-specific RACT determination prior to development of a categorical RACT rule; or
 - (e) When a source-specific RACT determination is needed to address either specific air quality problems for which the source is a significant contributor or source-specific economic concerns.

RCW 70.94.154(5) contains additional procedural requirements to be followed when determining RACT.

- (5) In determining RACT, ecology and local authorities shall utilize the factors set forth in RCW 70.94.030 and shall consider RACT determinations and guidance made by the federal environmental protection agency, other states and local authorities for similar sources, and other relevant factors. In establishing or revising RACT requirements, ecology and local authorities shall address, where practicable, all air contaminants deemed to be of concern for that source or source category.

Although there are some similarities between a RACT analysis and a Best Available Control Technology (BACT) analysis, the two analyses are defined differently. Per RCW 70.94.030(6), BACT means “an emission limitation based on the maximum degree of reduction for each air pollutant subject to regulation under this chapter emitted from or that results from any new or modified stationary source, that the permitting authority, on a case-by-case basis, taking into account energy, environmental, and economic impacts and other costs, determines is achievable for such a source or modification through application of production processes and available methods, systems, and techniques, including fuel cleaning, clean fuels, or treatment or innovative

fuel combustion techniques for control of each such a pollutant. In no event shall application of BACT result in emissions of any pollutants that will exceed the emissions allowed by any applicable standard under 40 *C.F.R.* Part 60 [NSPS] and Part 61 [NESHAP], as they existed on July 25, 1993, or their later enactments as adopted by reference by the director by rule.”

The RACT process includes an economic component that is generally less stringent than BACT in that it applies a reasonableness test for the application of emission limitations based on specific control technologies to a group of existing separate sources constructed of varying age. In contrast, BACT addresses the cost and removal efficiency of emission controls to be included in the construction of new or modified sources. The RACT economic analysis looks at the costs of adding or replacing controls on existing equipment.

We determined and ranked potential emission limitations reflecting the capabilities of different control technologies using a BACT-style approach. This approach provided helpful information to assess potential RACT options for addressing RH. In assessing what constitutes “reasonable” for this RACT analysis, Ecology performed both a quantitative and qualitative analysis. Specifically, a quantitative review of RH impacts using a top-level emission limit allowed Ecology to perform a qualitative analysis of less stringent emission limits as presented in Chapters 4 and 5 of this analysis.

1.3. Source impacts on visibility

This RH RACT analysis is organized as follows:

- Chapter 2 reviews the availability of additional control options for recovery furnaces and lime kilns at pulp and paper mills.
- Chapter 3 presents demonstrated emission limits for recovery furnaces and lime kilns in Washington State, other states, Canada, and Europe.
- Chapter 4 documents a comparison of emission reductions and lower emission limits demonstrated to be reasonably available at pulp and paper mills.
- Chapter 5 documents modeling analyses which estimate impacts of pulp mills upon visibility in Washington Class I areas (and also on Class I areas in surrounding states and provinces), before and after implementing additional controls.
- Chapter 6 provides a survey of general estimated capital and operating costs of the additional controls.
- Chapter 7 presents conclusions of this RH RACT analysis considering the information presented in Chapters 1 through 6.

2. Availability of Additional Controls

This chapter lists control options currently available for recovery furnaces and lime kilns. Available control technologies for PM, SO₂, and NO_x are presented in Tables 3, 4, and 5, respectively. As noted in the table notes, the only criteria for including the listed control options is the availability of the control option. Other considerations are presented in following chapters.

Control Technology	Brief Description	Available for RFs (Yes/No)¹	Available for LKs (Yes/No)¹
High Energy Recovery Boiler (HERB) ²	HERBs (furnaces) focus on effective air mixing and staging of air injection in the furnace for improved chemical recovery efficiency. This allows the furnace to run with less excess air resulting in less flue gas (less PM emissions) and also lowers the power consumption by the fans.	Yes	N/A
Fabric filters	A fabric filter (baghouse) consists of several fabric filters, typically configured in long, vertically suspended sock-like configurations. Dirty gas enters from one side, often from the outside of the bag, passing through the filter media and forming a particulate cake. The cake is removed by shaking or pulsing the fabric, which loosens the cake from the filter, allowing it to fall into a bin at the bottom of the baghouse. A variety of fabrics is available to cover fuel gas temperatures up to about 650°F. Baghouses are unsuitable for use on water saturated gas streams.	Yes	Yes
Cyclone separator(s)	Cyclone separators remove solids from the air stream by application of centrifugal force. In solid fuel combustion devices like hog fuel boilers, they are commonly used to remove large particles prior to the flue gas entering smaller particle control devices such as baghouses or ESPs. Multi-cyclones are capable of effectively removing particles down to approximately 3 micrometers. ³	Yes	Yes
Settling chambers	Similar to cyclone separators, settling chambers are used to remove large particles prior to the flue gas entering smaller particle control devices. However, whereas cyclone separators use centrifugal force, settling chambers use gravitational force and are limited to removal of particles larger than about 40-60 micrometers. ³	Yes	Yes
Wet scrubber	Wet scrubbers intercept dust particles using droplets of liquid (usually water). The larger, particle-enclosing water droplets are separated from the remaining droplets by gravity. The solid particulates are then separated from the water.	Yes	Yes
ESP (dry)	An electrostatic precipitator (ESP) removes particles from an air stream by electrically charging the particles, then passing them through a force field that causes them to migrate to an oppositely charged collector plate. An ESP generally refers to a dry ESP unless specifically noted otherwise. The dust from the collector plates falls into a collection hopper at the bottom of the ESP. The collection	Yes	Yes

Table 3. PM Control Technologies Available for Recovery Furnaces and Lime Kilns			
Control Technology	Brief Description	Available for RFs (Yes/No)¹	Available for LKs (Yes/No)¹
	efficiency of an ESP depends on particle diameter, electrical field strength, gas flowrate, and plate dimensions. A dry ESP is used for dry pollutants and uses a dry collecting surface.		
Wet ESP (or WESP)	The operation is identical to a dry ESP except that a WESP has a wet collecting surface and can be used for both wet and dry pollutants. The water addition can perform a number of tasks. It can change the electrical properties of the fly ash and can improve (or reduce) removal efficiency. The water is also used to remove sticky ashes from the WESP collector plants or to condense and remove semi-volatile compounds like some high molecular weight organic compounds. Unlike a dry ESP which removes only dry pollutants, a WESP can potentially remove solid, liquid, and soluble gas pollutants.	Yes	Yes
Electrified gravel bed filters (EGFs)	EGFs are a technique that is no longer implemented in Washington State. It used electricity to generate an electrostatic charge on a moving bed of gravel to collect particulate from a wood-fired boiler. The last unit operating in Washington was recently replaced with a baghouse.	Yes	Yes
Good operating practices	A properly operated emission unit will minimize the formation of PM ₁₀ emissions. Proper design of combustion units (e.g., boiler and recovery furnaces) concerns features such as the fuel and combustion air delivery system and the shape and size of the combustion chamber. Good operating practices for combustion units typically consist of controlling parameters such as fuel feed rates and air/fuel ratios.	Yes	Yes
<p>Note: RF = recovery furnace. LK = lime kilns.</p> <p>¹ The only criteria for including the listed control option is availability. Other considerations are presented in Chapters 4 through 6.</p> <p>² Andritz Pulp & Paper. Recovery boilers chemical recovery and green energy. The Andritz solution: High Energy Recovery Boiler (HERB) <www.andritz.com>. At least three HERB units have installed or are being installed in the U.S. per Andritz Pulp & Paper <www.andritz.com>. The three units are IP Valliant, Oklahoma; IP Campti, Louisiana; and PCA, Valdosta, Georgia. It is unclear if the OK and GA units have been included into the latest air permits at the time of this analysis. The Campti unit has been implemented, and permit limits are listed in Chapter 3.</p> <p>³ EPA APTI Course 413, 5th ed., v. 2: <i>Control of Particulate Matter Emissions Student Manual</i>, Crowder, J.W.; Smith, T., pp. 5-1, 6-24.</p>			

Table 4. SO₂ Control Technologies Available for Recovery Furnaces and Lime Kilns			
Control Technology	Brief Description	Available for RFs (Yes/No)¹	Available for LKs (Yes/No)¹
HERB ²	High energy recovery boilers (furnaces) focus on effective air mixing and air injection staging around the burning process for improved efficiency. This allows the furnace to run with less excess air resulting in less flue gas (less SO ₂ emissions) and also lowers the power consumption by the fans.	Yes	N/A
Flue gas desulfurization (FGD) w/wet scrubber	In FGD with a wet scrubber, a solution of sodium or calcium hydroxide absorbs SO ₂ from the flue gas forming sodium or calcium sulfite. The collected sulfite can be further oxidized to sulfate or left as the sulfite. Typically, large quantities of liquid or solid wastes are generated requiring disposal. Typical systems using sodium regenerate the sodium or re-use, while calcium based systems dispose of the calcium sulfate/sulfite.	Yes	Yes
Semi-dry lime hydrate slurry injection FGD w/fabric filter or ESP	For lime hydrate slurry injection, calcium hydroxide in the form of lime slurry is injected into the gas stream. Calcium hydroxide and SO ₂ will react to form calcium sulfite. A fabric filter or ESP will be needed to remove the dry solid reaction products from the gas stream.	Yes	Yes
Dry lime powder injection FGD w/fabric filter or ESP	Dry lime powder injection FGD controls SO ₂ using the same methods as lime hydrate slurry injection and depends on most of the same parameters. As with the lime slurry, a fabric filter or ESP is needed to remove the solid reaction products from the gas stream.	Yes	Yes
Spray dryer w/an ESP FGD	Spray dryer with an ESP FGD requires installation of a spray dryer and an ESP. Dry lime is injected by a spray dryer into the flue gas in the form of fine droplets under well controlled conditions such that the droplets will absorb SO ₂ from the flue gas and then become dry particles because of the evaporation of water. The dry particles are captured by the ESP downstream of the dryer. The captured particles are then removed from the system and disposed.	Yes	Yes
Low sulfur fuel selection	SO ₂ emissions are influenced by the sulfur content of the fuel as well as the sulfur content of the process material. For the recovery furnace, the black liquor solids are both the primary fuel and the material being processed. Fossil fuel is used to start a recovery furnace, and may be used to support the combustion process during operation. Selection of lower sulfur fuel can reduce SO ₂ emissions from the furnace. For the lime kiln, the fuel is the dominant source of sulfur rather than the lime feed.	Yes	Yes
Increased oxygen levels at burner	Increased oxygen levels at the burner have been shown to decrease SO ₂ emissions from lime kilns. This is best used with a scrubbing system where the increase in oxygen drives the SO ₂ to SO ₃ allowing the SO ₃ to react with lime or sodium oxide to produce CaSO ₄ or Na ₂ SO ₄ .	No	Yes

Table 4. SO₂ Control Technologies Available for Recovery Furnaces and Lime Kilns			
Control Technology	Brief Description	Available for RFs (Yes/No)¹	Available for LKs (Yes/No)¹
Wet heat recovery	Recirculating gasses through a wet heat recovery system before releasing through an exhaust stack.	Yes	No
Good operating practices	Good operating practices imply that the emission unit is operated within parameters that minimize emissions of air pollutants and maximize combustion efficiency.	Yes	Yes
<p>¹ The only criteria for including the listed control option is availability. Other considerations are presented in Chapters 4 through 6.</p> <p>² Andritz Pulp & Paper. Recovery boilers chemical recovery and green energy. The Andritz solution: High Energy Recovery Boiler (HERB). <www.andritz.com> At least three HERB units have installed or are being installed in the U.S. per Andritz Pulp & Paper <www.andritz.com> The three units are IP Valliant, Oklahoma; IP Campti, Louisiana; and PCA, Valdosta, Georgia. It is unclear if the OK and GA units have been included into the latest air permits at the time of this analysis. The Campti unit has been implemented, and permit limits are listed in Chapter 3.</p>			

Table 5. NO_x Control Technologies Available for Recovery Furnaces and Lime Kilns			
Control Technology	Brief Description	Available for RFs (Yes/No)¹	Available for LKs (Yes/No)¹
HERB ²	HERBs (furnaces) focus on effective air mixing around the burning process for improved efficiency. This allows the furnace to run with less excess air resulting in less flue gas (less emissions) and also lowers the power consumption by the fans. Less excess air results in potentially significant NO _x reductions.	Yes	N/A
Low excess air (LEA)	LEA is a technique where combustion is optimized by reducing the excess air introduced to the unit to the minimum amount necessary for stable, efficient combustion. Excess air is the air supplied in addition to the quantity required for stoichiometric combustion.	Yes	No
Staged combustion ³	Staged combustion technologies such as overfire air (OFA) reduce NO _x emissions by creating a fuel-rich zone via air staging (diverting a portion of the total amount of air required through separate ports). The highest temperatures are reached in the primary zone, generating thermal NO _x . "The general concept is to burn the fuel with an insufficient amount of air in a primary combustion zone. With insufficient oxygen available for complete combustion, most of the O ₂ is consumed by carbon and hydrogen, leaving less available to form NO _x . As a result the fuel nitrogen combines to form N ₂ (N+N=N ₂). During the few hundredths of a second it takes for combustion to occur, the flame cools slightly. Once this cooling has occurred, the rest of the air is added to complete	Yes	Yes

Table 5. NO_x Control Technologies Available for Recovery Furnaces and Lime Kilns			
Control Technology	Brief Description	Available for RFs (Yes/No)¹	Available for LKs (Yes/No)¹
	combustion. Since the fuel nitrogen radicals have disappeared, and the flame is too cool to generate a lot of thermal NO _x , relatively little NO _x will be formed in the secondary combustion zone.” To determine which ports to divert air to, can be a trial and error process unique to each boiler. A successful setup will be accompanied by a smoky unclear looking fire, not a clear blue flame which operators sometimes misguidedly try to obtain.		
Flue gas recirculation (FGR)	FGR reduces peak flame temperature by recirculating a portion of the flue gas back into the combustion zone as a replacement for combustion air. The recirculated gasses have a lower oxygen content that reduces the peak flame temperature in the combustion zone.	Yes	Yes
Low NO _x burners (LNBS)	LNBS are a technique with limited applicability to pile burning wood-fired boilers and recovery furnaces. LNBS modify the initial combustion conditions to reduce the peak flame temperature, and thereby reduce NO _x formation. They are often used in conjunction with modifications to overfire air systems, where a portion of combustion occurs through ports above or “over” the burners to complete combustion of other gases such as CO. They are most useful when using fuels like natural gas or distillate oil.	Yes	Yes
Fuel staging/reburning	Fuel staging is also known as “reburning” or “off-stoichiometric combustion.” Fuel staging is a technique where ten to twenty percent of the total fuel input is diverted to a second combustion zone downstream of the primary zone. Again, this is a technique to reduce the peak flame temperature during combustion.	Yes	Yes
Water/steam injection	Water/steam injection into the main flame can reduce the flame temperature and the generation of NO _x . It is an older technique most often used on older burner designs in natural gas and oil-fired boilers and gas turbines. If the flame temperature is sufficiently quenched, the generation of CO can increase and the process efficiency will decrease.	No	Yes
Mixing air fan	For lime kilns, this technology is a method of staging combustion air through the use of a fan that is mounted on the rotating kiln shell. This can reduce NO _x formation by decreasing peak flame temperatures.	No	Yes
Good operating practices and proper design	The formation of NO _x can be minimized by proper operation and design practices. Operators can control the combustion stoichiometry to minimize NO _x formation while achieving efficient fuel combustion.	Yes	Yes

Table 5. NO_x Control Technologies Available for Recovery Furnaces and Lime Kilns			
Control Technology	Brief Description	Available for RFs (Yes/No)¹	Available for LKs (Yes/No)¹
	This is the most basic combustion modification technique available.		
Selective Non-Catalytic Reduction (SNCR)	SNCR is an exhaust gas treatment process in which urea or ammonia is injected into the exhaust gas. High temperatures, normally between 1,600° and 1,900°F, promote the reaction between urea or ammonia (NH ₃) and NO _x to form N ₂ and water. The effectiveness of SNCR systems depends upon inlet NO _x concentration, temperature, mixing, residence time, reagent-to-NO _x ratio, and fuel sulfur content.	Yes	Yes
Selective Catalytic Reduction (SCR)	SCR is an exhaust gas treatment process in which NH ₃ or urea is injected into the exhaust gas upstream of a catalyst bed for exhaust temperatures between 450° and 750°F. In the SCR process, the urea or NH ₃ injected into the exhaust is first stored in a liquid storage tank and vaporized before injection. The exhaust/ammonia mixture then passes over the catalyst. The function of the catalyst is to lower the activation energy of the NO decomposition reaction, therefore, lowering the temperature necessary to carry out the reaction. On the catalyst surface, NH ₃ and NO or NO ₂ reacts to form diatomic nitrogen (N ₂) and water. When operated within the optimum temperature range, the reaction can result in removal efficiencies between 70 and 90 percent. The rate of NO _x removal increases with temperature up to a maximum removal rate at a temperature between 700° and 750°F. As the temperature increases above the optimum temperature, or decreases below the optimum range for a conventional vanadium pentoxide catalyst, the NO _x removal efficiency begins to decrease. Depending on the temperatures involved, low temperature and higher temperature catalyst formulations are available. The effectiveness of an SCR system depends upon the same factors as the SNCR system and the condition of the catalyst. The catalyst can degrade over time due to poisoning, fouling, thermal stress, and erosion by particulates, reducing NO _x removal efficiency.	Yes	Yes
Non-Selective Catalytic Reduction (NSCR) ³	This technology uses a catalyst without a reagent and requires zero excess air. The catalyst causes NO _x to give up its oxygen to products of incomplete combustion (PICs), CO, and hydrocarbons, causing the pollutants to destroy each other. However, if oxygen is present, the PICs will burn up without destroying the NO _x .	Yes	Yes
Oxidation/reduction scrubbing	Several proprietary oxidation/reduction (O/R) scrubbing NO _x removal processes are commercially available. The basic elements of a typical process include cooling of the combustion gas stream below	Yes	Yes

Table 5. NO_x Control Technologies Available for Recovery Furnaces and Lime Kilns			
Control Technology	Brief Description	Available for RFs (Yes/No)¹	Available for LKs (Yes/No)¹
	its dew point to condense water, treat with ozone or sodium chlorite to oxidize NO _x and SO ₂ to their highest oxidized forms, then absorb these oxides as acids in a scrubber. It has been reported that O/R scrubbing has a theoretical NO _x removal efficiency of 95 percent.		
<p>Notes: RF = recovery furnace. LK = lime kiln.</p> <p>¹ The only criteria for including the listed control option is availability. Other considerations are presented in Chapters 4 through 6.</p> <p>² ANDRITS Pulp & Paper. Recovery boilers chemical recovery and green energy. The Andritz solution: High Energy Recovery Boiler (HERB). <www.andritz.com> At least three HERB units have installed or are being installed in the U.S. per Andritz Pulp & Paper <www.andritz.com> The three units are IP Valliant, Oklahoma; IP Campti, Louisiana; and PCA, Valdosta, Georgia. It is unclear if the OK and GA units have been included into the latest air permits at the time of this analysis. The Campti unit has been implemented, and permit limits are listed in Chapter 3.</p> <p>³ Source: <i>NO_x Emissions Control from Stationary Sources, APTI Course 418</i>, Reorganized 2012 by Brian W. Doyle, PhD, PE, presented February 26-28, 2013, Boise, ID, Department of Environmental Quality.</p>			

3. Demonstrated Emission Limits for Recovery Furnaces and Lime Kilns

This chapter presents a survey of demonstrated emission limits for recovery furnaces and lime kilns at existing mills in Washington State. The emission limits are presented in Sections 3.1–3.3, and provide a basis for estimating the potential emission reductions presented in Chapter 4. April 14, 2014, New Source Performance Standards (NSPS) applicable to U.S. Kraft mill recovery furnaces and lime kilns equipped with electrostatic precipitators (ESPs) are also listed in the tables of Sections 3.1–3.3.

The provisions for RACT analysis provided in Sections 1.2 and 1.3 do not restrict consideration of emission limits that are being achieved to only those pulp and paper mills in Washington State. Therefore, while this survey emphasized emission limits that have been demonstrated in Washington State, it also includes information about various pulp and paper mills in other states and also in Canada and Europe. This survey does not include all pulp and paper mills currently in operation, but provides a general framework for emission limits that are being achieved by the individual mills listed based on facility permit information and technical support documents. During this analysis some mills may have discontinued operations or have changed names. This analysis has tried to provide the latest information and includes updated name changes or mill closure information where known.

Concentration based limits in grains per dry standard cubic foot (gr/dscf) and also parts per million (ppm), where provided, were used to compare emission limits between facilities. In some cases, Ecology had to convert units for facilities that use different units.

European Kraft pulp and paper mill information was obtained from the Integrated Pollution Prevention Control (ICCP) Reference Document on Best Available Techniques [BAT] in the [Kraft] Pulp and Paper Industry, December 2001, European Commission. As noted in the ICCP report, “a direct comparison of the emission levels between countries is difficult due to uncertainties in the basis of data (lack of harmonization in the methods of analysis and calculating emissions).” Unit conversions that Ecology estimated from BAT information, are approximately similar to BAT unit conversions performed by the National Council of Air and Stream Improvement (NCASI).

Unit conversion calculations and facility permit limits are provided in Appendix A.

3.1. Demonstrated PM emission limits for recovery furnaces and lime kilns

Table 6 provides a survey of demonstrated recovery furnace emission limits in Washington State and at randomly selected facilities in the U.S., Canada, and Europe. Canadian and European units have been converted to the listed unit for each limit. In most cases it is not known if the units in Section 3.1 are new, rebuilt, or modified, but information is provided where known. If a limit is required by a rule, the rule is listed under the column titled “Limit Reference.”

Table 6. Demonstrated PM Emission Limits at Recovery Furnaces				
Location	Facility (RF unit if specified)	Limit: gr/dscf^{1,2} @ 8% O₂ (daily) [annual]	Limit Reference	Control Technology
Europe	LCPDs: ³ low range	(0.011)	IPPC ³	BAT ³ options ⁴
USA	New/reconstructed after 5/23/13	0.015 ²	NSPS (4/14/14)	ESP
Louisiana ⁵	Int'l Paper CAMTI (No. 3)	0.015	BACT	[HERB], ESP ⁵
Minnesota	Boise Cascade Int'l Falls (EU320)	0.0165	MACT bubble	ESP (8-fields on)
Europe	LCPDs: ³ high range	(0.019)	IPPC ³	BAT ³ options ⁴
Arkansas	Georgia Pacific Crossert (8R)	0.02	BACT	ESP (wet bottom)
Georgia	Int'l Paper AM (No. 3)	0.021	MACT bubble	ESP
North Carolina	KapStone (No. 7)	0.021	BACT	ESP: Single stage, cold side 140k ft2 plate area
Mississippi	Weyerhaeuser NR PW (AA-100)	0.023	BACT	ESP
Georgia	GP Cedar Springs (No. 3)	0.021	MACT bubble	ESP
Louisiana	Port Hudson (No. 1)	0.025	BACT	ESP
Louisiana	Port Hudson (No. 2)	0.025	BACT	ESP
Alabama	Alabama River Cellulose (No. 1)	0.025	BACT	ESP (two in parallel)
Alabama	Alabama River Cellulose (No. 2)	0.025	BACT	ESP
Minnesota	Sappi Cloquet LLC (No. 10)	0.025	BACT	ESP – Envirotech/Buell
British Columbia	Prince George Vancouver (RB)	0.026	Permit PA2762	ESP
Washington	Weyerhaeuser (No. 10)	0.027 [0.020]	BART = BACT	ESP
Washington	Boise White Wallula (No. 3)	0.027 [0.021]	LAER	ESP
Washington	KapStone (22)	0.027	BACT	ESP
Maine	Red Shield (# 4)	0.028	MACT alternative	ESP (Flakt dry bottom two fields - compliance w/one field)
Georgia	GP Cedar Springs (No. 1)	0.030	BACT=MACT	ESP
Georgia	GP Cedar Springs (No. 2)	0.030	BACT=MACT	ESP
Idaho	Clearwater Lewiston (No. 5)	0.03	BACT	ESP
Florida	Palatka (No. 4)	0.030	BACT	ESP: (2 chambers w/6 fields each).
Washington	GP Camas (No. 3)	0.033	BACT	ESP = 2 chamber, 3 fields; scrubber = packed bed, cross-flow AirPol

Table 6. Demonstrated PM Emission Limits at Recovery Furnaces				
Location	Facility (RF unit if specified)	Limit: gr/dscf^{1,2} @ 8% O₂ (daily) [annual]	Limit Reference	Control Technology
Washington	GP Camas (No. 4)	0.033	BACT	ESP; scrubber (Teller)
Idaho	Clearwater Lewiston (No. 4)	0.040	BACT	ESP
Washington	KapStone (19)	0.040	BACT	ESP
USA	Modified RFs after 5/23/2013	0.044 ²	NSPS (4/14/14)	ESP
Georgia	Weyerhaeuser PWM (No. 3)	0.044	NSPS/NESHAP	ESP (east and west units)
Kentucky	Wycliffe Paper (03)	0.044	NSPS/NESHAP	wet bottom ESP+scrubber
Oregon	GP Consumer Products (EU24)	0.044	NSPS/NESHAP	ESP
Oregon	Boise White St Helens (2 & 3) ⁶	0.044	NSPS/NESHAP	ESP
Oregon	Cascade Pacific (RFEU)	0.044	NSPS/NESHAP	ESP 2 chamber, 4 field
Washington	Boise White Wallula (No. 2)	0.044	NSPS/NESHAP	ESP
Washington	KapStone (18)	0.044	BACT	ESP
Washington	PTPC (RF)	0.044	NSPS/NESHAP	ESP
Washington	WestRock (No. 4)	0.044	NSPS/NESHAP	ESP
British Columbia	Catalyst PC Vancouver (#3, w#4 on)	0.051	Permit	Scrubber
British Columbia	Catalyst PC Vancouver (#4, w#3 on)	0.051	Permit	Scrubber
British Columbia	Catalyst PC Vancouver (#4, w#3 out)	0.062	Permit	Scrubber
Georgia	International Paper AM (No. 2)	0.055	MACT bubble	ESP
British Columbia	Howe Sound Vancouver (E218529)	0.057	Permit	ESP
Washington	Cosmo (No. 1, 2 & 3 common stk)	0.10	WAC 173-410-040	Multiclones & scrubber ⁷

Notes: RF = recovery furnace. LK = lime kiln.

¹ gr/dscf = grains per dry standard cubic feet. Where needed, listed values were converted from metric units to these US units and to Standard conditions of 293.15 K. Standard pressure (1 atm) is the same at all facilities and therefore no conversion was needed. Where needed, oxygen content was converted to 8% (from 6% at some Canadian facilities; from 5% at European facilities).

² NSPS = New Source Performance Standards for Kraft pulp mills <http://www.gpo.gov/fdsys/pkg/FR-2014-04-04/pdf/2014-06719.pdf>. Because the April 14, 2014, NSPS limits are defined to be for filterable PM only, therefore for comparison purposes, the other limits in this table are assumed to be for filterable PM. However, please note the following regarding TSP vs PM₁₀ and filterable vs condensable: particulate limits are listed as total suspended particulate (TSP) even though some facilities have PM₁₀ limits. Other facilities in this table such as for International Paper CAMPTI (No. 3) in LA note updated emission factors (October 2012 permit) to include both filterable plus condensable particulate matter. Yet, the emission limits (at least for the CAMPTI unit) appear to be only for filterable particulate based on an October 22, 2013 (method 5 or 201a only) stack test. Available test data

Table 6. Demonstrated PM Emission Limits at Recovery Furnaces				
Location	Facility (RF unit if specified)	Limit: gr/dscf^{1,2} @ 8% O₂ (daily) [annual]	Limit Reference	Control Technology
showing compliance for the Boise Cascade Int'l Falls, MN (EU320) limit included both filterable and condensable particulate matter.				
³ Integrated Pollution Prevention Control (ICCP) Reference Document on Best Available Techniques [BAT] in the [kraft] Pulp and Paper Industry, December 2001, European Commission. LCPD = Large Combustion Plant Directive of the European Commission.				
⁴ General ICCP BAT approach: "In kraft pulp mills, emission of particulates are controlled by electrostatic precipitators and sometimes also in SO2 scrubbers." Specific BAT options for recovery furnaces: The BAT emission levels listed in this table "can generally be achieved by more modern recovery boilers by use of ESP only. Old recovery boilers achieve this (these) levels when they apply ESP and scrubbers. However, scrubbers are mainly applied for removal of SO2." ICCP BAT range for sulfite mills is 0.002 to 0.008 with "electrostatic precipitators and multi-stage scrubbers."				
⁵ At least three HERB units have been or are being installed in the United States per Andritz Pulp & Paper www.andritz.com. The three units are IP Valliant, Oklahoma; IP CAMPTI, Louisiana; and PCA, Valdosta, Georgia. It is unclear if the Oklahoma and Georgia units have been included into the latest air permits at the time of this analysis. The Campti unit has been implemented, and permit limits are listed in this table.				
⁶ Mill recently closed (~late 2012/early 2013).				
⁷ MACT rule dated February 18, 2003; effective May 19, 2003: HAP emissions (via MACT particulate rule) controlled through hog fuel boiler particulate matter per MACT II site specific rule 40CFR63.862(d).				

Of the facilities surveyed, the lowest demonstrated emissions for the units in Table 6 are the BAT limit range of European facilities that have demonstrated daily emission limits within the range of 0.011 gr/dscf and 0.019 gr/dscf. BATs are not permit limits, but are based on guidance documents called BREFs (BAT Reference document). Of the U.S. facilities surveyed, two had units with emission limits within this range: 0.015 gr/dscf hourly limit [International Paper CAMPTI, LA - new high energy recovery boiler (No. 3)] and 0.0165 gr/dscf hourly limit [Boise Cascade Int'l Falls MN, - existing unit: (EU320)].

In addition, U.S. Kraft recovery furnaces equipped with ESPs that are new or reconstructed after May 23, 2013, are required to meet an NSPS emission limit of 0.015 gr/dscf for filterable PM, and units built before May 23, 2013, must meet an emission limit of 0.044 gr/dscf for filterable PM. (Note: This NSPS requires that all recovery furnace sampling must also measure condensable PM, but condensable particulates are not to be included with filterable emissions when compared against the NSPS limits).

Ecology retains the option of adopting the lowest emission limit in Washington State as a reasonably achievable emission limit for this RACT analysis. The lowest demonstrated emission limit in Washington is 0.027 gr/dscf (hourly limit). This limit has been demonstrated at Weyerhaeuser (No. 10), Boise White Wallula (No. 3), and KapStone (22).

Table 7 provides a survey of demonstrated lime kiln emission limits in Washington State and at randomly selected facilities in the U.S., Canada, and Europe. Canadian and European units have been converted to the listed unit for each limit.

Table 7. Demonstrated PM Emission Limits at Lime Kilns				
Location	Facility (LK unit if specified)	Limit: gr/dscf^{1,2} at 10% O₂ (daily)	Limit Reference	Control Technology
USA	New/reconstructed after 5/23/13	0.010 ²	NSPS (4/14/14)	ESP
Europe	LCPDs: ³ low range	(0.01)	IPPC ³	BAT ³ options ⁴
Europe	LCPDs: ³ high range	(0.02)	IPPC ³	BAT ³ options ⁴
Washington	KapStone (3)	0.030	BACT	venturi scrubber
Washington	KapStone (4)	0.030	BACT	modified scrubber
Louisiana	Port Hudson (No. 2)	0.033	BACT	ESP+scrubber
Mississippi	Weyerhaeuser NR PW (AA-110)	0.033	BACT	ESP
Alabama	Alabama River Cellulose (No. 1)	0.035	BACT	venturi scrubber
Alabama	Alabama River Cellulose (No. 2)	0.035	BACT	ESP
Minnesota	Sappi Cloquet LLC (#10)	0.035	BACT	ESP
Washington	KapStone (5)	0.035 ng/0.060 oil	BACT	ESP
Washington	Weyerhaeuser (No. 4)	0.035 ng/0.07 oil	BACT	ESP
British Columbia	Howe Sound Vancouver (E218529)	0.044	Permit	ESP
Washington	Graymont	0.05 (coal or ng)	Permit	Baghouse
Louisiana	Port Hudson (No. 1)	0.050	BACT	High dP scrubber (replaced AirPol H-K scrubber for pet coke fuel)
Georgia	GP Cedar Springs (No. 2)	0.056	BACT=MACT	venturi scrubber
USA	Modified LKs after 5/23/13	0.064 ²	NSPS (4/14/14)	ESP
Arkansas	Georgia Pacific Crossert (#4)	0.064	BACT	scrubber
Georgia	GP Cedar Springs (No. 1)	0.064	BACT=MACT	venturi scrubber & mist eliminator
Georgia	Int'l Paper AM (No. 2)	0.064	MACT bubble	venturi scrubber & cyclone
Idaho	Clearwater Lewiston (No. 3)	0.064	BACT	ESP
Idaho	Clearwater Lewiston (No. 4)	0.064	BACT	ESP & packed bed scrubber
Kentucky	Wycliffe Paper (03)	0.064	NSPS/NESHAP	scrubber
Louisiana	Int'l Paper CAMPTI	0.064	BACT	wet scrubber
Oregon	GP Consumer Products (EU21)	0.064	NSPS/NESHAP	wet scrubber
Oregon	Boise White St. Helens ⁵	0.064	NSPS/NESHAP	scrubber
Oregon	Cascade Pacific (LKEU)	0.064	NSPS/NESHAP	scrubber
Washington	Boise White, Wallula	0.064 ng/0.12 oil	NSPS/NESHAP	scrubber (baghouse @ hot end of lime kiln)
Washington	PTPC (LK)	0.064	BACT	scrubber
Washington	WestRock (No. 1)	0.064	NSPS/NESHAP	scrubber
Washington	WestRock (No. 2)	0.064	NSPS/NESHAP	scrubber
British Columbia	Catalyst PC Vancouver (1,2 cmb stk)	0.066	Permit	ESP
Minnesota	Boise Cascade Int'l Falls (EU340)	0.066	MACT Bubble	wet scrubber

Table 7. Demonstrated PM Emission Limits at Lime Kilns				
Location	Facility (LK unit if specified)	Limit: gr/dscf ^{1,2} at 10% O ₂ (daily)	Limit Reference	Control Technology
Washington	GP Camas (No. 4)	0.067 ng/0.13 oil	NESHAP (NG)	Ducon rectangular cross-section variable throat venturi scrubber
Maine	Red Shield	0.130	MACT alternative	venturi scrubber
North Carolina	Kapstone	0.140	BACT	venturi scrubber
Georgia	International Paper AM (No. 1)	0.176	MACT bubble	venturi scrubber & cyclone
British Columbia	Prince George Vancouver	(0.101)	Permit PA2762	Scrubber
Florida	Palatka (No. 4)	N/A	BACT	cyclone and micromist style scrubber

Note: LK = lime kiln.

- ¹ gr/dscf = grains per dry standard cubic feet. Where needed, listed values were converted from metric units to these US units and to Standard conditions of 293.15 K. Standard pressure (1 atm) is the same at all facilities and therefore no conversion was needed. Where needed, oxygen content was converted to 10% (from 5% at European facilities).
- ² Particulate limits are listed as total suspended particulate (TSP) even though some facilities have PM₁₀ limits. However, because the March 14, 2014, NSPS limits are defined to be for filterable PM only, therefore the other limits in this table are assumed to be for filterable PM.
- ³ Integrated Pollution Prevention Control (ICCP) Reference Document on Best Available Techniques [BAT] in the [kraft] Pulp and Paper Industry, December 2001, European Commission. LCPD = Large Combustion Plant Directive of the European Commission.
- ⁴ General ICCP BAT approach: "In kraft pulp mills, emission of particulates are controlled by electrostatic precipitators and sometimes also in SO₂ scrubbers." Specific BAT options for lime kilns: The BAT emission levels listed in this table "can generally be achieved when using an ESP."
- ⁵ Mill recently closed (~late 2012/early 2013).

Of the limits surveyed, the lowest demonstrated or required emission limit for the units in Table 7 are the April 14, 2014, NSPS for lime kilns. Lime kilns equipped with ESPs that are new or reconstructed after May 23, 2013, are required to meet an NSPS emission limit of 0.010 gr/dscf for filterable PM, and units built before May 23, 2013, must meet an emission limit of 0.064 gr/dscf for filterable PM. (Note: This NSPS requires that all lime kiln sampling must also measure condensable PM, but condensable particulate is not to be included with filterable emissions when compared against the NSPS limits).

BAT emissions of European facilities have demonstrated daily emissions within the range of 0.01 gr/dscf and 0.02 gr/dscf (for natural gas or oil). BATs are not permit limits, but are based on BREFs.

Ecology retains the option of adopting the lowest emission limit in Washington State as a reasonably achievable emission limit for this RACT analysis. The lowest demonstrated emission limit in Washington is 0.030 gr/dscf (hourly average limit). This limit has been demonstrated at two Washington lime kilns: KapStone (3) and KapStone (4).

3.2. Demonstrated SO₂ emission limits for recovery furnaces and lime kilns

Table 8 provides a survey of demonstrated SO₂ emission limits for recovery furnaces in Washington State and at randomly selected facilities in the U.S., Canada, and Europe. Canadian and European units have been converted to the listed unit for each limit. In most cases it is not known if the units in Section 3.2 are new, rebuilt, or modified, but information is provided where known. If a limit is required by a rule, the rule is listed under the column titled “Limit Ref.”

Table 8. SO₂ Emission Limits¹ Demonstrated at Recovery Furnaces				
Location	Facility (RF unit if specified)	Limit: gr/dscf^{1,2} ppm @ 8% O₂	Limit Reference	Control Technology
Europe	LCPDs: ¹ low range	2-3 ³ (24-hr avg.)	IPPC ¹	BAT ¹ options ⁴
Washington	GP Camas (No. 3)	10 (24-hr avg.)	BACT	scrubber & wet heat recovery
Washington	GP Camas (No. 4)	10 (24-hr avg.)	BACT	scrubber & wet heat recovery
Europe	LCPDs: ¹ high range	16-18 ³ (24-hr avg.)	IPPC ¹	BAT ¹ options ⁴
Louisiana ⁵	Int'l Paper CAMTI (No. 3)	20 (3-hr avg.)	BACT	HERB, high solids liquor firing, proper design and operation ⁵
Idaho	Clearwater Lewiston (No. 5)	50 (3-hr avg.)	BACT	Good Operating Practices or none listed in permit
Washington	KapStone (18)	60 (3-hr avg.) [switched to 94 lb/hr units]	WAC 173-405-040(11)(a)	Good Operating Practices
Washington	KapStone (19)	60 (3-hr avg.) [switched to 149 lb/hr units]	WAC 173-405-040(11)(a)	Good Operating Practices
Washington	Weyerhaeuser (No. 10)	75 (3-hr avg.)	BART=BACT	Good Operating Practices
Florida	Palatka (No. 4)	100 (24-hr avg.)	BACT	Good Operating Practices or none listed in permit
Alabama	Alabama River Cellulose (No.1)	100	BACT	Good Operating Practices or none listed in permit
Maine	Red Shield (# 4)	100	BPT	Good Operating Practices, fuel sulfur std = 0.5%
North Carolina	Kapstone (No. 7)	110 (3-hr avg.)	BACT	Good Operating Practices or

Table 8. SO₂ Emission Limits¹ Demonstrated at Recovery Furnaces				
Location	Facility (RF unit if specified)	Limit: gr/dscf^{1,2} ppm @ 8% O₂	Limit Reference	Control Technology
				none listed in permit
Louisiana	Port Hudson (No. 1)	120	BACT	Good Operating Practices or none listed in permit
Louisiana	Port Hudson (No. 2)	120	BACT	Good Operating Practices
Washington	KapStone (22)	120 (3-hr avg.) [switched to 295 lb/hr units]	WAC 173-405-040(11)(a)	Good Operating Practices
Mississippi	Weyerhaeuser NR PW (AA-100)	153 (or 200 ppm at 4% O ₂)	BACT	Good Operating Practices or none listed in permit
Oregon	Cascade Pacific (RFEU)	180	BACT	Good Operating Practices or none listed in permit
Washington	PTPC (RF)	200	BACT	Good Operating Practices
Georgia	Weyerhaeuser PWM (No. 3)	200	PSD Limit	Good Operating Practices or none listed in permit
Minnesota	Sappi Cloquet LLC (#10)	250	Minn R7007.3000	Good Operating Practices or none listed in permit
Georgia	GP Cedar Springs (No. 1)	300	PSD Limit	Good Operating Practices or none listed in permit
Georgia	GP Cedar Springs (No. 2)	300	PSD Limit	Good Operating Practices or none listed in permit
Oregon	GP Consumer Products (EU24)	300 (3-hr avg.)	OAR-340-234-0210(3)	Good Operating Practices or none listed in permit
Oregon	Boise White St. Helens (2&3) ⁶	300 (3-hr avg.)	BACT	Good Operating Practices or none listed in permit
Georgia	GP Cedar Springs (No. 3)	350 (24-hr avg.)	BART	Good Operating Practices or none listed in permit
Washington	Cosmo (No. 1, 2 & 3 common stk) ⁷	360 ⁷	Order DE95AQ-1034	multiclones (RFs 1,2&3),

Table 8. SO₂ Emission Limits¹ Demonstrated at Recovery Furnaces				
Location	Facility (RF unit if specified)	Limit: gr/dscf^{1,2} ppm @ 8% O₂	Limit Reference	Control Technology
				absorption tower (RF 1&2), evaporator & 3 SO ₂ venturi absorbers in series (RF3) ⁷
Washington	WestRock (No. 4)	500 (150 30-day)	WAC 173-405-040(11)(a)	Good Operating Practices
Washington	Boise White Wallula (No. 2)	500	WAC 173-405-040(11)(a)	Good Operating Practices
Washington	Boise White Wallula (No. 3)	500	WAC 173-405-040(11)(a)	Good Operating Practices
Enocell, Finland	Not specified in IPPC ²	≤ 2 (annual avg)	IPPC ²	BAT ² options ⁴
Frövi, Sweden	Not specified in IPPC ²	≤ 2 (annual avg)	IPPC ²	BAT ² options ⁴
Joutseno, Finland	Not specified in IPPC ²	≤ 2 (annual avg)	IPPC ²	BAT ² options ⁴
Dynäs, Sweden	Not specified in IPPC ²	≤ 2 (annual avg)	IPPC ²	BAT ² options ⁴
Pöls AG, Austria	Not specified in IPPC ²	≤ 2 (annual avg)	IPPC ²	BAT ² options ⁴
Oulu, Finland	Not specified in IPPC ²	≤ 2 (annual avg)	IPPC ²	BAT ² options ⁴
Östrand, Sweden	Not specified in IPPC ²	≤ 2 (annual avg)	IPPC ²	BAT ² options ⁴
Varö, Sweden	Not specified in IPPC ²	≤ 2 (annual avg)	IPPC ²	BAT ² options ⁴
Stora Celbi, Portugal	Not specified in IPPC ²	≤ 2 (annual avg)	IPPC ²	BAT ² options ⁴
Vallvik, Sweden	Not specified in IPPC ²	≤ 2 (annual avg)	IPPC ²	BAT ² options ⁴
Mönsterås, Sweden	Not specified in IPPC ²	4 (annual avg)	IPPC ²	BAT ² options ⁴
Obbola, Sweden	Not specified in IPPC ²	4 (annual avg)	IPPC ²	BAT ² options ⁴
Skutskär, Sweden	Not specified in IPPC ²	5 (annual avg)	IPPC ²	BAT ² options ⁴
Bäckhammar, Sweden	Not specified in IPPC ²	5 (annual avg)	IPPC ²	BAT ² options ⁴
Skärblacka, Sweden	Not specified in IPPC ²	6 (annual avg)	IPPC ²	BAT ² options ⁴
Skoghall, Sweden	Not specified in IPPC ²	6 (annual avg)	IPPC ²	BAT ² options ⁴
Wisaforest, Finland	Not specified in IPPC ²	7 (annual avg)	IPPC ²	BAT ² options ⁴
Husum, Sweden	Not specified in IPPC ²	12 (annual avg)	IPPC ²	BAT ² options ⁴
Aspa, Sweden	Not specified in IPPC ²	15 (annual avg)	IPPC ²	BAT ² options ⁴
Ääneskoski, Finland	Not specified in IPPC ²	15 (annual avg)	IPPC ²	BAT ² options ⁴
Kaskinen, Finland	Not specified in IPPC ²	16 (annual avg)	IPPC ²	BAT ² options ⁴

Table 8. SO ₂ Emission Limits ¹ Demonstrated at Recovery Furnaces				
Location	Facility (RF unit if specified)	Limit: gr/dscf ^{1,2} ppm @ 8% O ₂	Limit Reference	Control Technology
Iggesund, Sweden	Not specified in IPPC ²	16 (annual avg)	IPPC ²	BAT ² options ⁴
Huelva, Spain	Not specified in IPPC ²	17 (annual avg)	IPPC ²	BAT ² options ⁴
Sunila, Finland	Not specified in IPPC ²	18 (annual avg)	IPPC ²	BAT ² options ⁴

Note: RF = recovery furnace.

¹ Limit units are hourly unless listed otherwise.

² Listed individual European facility emissions are not limits, but are annual average combined SO₂ and TRS emissions levels at “well performing existing pulp mills.” Integrated Pollution Prevention Control (ICCP) Reference Document on Best Available Techniques [BAT] in the [kraft] Pulp and Paper Industry, December 2001, European Commission. LCPD = Large Combustion Plant Directive of the European Commission. European low and high range BAT limits units are 24-hour averages. The 2001 report does not separate SO₂ and TRS individually, therefore the amount of SO₂ emissions is assumed to be less than the listed amount, but according to the report: “Gaseous sulphur is mainly SO₂-S. Usually only very small amounts of H₂S is released.”

³ NCASI calculated a BAT range of 1.8-18 ppm (calculations not shown): *NCASI 2009 Environmental Footprint Comparison Tool, Trade-Offs and Co-benefits accompanying SO_x and NO_x Control* (based on 2001 European BAT). Ecology calculated values similar to NCASI, with a range of 3.3 to 16.4 ppm (converting from 2001 BAT inputs in European units of mg/Nm³ at 273K, 101.3 kPa with dry gas and 5% oxygen).

⁴ General ICCP BAT approach: “If changes in the fuel or the operation do not give enough reduction of SO₂ emission, removing sulphur oxides from flue gases by absorption in alkaline liquid is considered BAT.” Specific BAT options for recovery furnaces: “Recovery boilers with high dry solids content of black liquor release very low SO₂ emissions.” BAT range for sulfite mills is 16 to 49 based on the following from ICCP: “reduction of SO₂ emission from flue gases by absorption in alkaline liquid is considered BAT. A removal efficiency for SO₂ of 95 + % is achievable. From recovery boilers equipped with multi-stage scrubber....”

⁵ At least three HERB units have been or are being installed in the United States per Andritz Pulp & Paper www.andritz.com. The three units are IP Valliant, Oklahoma; IP Campti, Louisiana; and PCA, Valdosta, Georgia. It is unclear if the Oklahoma and Georgia units have been included into the latest air permits at the time of this analysis. The Campti unit has been implemented, and permit limits are listed in this table.

⁶ Mill recently closed (~late 2012/early 2013).

⁷ SO₂ was not selected for further evaluation in the 2010 RH SIP for sulfite mills (2010 Regional Haze SIP, p. 10-8 Table 10-2).

The lowest demonstrated emissions (for 1- to 24-hr average ranges) for the units in Table 8 are from 2-3 ppm to 16-18 ppm (24-hr average BAT emission limit of European facilities). BATs are not permit limits, but are based on BREFs.

Ecology also retains the option of adopting the lowest emission limits in Washington State as a reasonably achievable emission limits for this RACT analysis. The lowest demonstrated emission limits in Washington (for 1- to 24-hr average ranges) are 10 ppm (24-hr average at GP Camas, WA units Nos. 3 and 4).

Table 9 provides a survey of demonstrated SO₂ emission limits for lime kilns in Washington State and at randomly selected facilities in the U.S., Canada, and Europe. Canadian and European units have been converted to the listed unit for each limit.

Table 9. SO₂ Emission Limits¹ Demonstrated at Lime Kilns				
Location	Facility (LK unit if specified)	Limit:^{1,2} ppm @ 10% O₂	Limit Reference	Control Technology
Europe	LCPDs: ¹ low range (w/o NCG incineration)	1-2 ³ (24-hr avg.)	IPPC ¹	BAT ¹ options ⁴
Europe	LCPDs: ¹ high range (w/o NCG incineration)	8 ³ (24-hr avg.)	IPPC ¹	BAT ¹ options ⁴
Florida	Palatka (No. 4)	16.9	BACT	scrubber
Alabama	Alabama River Cellulose (No. 1)	50	BACT	scrubber
Alabama	Alabama River Cellulose (No. 1)	50	BACT	scrubber
Alabama	Alabama River Cellulose (No. 2)	50	BACT	Good Operating Practices or none listed in permit
Mississippi	Weyerhaeuser NR PW (AA-110)	50	BACT	Good Operating Practices or none listed in permit
Washington	KapStone (3)	20 (3-hr avg.)	WAC 173-405-040(11)(a)	scrubber, Good Operating Practices
Washington	KapStone (4)	20 (3-hr avg.)	WAC 173-405-040(11)(a)	scrubber, Good Operating Practices
Washington	KapStone (5)	20 (3-hr avg.)	WAC 173-405-040(11)(a)	Good Operating Practices
Idaho	Clearwater Lewiston (No. 4)	20 (3-hr avg.)	BACT	scrubber, Good Operating Practices
Europe	LCPDs: ¹ low range (w/ NCG incineration)	42 ³ (24-hr avg.)	IPPC ¹	BAT ¹ = scrubber and/or low sulfur fuel
Europe	LCPDs: ¹ high range (w/ NCG incineration)	83-105 ³ (24-hr avg.)	IPPC ¹	BAT ¹ = Scrubber and/or low sulfur fuel
Washington	GP Camas (No. 4)	500	WAC 173-405-040(11)(a)	Ducon rectangular cross-section variable throat venturi scrubber
Washington	Weyerhaeuser (No. 4)	500	BACT	low sulfur input (no pulp mill evaporator condensate in lime mud washing)
Washington	PTPC (RF)	500	WAC 173-405-040(11)(a)	scrubber
Washington	WestRock (No. 1)	500	WAC 173-405-040(11)(a)	scrubber, Good Operating Practices
Washington	WestRock (No. 2)	500	WAC 173-405-040(11)(a)	scrubber, Good Operating Practices

Table 9. SO₂ Emission Limits¹ Demonstrated at Lime Kilns				
Location	Facility (LK unit if specified)	Limit:^{1,2} ppm @ 10% O₂	Limit Reference	Control Technology
Washington	Graymont	1000 (coal or ng)	Permit (facility-wide limit)	baghouse for PM only
Oulu, Finland	Not specified in IPPC ¹	2 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Husum, Sweden	Not specified in IPPC ¹	3 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Skoghall, Sweden	Not specified in IPPC ¹	3 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Dynäs, Sweden	Not specified in IPPC ¹	3 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Frövi, Sweden	Not specified in IPPC ¹	3 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Obbola, Sweden	Not specified in IPPC ¹	3 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Bäckhammar, Sweden	Not specified in IPPC ¹	3 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Pöls AG, Austria	Not specified in IPPC ¹	3 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Joutseno, Finland	Not specified in IPPC ¹	3 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Washington	Boise White Wallula	5 (annual avg.)	Order DE96AQ1078	Scrubber & low sulfur content (1.55%) in oil, Good Operating Practices
Stora Celbi, Portugal	Not specified in IPPC ¹	6 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Wisaforest, Finland	Not specified in IPPC ¹	8 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Kaskinen, Finland	Not specified in IPPC ¹	12-30 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Mönsterås, Sweden	Not specified in IPPC ¹	14-31 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Skärblacka, Sweden	Not specified in IPPC ¹	14-31 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Ääneskoski, Finland	Not specified in IPPC ¹	16-33 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Sunila, Finland	Not specified in IPPC ¹	17-33 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Aspa, Sweden	Not specified in IPPC ¹	28-41 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Skutskär, Sweden	Not specified in IPPC ¹	28-41 (annual avg.)	IPPC ¹	BAT ¹ options ⁴

Table 9. SO ₂ Emission Limits ¹ Demonstrated at Lime Kilns				
Location	Facility (LK unit if specified)	Limit: ^{1,2} ppm @ 10% O ₂	Limit Reference	Control Technology
Iggesund, Sweden	Not specified in IPPC ¹	44 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Enocell, Finland	Not specified in IPPC ¹	48 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Vallvik, Sweden	Not specified in IPPC ¹	81 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Varö, Sweden	Not specified in IPPC ¹	81 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Östrand, Sweden	Not specified in IPPC ¹	104 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Huelva, Spain	Not specified in IPPC ¹	160 (annual avg.)	IPPC ¹	BAT ¹ options ⁴

Note: LK = lime kiln.

¹ Listed individual European facility emissions are not limits, but are annual average combined SO₂ and TRS emissions levels at “well performing existing pulp mills.” ICCP reference document on BAT in the [kraft] Pulp and Paper Industry, December 2001, European Commission. LCPD = Large Combustion Plant Directive of the European Commission. European low and high range BAT limits units are 24-hr averages. The 2001 report does not separate SO₂ and TRS individually. Therefore, the amount of SO₂ emissions is assumed to be less than the listed amount, but according to the report: “Gaseous sulphur is mainly SO₂-S. Usually only very small amounts of H₂S is released.” There are two possible values provided in the ICCP report depending on whether an oil fired lime kiln includes non-condensable gas (NCG) incineration or not. For facilities with listed SO₂ levels up to the maximum oil-fired range specified in the report for non-NCG incineration, non-NCG incineration was assumed. For facilities with listed emission levels in between the specified NCG or non-NCG oil fired emission levels of the report, a range of the two emission levels was provided. For facilities with listed SO₂ levels above the minimum oil-fired range for NCG incineration specified in the report, NCG incineration was assumed.

² Limit units are hourly unless listed otherwise.

³ NCASI calculated a BAT range of 1.8-105 ppm (calculations not shown): *NCASI 2009 Environmental Footprint Comparison Tool, Trade-Offs and Co-benefits accompanying SO_x and NO_x Control* (based on 2001 European BAT). This range is assumed to include lime kilns that perform NCG incineration, as well as those lime kilns that do not perform NCG incineration. Ecology calculated values similar to NCASI, with a range of 1.4 to 83 ppm (converting from 2001 BAT inputs in European units of mg/Nm³ at 273K, 101.3 kPa with dry gas and 5% oxygen). [For lime kilns without NCG incineration, Ecology calculated a range of 1.4 – 8 ppm, and for lime kilns with NCG incineration, Ecology calculated a range of 42-83 ppm].

⁴ General ICCP BAT approach: “If changes in the fuel or the operation do not give enough reduction of SO₂ emission, removing sulphur oxides from flue gases by absorption in alkaline liquid is considered BAT.” Specific BAT options for lime kilns: “Depending on the amount of sulphur (NCG) applied to the lime kiln a scrubber may be required. Another option for SO₂ reduction would be to choose another location for the incinerations of NCG than the lime kiln or use less sulphur containing oil burned as fuel.”

The lowest demonstrated emission limits (for 1- to 24-hr average ranges) for the units in Table 9 are from 1-8 ppm (24-hr BAT) for lime kilns that do not incinerate NCGs to 42-105 ppm (24-hr BAT) for lime kilns with incineration of NCGs.

Ecology also retains the option of adopting the lowest emission limits in Washington State as a reasonably achievable emission limits for this RACT analysis. The lowest demonstrated emission limits (for 1-hr to 24-hr average ranges) in Washington are 20 ppm (3-hr average) for units with NCG incineration (KapStone, WA, units 3, 4, and 5).

3.3. Demonstrated NO_x emission limits for recovery furnaces and lime kilns

Table 10 provides a survey of demonstrated NO_x emission limits for recovery furnaces in Washington State and at randomly selected facilities in the U.S., Canada, and Europe. Canadian and European units have been converted to the listed unit for each emission limit. In most cases it is not known if the units in Section 3.3 are new, rebuilt, or modified, but information is provided where known. If a limit is required by a rule, the rule is listed under the column titled “Limit Ref.”

Table 10. NO _x Emission Limits ¹ Demonstrated at Recovery Furnaces				
Location	Facility (RF unit if specified)	Limit: ^{1,2} ppm @ 8% O ₂	Limit Reference	Control Technology
Europe	LCPDs: ¹ low range	36-40 ³ (24-hr avg.)	IPPC ¹	BAT ¹ options ⁴
Europe	LCPDs: ¹ high range	55-58 ³ (24-hr avg.)	IPPC ¹	BAT ¹ options ⁴
Alabama	Alabama River Cellulose (No. 2)	75	BACT	proper design & operation, combustion control, or not listed
Louisiana ⁵	International Paper CAMTI (No. 3)	80 (3-hr avg.)	BACT	High Energy Recovery Boiler [HERB], Proper combustion control ⁵
Mississippi	Weyerhaeuser NR PW (AA-100)	80 (8-hr avg.)	BACT	proper design & operation, combustion control, or not listed
Alabama	Alabama River Cellulose (No. 1)	90	BACT	proper design & operation, combustion control, or not listed
Washington	KapStone (22)	95 (3-hr avg.)	BACT	proper design & operation, combustion control, or not listed
Washington	KapStone (18)	95 (24-hr avg.)	BACT	proper design & operation, combustion control, or not listed
Washington	KapStone (19)	95 (24-hr avg.)	BACT	proper design & operation, combustion control, or not listed
Idaho	Clearwater Lewiston (No. 5)	100	BACT	proper design & operation, combustion control, or not listed
Arkansas	Georgia Pacific Crossert (8R)	110	BACT	BACT = ESP, boiler design, combustion control)

Table 10. NO_x Emission Limits¹ Demonstrated at Recovery Furnaces				
Location	Facility (RF unit if specified)	Limit:^{1,2} ppm @ 8% O₂	Limit Reference	Control Technology
Louisiana	Port Hudson (No. 1)	112	BACT	staged combustion, GED, PCT
Louisiana	Port Hudson (No. 2)	112	BACT	staged combustion, GED, PCT
Washington	Boise White Wallula(No. 3)	112 (24-hr avg.)	BACT	proper design & operation, combustion control, or not listed
Washington	Weyerhaeuser (No. 10)	140 (24-hr avg.)	BART = BACT	staged combustion system
Maine	Red Shield (# 4)	150 (24-hr avg.)	RACT	proper design & operation, combustion control, or not listed
Minnesota	Boise Cascade Int'l Falls (EU320)	80 (30-day avg.)	BACT	proper design & operation, combustion control, or not listed
Florida	Palatka (No. 4)	80 (30-day avg.)	BACT	Four-level overfire air system
Washington	WestRock (No. 4)	85 (30-day avg.)	BACT	proper design & operation, combustion control, or not listed
North Carolina	Kapstone (No. 7)	100 (30-day avg.)	BACT	proper design & operation, combustion control, or not listed
Minnesota	Sappi Cloquet LLC	115 (30-day avg.)	BACT	proper design & operation, combustion control, or not listed
Skärblacka, Sweden	Not specified in IPPC ¹	35 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Oulu, Finland	Not specified in IPPC ¹	41 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Wisaforest, Finland	Not specified in IPPC ¹	44 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Huelva, Spain	Not specified in IPPC ¹	45 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Mönsterås, Sweden	Not specified in IPPC ¹	48 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Frövi, Sweden	Not specified in IPPC ¹	51 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Joutseno, Finland	Not specified in IPPC ¹	51 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Obbola, Sweden	Not specified in IPPC ¹	51 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Stora Celbi, Portugal	Not specified in IPPC ¹	51 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Sunila, Finland	Not specified in IPPC ¹	51 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Skoghall, Sweden	Not specified in IPPC ¹	56 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Enocell, Finland	Not specified in IPPC ¹	59 (annual avg.)	IPPC ¹	BAT ¹ options ⁴

Table 10. NO_x Emission Limits¹ Demonstrated at Recovery Furnaces

Location	Facility (RF unit if specified)	Limit: ^{1,2} ppm @ 8% O ₂	Limit Reference	Control Technology
Husum, Sweden	Not specified in IPPC ¹	60 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Bäckhammar, Sweden	Not specified in IPPC ¹	60 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Dynäs, Sweden	Not specified in IPPC ¹	61 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Skutskär, Sweden	Not specified in IPPC ¹	62 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Aspa, Sweden	Not specified in IPPC ¹	63 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Östrand, Sweden	Not specified in IPPC ¹	67 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Kaskinen, Finland	Not specified in IPPC ¹	67 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Vallvik, Sweden	Not specified in IPPC ¹	70 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Iggesund, Sweden	Not specified in IPPC ¹	73 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Varö, Sweden	Not specified in IPPC ¹	73 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Pöls AG, Austria	Not specified in IPPC ¹	77 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Ääneskoski, Finland	Not specified in IPPC ¹	84 (annual avg.)	IPPC ¹	BAT ¹ options ⁴

Note: RF = recovery furnace.

¹ Listed individual European facility emissions are not limits, but annual average emissions levels at “well performing existing pulp mills.” Integrated Pollution Prevention Control (IPPC) Reference Document on Best Available Techniques [BAT] in the [kraft] Pulp and Paper Industry, December 2001, European Commission. LCPD = Large Combustion Plant Directive of the European Commission. European low and high range BAT limits units are 24-hour averages.

² Limit units are hourly unless listed otherwise.

³ NCASI calculated a BAT range of 40-58 ppm (calculations not shown): *NCASI 2009 Environmental Footprint Comparison Tool, Trade-Offs and Co-benefits accompanying SO_x and NO_x Control* (based on 2001 European BAT). Ecology calculated values similar to NCASI, with a range of 36 to 55 ppm (converting from 2001 BAT inputs in European units of mg/Nm³ at 273K, 101.3 kPa with dry gas and 5% oxygen).

⁴ General IPCC BAT approach: “The emission of nitrogen oxides can be controlled by burner design (low NO_x burners) and modified combustion conditions (primary methods). Specific BAT options for recovery furnaces: “The design of the recovery boiler (staged air feed systems) can result in relatively low NO_x concentrations.” BAT range for sulfite mills is 91 to 137 based on the following from IPCC: “The emission of nitrogen oxides can be controlled by burner design (low NO_x burners) and modified combustion conditions (primary methods). The design of the recovery boiler (staged air feed systems) can result in relatively low NO_x concentrations.... Secondary methods as selective non-catalytic reduction (SNCR) are usually not in operation.”

⁵ At least three HERB units have been or are being installed in the United States per Andritz Pulp & Paper www.andritz.com. The three units are IP Valliant, Oklahoma; IP Campti, Louisiana; and PCA, Valdosta, Georgia. It is unclear if the Oklahoma and Georgia units have been included into the latest

Table 10. NO_x Emission Limits¹ Demonstrated at Recovery Furnaces				
Location	Facility (RF unit if specified)	Limit:^{1,2} ppm @ 8% O₂	Limit Reference	Control Technology
air permits at the time of this analysis. The Campti unit has been implemented, and permit limits are listed in this table.				

The lowest demonstrated emissions in Table 10 (for 1- to 24-hr average ranges) are from 36-58 ppm (24-hr average for the BAT emission limit range of European facilities). BATs are not permit limits, but are based on BREFs.

Ecology also retains the option of adopting the lowest emission limits in Washington State as a reasonably achievable emission limits for this RACT analysis. The lowest demonstrated emission limits (for 1- to 24-hr average ranges) in Washington are 95 ppm for both a 3-hr average limit (KapStone, WA, unit 22), and 24-hr average limits (KapStone, WA, units 18 and 19).

Table 11 provides a survey of demonstrated NO_x emission limits for lime kilns in Washington State and at randomly selected facilities in the U.S., Canada, and Europe. Canadian and European units have been converted to the listed unit for each limit.

Table 11. NO_x Emission Limits¹ Demonstrated at Lime Kilns				
Location	Facility (LK unit if specified)	Limit:^{1,2} ppm @ 10% O₂	Limit Reference	Control Technology
Europe	LCPDs: ¹ low range (oil)	39-49 ³ (24-hr avg.)	IPPC ¹	BAT ¹ options ⁴
Europe	LCPDs: ¹ high range (oil)	77 ³ (24-hr avg.)	IPPC ¹	BAT ¹ options ⁴
Alabama	Alabama River Cellulose (No. 2)	100	BACT	proper design & operation, combustion control, or none listed in permit
Oregon	Cascade Pacific (LKEU)	112	BACT	proper design & operation, combustion control, or none listed in permit
Europe	LCPDs: ¹ low range (natural gas)	146 ³ (24-hr avg.)	IPPC ¹	BAT ¹ options ⁴
Maine	Red Shield (# 4)	170	RACT	proper design & operation, combustion control, or not listed
Alabama	Alabama River Cellulose (No. 1)	175	BACT	proper design & operation, combustion control, or none listed in permit
Mississippi	Weyerhaeuser NR PW (AA-110)	189 (or 300 ppm at 3.6% O ₂)	BACT	proper design & operation, combustion control, or not listed

Table 11. NO_x Emission Limits¹ Demonstrated at Lime Kilns				
Location	Facility (LK unit if specified)	Limit:^{1,2} ppm @ 10% O₂	Limit Reference	Control Technology
Minnesota	Sappi Cloquet LLC	220	BACT	proper design & operation, combustion control, or not listed
Europe	LCPDs: ¹ high range (natural gas)	231-292 ³ (24-hr avg.)	IPPC ¹	BAT ¹ options ⁴
Oregon	Boise White St Helens ⁵	270	BACT	proper design & operation, combustion control, or none listed in permit
Washington	KapStone (5)	275 (24-hr avg.)	BACT	proper design & operation, combustion control, or none listed in permit
Washington	KapStone (3)	340 (24-hr avg.)	BACT	proper design & operation, combustion control, or none listed in permit
Washington	KapStone (4)	340 (24-hr avg.)	BACT	proper design & operation, combustion control, or none listed in permit
Florida	Palatka (No. 4)	114 (30-day avg.)	BACT	proper design & operation, combustion control, or none listed in permit
Bäckhammar, Sweden	Not specified in IPPC ¹	15 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Huelva, Spain	Not specified in IPPC ¹	23 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Östrand, Sweden	Not specified in IPPC ¹	31 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Ääneskoski, Finland	Not specified in IPPC ¹	39 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Husum, Sweden	Not specified in IPPC ¹	42 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Iggesund, Sweden	Not specified in IPPC ¹	50 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Skoghall, Sweden	Not specified in IPPC ¹	58 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Kaskinen, Finland	Not specified in IPPC ¹	62 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Joutseno, Finland	Not specified in IPPC ¹	65 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Stora Celbi, Portugal	Not specified in IPPC ¹	65 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Enocell, Finland	Not specified in IPPC ¹	66 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Obbola, Sweden	Not specified in IPPC ¹	69 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Skutskär, Sweden	Not specified in IPPC ¹	73 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Aspa, Sweden	Not specified in IPPC ¹	77 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Mönsterås, Sweden	Not specified in IPPC ¹	66-81 (annual avg.)	IPPC ¹	BAT ¹ options ⁴

Table 11. NO _x Emission Limits ¹ Demonstrated at Lime Kilns				
Location	Facility (LK unit if specified)	Limit: ^{1,2} ppm @ 10% O ₂	Limit Reference	Control Technology
Frövi, Sweden	Not specified in IPPC ¹	66-81 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Vallvik, Sweden	Not specified in IPPC ¹	70-85 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Dynäs, Sweden	Not specified in IPPC ¹	70-85 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Skärblacka, Sweden	Not specified in IPPC ¹	74-89 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Varö, Sweden	Not specified in IPPC ¹	87-100 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Oulu, Finland	Not specified in IPPC ¹	91-104 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Sunila, Finland	Not specified in IPPC ¹	93-106 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Wisaforest, Finland	Not specified in IPPC ¹	115-126 (annual avg.)	IPPC ¹	BAT ¹ options ⁴
Pöls AG, Austria	Not specified in IPPC ¹	168 (annual avg.)	IPPC ¹	BAT ¹ options ⁴

Note: LK = lime kiln.

¹ Listed individual European facility emissions are not limits, but annual average emissions levels at “well performing existing pulp mills.” Integrated Pollution Prevention Control (IPPC) Reference Document on Best Available Techniques [BAT] in the [kraft] Pulp and Paper Industry, December 2001, European Commission. LCPD = Large Combustion Plant Directive of the European Commission. European low and high range BAT limits units are 24-hour averages. Individual facility fuel details are not provided in the 2001 IPPC report. For facilities with listed NO_x levels up to the maximum oil-fired range specified in the report, oil was the assumed fuel. For facilities with listed NO_x levels within the gas-fired range specified in the report, gas was the assumed fuel (Pöls AG, Austria). For facilities with listed emission levels in between the specified oil and gas fired emission levels of the report, a range consisting of both gas and oil fired kiln emission levels were provided.

² Limit units are hourly and at 10% oxygen unless listed otherwise.

³ NCASI calculated a BAT range of 49-292 ppm (calculations not shown): *NCASI 2009 Environmental Footprint Comparison Tool, Trade-Offs and Co-benefits accompanying SO_x and NO_x Control* (based on 2001 European BAT). This range is assumed to include both gas-fired and oil-fired lime kilns. Ecology calculated values similar to NCASI, with a range of 39 to 231 ppm (converting from 2001 BAT inputs in European units of mg/Nm³ at 273K, 101.3 kPa with dry gas and 5% oxygen). [For lime kilns that are oil fired, Ecology calculated a range of 39–77 ppm, and for lime kilns that are gas fired, Ecology calculated a range of 146-231 ppm].

⁴ General ICCP BAT approach: “The emission of nitrogen oxides can be controlled by burner design (low NO_x burners) and modified combustion conditions (primary methods). Specific BAT options for lime kilns: “The possibilities to decrease the NO_x emissions by adjusting the kiln running parameters, the flame shape, the air distribution and the excess oxygen is limited but can lead to slight reduction of NO_x formation (about 10-20%).”

⁵ Mill recently closed (~late 2012/early 2013).

The lowest demonstrated emissions (for 1- to 24-hr average ranges) for the units in Table 11 are 39-77 ppm for oil-fired kilns and 146-292 ppm BAT range for gas-fired kilns (24-hour average for the BAT emission limit range of European facilities). BATs are not permit limits, but are based on BREFs.

Ecology also retains the option of adopting the lowest emission limits in Washington State as reasonably achievable emission limits for this RACT analysis. The lowest demonstrated emission limits in Washington are 275 ppm (24-hr average limit at KapStone, WA, unit 5; unit uses oil and/or natural gas).

4. Estimated Emission Reductions Achievable

This section presents emission reductions that are estimated to be achieved for potential SO₂, NO_x, and PM RACT limits. Ecology interprets “reasonably available” control technology as defined in Section 1.2, to mean those control technologies that are currently demonstrating compliance with the SO₂, NO_x, and PM emission limits in Sections 3.1–3.3. There may be other control technologies listed in Chapter 2 which are capable of meeting the emission limits in Sections 3.1–3.3, but have not been demonstrated in practice. Potential emission reductions achievable using control technologies that have not been demonstrated in practice are not estimated as part of this RACT analysis.

4.1. Estimated emission reductions achievable (by facility)

In order to compare emission limits between facilities, units were converted to the extent possible given available facility information because some facility permits do not provide emission limits in comparable units. Concentration based limits in gr/dscf and also ppm, where provided, were used to compare emission limits between facilities. In addition, for Washington State pulp mills, recovery furnace and lime kiln compliance tests were compared to facility emission limits and also to potential RACT emission limits in order to estimate potential reductions from RACT options. Unit conversion and permit limit information is provided in Appendix A. Facility operating and emission information is provided in Appendix B and was the basis from which the estimated emission reductions listed in this chapter were calculated.

Estimated emission reductions are the difference between multi-year average annual emissions and the multi-year average annual emissions multiplied by the ratio of emission at the proposed RACT limit to measured emissions (if available) or calculated emissions (if measured emissions not available). This approach included the occasional need to convert mass per time units obtained from emission inventory data into concentration based limits for comparison purposes when compliance test results were unavailable. However, as noted in Section 5.2, the specific average pulp mill emission reductions from this section that are considered as RACT options in Chapter 5, are based on multi-year measured (compliance test) data, not on calculated data. For calculated data, multi-year average annual emission inventory units of tons per year (TPY) were

divided by multi-year average annual flow rate units of dry standard cubic feet per minute to provide concentration-based units.

This RACT analysis assumed emission limits with averaging times of 24 hours or less, are to an extent, comparable. For example: a daily (24-hr) limit would need to meet a similar 1-hr or 3-hr limit (etc.) most of the time in order to meet the daily limit. Limits based on averaging periods over 24 hours long were avoided. For example: although the recovery furnace at WestRock has a 150 ppm SO₂ limit for a 30-day rolling average, that facility's 1-hr 500 ppm SO₂ limit was used for similarly shorter averaging period comparison purposes instead.

Recovery furnaces can experience short duration spikes in SO₂ ppm levels and, as a result, some facilities have difficulty meeting short-term recovery furnace concentration emissions limits. One facility in Washington State, KapStone, switched from 3-hr average SO₂ concentration based permit limits of 60 ppm (RFs 18 & 19) to mass emission rate permit limits. However, the facility in Washington State with the lowest permitted recovery furnace SO₂ concentration based emission limit (10 ppm at GP Camas), consistently meets that limit, which is based on a 24-hr averaging period. In addition, the facility in Washington State with the next lowest recovery furnace SO₂ concentration based emission limit (75 ppm at Weyerhaeuser), demonstrates compliance with that limit, which is based on a 3-hr averaging period, and constitutes Ecology's BART determination for that unit per the RH SIP (p. L-374). It should be noted that the 75 ppm SO₂ limit listed in that facility's air operating permit is for conditions when supplemental oil is not used; or, if it is used, the black liquor solids (BLS) firing rate must be greater than 150,000 lb/hr.

This RACT analysis was based on a snapshot of emission inventories between approximately 2003 and 2011 depending on available data and facility operations (i.e., Cosmo did not operate from 2007–2010). Specific facility details may have changed since 2011. For example, at the KapStone facility, this analysis was based on emission inventory information for three recovery furnaces (RF18, RF19, and RF22). However, based on information from Ecology's Industrial Section which manages compliance at pulp mills, it appears that RF18 has not been operated continuously since 2012, but as a possible backup recovery furnace while RF19 is being modified. Eventually it will be permanently shut down under Notice of Construction (NOC) Order 8429. It is required to be shut down once RF19 is placed into operation after it is modified. By including all three recovery furnaces, this RACT analysis conservatively overestimates emission reductions for that facility.

Estimated emission reductions for each individual pulp mill in Washington State are provided in the following subsections. Recovery furnace HERB limits are not included for consideration below because there are currently no HERB units in operation in Washington State.

4.1.1. PTPC estimated emission reductions

PTPC, located in Port Townsend, WA, operates a Kraft pulp and paper mill that manufactures unbleached Kraft pulp, Kraft papers, and lightweight linerboard. Emissions and estimated emission reductions are presented in Tables 12 and 13.

Table 12. PTPC Recovery Furnace Emission Reductions								
Recovery Furnace Pollutant (units)	Potential RACT Limit (source)	Proposed Limit Avg Time	Current Permit Limit	Measured/Calculated Emissions	Annual Emission Averages (tons)			Notes
					NO _x	SO ₂	PM	
					206	105	116	
					Estimated Reductions (TPY)			
PM (gr/dscf at 8% O ₂)	0.0165 (lowest w/in BAT)	1-hr	0.044	0.027	---	---	45	1,2
PM (gr/dscf at 8% O ₂)	0.019 (Europe BAT)	24-hr	0.044	0.027	---	---	34	1,2
PM (gr/dscf at 8% O ₂)	0.027 (lowest WA limit)	1-hr	0.044	0.027	---	---	0	1,2
SO ₂ (ppm at 8% O ₂)	10 (lowest WA limit: w/Whr)	24-hr	200	28	---	67	---	1,2
SO ₂ (ppm at 8% O ₂)	18 (Europe BAT: No W/hr)	24-hr	200	28	---	37	---	1,2
SO ₂ (ppm at 8% O ₂)	75 (lowest WA limit: No W/hr)	3-hr	200	28	---	0	---	1,2
NO _x (ppm at 8% O ₂)	58 (Europe BAT)	24-hr	No limit	51	0	---	---	1,2
NO _x (ppm at 8% O ₂)	95 (lowest WA limit)	3-hr	No limit	51	0	---	---	1,2

Notes: --- = not applicable. Ng = natural gas. NCG = non condensable gas incineration. W/hr = wet heat recovery.

¹ Measured/calculated emissions are averages of 2003-2009 compliance tests or are calculated from 2003-2008 annual emission averages and other stack parameter information. Sea level pressure assumed for absolute stack pressure (facility is approximately at sea level). NO₂ molecular weight assumed for NO_x (MW = 46).

² Assumes limits with averaging periods of 24 hours or less are comparable (i.e., a daily limit would need to meet a similar value hourly limit most of the time in order to meet the daily limit.)

Table 13. PTPC Lime Kiln Emission Reductions								
Lime Kiln Pollutant (units)	Potential RACT Limit (source)	Proposed Limit Avg Time	Current Permit Limit	Measured/ Calculated Emissions	Annual Emission Averages (tons)			Notes
					NO _x	SO ₂	PM	
					51	1	23	
					Estimated Reductions (tpy)			
PM (gr/dscf at 10% O ₂)	0.02 (Europe BAT: oil or ng)	24-hr	0.064	0.036	---	---	10	(1),(2)
PM (gr/dscf at 10% O ₂)	0.030 (lowest WA limit: oil or ng)	1-hr	0.064	0.036	---	---	4	(1),(2)
SO ₂ (ppm at 10% O ₂)	20 (lowest WA limit w/or w/o NCG)	3-hr	500	4	---	0	---	(1),(2)
SO ₂ (ppm at 10% O ₂)	105 (Europe BAT w/NCG)	24-hr	500	4	---	0	---	(1),(2)
NO _x (ppm at 10% O ₂)	77 (Europe BAT: oil)	24-hr	No limit	81	2	---	---	(1),(2)
NO _x (ppm at 10% O ₂)	275 (lowest WA limit: oil or ng)	24-hr	No limit	81	0	---	---	(1),(2)
NO _x (ppm at 10% O ₂)	292 (Europe BAT: ng)	24-hr	No limit	(3)	(3)	---	---	(1),(2)

Notes: LK = lime kiln. --- = not applicable. Ng = natural gas. NCG = non condensable gas incineration.

(1) Measured/calculated emissions are averages of 2003-2009 compliance tests or are calculated from 2003-2008 annual emission averages and other stack parameter information. Sea level pressure assumed for absolute stack pressure (facility is approximately at sea level). NO₂ molecular weight assumed for NO_x (MW = 46).

(2) Assumes limits with averaging periods of 24 hours or less are comparable (i.e., a daily limit would need to meet a similar value hourly limit most of the time in order to meet the daily limit).

(3) The lime kiln at PTPC burns oil exclusively.

4.1.2. WestRock estimated emission reductions

WestRock is located in Tacoma, WA, and operates a recovery furnace and two lime kilns. Emissions and estimated emission reductions are presented in Tables 14–16.

Table 14. WestRock Recovery Furnace (No. 4) Emission Reductions								
Recovery Furnace Pollutant (units)	Potential RACT Limit (source)	Proposed Limit Avg Time	Current Permit Limit	Measured Emissions	Annual Emission Averages (tons)			Notes
					NO _x	SO ₂	PM	
					285	286	26	
					Estimated Reductions (tpy)			
PM (gr/dscf at 8% O ₂)	0.0165 (lowest w/in BAT)	1-hr	0.044	0.005	---	---	0	1,2
PM (gr/dscf at 8% O ₂)	0.019 (Europe BAT)	24-hr	0.044	0.005	---	---	0	1,2
PM (gr/dscf at 8% O ₂)	0.027 (lowest WA limit)	1-hr	0.044	0.005	---	---	0	1,2
SO ₂ (ppm at 8% O ₂)	10 (lowest WA limit: w/Whr)	24-hr	500	221	---	273	---	1,2
SO ₂ (ppm at 8% O ₂)	18 (Europe BAT: No W/hr)	24-hr	500	221	---	263	---	1,2
SO ₂ (ppm at 8% O ₂)	75 (lowest WA limit: No W/hr)	3-hr	500	221	---	189	---	1,2
NO _x (ppm at 8% O ₂)	58 (Europe BAT)	24-hr	85	50	0	---	---	1,2
NO _x (ppm at 8% O ₂)	95 (lowest WA limit)	3-hr	85	50	0	---	---	1,2

Notes: RF = recovery furnace. --- = not applicable. Ng = natural gas. NCG = non condensable gas incineration. W/hr = wet heat recovery.

¹ Measured/calculated emissions are averages of 2005-2011 compliance tests or are calculated from 2005-2009 annual emission averages and other stack parameter information. Sea level pressure assumed for absolute stack pressure (facility is approximately at sea level). NO₂ molecular weight assumed for NO_x (MW = 46).

² Assumes limits with averaging periods of 24 hours or less are comparable (i.e., a daily limit would need to meet a similar value hourly limit most of the time in order to meet the daily limit.)

Table 15. WestRock Lime Kiln (No. 1) Emission Reductions								
Lime Kiln Pollutant (units)	Potential RACT Limit (source)	Proposed Limit Avg Time	Current Permit Limit	Measured/ Calculated Emissions	Annual Emission Averages (tons)			Notes
					NO _x	SO ₂	PM	
					43	4	24	
					Estimated Reductions (tpy)			
PM (gr/dscf at 10% O ₂)	0.02 (Europe BAT: oil or ng)	24-hr	0.064	0.033	---	---	9	1,2
PM (gr/dscf at 10% O ₂)	0.030 (lowest WA limit: oil or ng)	1-hr	0.064	0.033	---	---	2	1,2
SO ₂ (ppm at 10% O ₂)	20 (lowest WA limit w/or w/o NCG)	3-hr	500	75	---	3	---	1,2
SO ₂ (ppm at 10% O ₂)	105 (Europe BAT: w/NCG)	24-hr	500	75	---	0	---	1,2
NO _x (ppm at 10% O ₂)	77 (Europe BAT: oil)	24-hr	No limit	41	0	---	---	1,2
NO _x (ppm at 10% O ₂)	275 (lowest WA limit: oil or ng)	24-hr	No limit	41	0	---	---	1,2
NO _x (ppm at 10% O ₂)	292 (Europe BAT: ng)	24-hr	No limit	41	0	---	---	1,2

Notes: LK = lime kiln. --- = not applicable. Ng = natural gas. NCG = non condensable gas incineration.

¹ Measured/calculated emissions are averages of 2005-2011 compliance tests or are calculated from 2005-2009 annual emission averages and other stack parameter information. Sea level pressure assumed for absolute stack pressure (facility is approximately at sea level). NO₂ molecular weight assumed for NO_x (MW = 46).

² Assumes limits with averaging periods of 24 hours or less are comparable (i.e., a daily limit would need to meet a similar value hourly limit most of the time in order to meet the daily limit.)

Table 16. WestRock Lime Kiln (No. 2) Emission Reductions								
Lime Kiln Pollutant (units)	Potential RACT Limit (source)	Proposed Limit Avg Time	Current Permit Limit	Measured/ Calculated Emissions	Annual Emission Averages (tons)			Notes
					NO _x	SO ₂	PM	
					2	1	5	
					Estimated Reductions (tpy)			
PM (gr/dscf at 10% O ₂)	0.02 (Europe BAT: oil or ng)	24-hr	0.064	0.042	---	---	3	1,2
PM (gr/dscf at 10% O ₂)	0.030 (lowest WA limit: oil or ng)	1-hr	0.064	0.042	---	---	1	1,2
SO ₂ (ppm at 10% O ₂)	20 (lowest WA limit w/or w/o NCG)	3-hr	500	73	---	1	---	1,2
SO ₂ (ppm at 10% O ₂)	105 (Europe BAT: w/NCG)	24-hr	500	73	---	0	---	1,2
NO _x (ppm at 10% O ₂)	77 (Europe BAT: oil)	24-hr	No limit	6	0	---	---	1,2
NO _x (ppm at 10% O ₂)	275 (lowest WA limit: oil or ng)	24-hr	No limit	6	0	---	---	1,2
NO _x (ppm at 10% O ₂)	292 (Europe BAT: ng)	24-hr	No limit	6	0	---	---	1,2

Notes: LK = lime kiln. --- = not applicable. Ng = natural gas. NCG = non condensable gas incineration.

¹ Measured/calculated emissions are averages of 2005-2011 compliance tests or are calculated from 2005-2009 annual emission averages and other stack parameter information. Sea level pressure assumed for absolute stack pressure (facility is approximately at sea level). NO₂ molecular weight assumed for NO_x (MW = 46).

² Assumes limits with averaging periods of 24 hours or less are comparable (i.e., a daily limit would need to meet a similar value hourly limit most of the time in order to meet the daily limit.)

4.1.3. Weyerhaeuser estimated emission reductions

Weyerhaeuser is located in Longview, WA, and operates a recovery furnace and a lime kiln. Emissions and estimated emission reductions are presented in Tables 17 and 18.

Table 17. Weyerhaeuser Recovery Furnace (No. 10) Emission Reductions								
Recovery Furnace Pollutant (units)	Potential RACT Limit (source)	Proposed Limit Avg Time	Current Permit Limit	Measured/ Calculated Emissions	Annual Emission Averages (tons)			Notes
					NO _x	SO ₂	PM	
					584	35	43	
					Estimated Reductions (tpy)			
PM (gr/dscf at 8% O ₂)	0.0165 (lowest w/in BAT)	1-hr	0.027	0.004	---	---	0	1,2
PM (gr/dscf at 8% O ₂)	0.019 (Europe BAT)	24-hr	0.027	0.004	---	---	0	1,2
PM (gr/dscf at 8% O ₂)	0.027 (lowest WA limit)	1-hr	0.027	0.004	---	---	0	1,2
SO ₂ (ppm at 8% O ₂)	10 (lowest WA limit: w/Whr)	24-hr	75	2.9	---	0	---	1,2
SO ₂ (ppm at 8% O ₂)	18 (Europe BAT: No W/hr)	24-hr	75	2.9	---	0	---	1,2
SO ₂ (ppm at 8% O ₂)	75 (lowest WA limit: No W/hr)	3-hr	75	2.9	---	0	---	1,2
NO _x (ppm at 8% O ₂)	58 (Europe BAT)	24-hr	140	67	78	---	---	1,2
NO _x (ppm at 8% O ₂)	95 (lowest WA limit)	3-hr	140	67	0	---	---	1,2

Notes: RF = recovery furnace. --- = not applicable. Ng = natural gas. NCG = non condensable gas incineration. W/hr = wet heat recovery.

¹ Measured/calculated emissions are averages of 2011-2012 compliance tests or are calculated from 200-2007 annual emission averages and other stack parameter information. Sea level pressure assumed for absolute stack pressure (facility is approximately at sea level w/in 20 ft). NO₂ molecular weight assumed for NO_x (MW = 46).

² Assumes limits with averaging periods of 24 hours or less are comparable (i.e., a daily limit would need to meet a similar value hourly limit most of the time in order to meet the daily limit.)

Table 18. Weyerhaeuser Lime Kiln (No. 4) Emission Reductions								
Lime Kiln Pollutant (units)	Potential RACT Limit (source)	Proposed Limit Avg Time	Current Permit Limit	Measured/ Calculated Emissions	Annual Emission Averages (tons)			Notes
					NO _x	SO ₂	PM	
					129	6	20	
					Estimated Reductions (tpy)			
PM (gr/dscf at 10% O ₂)	0.02 (Europe BAT: oil or ng)	24-hr	0.035	0.002	---	---	0	1,2
PM (gr/dscf at 10% O ₂)	0.030 (lowest WA limit: oil or ng)	1-hr	0.035	0.002	---	---	0	1,2
SO ₂ (ppm at 10% O ₂)	20 (lowest WA limit w/or w/o NCG)	3-hr	500	5.2	---	0	---	1,2
SO ₂ (ppm at 10% O ₂)	105 (Europe BAT: w/NCG)	24-hr	500	5.2	---	0	---	1,2
NO _x (ppm at 10% O ₂)	77 (Europe BAT: oil)	24-hr	No limit	156	65	---	---	1,2
NO _x (ppm at 10% O ₂)	275 (lowest WA limit: oil or ng)	24-hr	No limit	156	0	---	---	1,2
NO _x (ppm at 10% O ₂)	292 (Europe BAT: ng)	24-hr	No limit	156	0	---	---	1,2

Notes: LK = lime kiln. --- = not applicable. Ng = natural gas. NCG = non condensable gas incineration.

¹ Measured/calculated emissions are averages of 2011-2012 compliance tests or are calculated from 2003-2007 annual emission averages and other stack parameter information. Sea level pressure assumed for absolute stack pressure (facility is approximately at sea level w/in 20 ft). NO₂ molecular weight assumed for NO_x (MW = 46).

² Assumes limits with averaging periods of 24 hours or less are comparable (i.e., a daily limit would need to meet a similar value hourly limit most of the time in order to meet the daily limit.)

4.1.4. GP Camas estimated emission reductions

GP Camas is located in Camas, WA, and operates two recovery furnaces and a lime kiln. Emissions and estimated emission reductions are presented in Tables 19–21.

Table 19. GP Camas Recovery Furnace (No. 3) Emission Reductions								
Recovery Furnace Pollutant (units)	Potential RACT Limit (source)	Proposed Limit Avg Time	Current Permit Limit	Measured/ Calculated Emissions	Annual Emission Averages (tons)			Notes
					NO _x	SO ₂	PM	
					119	2	7	
					Estimated Reductions (tpy)			
PM (gr/dscf at 8% O ₂)	0.0165 (lowest w/in BAT)	1-hr	0.033	0.033	---	---	0	1,2
PM (gr/dscf at 8% O ₂)	0.019 (Europe BAT)	24-hr	0.033	0.033	---	---	0	1,2
PM (gr/dscf at 8% O ₂)	0.027 (lowest WA limit)	1-hr	0.033	0.033	---	---	0	1,2
SO ₂ (ppm at 8% O ₂)	10 (lowest WA limit: w/Whr)	24-hr	10	0.8	---	0	---	1,2
SO ₂ (ppm at 8% O ₂)	18 (Europe BAT: No W/hr)	24-hr	10	0.8	---	0	---	1,2
SO ₂ (ppm at 8% O ₂)	75 (lowest WA limit: No W/hr)	3-hr	10	0.8	---	0	---	1,2
NO _x (ppm at 8% O ₂)	58 (Europe BAT)	24-hr	No limit	57	0	---	---	1,2
NO _x (ppm at 8% O ₂)	95 (lowest WA limit)	3-hr	No limit	57	0	---	---	1,2

Notes: RF = recovery furnace. --- = not applicable. Ng = natural gas. NCG = non condensable gas incineration. W/hr = wet heat recovery.

¹ Measured/calculated emissions are averages of 2007-2009 compliance tests or are calculated from 2003-2007 annual emission averages and other stack parameter information. Sea level pressure assumed for absolute stack pressure (facility is approximately at sea level w/in 75 ft). NO₂ molecular weight assumed for NO_x (MW = 46).

² Assumes limits with averaging periods of 24 hours or less are comparable (i.e., a daily limit would need to meet a similar value hourly limit most of the time in order to meet the daily limit.)

Table 20. GP Camas Recovery Furnace (No. 4) Emission Reductions								
Recovery Furnace Pollutant (units)	Potential RACT Limit (source)	Proposed Limit Avg Time	Current Permit Limit	Measured/Calculated Emissions	Annual Emission Averages (tons)			Notes
					NO _x	SO ₂	PM	
					207	3	65	
					Estimated Reductions (tpy)			
PM (gr/dscf at 8% O ₂)	0.0165 (lowest w/in BAT)	1-hr	0.033	0.020	---	---	11	1,2
PM (gr/dscf at 8% O ₂)	0.019 (Europe BAT)	24-hr	0.033	0.020	---	---	3	1,2
PM (gr/dscf at 8% O ₂)	0.027 (lowest WA limit)	1-hr	0.033	0.020	---	---	0	1,2
SO ₂ (ppm at 8% O ₂)	10 (lowest WA limit: w/Whr)	24-hr	10	1.6	---	0	---	1,2
SO ₂ (ppm at 8% O ₂)	18 (Europe BAT: No W/hr)	24-hr	10	1.6	---	0	---	1,2
SO ₂ (ppm at 8% O ₂)	75 (lowest WA limit: No W/hr)	3-hr	10	1.6	---	0	---	1,2
NO _x (ppm at 8% O ₂)	58 (Europe BAT)	24-hr	No limit	73	42	---	---	1,2
NO _x (ppm at 8% O ₂)	95 (lowest WA limit)	3-hr	No limit	73	0	---	---	1,2

Notes: RF = recovery furnace. --- = not applicable. Ng = natural gas. NCG = non condensable gas incineration. W/hr = wet heat recovery.

¹ Measured/calculated emissions are averages of 2007-2009 compliance tests or are calculated from 2003-2007 annual emission averages and other stack parameter information. Sea level pressure assumed for absolute stack pressure (facility is approximately at sea level w/in 75 ft). NO₂ molecular weight assumed for NO_x (MW = 46).

² Assumes limits with averaging periods of 24 hours or less are comparable (i.e., a daily limit would need to meet a similar value hourly limit most of the time in order to meet the daily limit.)

Table 21. GP Camas Lime Kiln (No. 4) Emission Reductions								
Lime Kiln Pollutant (units)	Potential RACT Limit (source)	Proposed Limit Avg Time	Current Permit Limit	Measured/ Calculated Emissions	Annual Emission Averages (tons)			Notes
					NO _x	SO ₂	PM	
					104	1	13	
					Estimated Reductions (tpy)			
PM (gr/dscf at 10% O ₂)	0.02 (Europe BAT: oil or ng)	24-hr	0.067	0.021	---	---	1	(1),(2)
PM (gr/dscf at 10% O ₂)	0.030 (lowest WA limit: oil or ng)	1-hr	0.067	0.021	---	---	0	(1),(2)
SO ₂ (ppm at 10% O ₂)	20 (lowest WA limit w/or w/o NCG)	3-hr	500	2.0	---	0	---	(1),(2)
SO ₂ (ppm at 10% O ₂)	105 (Europe BAT w/NCG)	24-hr	500	2.0	---	0	---	(1),(2)
NO _x (ppm at 10% O ₂)	77 (Europe BAT: oil)	24-hr	No limit	(3)	(3)	---	---	(1),(2)
NO _x (ppm at 10% O ₂)	275 (lowest WA limit: oil or ng)	24-hr	No limit	361	25	---	---	(1),(2)
NO _x (ppm at 10% O ₂)	292 (Europe BAT: ng)	24-hr	No limit	367	20	---	---	(1),(2)

Notes: LK = lime kiln. --- = not applicable. Ng = natural gas. NCG = non condensable gas incineration.

(1) Measured/calculated emissions are averages of 2007-2009 compliance tests or are calculated from 2003-2007 annual emission averages and other stack parameter information. Sea level pressure assumed for absolute stack pressure (facility is approximately at sea level w/in 75 ft). NO₂ molecular weight assumed for NO_x (MW = 46).

(2) Assumes limits with averaging periods of 24 hours or less are comparable (i.e., a daily limit would need to meet a similar value hourly limit most of the time in order to meet the daily limit).

(3) The LK (No. 4) at GP Camas does not burn oil. The fuel oil burner was decommissioned in early 2011.

4.1.5. KapStone estimated emission reductions

KapStone is located in Longview, WA, and operates three recovery furnaces and three lime kilns. Emissions and estimated emission reductions are presented in Tables 22–27.

Table 22. KapStone Recovery Furnace (No. 18) Emission Reductions								
Recovery Furnace Pollutant (units)	Potential RACT Limit (source)	Proposed Limit Avg Time	Current Permit Limit	Measured Emissions	Annual Emission Averages (tons)			Notes
					NO _x	SO ₂	PM	
					127	12	4	
					Estimated Reductions (tpy)			
PM (gr/dscf at 8% O ₂)	0.0165 (lowest w/in BAT)	1-hr	0.044	0.0014	---	---	0	1,2
PM (gr/dscf at 8% O ₂)	0.019 (Europe BAT)	24-hr	0.044	0.0014	---	---	0	1,2
PM (gr/dscf at 8% O ₂)	0.027 (lowest WA limit)	1-hr	0.044	0.0014	---	---	0	1,2
SO ₂ (ppm at 8% O ₂)	10 (lowest WA limit: w/Whr)	24-hr	60 (removed)	30	---	8	---	1,2
SO ₂ (ppm at 8% O ₂)	18 (Europe BAT: No W/hr)	24-hr	60 (removed)	30	---	5	---	1,2
SO ₂ (ppm at 8% O ₂)	75 (lowest WA limit: No W/hr)	3-hr	60 (removed)	30	---	0	---	1,2
NO _x (ppm at 8% O ₂)	58 (Europe BAT)	24-hr	95	56	0	---	---	1,2
NO _x (ppm at 8% O ₂)	95 (lowest WA limit)	3-hr	95	56	0	---	---	1,2

Notes: RF = recovery furnace. --- = not applicable. Ng = natural gas. NCG = non condensable gas incineration. W/hr = wet heat recovery.

¹ Measured/calculated emissions are averages of 2010-2013 compliance tests or are calculated from 2005-2011 annual emission averages and other stack parameter information. Sea level pressure assumed for absolute stack pressure (facility is approximately at sea level w/in 20 ft). NO₂ molecular weight assumed for NO_x (MW = 46).

² Assumes limits with averaging periods of 24 hours or less are comparable (i.e., a daily limit would need to meet a similar value hourly limit most of the time in order to meet the daily limit.)

Table 23. KapStone Recovery Furnace (No. 19) Emission Reductions								
Recovery Furnace Pollutant (units)	Potential RACT Limit (source)	Proposed Limit Avg Time	Current Permit Limit	Measured Emissions	Annual Emission Averages (tons)			Notes
					NO _x	SO ₂	PM	
					173	18	14	
					Estimated Reductions (tpy)			
PM (gr/dscf at 8% O ₂)	0.0165 (lowest w/in BAT)	1-hr	0.040	0.004	---	---	0	1,2
PM (gr/dscf at 8% O ₂)	0.019 (Europe BAT)	24-hr	0.040	0.004	---	---	0	1,2
PM (gr/dscf at 8% O ₂)	0.027 (lowest WA limit)	1-hr	0.040	0.004	---	---	0	1,2
SO ₂ (ppm at 8% O ₂)	10 (lowest WA limit: w/Whr)	24-hr	60 (removed)	28	---	11	---	1,2
SO ₂ (ppm at 8% O ₂)	18 (Europe BAT: No W/hr)	24-hr	60 (removed)	28	---	6	---	1,2
SO ₂ (ppm at 8% O ₂)	75 (lowest WA limit: No W/hr)	3-hr	60 (removed)	28	---	0	---	1,2
NO _x (ppm at 8% O ₂)	58 (Europe BAT)	24-hr	95	61	8	---	---	1,2
NO _x (ppm at 8% O ₂)	95 (lowest WA limit)	3-hr	95	61	0	---	---	1,2

Notes: RF = recovery furnace. --- = not applicable. Ng = natural gas. NCG = non condensable gas incineration. W/hr = wet heat recovery.

¹ Measured/calculated emissions are averages of 2010-2013 compliance tests or are calculated from 2005-2011 annual emission averages and other stack parameter information. Sea level pressure assumed for absolute stack pressure (facility is approximately at sea level w/in 20 ft). NO₂ molecular weight assumed for NO_x (MW = 46).

² Assumes limits with averaging periods of 24 hours or less are comparable (i.e., a daily limit would need to meet a similar value hourly limit most of the time in order to meet the daily limit.)

Table 24. KapStone Recovery Furnace (No. 22) Emission Reductions								
Recovery Furnace Pollutant (units)	Potential RACT Limit (source)	Proposed Limit Avg Time	Current Permit Limit	Measured Emissions	Annual Emission Averages (tons)			Notes
					NO _x	SO ₂	PM	
					268	60	8	
					Estimated Reductions (tpy)			
PM (gr/dscf at 8% O ₂)	0.0165 (lowest w/in BAT)	1-hr	0.027	0.001	---	---	0	1,2
PM (gr/dscf at 8% O ₂)	0.019 (Europe BAT)	24-hr	0.027	0.001	---	---	0	1,2
PM (gr/dscf at 8% O ₂)	0.027 (lowest WA limit)	1-hr	0.027	0.001	---	---	0	1,2
SO ₂ (ppm at 8% O ₂)	10 (lowest WA limit: w/Whr)	24-hr	120 (removed)	86	---	53	---	1,2
SO ₂ (ppm at 8% O ₂)	18 (Europe BAT: No W/hr)	24-hr	120 (removed)	86	---	47	---	1,2
SO ₂ (ppm at 8% O ₂)	75 (lowest WA limit: No W/hr)	3-hr	120 (removed)	86	---	8	---	1,2
NO _x (ppm at 8% O ₂)	58 (Europe BAT)	24-hr	95	66	32	---	---	1,2
NO _x (ppm at 8% O ₂)	95 (lowest WA limit)	3-hr	95	66	0	---	---	1,2

Notes: RF = recovery furnace. --- = not applicable. Ng = natural gas. NCG = non condensable gas incineration. W/hr = wet heat recovery.

¹ Measured/calculated emissions are averages of 2010-2013 compliance tests or are calculated from 2005-2011 annual emission averages and other stack parameter information. Sea level pressure assumed for absolute stack pressure (facility is approximately at sea level w/in 20 ft). NO₂ molecular weight assumed for NO_x (MW = 46).

² Assumes limits with averaging periods of 24 hours or less are comparable (i.e., a daily limit would need to meet a similar value hourly limit most of the time in order to meet the daily limit.)

Table 25. KapStone Lime Kiln (No. 3) Emission Reductions								
Lime Kiln Pollutant (units)	Potential RACT Limit (source)	Proposed Limit Avg Time	Current Permit Limit	Measured Emissions	Annual Emission Averages (tons)			Notes
					NO _x	SO ₂	PM	
					24	0	3	
					Estimated Reductions (tpy)			
PM (gr/dscf at 10% O ₂)	0.02 (Europe BAT: oil or ng)	24-hr	0.030	0.01	---	---	0	1,2
PM (gr/dscf at 10% O ₂)	0.030 (lowest WA limit: oil or ng)	1-hr	0.030	0.01	---	---	0	1,2
SO ₂ (ppm at 10% O ₂)	20 (lowest WA limit w/or w/o NCG)	3-hr	20	2.1	---	0	---	1,2
SO ₂ (ppm at 10% O ₂)	105 (Europe BAT: w/NCG)	24-hr	20	2.1	---	0	---	1,2
NO _x (ppm at 10% O ₂)	77 (Europe BAT: oil)	24-hr	340	84	2	---	---	1,2
NO _x (ppm at 10% O ₂)	275 (lowest WA limit: oil or ng)	24-hr	340	84	0	---	---	1,2
NO _x (ppm at 10% O ₂)	292 (Europe BAT: ng)	24-hr	340	84	0	---	---	1,2

Notes: LK = lime kiln. --- = not applicable. Ng = natural gas. NCG = non condensable gas incineration.

¹ Measured/calculated emissions are averages of 2010-2013 compliance tests or are calculated from 2005-2011 annual emission averages and other stack parameter information. Sea level pressure assumed for absolute stack pressure (facility is approximately at sea level w/in 20 ft). NO₂ molecular weight assumed for NO_x (MW = 46).

² Assumes limits with averaging periods of 24 hours or less are comparable (i.e., a daily limit would need to meet a similar value hourly limit most of the time in order to meet the daily limit.)

Table 26. KapStone Lime Kiln (No. 4) Emission Reductions								
Lime Kiln Pollutant (units)	Potential RACT Limit (source)	Proposed Limit Avg Time	Current Permit Limit	Measured Emissions	Annual Emission Averages (tons)			Notes
					NO _x	SO ₂	PM	
					54	2	8	
					Estimated Reductions (tpy)			
PM (gr/dscf at 10% O ₂)	0.02 (Europe BAT: oil or ng)	24-hr	0.030	0.015	---	---	0	1,2
PM (gr/dscf at 10% O ₂)	0.030 (lowest WA limit: oil or ng)	1-hr	0.030	0.015	---	---	0	1,2
SO ₂ (ppm at 10% O ₂)	20 (lowest WA limit w/or w/o NCG)	3-hr	20	3.3	---	0	---	1,2
SO ₂ (ppm at 10% O ₂)	105 (Europe BAT: w/NCG)	24-hr	20	3.3	---	0	---	1,2
NO _x (ppm at 10% O ₂)	77 (Europe BAT: oil)	24-hr	340	126	21	---	---	1,2
NO _x (ppm at 10% O ₂)	275 (lowest WA limit: oil or ng)	24-hr	340	126	0	---	---	1,2
NO _x (ppm at 10% O ₂)	292 (Europe BAT: ng)	24-hr	340	126	0	---	---	1,2

Notes: LK = lime kiln. --- = not applicable. Ng = natural gas. NCG = non condensable gas incineration.

¹ Measured/calculated emissions are averages of 2010-2013 compliance tests or are calculated from 2005-2011 annual emission averages and other stack parameter information. Sea level pressure assumed for absolute stack pressure (facility is approximately at sea level w/in 20 ft). NO₂ molecular weight assumed for NO_x (MW = 46).

² Assumes limits with averaging periods of 24 hours or less are comparable (i.e., a daily limit would need to meet a similar value hourly limit most of the time in order to meet the daily limit.)

Table 27. KapStone Lime Kiln (No. 5) Emission Reductions								
Lime Kiln Pollutant (units)	Potential RACT Limit (source)	Proposed Limit Avg Time	Current Permit Limit	Measured Emissions	Annual Emission Averages (tons)			Notes
					NO _x	SO ₂	PM	
					41	1	1	
					Estimated Reductions (tpy)			
PM (gr/dscf at 10% O ₂)	0.02 (Europe BAT: oil or ng)	24-hr	0.035	0.002	---	---	0	1,2
PM (gr/dscf at 10% O ₂)	0.030 (lowest WA limit: oil or ng)	1-hr	0.035	0.002	---	---	0	1,2
SO ₂ (ppm at 10% O ₂)	20 (lowest WA limit w/or w/o NCG)	3-hr	20	1.9	---	0	---	1,2
SO ₂ (ppm at 10% O ₂)	105 (Europe BAT: w/NCG)	24-hr	20	1.9	---	0	---	1,2
NO _x (ppm at 10% O ₂)	77 (Europe BAT: oil)	24-hr	275	98	9	---	---	1,2
NO _x (ppm at 10% O ₂)	275 (lowest WA limit: oil or ng)	24-hr	275	98	0	---	---	1,2
NO _x (ppm at 10% O ₂)	292 (Europe BAT: ng)	24-hr	275	98	0	---	---	1,2

Notes: LK = lime kiln. --- = not applicable. Ng = natural gas. NCG = non condensable gas incineration.

¹ Measured/calculated emissions are averages of 2010-2013 compliance tests or are calculated from 2005-2011 annual emission averages and other stack parameter information. Sea level pressure assumed for absolute stack pressure (facility is approximately at sea level w/in 20 ft). NO₂ molecular weight assumed for NO_x (MW = 46).

² Assumes limits with averaging periods of 24 hours or less are comparable (i.e., a daily limit would need to meet a similar value hourly limit most of the time in order to meet the daily limit.)

4.1.6. Boise White Wallula estimated emission reductions

Boise White Wallula is located in Wallula, WA, and operates two recovery furnaces and a lime kiln. Emissions and estimated emission reductions are presented in Tables 28–30.

Table 28. Boise White Wallula Recovery Furnace (No. 2) Emission Reductions								
Recovery Furnace Pollutant (units)	Potential RACT Limit (source)	Proposed Limit Avg Time	Current Permit Limit	Measured/ Calculated Emissions	Annual Emission Averages (tons)			Notes
					NO _x	SO ₂	PM	
					67	294	9	
					Estimated Reductions (tpy)			
PM (gr/dscf at 8% O ₂)	0.0165 (lowest w/in BAT)	1-hr	0.044	0.006	---	---	0	1,2
PM (gr/dscf at 8% O ₂)	0.019 (Europe BAT)	24-hr	0.044	0.006	---	---	0	1,2
PM (gr/dscf at 8% O ₂)	0.027 (lowest WA limit)	1-hr	0.044	0.006	---	---	0	1,2
SO ₂ (ppm at 8% O ₂)	10 (lowest WA limit: w/Whr)	24-hr	500	173	---	277	---	1,2
SO ₂ (ppm at 8% O ₂)	18 (Europe BAT: No W/hr)	24-hr	500	173	---	264	---	1,2
SO ₂ (ppm at 8% O ₂)	75 (lowest WA limit: No W/hr)	3-hr	500	173	---	167	---	1,2
NO _x (ppm at 8% O ₂)	58 (Europe BAT)	24-hr	No limit	57	0	---	---	1,2
NO _x (ppm at 8% O ₂)	95 (lowest WA limit)	3-hr	No limit	57	0	---	---	1,2

Notes: RF = recovery furnace. --- = not applicable. Ng = natural gas. NCG = non condensable gas incineration. W/hr = wet heat recovery.

¹ Measured/calculated emissions are averages of 2005-2012 compliance tests or are calculated from 2005-2011 annual emission averages and other stack parameter information. Sea level pressure assumed for absolute stack pressure (facility is approximately at sea level w/in 100 ft). NO₂ molecular weight assumed for NO_x (MW = 46).

² Assumes limits with averaging periods of 24 hours or less are comparable (i.e., a daily limit would need to meet a similar value hourly limit most of the time in order to meet the daily limit.)

Table 29. Boise White Wallula Recovery Furnace (No. 3) Emission Reductions								
Recovery Furnace Pollutant (units)	Potential RACT Limit (source)	Proposed Limit Avg Time	Current Permit Limit	Measured Emissions	Annual Emission Averages (tons)			Notes
					NO _x	SO ₂	PM	
					285	496	15	
					Estimated Reductions (tpy)			
PM (gr/dscf at 8% O ₂)	0.0165 (lowest w/in BAT)	1-hr	0.027	0.003	---	---	0	1,2
PM (gr/dscf at 8% O ₂)	0.019 (Europe BAT)	24-hr	0.027	0.003	---	---	0	1,2
PM (gr/dscf at 8% O ₂)	0.027 (lowest WA limit)	1-hr	0.027	0.003	---	---	0	1,2
SO ₂ (ppm at 8% O ₂)	10 (lowest WA limit: w/Whr)	24-hr	500	49	---	395	---	1,2
SO ₂ (ppm at 8% O ₂)	18 (Europe BAT: No W/hr)	24-hr	500	49	---	314	---	1,2
SO ₂ (ppm at 8% O ₂)	75 (lowest WA limit: No W/hr)	3-hr	500	49	---	0	---	1,2
NO _x (ppm at 8% O ₂)	58 (Europe BAT)	24-hr	112	61	14	---	---	1,2
NO _x (ppm at 8% O ₂)	95 (lowest WA limit)	3-hr	112	61	0	---	---	1,2

Notes: RF = recovery furnace. --- = not applicable. Ng = natural gas. NCG = non condensable gas incineration. W/hr = wet heat recovery.

¹ Measured/calculated emissions are averages of 2005-2012 compliance tests or are calculated from 2005-2011 annual emission averages and other stack parameter information. Sea level pressure assumed for absolute stack pressure (facility is approximately at sea level w/in 100 ft). NO₂ molecular weight assumed for NO_x (MW = 46).

² Assumes limits with averaging periods of 24 hours or less are comparable (i.e., a daily limit would need to meet a similar value hourly limit most of the time in order to meet the daily limit.)

Table 30. Boise White Wallula Lime Kiln Emission Reductions								
Lime Kiln Pollutant (units)	Potential RACT Limit (source)	Proposed Limit Avg Time	Current Permit Limit	Measured/Calculated Emissions	Annual Emission Averages (tons)			Notes
					NO _x	SO ₂	PM	
					59	3	48	
					Estimated Reductions (tpy)			
PM (gr/dscf at 10% O ₂)	0.02 (Europe BAT: oil or ng)	24-hr	0.064	0.047	---	---	28	1,2
PM (gr/dscf at 10% O ₂)	0.030 (lowest WA limit: oil or ng)	1-hr	0.064	0.047	---	---	18	1,2
SO ₂ (ppm at 10% O ₂)	20 (lowest WA limit w/or w/o NCG)	3-hr	5/yr; 19 lb/day	2.4	---	0	---	1,2
SO ₂ (ppm at 10% O ₂)	105 (Europe BAT: w/NCG)	24-hr	5/yr; 19 lb/day	2.4	---	0	---	1,2
NO _x (ppm at 10% O ₂)	77 (Europe BAT: oil)	24-hr	No limit	67	0	---	---	1,2
NO _x (ppm at 10% O ₂)	275 (lowest WA limit: oil or ng)	24-hr	No limit	67	0	---	---	1,2
NO _x (ppm at 10% O ₂)	292 (Europe BAT: ng)	24-hr	No limit	67	0	---	---	1,2

Notes: LK = lime kiln. --- = not applicable. Ng = natural gas. NCG = non condensable gas incineration.

¹ Measured/calculated emissions are averages of 2005-2012 compliance tests or are calculated from 2005-2011 annual emission averages and other stack parameter information. Sea level pressure assumed for absolute stack pressure (facility is approximately at sea level w/in 100 ft). NO₂ molecular weight assumed for NO_x (MW = 46).

² Assumes limits with averaging periods of 24 hours or less are comparable (i.e., a daily limit would need to meet a similar value hourly limit most of the time in order to meet the daily limit.)

4.1.7. Cosmo estimated emission reductions

Cosmo is located in Cosmopolis, WA, and operates a sulfite recovery furnace. The sulfite mill process does not include the use of lime kilns. Emissions and estimated emission reductions are presented in Table 31.

Table 31. Cosmo Recovery Furnace Emission Reductions								
Recovery Furnace Pollutant (units)	Potential RACT Limit (source)	Proposed Limit Avg Time	Current Permit Limit	Measured/ Calculated Emissions	Annual Emission Averages (tons)			Notes
					NO _x	SO ₂	PM	
					348	169	195	
					Estimated Reductions (tpy)			
PM (gr/dscf at 8% O ₂)	0.0165 (lowest w/in BAT)	1-hr	0.10	0.054	---	---	135	(1),(2),(3)
PM (gr/dscf at 8% O ₂)	0.008 (Europe sulfite BAT)	24-hr	0.10	0.054	---	---	166	(1),(2),(3)
PM (gr/dscf at 8% O ₂)	0.027 (lowest WA limit)	1-hr	0.10	0.054	---	---	97	(1),(2),(3)
SO ₂ (ppm at 8% O ₂)	10 (lowest WA limit w/Whr)	24-hr	360	308	---	164	---	(1),(2),(3)
SO ₂ (ppm at 8% O ₂)	49 (Europe sulfite BAT: No Whr)	24-hr	360	308	---	142	---	(1),(2),(3)
SO ₂ (ppm at 8% O ₂)	75 (lowest WA limit: No Whr)	3-hr	360	308	---	128	---	(1),(2),(3)
NO _x (ppm at 8% O ₂)	137 (Europe sulfite BAT)	24-hr	No limit	86	0	---	---	(1),(2),(3)
NO _x (ppm at 8% O ₂)	95 (lowest WA limit)	3-hr	No limit	86	0	---	---	(1),(2),(3)

Notes: RF = recovery furnace. --- = not applicable. Ng = natural gas. NCG = non condensable gas incineration. Whr = wet heat recovery.

(1) Measured/calculated emissions are averages of 2011-2012 compliance tests or are calculated from emission inventory data. Because the facility did not operate from 2007 through 2010, emission inventories from 2005, 2006 and 2011 were evaluated and 2011 annual emissions were chosen for this evaluation. Sea level pressure assumed for absolute stack pressure (facility is approximately at sea level). NO₂ molecular weight assumed for NO_x (MW = 46).

(2) Assumes limits with averaging periods of 24 hours or less are comparable (i.e., a daily limit would need to meet a similar value hourly limit most of the time in order to meet the daily limit).

(3) Cosmo is currently the only sulfite mill in WA. Emission limits are compared between sulfate (kraft) mills and this sulfite mill, even though they are different processes. Sulfite mill BAT values were used where noted.

4.1.8. Graymont estimated emission reductions

Graymont is located in Tacoma, WA, and operates a calcining lime kiln. Emissions and estimated emission reductions are presented in Table 32.

Table 32. Graymont Calcining Lime Kiln (CLK) Emission Reductions								
Lime Kiln Pollutant (units)	Potential RACT Limit (source)	Proposed Limit Avg Time	Current Permit Limit	Measured/ Calculated Emissions	Annual Emission Averages (tons)			Notes
					NO _x	SO ₂	PM	
					56	9	63	
					Estimated Reductions (tpy)			
PM (gr/dscf at 10% O ₂)	0.02 (Europe BAT for any fuel)	24-hr	0.05	0.012	---	---	0	(1),(2),(3)
PM (gr/dscf at 10% O ₂)	0.030 (lowest WA limit for ng)	1-hr	0.05	0.012	---	---	0	(1),(2),(3)
SO ₂ (ppm at 10% O ₂)	8 (Europe BAT w/o NCG)	24-hr	1000	12	---	3	---	(1),(2),(3)
SO ₂ (ppm at 10% O ₂)	20 (lowest WA limit w/or w/o NCG)	3-hr	1000	12	---	0	---	(1),(2),(3)
NO _x (ppm at 10% O ₂)	275 (lowest WA limit: oil or ng)	24-hr	No limit	107	0	---	---	(1),(2),(3)
NO _x (ppm at 10% O ₂)	292 (Europe BAT: ng)	24-hr	No limit	107	0	---	---	(1),(2),(3)

Notes: LK = lime kiln. --- = not applicable. Ng = natural gas. NCG = non condensable gas incineration.

(1) Listed emissions are averages of, or calculated from, 2009 & 2011 compliance tests and 2006-2012 emission inventory emissions and other stack parameter information. Based on information from the Puget Sound Clean Air Agency (PSCAA), coal was the primary fuel for most of these years until approximately 2010. Ng was used in 2011-2012. Sea level pressure assumed for absolute stack pressure (facility is approximately at sea level). NO₂ molecular weight assumed for NO_x (MW = 46).

(2) Assumes limits with averaging periods of 24 hours or less are comparable (i.e., a daily limit would need to meet a similar value hourly limit most of the time in order to meet the daily limit).

(3) Ecology could not find information indicating that the Graymont kiln performs incineration of NCG. Based on information from PSCAA, coal was the primary fuel used for the Graymont lime kiln for most of 2006 through 2010. Ng was used in 2011-2012. PSCAA permit statement of basis indicates the kiln can burn coal or ng. Oil is not listed as fuel source for the kiln.

4.2. Estimated emission reductions for recovery furnaces achievable (cumulative data)

Table 33. Tons of Potential Pollutant Reduction Based on Proposed RACT Limit Options for Recovery Furnaces								
Pollutant/ Avg Period:	PM 1-hr	PM 1-hr	PM 1-hr	SO ₂ 24-hr ¹	SO ₂ 24-hr	SO ₂ 3-hr	NO _x 24-hr	NO _x 3-hr
Proposed RACT Limit for Recovery Furnace:	0.0165 gr/dscf at 8% O₂ (basis: BAT; sulfite BAT = 0.008 gr/dscf)	0.019 gr/dscf at 8% O₂ (basis: BAT; sulfite BAT = 0.008 gr/dscf)	0.027 gr/dscf at 8% O₂ (basis: WA)	10 ppm at 8% O₂ (basis: GP WA = w/in BAT)	18 ppm at 8% O₂ (basis: BAT; sulfite BAT = 49 ppm)	75 ppm at 8% O₂ (basis: lowest WA w/o Whr)	58 ppm at 8% O₂ (basis: BAT; sulfite BAT = 137 ppm)	95 ppm at 8% O₂ (basis: WA)
Boise White Wallula No. 3	0	0	0	395	314	0	14	0
Boise White Wallula No. 2	0	0	0	277	264	167	0	0
WestRock No. 4	0	0	0	273	263	189	0	0
Cosmo (1, 2,& 3)	135	166	97	164	142	128	0	0
PTPC RF	45	34	0	67	37	0	0	0
Weyerhaeuser No. 10	0	0	0	0	0	0	78	0
GP Camas No. 4	11	3	0	0	0	0	42	0
GP Camas No. 3	0	0	0	0	0	0	0	0
KapStone RF22	0	0	0	53	47	8	32	0
KapStone RF19	0	0	0	11	6	0	8	0
KapStone RF18	0	0	0	8	5	0	0	0
Total	191	203	97	1248	1078	491	176	0

Notes: RF = recovery furnace. Whr = wet heat recovery

¹ Based on GP Camas RF Nos. 3 and 4, which have wet heat recovery systems.




Figure 2. Estimated potential PM emission reductions for recovery furnaces




Figure 3. Estimated potential SO₂ emission reductions for recovery furnaces




Figure 4. Estimated potential NO_x emission reductions for recovery furnaces

4.3. Estimated emission reductions for lime kilns achievable (cumulative data)

Pollutant/ Avg Period:	PM (ng or oil) 24-hr	PM (ng or oil) 24-hr	SO ₂ (w/o NCG) 24-hr	SO ₂ (w/or w/o NCG) 3-hr	SO ₂ (w/NCG) 24-hr	NO _x (oil) 24-hr	NO _x (ng or oil) 24-hr	NO _x (gas) 24-hr
Proposed RACT Limit for Lime Kiln:	0.02 gr/dscf at 10% O ₂ (basis: BAT (ng or oil))	0.030 gr/dscf at 10% O ₂ (basis: WA)	8 ppm at 10% O ₂ (basis: BAT w/o NCG)	20 ppm at 10% O ₂ (basis: GP WA = w/in BAT w/or w/o NCG)	105 ppm at 10% O ₂ (basis: BAT w/NCG)	77 ppm at 10% O ₂ (basis: BAT (oil))	275 ppm at 10% O ₂ (basis: WA w/oil or ng)	292 ppm at 10% O ₂ (basis: BAT (ng))
Boise White Wallula LK ⁽¹⁾	28	18	N/A	0	0	0	0	0
WestRock No. 1 ⁽¹⁾	9	2	N/A	3	0	0	0	0
WestRock No. 2 ⁽¹⁾	3	1	N/A	1	0	0	0	0
PTPC LK ⁽²⁾	10	4	N/A	0	0	2	0	N/A
Weyerhaeuser No. 4 ⁽¹⁾	0	0	N/A	0	0	65	0	0
GP Camas No. 4 ⁽³⁾	1	0	N/A	0	0	N/A ⁽³⁾	25	20
KapStone LK3 ⁽¹⁾	0	0	N/A	0	0	2	0	0
KapStone LK4 ⁽¹⁾	0	0	N/A	0	0	21	0	0
KapStone LK5 ⁽¹⁾	0	0	N/A	0	0	9	0	0
Graymont CLK No. 1 ⁽⁴⁾	0	0	3	0	N/A ⁽⁵⁾	N/A ⁽⁴⁾	0	0
Total	51	25	3	4	0	99	25	20

Notes: LK = lime kiln. N/A = not applicable or information not available or not found. NCG = non condensable gas incineration.

⁽¹⁾ Ecology found information indicating that the facility has the capability to burn oil or gas in the Lime Kilns.

⁽²⁾ The LK at PTPC burns oil exclusively.

⁽³⁾ The LK (No. 4) at GP Camas does not burn oil. The fuel oil burner was decommissioned in early 2011.

⁽⁴⁾ Based on information from PSCAA, coal was the primary fuel used for the Graymont lime kiln for most of 2006 through 2010. Natural gas was used in 2011-2012. PSCAA permit statement of basis indicates the kiln can burn coal or natural gas. Oil is not listed as fuel source for the kiln.

⁽⁵⁾ Ecology could not find information indicating that the Graymont kiln performs incineration of NCG.




Figure 5. Estimated potential PM emission reductions for lime kilns




Figure 6. Estimated potential SO₂ emission reductions for lime kilns




Figure 7. Estimated potential NO_x emission reductions for lime kilns

4.4. Discussion of estimated potential emission reductions

This section discusses the potential of adopting the various emission levels presented in Sections 4.1–4.3. An evaluation of the potential actual emissions reductions possible if the option were to be implemented is given based on the calculations presented in Sections 4.2 and 4.3.

4.4.1. Discussion of estimated potential emission reductions for recovery furnaces

Based on the estimated potential emission reductions summarized in Sections 4.2 and 4.3, Ecology makes the following observations regarding the benefits of adopting these limits, and if further consideration is warranted:

- PM:
 - According to Table 6, an HERB unit RF (No. 3), at the International Paper CAMTI facility in Louisiana, achieves an emission limit of 0.015 gr/dscf (at 8% O₂), which is

within European BAT ranges. Implementing the HERB process on an existing recovery furnace would be a significant reconstruction of the furnace. There are currently no HERB units in Washington State and the technology is not considered further.

- The other U.S. facility in Table 6 with emissions within European BAT ranges uses an ESP. According to Table 33 (and Figure 2), the potential benefit of adopting an emission limit of 0.0165 grains/dscf (at 8% O₂) would provide an estimated 191 tpy of pollutant reduction. This limit is based on the use of an ESP with eight fields online versus the more common ESP configuration with two or three fields online. The facility with this control technology implemented it as part of a MACT cumulative emission rate limit alternative covering three emission units (recovery boiler, lime kiln, smelt dissolving tank) as described in 40 CFR 862(a)(1). No recovery furnace controlled by an 8-field ESP is currently operating in Washington State.
- According to Table 33 (and Figure 2), adopting an emission limit of 0.019 grains/dscf (at 8% O₂) would provide an estimated 203 tpy of pollutant reduction. This limit is the upper limit range of the European BAT PM limits for recovery furnaces. [Note: a sulfite BACT limit of 0.008 grains/dscf (at 8% O₂) was used for emission reductions estimates for Washington's sulfite mill (Cosmo)].
- According to Table 33 (and Figure 2), the potential benefit of adopting an emission limit of 0.027 grains/dscf (at 8% O₂) would provide an estimated 97 tpy of PM reduction. This limit is currently demonstrated at three recovery furnaces in Washington State. This limit and control technology can be considered reasonable to adopt for the other recovery furnaces in Washington. This limit is considered for further analysis.
- SO₂:
 - According to Table 33 (and Figure 3), the potential benefit of adopting an emission limit of 10 ppm (at 8% O₂), would provide an estimated 1,248 tpy of pollutant reduction, primarily from one facility. The potential pollutant reductions achievable from adopting this limit, provides the greatest estimated pollutant reduction for the proposed recovery furnaces emission limits in Table 33. Based on the potential benefit of implementing this limit, and because this limit has already been demonstrated at two recovery furnaces in Washington State, this limit is considered for further analysis.
 - According to Table 33 (and Figure 3), the potential benefit of adopting an emission limit of 18 ppm (at 8% O₂), would provide an estimated 1,078 tpy of pollutant reduction. This limit is the upper limit range of the European BAT SO₂ limits for recovery furnaces. [Note: a sulfite BAT limit of 49 ppm (at 8% O₂) was used for emission reductions estimates for Washington's sulfite mill (Cosmo)]. These BAT limits have not been, but could be implemented in Washington State.
 - According to Table 33 (and Figure 3), the potential benefit of adopting an emission limit of 75 ppm (at 8% O₂), would provide an estimated 491 TPY of pollutant reduction. Based on the potential benefit of implementing this limit, and because this

limit has already been demonstrated at a recovery furnace in Washington State, this limit is considered for further analysis.

- NO_x:
 - According to Table 33 (and Figure 4), the potential benefit of adopting an emission limit of 58 ppm (at 8% O₂), would provide an estimated 176 TPY of pollutant reduction. This limit is the upper limit range of the European BAT NO_x limits for recovery furnaces. [Note: a sulfite BAT limit of 137 ppm (at 8% O₂) was used for emission reductions estimates for Washington's sulfite mill (Cosmo)]. These BAT limits have not been implemented in Washington State.
 - According to Table 33 (and Figure 4), the potential benefit of adopting an emission limit of 95 ppm (at 8% O₂), would not provide pollutant reductions based on how recovery furnaces in Washington operated their units during the emission inventory evaluated as part of this analysis. However, adopting this limit could lower the potential to emit levels at some of these facilities, and therefore could be considered for further analysis. This limit has been implemented at three recovery furnaces in Washington State with limit averaging periods of three to 24 hours.

4.4.2. Discussion of estimated potential emission reductions for lime kilns

Based on the estimated potential emission reductions presented in this chapter, Ecology makes the following observations regarding the benefits of adopting these limits, and if further consideration is warranted:

- PM:
 - According to Table 34 (and Figure 5), the potential benefit of adopting an emission limit of 0.02 grains/dscf (at 10% O₂) would provide an estimated 51 TPY of pollutant reduction. This limit is the upper limit range of the European BAT PM limits for lime kilns. This specific limit has not been implemented in Washington State.
 - According to Table 34 (and Figure 5), the potential benefit of adopting an emission limit of 0.030 grains/dscf (at 10% O₂) would provide an estimated 25 TPY of pollutant reduction. This limit has been implemented at two lime kilns in Washington State. Adopting this limit could lower the potential to emit levels at other lime kilns in Washington State, and therefore could be considered for further analysis.
- SO₂:
 - According to Table 34 (and Figure 6), the potential benefit of adopting an emission limit of 8 ppm (at 10% O₂) would provide an estimated 3 TPY of pollutant reduction. This limit is the upper limit range of the European BAT PM limits for lime kilns that do not incinerate NCGs. This specific limit has not been implemented in Washington State.
 - According to Table 34 (and Figure 6), the potential benefit of adopting an emission limit of 20 ppm (at 10% O₂) would provide an estimated 4 TPY of pollutant

reduction. This limit has been implemented at three lime kilns in Washington State, and is therefore considered for further analysis.

- According to Table 34 (and Figure 6), the potential benefit of adopting an emission limit of 105 ppm (at 10% O₂) would not provide pollutant reductions based on how lime kilns in Washington operated their units during the emission inventory evaluated as part of this analysis.
- NO_x:
 - According to Table 34 (and Figure 7), the potential benefit of adopting an emission limit of 77 ppm (at 10% O₂), would provide an estimated 99 TPY of pollutant reduction. This limit is the upper limit range of the European BAT NO_x limits for lime kilns that use fuel oil. This specific limit has not been implemented in Washington State.
 - According to Table 34 (and Figure 7), the potential benefit of adopting an emission limit of 275 ppm (at 10% O₂), would provide an estimated 25 TPY of pollutant reduction. This limit has been implemented at one lime kiln in Washington State, which can use either oil or natural gas fuel. Adopting this limit could lower the potential to emit levels at other lime kilns in Washington State, and therefore could be considered for further analysis.
 - According to Table 34 (and Figure 7), the potential benefit of adopting an emission limit of 292 ppm (at 10% O₂), would provide an estimated 20 TPY of pollutant reduction. This limit is the upper limit range of the European BAT NO_x limits for lime kilns that use natural gas. Not all lime kilns in Washington have access to natural gas. This specific limit has not been implemented in Washington State.

5. Impacts of Controls on Visibility

The impacts of additional controls are presented in the following subsections. A previous similar study (BART modeling analysis) is included below in Section 5.1 as background information, as it was used in the 2010 RH SIP. Section 5.2 concludes with more current impacts analysis modeling results using the emission reduction estimates in Section 4 of this analysis.

5.1. Impacts of pulp and paper mills on visibility (BART modeling analysis)

This section addresses the impact of pulp and paper mill sources upon visibility in Class I areas in Washington State. Details describing how visibility is measured using units of *dv* was provided in the RH SIP.

Available visibility modeling results from Chapter 11 of the RHSIP BART analysis, performed for five of the seven pulp mills, is provided in Table 35. The other facilities evaluated and modeled for this RACT review did not meet one or more of the technical criteria to require

BART modeling. The values in Table 35 are the 22nd highest (98th percentile) delta Δv and are based on 2003-2005 emissions using the CALPUFF model as described in the BART modeling protocol in Appendix H of the 2010 RH SIP. The results include BART-eligible units at each individual facility and are not necessarily recovery furnaces and/or lime kilns.

As explained in Appendix H of the 2010 RH SIP, the BART modeling protocol including two types of modeling analysis:

- BART Exemption Analysis: to ascertain BART eligible sources, and,
- BART Determination Analysis: to determine visibility impacts for the pre-BART control and post-BART control scenarios on individual BART-eligible units at individual (BART-eligible) sources. (Note: a BART-eligible source refers to the entire facility that has BART-eligible emission units).

The results in Table 35 are from the BART Determination Analysis contained in the RH SIP.

WA Class I Areas (unless indicated otherwise)	GP Camas⁽¹⁾	KapStone⁽¹⁾	PTPC	WestRock	Weyerhaeuser	Boise White Wallula⁽²⁾	Cosmo⁽³⁾
Alpine Lakes Wilderness	0.071	0.21	0.284	0.391	0.4	Not modeled	Not modeled
Glacier Peak Wilderness	0.045	0.128	0.251	0.256	0.248	Not modeled	Not modeled
Goat Rocks Wilderness	0.101	0.228	0.137	0.21	0.457	Not modeled	Not modeled
Mt. Adams Wilderness	0.123	0.251	0.124	0.205	0.44	Not modeled	Not modeled
Mt. Rainier National Park	0.101	0.3	0.244	0.441	0.595	Not modeled	Not modeled
North Cascades National Park	N/A	0.111	0.236	0.22	0.218	Not modeled	Not modeled
Olympic National Park	0.086	0.29	1.306 ⁽⁴⁾	0.383	0.583	Not Modeled	Not Modeled
Pasayten Wilderness	N/A	N/A	0.125	0.126	NA	Not Modeled	Not Modeled
Columbia River Gorge (Class II)	2.469	0.517	0.06	0.082	0.675	Not Modeled	Not Modeled
Mt. Hood (Oregon)	0.381	0.43	N/A	0.147	0.689	Not Modeled	Not Modeled
Mount Jefferson Wilderness (Oregon)	0.149	0.219	N/A	0.092	0.367	Not Modeled	Not Modeled
Diamond Peak Wilderness Area (Oregon)	0.044	0.115	N/A	N/A	0.192	Not Modeled	Not Modeled

WA Class I Areas (unless indicated otherwise)	GP Camas⁽¹⁾	KapStone⁽¹⁾	PTPC	WestRock	Weyerhaeuser	Boise White Wallula⁽²⁾	Cosmo⁽³⁾
Mount Washington Wilderness Area (Oregon)	0.084	0.169	N/A	N/A	0.289	Not Modeled	Not Modeled
Three Sisters Wilderness Area (Oregon)	0.087	0.178	N/A	N/A	0.291	Not Modeled	Not Modeled
Eagle Cap Wilderness (Oregon)	N/A	N/A	N/A	N/A	N/A	Not Modeled	Not Modeled
Crater Lake National Park (Oregon)	0.031	N/A	N/A	N/A	N/A	Not Modeled	Not Modeled
Strawberry Mountain Wilderness (Oregon)	0.044	N/A	N/A	N/A	N/A	Not Modeled	Not Modeled
Hells Canyon (Idaho)	N/A	N/A	N/A	N/A	N/A	Not Modeled	Not Modeled

(1) Visibility reduction values are based on a spatially-varying O₃ background modeling input.
(2) No BART-eligible equipment based on age and PTE.
(3) Sulfite pulp mills exempt from BART.
(4) Port Townsend used the NH₃-limiting method to model impacts at Olympic NP. Their use of the new IMPROVE equation was undone by Ecology and impacts recalculated. See Table 11-9 of Regional Haze SIP page 11-11.

5.2. Impacts of pulp and paper mills on visibility (RACT modeling analysis)

As with the BART analysis, modeling was used to determine potential improvements in RH based on the proposed RACT options described in this section. However, modeling for this RACT analysis was not bound to the procedures described in the BART modeling protocol in Appendix H of the 2010 RH SIP. Whereas the CALPUFF model was chosen as part of the protocol developed for the BART analysis, a different modeling approach was used for this RACT analysis. Ecology contracted with Washington State University (WSU) for the modeling portion of this analysis. See Appendix C for the full WSU RACT modeling protocol.

The pre-RACT baseline and post-RACT limit control results of the WSU modeling are based on the following:

- For the pre-RACT baseline analysis: a baseline emission inventory using emissions from the year 2007 based on an aggregation of emissions from a comprehensive list of emitting facilities in Washington State (not just pulp mills).
- Post-RACT:¹ Based on Table 33, Figures 2 and 3, and Section 4.4.1, the following maximum potential emission reductions using the lowest demonstrated limits in Washington State were used in this first post-RACT scenario:
 - For recovery furnaces, the lowest SO₂ emission limit demonstrated in Washington State is 10 ppm.
 - For recovery furnaces, the lowest PM emission limit demonstrated in Washington State is 0.027 gr/dscf @ 8% O₂.

Recovery furnace NO_x emission reductions and lime kiln emission reductions for SO₂, PM, and NO_x were estimated to be considerably less than these two emission reductions and, therefore, were set aside as part of potential future post-RACT modeling scenarios depending on the results of the first post-RACT modeling scenario (see Section 5.2.2).

As detailed in Chapter 4, measured or calculated emissions are averages of multi-year compliance tests or are calculated from averages of multi-year emission inventory emissions and other stack parameter information. Estimated emission reductions are the difference between average annual emissions and the average annual emissions multiplied by the ratio of emission at the proposed RACT limit to measured or calculated emission. Ecology’s approach is based on a survey of average emission reductions using average emission inventory emissions from multiple years, so that average individual unit percent reductions are assumed to be applicable to approximately any given year that the facility operated around this timeframe.

As noted in Appendix C, emissions for modeling were taken from 2007 inventories provided by state agencies via NW-AIRQUEST. All of the facilities’ multi-year emission inventory emissions that were averaged include the year 2007, except for Cosmo Specialty Fiber. Because the facility did not operate from 2007 through 2010, emission inventories from 2005, 2006, and 2011 were evaluated, and 2011 annual emissions were chosen for this evaluation.

5.2.1. Modeling results

The RACT visibility modeling results from the 2014-2015 WSU RH modeling analysis are provided in Table 36 (See Appendix C for additional WSU RACT modeling results).

WA Class I Areas (unless indicated otherwise)	Δdv Visibility Impacts due to Potential RACT Limit
Alpine Lakes Wilderness	0.127
Glacier Peak Wilderness	0.117
North Cascades National Park	0.080

¹ For the first post-RACT analysis, specific pulp mill emission reduction estimates developed in Chapters 2-4 were used, which were based on measured (compliance test) data only, not on calculated data.

Table 36. Visibility Modeling Results: 8th Highest Delta dv, (98th Percentile)	
WA Class I Areas (unless indicated otherwise)	Δdv Visibility Impacts due to Potential RACT Limit
Mount Baker Wilderness	0.057
Selway Bitterroot Wilderness (Idaho, Montana)	0.053
Spokane Tribe Class I area	0.053
Pasayten Wilderness	0.045
Three Sisters Wilderness Area (Oregon)	0.044
Mount Washington Wilderness Area (Oregon)	0.041
Goat Rocks Wilderness	0.038
Mt. Rainier National Park	0.037
Hells Canyon Wilderness (Idaho)	0.033
Mount Jefferson Wilderness (Oregon)	0.031
Eagle Cap Wilderness (Oregon)	0.030
Mount Adams Wilderness	0.030
Columbia River Gorge (WA & Oregon) (Class II)	0.029
Olympic National Park	0.023
Mt. Hood Wilderness (Oregon)	0.022
Sawtooth Wilderness (Idaho)	0.021
Diamond Peak Wilderness Area (Oregon)	0.018
Crater Lake National Park (Oregon)	0.017
Yellowstone National Park (Wyoming)	0.016
Strawberry Mountain Wilderness (Oregon)	0.015
Craters of the Moon National Park (Idaho)	0.011
Mountain Lakes Wilderness (Oregon)	0.009
Craters of the Moon National Park (Idaho)	0.011
Mountain Lakes Wilderness (Oregon)	0.009

The locations with the top three delta dv benefit are Alpine Lakes (0.127), Glacier Peak (0.117), and North Cascades (0.080). The modeled visibility data listed is for grid cells where at least half of the area of the cell was within any Class I wilderness area or national park (or Columbia River Gorge scenic area). In other words, these are the highest grid cell delta dv values. The rest of these areas, including their IMPROVE monitoring locations (if present) have less delta dv benefit. For example, the IMPROVE monitoring site at North Cascades National Park has an 8th highest delta dv benefit of only 0.0136, or about 1/6 the benefit of the grid cell of maximum delta dv benefit (0.080) listed in Table 36.

5.2.2. Additional modeling scenarios

Because the results obtained from the first post-RACT modeling analysis described in Sections 5.2 and 5.2.1 do not show sufficient delta dv benefit (less than 0.13 dv impacts at highest modeled grid cell), Ecology determined that additional post-RACT modeling scenarios using smaller RACT limited emission reductions would not be useful.

6. Estimated Costs

This chapter presents the estimated costs for facilities in Washington to achieve the emission reductions presented in Chapter 4.

Ecology is interpreting “reasonably available” control technology as defined in Section 1.2, to mean the best performing control technologies that are currently demonstrating compliance with the emission limits in Sections 3.1–3.3. There may be other control technologies listed in Chapter 2, which are capable of meeting the emission rates and estimated emission reductions presented in Chapter 4, which have not been demonstrated in practice. We have only estimated costs to implement control technologies that have been demonstrated in practice.

Prior to implementing a RACT limit, Ecology intended to work closely with the source category sources to develop a more accurate cost evaluation.² As the visibility improvement modeling presented in Chapter 5 and Appendix C shows minimal visibility improvement, Ecology does not believe that it is necessary to develop mill specific cost estimates for implementing the evaluated RACT limits. However, Ecology is providing the following general estimates of costs based on the cost references listed in Section 6.1.

6.1. Capital and operating costs

Estimated costs to implement control technologies that have been demonstrated in practice are presented in Tables 37 and 38 for recovery furnaces and lime kilns, respectively.

Control Technology Option	Capital Costs (\$) [O&M Costs if Available]	Total Annual Costs (\$)	Note(s)
HERB (PM, SO ₂ , NO _x)	100 to ~300 million (250 million Euro)	12–22 million	1,2,,8
Add scrubber to ESP (PM, SO ₂)	12 million	3–9 million	2,3
WESP (PM)	1.1–13.9 million [0.3–13.9 million]	0.5–16.3 million	4
Good Operating Practices (SO ₂)	Currently used		
Staged combustion control [may include FGR, low excess air, overfire air, LNB, secondary, tertiary, quaternary combustion] (NO _x)	Currently used		
Improve and/or rebuild ESP (PM)	Using ESP improvements, the BART analysis [August 2009-Appendix L] of the Ecology 2010 Regional Haze SIP for PTPC estimated a 53 ton per year reduction at \$5,100 per ton. A similar BART analysis for Weyerhaeuser estimated a 33 ton per year reduction at \$122,000 per ton if an additional ESP field was installed.		2,5,6

² Ecology memorandum: *The Five RACT Criteria and how Ecology Should Implement Them*, Wayne Wooster, June 14, 1993.

Table 37. Recovery Furnace Estimated Control Costs			
Control Technology Option	Capital Costs (\$) [O&M Costs if Available]	Total Annual Costs (\$)	Note(s)
	The total installed cost for a typical ESP rebuild from reference (5) was 5.7 million.		
Recovery boiler optimization [including wet heat recovery/secondary, tertiary, quaternary air /HVLC gas incineration] (PM, SO ₂ , NO _x)	The Kotka Mill in Finland recently (2013) invested 3 million euros (\$3.8 million) into boiler optimization for its recovery boiler. Improvements include renewing the bottom of the boiler and implementing new air distribution technology.		1
	Wet heat recovery has been demonstrated at GP Camas for its two RFs. Costs specific to the wet heat recovery portion of the recovery furnaces is difficult to isolate, but appears to have been part of an overall recovery furnace and smelt dissolver vent recovery modernization project with estimates as follows: <ul style="list-style-type: none"> • \$2.7 million ESP with total annual costs of \$417,750; • \$1.7 million Cross-flow scrubber with total annual costs of \$419,800; • \$175,000 Packed bed scrubber with total annual costs of \$224,300. 		7
Fabric filters-baghouse (PM)	This technology has not been demonstrated in practice at the mills surveyed in Chapter 3 (due to technical or economic infeasibilities). Costs are not considered.		
Cyclone separator (PM)	This technology has not been demonstrated in practice at the mills surveyed in Chapter 3 (due to technical or economic infeasibilities). Costs are not considered.		
Electrified gravel bed filters (PM)	This technology has not been demonstrated in practice at the mills surveyed in Chapter 3 (due to technical or economic infeasibilities). Costs are not considered.		
Flue gas desulfurization (FGD) w/wet scrubber (SO ₂)	This technology has not been demonstrated in practice at the mills surveyed in Chapter 3 (due to technical or economic infeasibilities). Costs are not considered.		
Semi-dry lime hydrate slurry injection FGD (SO ₂)	This technology has not been demonstrated in practice at the mills surveyed in Chapter 3 (due to technical or economic infeasibilities). Costs are not considered.		
Dry lime powder injection FGD (SO ₂)	This technology has not been demonstrated in practice at the mills surveyed in Chapter 3 (due to technical or economic infeasibilities). Costs are not considered.		
Spray dryer w/an ESP FGD (SO ₂)	This technology has not been demonstrated in practice at the mills surveyed in Chapter 3 (due to technical or economic infeasibilities). Costs are not considered.		
Low sulfur fuel selection (SO ₂)	This technology has not been demonstrated in practice at the mills surveyed in Chapter 3 (due to technical or economic infeasibilities). Costs are not considered.		
Selective non-catalytic reduction (SNCR) [NO _x]	This technology has not been demonstrated in practice at the mills surveyed in Chapter 3 (due to technical or economic infeasibilities). Costs are not considered.		
Selective catalytic reduction (SCR) [NO _x]	This technology has not been demonstrated in practice at the mills surveyed in Chapter 3 (due to technical or economic infeasibilities). Costs are not considered.		
Oxidation/reduction scrubbing (NO _x)	This technology has not been demonstrated in practice at the mills surveyed in Chapter 3 (due to technical or economic infeasibilities). Costs are not considered.		

Table 37. Recovery Furnace Estimated Control Costs

Control Technology Option	Capital Costs (\$) [O&M Costs if Available]	Total Annual Costs (\$)	Note(s)
			<p>¹ HERB annualized cost based on Andritz Pulp & Paper. Recovery boilers Chemical recovery and green energy. The Andritz solution: High Energy Recovery Boiler (HERB). www.andritz.com Annual costs based on high energy boiler costs ranging from 80 to 150 million Euros converted to USD at \$1.25/Euro: (approximate average of \$/Euro from 2011 – 2015). Higher end costs of 250 million Euro found for Iggesund Paperboard’s Swedish paperboard mill Published: Thu, 2014-06-19 10:07 www.pulpapernews.com). Other references: June/July 2007 Enviro-Friendly. Acuna & Associates webpages. www.pulpapernews.com article dated June 13, 2012. www.pressportal.ch press webpage regarding Andritz. Boiler improvement information from www.pulpapernews.com article dated November 9, 2012. At least three HERB units have been or are installed in the United States per Andritz Pulp & Paper www.andritz.com. The three units are IP Valliant, Oklahoma; IP Campti, Louisiana; and PCA, Valdosta, Georgia. It is unclear if the Oklahoma and Georgia units have been included into their latest air permits at the time of this analysis. The Campti unit has been implemented, and permit limits for this facility are listed in chapter 3.</p> <p>² Cost estimates are based on the assumption that the listed control option is able to reduce emissions to the emission levels of facilities currently using those technologies. However, unknown facility details and variable costs from different vendors could have a significant effect on estimated control technology costs.</p> <p>³ Based on Ecology BART analysis [August 2009 (Appendix L of 2010 Regional Haze SIP) for PTPC, estimated annualized costs were approximately: \$8.5 million (\$20,383/ton) and for Weyerhaeuser, (annualized costs were approximately: 3.3 million (\$28,000/ton). Total costs (including installation) for retrofitting a recovery furnace ESP with a scrubber are listed in a 1/31/2007 EPA document as approximately \$12 million (letter from EPA addressed to Division of Air Quality, North Carolina Department of Environment and Natural Resources). .</p> <p>⁴ WESP costs obtained from EPA-452/F-03-030 Air Pollution Control Technology Fact Sheet based on capital costs of \$20-\$40 per scfm; O&M costs of \$5-40 per scfm; annualized costs of \$9-\$47 per scfm; applied to each average scfm flow rate calculated from average dscfm flow rates and average water content for each facility. See Appendix D.</p> <p>⁵ The total installed cost estimates for base and most advanced ESP designs ranged from \$9.6 to \$12.2 million (“Advanced ESP Designs for Black Liquor Recovery Boilers”, Grieco., et al other, August 12, 2012. Griego indicated costs of \$5.7 million for an assumed typical ESP rebuild. However, the PM reductions under this scenario would be less (based on 0.039 gr/dscf at 8% oxygen) than what was considered for this RACT analysis (based on 0.027 gr/dscf at 8% oxygen).</p> <p>⁶ Annualized costs based on Ecology BART analysis [August 2009 (Appendix L of 2010 Regional Haze SIP) for Port of Port Townsend (\$270,000) and Weyerhaeuser (\$4,000,000) mills.</p> <p>⁷ Letter to Alan Butler, Ecology from Candice Hatch, CH2M Hill., Camas Mill (GP Camas) Energy and Recovery Modernization PSD Permit Application., October 7, 1988, as part of Telecopy Transmittal from Alan Butler to Bill Powers dated April 6, 1989.</p> <p>⁸ Cosmo is currently the only sulfite mill operating in Washington. Pollutant reductions are based on emission limit comparisons between sulfate (kraft) and sulfite mills which are different processes.</p>

Table 38. Lime Kiln Estimated Control Costs			
Control Technology Option	Capital Costs (\$) [O&M Costs if Available]	Total Annual Costs (\$)	Note(s)
New scrubber or add scrubber after existing lime kiln ESP if present (PM, SO ₂)	12 million		1,2,5
Add WESP (PM)	0.2–2.6 million [0.04–2.6 million]	0.08–3 million	3
Replace scrubber w/WESP (PM)	Estimated BART capital costs of 1.5 million/kiln for replacing a venture scrubber w/a WESP is considered a high capital cost.		4
Replace scrubber w/dry ESP (PM)	Not recommended		4
Fuel selection – use less gas and more oil (NO _x)			5
Low sulfur fuels, low sulfur lime mud (SO ₂)			5
Fabric filters-baghouse (PM)	This technology has not been demonstrated in practice at the mills surveyed in Chapter 3 (due to technical or economic infeasibilities). Costs are not considered.		
Cyclone separator (PM)	This technology has not been demonstrated in practice at the mills surveyed in Chapter 3 (due to technical or economic infeasibilities). Costs are not considered.		
Electrified gravel bed filters (PM)	This technology has not been demonstrated in practice at the mills surveyed in Chapter 3 (due to technical or economic infeasibilities). Costs are not considered.		
Flue gas desulfurization (FGD) w/wet scrubber (SO ₂)	This technology has not been demonstrated in practice at the mills surveyed in Chapter 3 (due to technical or economic infeasibilities). Costs are not considered.		
Semi-dry lime hydrate slurry injection FGD (SO ₂)	This technology has not been demonstrated in practice at the mills surveyed in Chapter 3 (due to technical or economic infeasibilities). Costs are not considered.		
Dry lime powder injection FGD (SO ₂)	This technology has not been demonstrated in practice at the mills surveyed in Chapter 3 (due to technical or economic infeasibilities). Costs are not considered.		
Spray dryer w/an ESP FGD (SO ₂)	This technology has not been demonstrated in practice at the mills surveyed in Chapter 3 (due to technical or economic infeasibilities). Costs are not considered.		
Low sulfur fuel selection (SO ₂)	This technology has not been demonstrated in practice at the mills surveyed in Chapter 3 (due to technical or economic infeasibilities). Costs are not considered.		
Increased oxygen levels at burner (SO ₂)	This technology has not been demonstrated in practice at the mills surveyed in Chapter 3 (due to technical or economic infeasibilities). Costs are not considered.		
Water/steam injection (NO _x)	This technology has not been demonstrated in practice at the mills surveyed in Chapter 3 (due to technical or economic infeasibilities). Costs are not considered.		
Mid-kiln firing (NO _x)	This technology has not been demonstrated in practice at the mills surveyed in Chapter 3 (due to technical or economic infeasibilities). Costs are not considered.		
Mixing air fan (NO _x)	This technology has not been demonstrated in practice at the mills surveyed in Chapter 3 (due to technical or economic infeasibilities). Costs are not considered.		

Table 38. Lime Kiln Estimated Control Costs			
Control Technology Option	Capital Costs (\$) [O&M Costs if Available]	Total Annual Costs (\$)	Note(s)
Selective non-catalytic reduction (SNCR) [NO _x]	This technology has not been demonstrated in practice at the mills surveyed in Chapter 3 (due to technical or economic infeasibilities). Costs are not considered.		
Selective catalytic reduction (SCR) [NO _x]	This technology has not been demonstrated in practice at the mills surveyed in Chapter 3 (due to technical or economic infeasibilities). Costs are not considered.		
Oxidation/reduction scrubbing (NO _x)	This technology has not been demonstrated in practice at the mills surveyed in Chapter 3 (due to technical or economic infeasibilities). Costs are not considered.		
<p>¹ Cost estimates are based on the assumption that the listed control option is able to reduce emissions to the emission levels of facilities currently using those technologies. However, due to unknown facility details and variable costs from different vendors could have significant effect on costs.</p> <p>² Assumes the costs of retrofitting a lime kiln ESP with a scrubber is approximately similar to retrofitting a recovery furnace ESP with a scrubber. Total costs (including installation) for retrofitting a recovery furnace ESP with a scrubber are listed in a 1/31/2007 EPA document as approximately \$12 million (letter from EPA addressed to Division of Air Quality, North Carolina Department of Environment and Natural Resources)</p> <p>³ Wet electrostatic precipitator costs obtained from EPA-452/F-03-030 Air Pollution Control Technology Fact Sheet based on capital costs of \$20-\$40 per scfm; O&M costs of \$5-40 per scfm; annualized costs of \$9-\$47 per scfm; applied to each average scfm flow rate calculated from average dscfm flowrates and average water content for each facility. See Appendix D.</p> <p>⁴ In Maine, the "replacement of the existing venture scrubbers with WESPs would result in high capital costs (\$1.5 million per kiln)." Replacing existing venturi scrubbers with dry ESPs "could increase SO₂ emissions from the lime kilns when compared to use of the venturi scrubbers." In Maine, "the use of the existing venturi scrubbers to control PM₁₀ emissions from... (lime kilns)... represents BART." (73956 Federal Register / Vol. 76, No. 229 / Tuesday, November 29, 2011 / Proposed Rules 40 CFR Part 52 [EPA-R01-OAR-2010-1043; A-1-FRL-9496-5], Approval and Promulgation of Air Quality Implementation Plans; Maine; Regional Haze).</p> <p>⁵ Based on the results of Section 5, specific costs were not pursued for all control options.</p>			

7. Conclusions

An impact of 0.5 dv was considered the minimum visibility impact for a source to be subject to BART. While a potential visibility improvement of 0.5 dv or more would have clearly triggered a more in-depth evaluation of the RACT/Four-Factor reasonable progress factors, the significantly smaller annual visibility improvements that have been modeled were determined to be too small to pursue further at this time. As noted in Section 4, this RACT analysis was based on a snapshot of emission inventories between approximately 2003 and 2011. A conservative approach was used for this RACT analysis so that if specific facility details have changed since 2011, the following conclusions of this analysis are assumed to be the same.

These factors are discussed for each of the seven facilities in the subsections below.

7.1. PTPC conclusions

Based on the modeling results presented in Chapter 5 and Appendix C, Ecology is not proposing that PTPC adopt the potential RACT limits considered in Chapter 4. Ecology believes that the potential visibility improvements are too minimal to justify the cost of implementing these RACT limits. Other RACT requirements are not being considered at this time.

7.2. WestRock conclusions

Based on the modeling results presented in Chapter 5 and Appendix C, Ecology is not proposing that WestRock adopt the potential RACT limits considered Chapter 4. Ecology believes that the potential visibility improvements are too minimal to justify the cost of implementing these RACT limits. Other RACT requirements are not being considered at this time.

7.3. Weyerhaeuser conclusions

Based on the modeling results presented in Chapter 5 and Appendix C, Ecology is not proposing that Weyerhaeuser adopt the potential RACT limits considered Chapter 4. Ecology believes that the potential visibility improvements are too minimal to justify the cost of implementing these RACT limits. Other RACT requirements are not being considered at this time.

7.4. GP Camas conclusions

Based on the modeling results presented in Chapter 5 and Appendix C, Ecology is not proposing that GP Camas adopt the potential RACT limits considered Chapter 4. Ecology believes that the potential visibility improvements are too minimal to justify the cost of implementing these RACT limits. Other RACT requirements are not being considered at this time.

7.5. KapStone conclusions

Based on the modeling results presented in Chapter 5 and Appendix C, Ecology is not proposing that KapStone adopt the potential RACT limits considered in Chapter 4. Ecology believes that the potential visibility improvements are too minimal to justify the cost of implementing these RACT limits. Other RACT requirements are not being considered at this time.

7.6. Boise White Wallula Mill conclusions

Based on the modeling results presented in Chapter 5 and Appendix C, Ecology is not proposing that Boise White Wallula adopt the potential RACT limits considered in Chapter 4. Ecology believes that the potential visibility improvements are too minimal to justify the cost of implementing these RACT limits. Other RACT requirements are not being considered at this time.

7.7. Cosmo specialty fiber mill conclusions

Based on the modeling results presented in Chapter 5 and Appendix C, Ecology is not proposing that Cosmo adopt the potential RACT limits considered in Chapter 4. Ecology believes that the potential visibility improvements are too minimal to justify the cost of implementing these RACT limits. Other RACT requirements are not being considered at this time.

7.8. Graymont lime kiln conclusions

Based on the modeling results presented in Chapter 5 and Appendix C, Ecology is not proposing that the Graymont lime kiln adopt the potential RACT limits considered in Chapter 4. Ecology believes that the potential visibility improvements are too minimal to justify the cost of implementing these RACT limits. Other RACT requirements are not being considered at this time.

Appendices

Appendix A. Unit Conversions and Permit Limit Information

Section A-1 Unit Conversions

Recovery Furnace Particulate Matter Unit Conversions

Location	Facility (RF Unit if specified)	Limit A: gr/dscf (at 8% O2)	Limit B: Daily avg: gr/dscf (at 8% O2)	Flow range (m3/Adt)	mg/dscm (at 8% O2)	mg/dscm (at 6% O2)	mg/Nm3 (at5%O2)	kg TSP/ ADt	m3/min
Europe	LCPDs ^b : low range	NA	0.011	7000-9000	26		30	0.2	
USA	New/reconstructed after 5/23/2013	0.015							
Louisiana (e)	International Paper CAMTI (No. 3)	0.015							
Minnesota	Boise Cascade Int'l Falls (EU320)	0.0165							
Europe	LCPDs ^b : high range	NA	0.019	7000-9000	44		50	0.5	
Arkansas	Georgia Pacific Crossert (8R)	0.02							
Georgia	International Paper AM (No. 3)	0.021							
North Carolina	Kapstone (No. 7)	0.021							
Mississippi	Weyerhaeuser NR PW (AA-100)	0.023							
Georgia	GP Cedar Springs (No. 3)	0.024							
Louisiana	Port Hudson (No. 1)	0.025							
Louisiana	Port Hudson (No. 2)	0.025							
Alabama	Alabama River Cellulose (No. 1)	0.025							
Alabama	Alabama River Cellulose (No. 2)	0.025							
Minnesota	Sappi Cloquet LLC (#10)	0.025							
British	Prince George Vancouver (RB)	0.026			60				5550
Washington	Weyerhaeuser (No. 10)	0.027							
Washington	Boise White Wallula (No. 3)	0.027							
Washington	Kapstone (22)	0.027							
Maine	Red Shield (# 4)	0.028							
Georgia	GP Cedar Springs (No. 1)	0.030							
Georgia	GP Cedar Springs (No. 2)	0.030							
Idaho	Clearwater Lewiston (No. 5)	0.03							
Florida	Palatka (No. 4)	0.030							
Washington	GP Camas (No. 3)	0.033			75				
Washington	GP Camas (No. 4)	0.033			75				
Idaho	Clearwater Lewiston (No. 4)	0.040							
Washington	Kapstone (19)	0.040							
USA	Modified RFs after 5/23/2013	0.044							
Georgia	Weyerhaeuser PWM (No. 3)	0.044			0.10				
Kentucky	Wycliffe Paper (03)	0.044							
Oregon	GP Consumer Products (EU24)	0.044							
Oregon	Boise White St Helens (2 & 3)	0.044							
Oregon	Cascade Pacific (RFEU)	0.044							
Washington	Boise White Wallula (No. 2)	0.044							
Washington	Kapstone (18)	0.044							
Washington	PTPC (RF)	0.044							
Washington	WestRock (No. 4)	0.044							
British	Catalyst PC Vancouver (#3, w#4 on)	0.051			117	135			7000
British	Catalyst PC Vancouver (#4, w#3 on)	0.051			117	135			7000
British	Catalyst PC Vancouver (#4, w#3 out)	0.062			143	165			9000
Georgia	International Paper AM (No. 2)	0.055							
British	Howe Sound Vancouver (E218529)	0.057			130	150			5950
Washington	Cosmo (No. 1, 2 & 3 common stk)	0.10							
Europe (sulphite)	LCPDs* for Paper Sector (low range)	NA	0.002	6000-7000	4		5	0.02	
Europe (sulphite)	LCPDs* for Paper Sector (high range)	NA	0.008	6000-7000	17		20	0.15	

Lime Kiln Particulate Matter Unit Conversions

Location	Facility (LK Unit if specified)	Limit A: gr/dscf (at 10% O2)	Limit B: gr/dscf (at 10% O2) daily avg	Limit B Ref:	F: flow rate (m3/Adt)	mg/dscm (at 10% O2)	mg/Nm3 (at5%O2)	kg TSP/ ADT	m3/min
USA	New/reconstructed after 5/23/2013	0.010							
Europe	LCPDs ^b : low range	NA	0.01	IPPC	1000	22	30	0.03	
Europe	LCPDs ^b : high range	NA	0.02	IPPC	1000	37	50	0.05	
Washington	Kapstone (3)	0.030							
Washington	Kapstone (4)	0.030							
Louisiana	Port Hudson (No. 2)	0.033							
Mississippi	Weyerhaeuser NR PW (AA-110)	0.033							
Alabama	Alabama River Cellulose (No. 1)	0.035							
Alabama	Alabama River Cellulose (No. 2)	0.035							
Minnesota	Sappi Cloquet LLC (#10)	0.035							
Washington	Kapstone (5)	0.035 ng / 0.060							
Washington	Weyerhaeuser (No. 4)	0.035 ng / 0.07							
British	Howe Sound Vancouver (E218529)	0.044				100			1035
Washington	Graymont	0.05 (coal or ng)							
Louisiana	Port Hudson (No. 1)	0.05							
Georgia	GP Cedar Springs (No. 2)	0.056							
USA	Modified LKs after 5/23/2013	0.064							
Arkansas	Georgia Pacific Crossert (#4)	0.064							
Georgia	GP Cedar Springs (No. 1)	0.064							
Georgia	International Paper AM (No. 2)	0.064							
Georgia	Weyerhaeuser PWM (No. 2)	0.064							
Idaho	Clearwater Lewiston (No. 3)	0.064							
Idaho	Clearwater Lewiston (No. 4)	0.064							
Kentucky	Wycliffe Paper (03)	0.064							
Louisiana	International Paper CAMPTI	0.064							
Oregon	GP Consumer Products (EU21)	0.064							
Oregon	Boise White St Helens	0.064							
Oregon	Cascade Pacific (LKEU)	0.064							
Washington	Boise White Wallula	0.064 ng / 0.12							
Washington	PTPC (LK)	0.064							
Washington	WestRock (No. 1)	0.064							
Washington	WestRock (No. 2)	0.064							
British	Catalyst PC Vancouver (1,2 cmb stk)	0.066				150			950
Minnesota	Boise Cascade Int'l Falls (EU340)	0.066							
Washington	GP Camas (No. 4)	0.067 ng / 0.13 oil							
Maine	Red Shield	0.13							
North Carolina	Kapstone	0.14							
Georgia	International Paper AM (No. 1)	0.176							
British	Prince George Vancouver	0.201	0.101			460			850
Florida	Palatka (No. 4)	NA							

Recovery Furnace SO₂ Unit Conversions

Location	Facility (RF Unit if specified)	Limit A: ppm (at 8% O ₂)	Limit C: 24-hr avg ppm (at 8% O ₂)	Limit E: Annual ppm (at 8% O ₂)	mg/dscm (at 8% O ₂)	mg/Nm ³ (at 5% O ₂)	kg S/ADt
Europe	LCPDs ^b : low range	3.3 (24-hr avg)	3.3		9	10	0.1
Washington	GP Camas (No. 3)	10 (24-hr avg)	10				
Washington	GP Camas (No. 4)	10 (24-hr avg)	10				
Europe	LCPDs ^b : high range	16 (24-hr avg)	16.4		44	50	0.4
Louisiana	International Paper CAMTI (No. 3)	20 (3-hr avg)					
Idaho	Clearwater Lewiston (No. 5)	50 (3-hr avg)					
Washington	Kapstone (18)	60 (3-hr avg) [switched to lb/hr units]					
Washington	Kapstone (19)	60 (3-hr avg) [switched to lb/hr units]					
Washington	Weyerhaeuser (No. 10)	75 (3-hr avg)					
Florida	Palatka (No. 4)	100 (24-hr avg)					
Alabama	Alabama River Cellulose (No.1)	100					
Alabama	Alabama River Cellulose (No.2)	100					
Maine	Red Shield (# 4)	100					
North Carolina	Kapstone (No. 7)	110 (3-hr avg)		75			
Louisiana	Port Hudson (No. 1)	120					
Louisiana	Port Hudson (No. 2)	120					
Washington	Kapstone (22)	120 (3-hr avg) [switched to lb/hr units]					
Mississippi	Weyerhaeuser NR PW (AA-100)	153					
Oregon	Cascade Pacific (RFEU)	180					
Washington	PTPC (RF)	200					
Georgia	Weyerhaeuser PWM (No. 3)	200					
Minnesota	Sappi Cloquet LLC (#10)	250					
Georgia	GP Cedar Springs (No. 1)	300					
Georgia	GP Cedar Springs (No. 2)	300					
Oregon	GP Consumer Products (EU24)	300 (3-hr avg)	300				
Oregon	Boise White St Helens (2&3)	300 (3-hr avg)	300				
Georgia	GP Cedar Springs (No. 3)	350 (24-hr avg)		350			
Washington	Cosmo (No. 1, 2 & 3 common stk) (c)	360 (c)					
Washington	WestRock (No. 4)	500 (150 30-day)					
Washington	Boise White Wallula (No. 2)	500					
Washington	Boise White Wallula (No. 3)	500					
Enocell, Finland	Not specified in IPPC ^b	≤ 2 (annual avg)		0.1	0.21	0.24	(a)
Frövi, Sweden	Not specified in IPPC ^b	≤ 2 (annual avg)		0.2	0.6	0.7	(a)
Joutseno, Finland	Not specified in IPPC ^b	≤ 2 (annual avg)		0.5	1.3	1.5	(a)
Dynäs, Sweden	Not specified in IPPC ^b	≤ 2 (annual avg)		0.7	1.7	2.0	(a)
Pöls AG, Austria	Not specified in IPPC ^b	≤ 2 (annual avg)		0.7	1.7	2.0	(a)
Oulu, Finland	Not specified in IPPC ^b	≤ 2 (annual avg)		0.9	2.4	2.8	(a)
Östrand, Sweden	Not specified in IPPC ^b	≤ 2 (annual avg)		1.5	4.1	4.7	(a)
Varö, Sweden	Not specified in IPPC ^b	≤ 2 (annual avg)		1.5	4.1	4.7	(a)
Stora Celbi, Portugal	Not specified in IPPC ^b	≤ 2 (annual avg)		1.5	4.1	4.7	(a)
Vallvik, Sweden	Not specified in IPPC ^b	≤ 2 (annual avg)		2.0	5.2	6.0	(a)
Mönsterås, Sweden	Not specified in IPPC ^b	4 (annual avg)		3.7	9.9	11.3	(a)
Obbola, Sweden	Not specified in IPPC ^b	4 (annual avg)		3.7	9.9	11.3	(a)
Skutskär, Sweden	Not specified in IPPC ^b	5 (annual avg)		5.0	13.4	15.3	(a)
Bäckhammar,	Not specified in IPPC ^b	5 (annual avg)		5.0	13.4	15.3	(a)
Skärblacka, Sweden	Not specified in IPPC ^b	6 (annual avg)		6.3	16.8	19.3	(a)
Skoghall, Sweden	Not specified in IPPC ^b	6 (annual avg)		6.3	16.8	19.3	(a)
Wisaforest, Finland	Not specified in IPPC ^b	7 (annual avg)		6.7	17.8	20.4	(a)
Husum, Sweden	Not specified in IPPC ^b	12 (annual avg)		12.0	31.9	36.7	(a)
Aspa, Sweden	Not specified in IPPC ^b	15 (annual avg)		14.6	38.9	44.7	(a)
Ääneskoski, Finland	Not specified in IPPC ^b	15 (annual avg)		15.5	41.2	47.3	(a)
Kaskinen, Finland	Not specified in IPPC ^b	16 (annual avg)		16.0	42.6	48.9	(a)
Iggesund, Sweden	Not specified in IPPC ^b	16 (annual avg)		16.4	43.6	50.0	(a)
Huelva, Spain	Not specified in IPPC ^b	17 (annual avg)		16.8	44.7	51.3	(a)
Sunila, Finland	Not specified in IPPC ^b	18 (annual avg)		17.8	47.4	54.4	(a)
British Columbia	Prince George Vancouver (RB)	11			30		
Minnesota	Boise Cascade Int'l Falls (EU320)	NA					
Arkansas	Georgia Pacific Crossert (8R)	NA					
Georgia	International Paper AM (No. 3)	NA					
Georgia	International Paper AM (No. 2)	NA					
Idaho	Clearwater Lewiston (No. 4)	NA					
Kentucky	Wycliffe Paper (03)	NA					
British Columbia	Catalyst PC Vancouver (#3, w#4 on)	*as specified in S content of fuel					
British Columbia	Catalyst PC Vancouver (#4, w#3 on)	*as specified in S content of fuel					
British Columbia	Catalyst PC Vancouver (#4, w#3 out)	*as specified in S content of fuel					
British Columbia	Howe Sound Vancouver (E218529)	NA					
Europe (sulphite)	LCPDs* for Paper Sector (low range)	16 (24-hr avg)	16.4		44	50	0.3
Europe (sulphite)	LCPDs* for Paper Sector (high range)	49 (24-hr avg)	49.1		131	150	1.0

Notes:
(a) See European Mills Summary

Lime Kiln SO₂ Unit Conversions

Location	Facility (LK Unit if specified)	Limit A: ppm (at 10% O ₂)	Oil fired w/o NCG: Limit C:ppm 24-hr avg	Oil fired wNCG: Limit C:ppm 24-hr avg	Oil fired w/o NCG: Limit D: Annual ppm (at 10% O ₂)	Oil fired w NCG: Limit D: Annual ppm (at 10% O ₂)	Oil fired w/o NCG: g/dscm (at 10% O ₂)
Europe	LCPDs ^b : low range (w/o NCG incineration)	1.4 (24-hr avg)	1.4				4
Europe	LCPDs ^b : high range (w/o NCG incineration)	8 (24-hr avg)	8.3				22
Florida	Palatka (No. 4)	16.9					
Alabama	Alabama River Cellulose (No. 1)	50					
Alabama	Alabama River Cellulose (No. 2)	50					
Mississippi	Weyerhaeuser NR PW (AA-110)	50					
Washington	Kapstone (3)	20 (3-hr avg)					
Washington	Kapstone (4)	20 (3-hr avg)					
Washington	Kapstone (5)	20 (3-hr avg)					
Idaho	Clearwater Lewiston (No. 4)	20 (3-hr avg)					
Europe	LCPDs ^b : low range (w/ NCG incineration)	42 (24-hr avg)		41.5			
Europe	LCPDs ^b : high range (w/ NCG incineration)	83 (24-hr avg)		83.0			
Washington	GP Camas (No. 4)	500					
Washington	Weyerhaeuser (No. 4)	500					
Washington	PTPC (RF)	500					
Washington	WestRock (No. 1)	500					
Washington	WestRock (No. 2)	500					
Washington	Graymont	1000 (coal or ng)					
Oulu, Finland	Not specified in IPPC ^b	2 (annual avg)			2	22	4.4
Husum,	Not specified in IPPC ^b	3 (annual avg)			3	23	7.4
Skoghall,	Not specified in IPPC ^b	3 (annual avg)			3	23	7.4
Dynäs,	Not specified in IPPC ^b	3 (annual avg)			3	23	7.4
Frövi, Sweden	Not specified in IPPC ^b	3 (annual avg)			3	23	7.4
Obbola,	Not specified in IPPC ^b	3 (annual avg)			3	23	7.4
Bäckhammar,	Not specified in IPPC ^b	3 (annual avg)			3	23	7.4
Pöls AG,	Not specified in IPPC ^b	3 (annual avg)			3	23	7.4
Joutseno,	Not specified in IPPC ^b	3 (annual avg)			3	23	8.8
Washington	Boise White Wallula	5 (annual avg)					
Stora Celbi,	Not specified in IPPC ^b	6 (annual avg)			6	25	14.7
Wisaforest,	Not specified in IPPC ^b	8 (annual avg)			8	27	22.1
Kaskinen,	Not specified in IPPC ^b	12-30 (annual avg)			12	30	32.4
Mönsterås,	Not specified in IPPC ^b	14-31 (annual avg)			14	31	36.8
Skärblacka,	Not specified in IPPC ^b	14-31 (annual avg)			14	31	36.8
Ääneskoski,	Not specified in IPPC ^b	16-33 (annual avg)			16	33	43.5
Sunila, Finland	Not specified in IPPC ^b	17-33 (annual avg)			17	33	44.9
Aspa, Sweden	Not specified in IPPC ^b	28-41 (annual avg)			28	41	73.7
Skutskär,	Not specified in IPPC ^b	28-41 (annual avg)			28	41	73.7
Iggesund,	Not specified in IPPC ^b	44 (annual avg)			30	44	81.0
Enocell,	Not specified in IPPC ^b	48 (annual avg)			37	48	98.0
Vallvik,	Not specified in IPPC ^b	81 (annual avg)			80	81	213.7
Varö, Sweden	Not specified in IPPC ^b	81 (annual avg)			80	81	213.7
Östrand,	Not specified in IPPC ^b	104 (annual avg)			111	104	294.7
Huelva, Spain	Not specified in IPPC ^b	160 (annual avg)			185	160	493.6
Louisiana	International Paper CAMTI (No. 3)	NA					
Minnesota	Boise Cascade Int'l Falls (EU320)	NA					
North Carolina	Kapstone (No. 7)	NA					
British Columbia	Prince George Vancouver (RB)	NA					
Maine	Red Shield (# 4)	NA					
Louisiana	Port Hudson (No. 1)	NA					
Louisiana	Port Hudson (No. 2)	NA					
Minnesota	Sappi Cloquet LLC	NA					
Georgia	GP Cedar Springs (No. 1)	NA					
Georgia	GP Cedar Springs (No. 2)	NA					
Oregon	Cascade Pacific (LKEU)	TBD per permit					
Arkansas	Georgia Pacific Crossert (#4)	NA					
Georgia	Weyerhaeuser PWM (No. 2)	NA					
Georgia	International Paper AM (No. 1)	NA					
Georgia	International Paper AM (No. 2)	NA					
Idaho	Clearwater Lewiston (No. 3)	NA					
Kentucky	Wycliffe Paper (03)	NA					
Oregon	GP Consumer Products (EU21)	NA					
Oregon	Boise White St Helens	NA					
British Columbia	Catalyst PC Vancouver (#3, w#4 on)	"as specified in S content of fuel reg"					
British Columbia	Catalyst PC Vancouver (#4, w#3 on)	"as specified in S content of fuel reg"					
British Columbia	Catalyst PC Vancouver (#4, w#3 out)	"as specified in S content of fuel reg"					
British Columbia	Howe Sound Vancouver (E218529)	NA					
Notes:							
(a) See European Mills Summary							

Lime Kiln SO₂ Unit Conversions (Continued)

Location	Facility (LK Unit if specified)	Limit A: ppm (at 10% O ₂)	Oil fired w NCG: g/dscm (at 10% O ₂)	Oil fired w/o NCG: mg/Nm ³ (at5%O ₂)	Oil fired w/o NCG: kg S/ ADt	Oil fired w NCG: mg/Nmc (at5%O ₂)	Oil fired w NCG: kg S/ ADt
Europe	LCPDs ^a : low range (w/o NCG incineration)	1.4(24-hr avg)		5	0.005		---
Europe	LCPDs ^a : high range (w/o NCG)	8 (24-hr avg)		30	0.03		---
Florida	Palatka (No. 4)	16.9					
Alabama	Alabama River Cellulose (No. 1)	50					
Alabama	Alabama River Cellulose (No. 2)	50					
Mississippi	Weyerhaeuser NR PW (AA-110)	50					
Washington	Kapstone (3)	20 (3-hr avg)					
Washington	Kapstone (4)	20 (3-hr avg)					
Washington	Kapstone (5)	20 (3-hr avg)					
Idaho	Clearwater Lewiston (No. 4)	20 (3-hr avg)					
Europe	LCPDs ^a : low range (w/ NCG)	42 (24-hr avg)	111			150	0.1
Europe	LCPDs ^a : high range (w/ NCG)	83 (24-hr avg)	221			300	0.3
Washington	GP Camas (No. 4)	500					
Washington	Weyerhaeuser (No. 4)	500					
Washington	PTPC (RF)	500					
Washington	WestRock (No. 1)	500					
Washington	WestRock (No. 2)	500					
Washington	Graymont	1000 (coal or ng)					
Oulu, Finland	Not specified in IPPC ^b	2 (annual avg)	58.6	6.0	(a)	79.5	(a)
Husum,	Not specified in IPPC ^b	3 (annual avg)	60.8	10.0	(a)	82.5	(a)
Skoghall,	Not specified in IPPC ^b	3 (annual avg)	60.8	10.0	(a)	82.5	(a)
Dynäs,	Not specified in IPPC ^b	3 (annual avg)	60.8	10.0	(a)	82.5	(a)
Frövi, Sweden	Not specified in IPPC ^b	3 (annual avg)	60.8	10.0	(a)	82.5	(a)
Obbola,	Not specified in IPPC ^b	3 (annual avg)	60.8	10.0	(a)	82.5	(a)
Bäckhammar,	Not specified in IPPC ^b	3 (annual avg)	60.8	10.0	(a)	82.5	(a)
Pöls AG,	Not specified in IPPC ^b	3 (annual avg)	60.8	10.0	(a)	82.5	(a)
Joutseno,	Not specified in IPPC ^b	3 (annual avg)	61.9	12.0	(a)	84.0	(a)
Washington	Boise White Wallula	5 (annual avg)			(a)		(a)
Stora Celbi,	Not specified in IPPC ^b	6 (annual avg)	66.3	20.0	(a)	90.0	(a)
Wisaforest,	Not specified in IPPC ^b	8 (annual avg)	71.8	30.0	(a)	97.5	(a)
Kaskinen,	Not specified in IPPC ^b	12-30 (annual avg)	79.6	44.0	(a)	108.0	(a)
Mönsterås,	Not specified in IPPC ^b	14-31 (annual avg)	82.9	50.0	(a)	112.5	(a)
Skärblacka,	Not specified in IPPC ^b	14-31 (annual avg)	82.9	50.0	(a)	112.5	(a)
Ääneskoski,	Not specified in IPPC ^b	16-33 (annual avg)	87.9	59.0	(a)	119.3	(a)
Sunila,	Not specified in IPPC ^b	17-33 (annual avg)	89.0	61.0	(a)	120.8	(a)
Aspa, Sweden	Not specified in IPPC ^b	28-41 (annual avg)	110.5	100.0	(a)	150.0	(a)
Skutskär,	Not specified in IPPC ^b	28-41 (annual avg)	110.5	100.0	(a)	150.0	(a)
Iggesund,	Not specified in IPPC ^b	44 (annual avg)	116.0	110.0	(a)	157.5	(a)
Enocell,	Not specified in IPPC ^b	48 (annual avg)	128.8	133.0	(a)	174.8	(a)
Vällvik,	Not specified in IPPC ^b	81 (annual avg)	215.5	290.0	(a)	292.5	(a)
Varö, Sweden	Not specified in IPPC ^b	81 (annual avg)	215.5	290.0	(a)	292.5	(a)
Östrand,	Not specified in IPPC ^b	104 (annual avg)	276.3	400.0	(a)	375.0	(a)
Huelva, Spain	Not specified in IPPC ^b	160 (annual avg)	425.5	670.0	(a)	577.5	(a)
Louisiana	International Paper CAMTI (No. 3)	NA					
Minnesota	Boise Cascade Int'l Falls (EU320)	NA					
North Carolina	Kapstone (No. 7)	NA					
British	Prince George Vancouver (RB)	NA					
Maine	Red Shield (# 4)	NA					
Louisiana	Port Hudson (No. 1)	NA					
Louisiana	Port Hudson (No. 2)	NA					
Minnesota	Sappi Cloquet LLC	NA					
Georgia	GP Cedar Springs (No. 1)	NA					
Georgia	GP Cedar Springs (No. 2)	NA					
Oregon	Cascade Pacific (LKEU)	TBD per permit					
Arkansas	Georgia Pacific Crossert (#4)	NA					
Georgia	Weyerhaeuser PWM (No. 2)	NA					
Georgia	International Paper AM (No. 1)	NA					
Georgia	International Paper AM (No. 2)	NA					
Idaho	Clearwater Lewiston (No. 3)	NA					
Kentucky	Wycliffe Paper (03)	NA					
Oregon	GP Consumer Products (EU21)	NA					
Oregon	Boise White St Helens	NA					
British Columbia	Catalyst PC Vancouver (#3, w#4 on)	"as specified in S content of fuel reg"					
British Columbia	Catalyst PC Vancouver (#4, w#3 on)	"as specified in S content of fuel reg"					
British Columbia	Catalyst PC Vancouver (#4, w#3 out)	"as specified in S content of fuel reg"					
British	Howe Sound Vancouver (E218529)	NA					

Notes:
(a) See European Mills Summary

Recovery Furnace NOx Unit Conversions

Location	Facility (RF Unit if specified)	Limit A: ppm _d (at 8% O ₂)	Limit C: 24-hr avg: ppm (at 8% O ₂)	Annual ppm (@8%O ₂)	mg/dscm (at 8% O ₂)	mg/Nm ³ (at5%O ₂)	kg NO _x /ADt
Europe	LCPDs ^b : low range	36 (24-hr avg)	36		70	80	0.7
Europe	LCPDs ^b : high range	55 (24-hr avg)	55		105	120	1.1
Alabama	Alabama River Cellulose (No. 2)	75					
Louisiana	International Paper CAMTI (No. 3)	80 (3-hr avg)					
Mississippi	Weyerhaeuser NR PW (AA-100)	80 (8-hr avg)					
Alabama	Alabama River Cellulose (No. 1)	90					
Washington	Kapstone (22)	95 (3-hr avg)					
Washington	Kapstone (18)	95 (24-hr avg)	95				
Washington	Kapstone (19)	95 (24-hr avg)	95				
Idaho	Clearwater Lewiston (No. 5)	100					
Arkansas	Georgia Pacific Crossert (8R)	110					
Louisiana	Port Hudson (No. 1)	112					
Louisiana	Port Hudson (No. 2)	112					
Washington	Boise White Wallula (No. 3)	112 (24-hr avg)	112				
Washington	Weyerhaeuser (No. 10)	140 (24-hr avg)	140				
Maine	Red Shield (# 4)	150 (24-hr avg)					
Minnesota	Boise Cascade Int'l Falls (EU320)	80 (30-day avg)					
Florida	Palatka (No. 4)	80 (30-day avg)					
Washington	WestRock (No. 4)	85 (30-day avg)					
North Carolina	Kapstone (No. 7)	100 (30-day avg)					
Minnesota	Sappi Cloquet LLC	115 (30-day avg)					
Skärblacka, Sweden	Not specified in IPPC ^b	35 (annual avg)		35	66	76	(a)
Oulu, Finland	Not specified in IPPC ^b	41 (annual avg)		41	79	91	(a)
Wisaforest, Finland	Not specified in IPPC ^b	44 (annual avg)		44	84	96.4	(a)
Huelva, Spain	Not specified in IPPC ^b	45 (annual avg)		45	85	98	(a)
Mönsterås, Sweden	Not specified in IPPC ^b	48 (annual avg)		48	91	105	(a)
Frövå, Sweden	Not specified in IPPC ^b	51 (annual avg)		51	97	111	(a)
Joutseno, Finland	Not specified in IPPC ^b	51 (annual avg)		51	97	111.3	(a)
Obbola, Sweden	Not specified in IPPC ^b	51 (annual avg)		51	98	112	(a)
Stora Celbi, Portugal	Not specified in IPPC ^b	51 (annual avg)		51	98	112	(a)
Sunila, Finland	Not specified in IPPC ^b	51 (annual avg)		51	98	112.9	(a)
Skoghall, Sweden	Not specified in IPPC ^b	56 (annual avg)		56	108	124	(a)
Enocell, Finland	Not specified in IPPC ^b	59 (annual avg)		59	112	128.6	(a)
Husum, Sweden	Not specified in IPPC ^b	60 (annual avg)		60	114	131	(a)
Bäckhammar,	Not specified in IPPC ^b	60 (annual avg)		60	115	132	(a)
Dynäs, Sweden	Not specified in IPPC ^b	61 (annual avg)		61	117	134	(a)
Skutskär, Sweden	Not specified in IPPC ^b	62 (annual avg)		62	119	136	(a)
Aspa, Sweden	Not specified in IPPC ^b	63 (annual avg)		63	121	139	(a)
Östrand, Sweden	Not specified in IPPC ^b	67 (annual avg)		67	127	146	(a)
Kaskinen, Finland	Not specified in IPPC ^b	67 (annual avg)		67	128	146.6	(a)
Vallvik, Sweden	Not specified in IPPC ^b	70 (annual avg)		70	134	154	(a)
Iggesund, Sweden	Not specified in IPPC ^b	73 (annual avg)		73	139	160	(a)
Varö, Sweden	Not specified in IPPC ^b	73 (annual avg)		73	140	161	(a)
Pöls AG, Austria	Not specified in IPPC ^b	77 (annual avg)		77	148	170	(a)
Ääneskoski, Finland	Not specified in IPPC ^b	84 (annual avg)		84	161	184.8	(a)
Georgia	GP Cedar Springs (No. 1)	NA					
Georgia	GP Cedar Springs (No. 2)	NA					
Georgia	GP Cedar Springs (No. 3)	NA					
Georgia	International Paper AM (No. 2)	NA					
Georgia	International Paper AM (No. 3)	NA					
Georgia	Weyerhaeuser PWM (No. 3)	NA					
Idaho	Clearwater Lewiston (No. 4)	NA					
Kentucky	Wycliffe Paper (O3)	NA					
Oregon	Cascade Pacific (RFEU)	TBD per permit					
Oregon	GP Consumer Products (EU24)	No limit in permit					
Oregon	Boise White St Helens (2&3)	No limit in permit					
Washington	Boise White Wallula (No. 2)	NA					
Washington	Cosmo (No. 1, 2 & 3 common stk)	NA					
Washington	GP Camas (No. 3)	NA					
Washington	GP Camas (No. 4)	NA					
Washington	PTPC (RF)	NA					
British Columbia	Catalyst PC Vancouver (#3, w#4 on)	NA					
British Columbia	Catalyst PC Vancouver (#4, w#3 on)	NA					
British Columbia	Catalyst PC Vancouver (#4, w#3 out)	NA					
British Columbia	Howe Sound Vancouver (E218529)	NA					
British Columbia	Prince George Vancouver (RB)	11.3					
Europe-sulphite	LCPDs ^b : low range	91 (24-hr avg)	91		30	200	1.0
Europe-sulphite	LCPDs ^b : high range	137 (24-hr avg)	137		174	300	2.0

Notes:
(a) See European Mills Summary

Lime Kiln NOx Unit Conversions

Location	Facility (LK Unit if specified)	Limit A: ppmd (at 10% O2)	Oil fired: 24- hr avg: ppm (at 10% O2)	Nat Gas fired: 24-hr avg: ppm (at 10% O2)	Annual range ppm @10%O 2	Nat Gas fired: annua Lave:	Oil fired: annual avg: ppm (at 10% O2)	Nat Gas fired: mg/Nm3(at 10%O2)
Europe	LCPDs ^b : low range (oil)	39 (24-hr avg)	39					
Europe	LCPDs ^b : high range (oil)	77 (24-hr avg)	77					
Alabama	Alabama River Cellulose (No. 2)	100						
Oregon	Cascade Pacific (LKEU)	112						
Europe	LCPDs ^b : low range (natural gas)	146 (24-hr avg)		146				280
Maine	Red Shield (# 4)	170						
Alabama	Alabama River Cellulose (No. 1)	175						
Mississippi	Weyerhaeuser NR PW (AA-110)	189 (or 300)						189
Minnesota	Sappi Cloguet LLC	220						
Europe	LCPDs ^b : high range (natural gas)	231 (24-hr avg)		231				442
Oregon	Boise White St Helens	270						
Washington	Kapstone (5)	275 (24-hr avg)						
Washington	Kapstone (3)	340 (24-hr avg)						
Washington	Kapstone (4)	340 (24-hr avg)						
Florida	Palatka (No. 4)	114 (30-day)						
Bäckhammar,	Not specified in IPPC ^b	15 (annual avg)			15	2	15	3
Huelva, Spain	Not specified in IPPC ^b	23 (annual avg)			23	2	23	4
Östrand,	Not specified in IPPC ^b	31 (annual avg)			31	11	31	21
Ääneskoski,	Not specified in IPPC ^b	39 (annual avg)			39	20	39	38
Husum,	Not specified in IPPC ^b	42 (annual avg)			42	23	42	45
Iggesund,	Not specified in IPPC ^b	50 (annual avg)			50	32	50	61
Skoghall,	Not specified in IPPC ^b	58 (annual avg)			58	40	58	77
Kaskinen,	Not specified in IPPC ^b	62 (annual avg)			62	45	62	85
Joutseno,	Not specified in IPPC ^b	65 (annual avg)			65	48	65	92
Stora Celbi,	Not specified in IPPC ^b	65 (annual avg)			65	49	65	94
Enocell,	Not specified in IPPC ^b	66 (annual avg)			66	49	66	94
Obbola,	Not specified in IPPC ^b	69 (annual avg)			69	53	69	102
Skutskär,	Not specified in IPPC ^b	73 (annual avg)			73	57	73	110
Aspa, Sweden	Not specified in IPPC ^b	77 (annual avg)			77	62	77	118
Mönsteras,	Not specified in IPPC ^b	66-81 (annual)			66-81	66	81	126
Frövi, Sweden	Not specified in IPPC ^b	66-81 (annual)			66-81	66	81	126
Vällvik,	Not specified in IPPC ^b	70-85 (annual)			70-85	70	85	134
Dynäs,	Not specified in IPPC ^b	70-85 (annual)			70-85	70	85	134
Skärblacka,	Not specified in IPPC ^b	74-89 (annual)			74-89	74	89	142
Varö, Sweden	Not specified in IPPC ^b	87-100 (annual)			87-100	87	100	167
Oulu, Finland	Not specified in IPPC ^b	91-104 (annual)			91-104	91	104	175
Sunila, Finland	Not specified in IPPC ^b	93-106 (annual)			93-106	93	106	179
Wisaforest,	Not specified in IPPC ^b	115-126			115-126	115	126	220
Pöls AG,	Not specified in IPPC ^b	168 (annual avg)			168	168	173	321
Arkansas	Georgia Pacific Crossert (#4)	NA						
Georgia	GP Cedar Springs (No. 1)	NA						
Georgia	GP Cedar Springs (No. 2)	NA						
Georgia	International Paper AM (No. 2)	NA						
Georgia	International Paper AM (No. 3)	NA						
Georgia	Weyerhaeuser PWM (No. 2)	NA						
Idaho	Clearwater Lewiston (No. 4)	NA						
Idaho	Clearwater Lewiston (No. 5)	NA						
Kentucky	Wycliffe Paper (03)	NA						
Louisiana	Port Hudson (No. 1)	NA						
Louisiana	Port Hudson (No. 2)	NA						
Louisiana	International Paper CAMTI (No. 3)	NA						
Minnesota	Boise Cascade Int'l Falls (EU320)	NA						
North Carolina	Kapstone (No. 7)	NA						
Oregon	GP Consumer Products (EU21)	NA						
Washington	Boise White Wallula	NA						
Washington	GP Camas (No. 4)	NA						
Washington	PTPC (RF)	NA						
Washington	WestRock (No. 1)	NA						
Washington	WestRock (No. 2)	NA						
Washington	Weyerhaeuser (No. 4)	NA						
British	Catalyst PC Vancouver (#3, w#4 on)	NA						
British	Catalyst PC Vancouver (#4, w#3 on)	NA						
British	Catalyst PC Vancouver (#4, w#3 out)	NA						
British	Howe Sound Vancouver (E218529)	NA						
British	Prince George Vancouver (RB)	NA						
Notes:								
(a) See European Mills Summary								

Lime Kiln NO_x Unit Conversions (Continued)

Location	Facility (LK Unit if specified)	Limit A: ppmvd (at 10% O ₂)	Oil fired : mg/Nm ³ (at 10%O ₂)	Nat Gas fired: mg/Nm ³ (at5%O ₂)	Nat Gas fired: kg NO _x / ADt	Oil fired : mg/Nm ³ (at5%O ₂)	Oil fired: kg NO _x / ADt
Europe	LCPDs ^b : low range (oil)	39 (24-hr avg)	74			100	0.1
Europe	LCPDs ^b : high range (oil)	77 (24-hr avg)	147			200	0.2
Alabama	Alabama River Cellulose (No. 2)	100					
Oregon	Cascade Pacific (LKEU)	112					
Europe	LCPDs ^b : low range (natural gas)	146 (24-hr avg)		380	0.4		
Maine	Red Shield (# 4)	170					
Alabama	Alabama River Cellulose (No. 1)	175					
Mississippi	Weyerhaeuser NR PW (AA-110)	189 (or 300 ppm)					
Minnesota	Sappi Cloquet LLC	220					
Europe	LCPDs ^b : high range (natural gas)	231 (24-hr avg)		600	0.6		
Oregon	Boise White St Helens	270					
Washington	Kapstone (5)	275 (24-hr avg)					
Washington	Kapstone (3)	340 (24-hr avg)					
Washington	Kapstone (4)	340 (24-hr avg)					
Florida	Palatka (No. 4)	114 (30-day avg)					
Bäckhammar,	Not specified in IPPC ^b	15 (annual avg)	29	4	(a)	40	(a)
Huelva, Spain	Not specified in IPPC ^b	23 (annual avg)	44	6	(a)	60	(a)
Östrand,	Not specified in IPPC ^b	31 (annual avg)	59	28	(a)	80	(a)
Ääneskoski,	Not specified in IPPC ^b	39 (annual avg)	74	51	(a)	101	(a)
Husum,	Not specified in IPPC ^b	42 (annual avg)	81	61	(a)	110	(a)
Iggesund,	Not specified in IPPC ^b	50 (annual avg)	96	83	(a)	130	(a)
Skoghall,	Not specified in IPPC ^b	58 (annual avg)	111	105	(a)	150	(a)
Kaskinen,	Not specified in IPPC ^b	62 (annual avg)	118	116	(a)	160	(a)
Joutseno,	Not specified in IPPC ^b	65 (annual avg)	124	125	(a)	168	(a)
Stora Celbi,	Not specified in IPPC ^b	65 (annual avg)	125	127	(a)	170	(a)
Enocell,	Not specified in IPPC ^b	66 (annual avg)	126	128	(a)	171	(a)
Obbola,	Not specified in IPPC ^b	69 (annual avg)	133	138	(a)	180	(a)
Skutskär,	Not specified in IPPC ^b	73 (annual avg)	140	149	(a)	190	(a)
Aspa, Sweden	Not specified in IPPC ^b	77 (annual avg)	147	160	(a)	200	(a)
Mönsterås,	Not specified in IPPC ^b	66-81 (annual)	155	171	(a)	210	(a)
Frövi, Sweden	Not specified in IPPC ^b	66-81 (annual)	155	171	(a)	210	(a)
Vallvik,	Not specified in IPPC ^b	70-85 (annual)	162	182	(a)	220	(a)
Dynäs,	Not specified in IPPC ^b	70-85 (annual)	162	182	(a)	220	(a)
Skärblacka,	Not specified in IPPC ^b	74-89 (annual)	169	193	(a)	230	(a)
Varö, Sweden	Not specified in IPPC ^b	87-100 (annual)	192	226	(a)	260	(a)
Oulu, Finland	Not specified in IPPC ^b	91-104 (annual)	199	237	(a)	270	(a)
Sunila, Finland	Not specified in IPPC ^b	93-106 (annual)	203	242.5	(a)	275	(a)
Wisaforest,	Not specified in IPPC ^b	115-126 (annual)	240	298.6	(a)	326	(a)
Pöls AG,	Not specified in IPPC ^b	168 (annual avg)	332	435	(a)	450	(a)
Arkansas	Georgia Pacific Crossert (#4)	NA					
Georgia	GP Cedar Springs (No. 1)	NA					
Georgia	GP Cedar Springs (No. 2)	NA					
Georgia	International Paper AM (No. 2)	NA					
Georgia	International Paper AM (No. 3)	NA					
Georgia	Weyerhaeuser PWM (No. 2)	NA					
Idaho	Clearwater Lewiston (No. 4)	NA					
Idaho	Clearwater Lewiston (No. 5)	NA					
Kentucky	Wycliffe Paper (03)	NA					
Louisiana	Port Hudson (No. 1)	NA					
Louisiana	Port Hudson (No. 2)	NA					
Louisiana	International Paper CAMTI (No. 3)	NA					
Minnesota	Boise Cascade Int'l Falls (EU320)	NA					
North Carolina	Kapstone (No. 7)	NA					
Oregon	GP Consumer Products (EU21)	NA					
Washington	Boise White Wallula	NA					
Washington	GP Camas (No. 4)	NA					
Washington	PTPC (RF)	NA					
Washington	WestRock (No. 1)	NA					
Washington	WestRock (No. 2)	NA					
Washington	Weyerhaeuser (No. 4)	NA					
British	Catalyst PC Vancouver (#3, w#4 on)	NA					
British	Catalyst PC Vancouver (#4, w#3 on)	NA					
British	Catalyst PC Vancouver (#4, w#3 out)	NA					
British	Howe Sound Vancouver (E218529)	NA					
British	Prince George Vancouver (RB)	NA					
Notes: (a) See European Mills Summary							

European Mills Summary

Estimated Annual Average Calculations (5),(6)					
		(oil fired)	(gas fired)		(oil w/o ncg incineration)
	Recovery Boiler	Lime Kiln	Lime Kiln	Recovery Boiler	Lime Kiln
	NOx	NOx (4)	NOx (4)	SO2 (1),(2)	SO2 (1),(2)
Facility	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³
Aspa, Sweden	139	200	160	44.7	100.0
Iggesund, Sweden	160	130	83	50.0	110.0
Husum, Sweden	131	110	61	36.7	10.0
Mönsterås, Sweden	105	210	171	11.3	50.0
Östrand, Sweden	146	80	28	4.7	400.0
Skutskär, Sweden	136	190	149	15.3	100.0
Skärblacka, Sweden	76	230	193	19.3	50.0
Skoghall, Sweden	124	150	105	19.3	10.0
Vallvik, Sweden	154	220	182	6.0	290.0
Varö, Sweden	161	260	226	4.7	290.0
Dynäs, Sweden	134	220	182	2.0	10.0
Frövi, Sweden	111	210	171	0.7	10.0
Obbola, Sweden	112	180	138	11.3	10.0
Bäckhammar, Sweden	132	40	4	15.3	10.0
Huelva, Spain	98	60	6	51.3	670.0
Pöls AG, Austria	170	450	435	2.0	10.0
Stora Celbi, Portugal	112	170	127	4.7	20.0
Enocell, Finland	128.6	171	128	0.2	133.0
Oulu, Finland	91	270	237	2.8	6.0
Ääneskoski, Finland	184.8	101	51	47.3	59.0
Kaskinen, Finland	146.6	160	116	48.9	44.0
Sunila, Finland	112.9	275	243	54.4	61.0
Joutseno, Finland	111.3	168	125	1.5	12.0
Wisaforest, Finland	96.4	326	299	20.4	30.0

Notes:

ICCP reference O2 content = 5%. For mg/Nm³, the N stands for normal conditions or standard European conditions of 0 degrees Celsius and sea level pressure (101.3 kPa).

(1) Inflated value - includes S from TRS [From IPPC Dec 2001 document: "Gaseous sulphur is mainly SO₂-S. Usually only very small amounts of H₂S is released (usually below 10 mg H₂S/Nm³)"]

(2) SO₂ trendline was calculated from information provided even though y-intercept of zero would normally be assumed. Results were positive except for the recovery boiler calculated SO₂ value (mg/Nm³) at Enocell, Finland. To avoid a negative calculated result at this facility, the mg/Nm³ value was estimated as a scaled fraction of the kg/ADt ratio of the next lowest SO₂ emitting facility (Frövi, Sweden).

(3) Source data values of <0.01, were set to 0.00999 as conservative approximations.

(4) NO_x Trendline was calculated from information provided even though y-intercept of zero would normally be assumed. Results were positive except for gas fired lime kiln calculated NO_x value (mg/Nm³) at Bäckhammar, Sweden. To avoid a negative calculated result at this facility, the mg/Nm³ value was estimated as a scaled fraction of the kg/ADt ratio of the next lowest NO_x emitting facility (Huelva, Spain).

(5) Source data: Integrated Pollution Prevention Control (ICCP) Reference Document on Best Available Techniques in the Pulp and Paper Industry, December 2001, European Commission.

(6) Whether an individual facility's lime kiln(s) is gas fired or oil fired for NO_x, and whether it is oil fired with non-condensable gas incineration, or without non-condensable gas incineration for SO₂ were not known. Ranges of values were calculated for both NO_x options and both SO₂ options. For NO_x values within or close to the oil-fired range, oil was the assumed fuel. For NO_x values within or close to the gas-fired range, gas was the assumed fuel. For values in between, both gas and oil fired ranges were provided.

European Mills Summary (Continued)

Estimated Annual Average Calculations (5),(6)					
Facility	(oil & ncg incineration)				
	Lime Kiln	Recovery Boiler	Lime Kiln	Recovery Boiler	Lime Kiln
	SO2 (1),(2)	NOx	NOx	SO2	SO2 (3)
	mg/Nm3	kg/Adt	kg/Adt	kg/Adt	kg/Adt
Aspa, Sweden	150.0	1.29	0.20	0.36	0.1
Iggesund, Sweden	157.5	1.5	0.13	0.4	0.11
Husum, Sweden	82.5	1.21	0.11	0.3	0.01
Mönsterås, Sweden	112.5	0.95	0.21	0.11	0.05
Östrand, Sweden	375.0	1.36	0.08	0.06	0.4
Skutskär, Sweden	150.0	1.26	0.19	0.14	0.1
Skärblacka, Sweden	112.5	0.66	0.23	0.17	0.05
Skoghall, Sweden	82.5	1.14	0.15	0.17	0.00999
Vallvik, Sweden	292.5	1.44	0.22	0.07	0.29
Varö, Sweden	292.5	1.51	0.26	0.06	0.29
Dynäs, Sweden	82.5	1.24	0.22	0.04	0.00999
Frövi, Sweden	82.5	1.01	0.21	0.03	0.01
Obbola, Sweden	82.5	1.02	0.18	0.11	0.00999
Bäckhammar, Sweden	82.5	1.22	0.04	0.14	0.01
Huelva, Spain	577.5	0.88	0.06	0.41	0.67
Pöls AG, Austria	82.5	1.6	0.45	0.04	0.00999
Stora Celbi, Portugal	90.0	1.02	0.17	0.06	0.02
Enocell, Finland	174.8	1.186	0.171	0.011	0.133
Oulu, Finland	79.5	0.81	0.27	0.046	0.006
Ääneskoski, Finland	119.3	1.748	0.101	0.38	0.059
Kaskinen, Finland	108.0	1.366	0.16	0.392	0.044
Sunila, Finland	120.8	1.029	0.275	0.433	0.061
Joutseno, Finland	84.0	1.013	0.168	0.036	0.012
Wisaforest, Finland	97.5	0.864	0.326	0.178	0.03

Notes:

ICCP reference O2 content = 5%. For mg/Nm3, the N stands for normal conditions or standard European conditions of 0 degrees Celsius and sea level pressure (101.3 kPa).

(1) Inflated value - includes S from TRS [From IPPC Dec 2001 document: "Gaseous sulphur is mainly SO2-S. Usually only very small amounts of H2S is released (usually below 10 mg H2S/Nm3)"]

(2) SO2 Trendline was calculated from information provided even though y-intercept of zero would normally be assumed. Results were positive except for the recovery boiler calculated SO2 value (mg/Nm3) at Enocell, Finland. To avoid a negative calculated result at this facility, the mg/Nm3 value was estimated as a scaled fraction of the kg/ADt ratio of the next lowest SO2 emitting facility (Frövi, Sweden).

(3) Source data values of <0.01, were set to 0.00999 as conservative approximations.


(4) NOx Trendline was calculated from information provided even though y-intercept of zero would normally be assumed. Results were positive except for gas fired lime kiln calculated NOx value (mg/Nm3) at Backhammar, Sweden. To avoid a negative calculated result at this facility, the mg/Nm3 value was estimated as a scaled fraction of the kg/ADt ratio of the next lowest NOx emitting facility (Huelva, Spain).

(5) Source data: Integrated Pollution Prevention Control (ICCP) Reference Document on Best Available Techniques in the Pulp and Paper Industry, December 2001, European Commission.

(6) Whether an individual facility's lime kiln(s) is gas fired or oil fired for NOx, and whether it is oil fired with non-condensable gas incineration (ncg), or without non-condensable gas incineration for SO2 were not known. Ranges of values were calculated for both NOx options and both SO2 options. For NOx values within or close to the oil-fired range, oil was the assumed fuel. For NOx values within or close to the gas-fired range, gas was the assumed fuel. For values in between, both gas and oil fired ranges were provided.


European Mills Summary (Continued)
Plot of kg/ADt pulp based on values from IPPC Dec 2001 page 106-108

Recovery Furnaces BAT Ranges			
kg/ADt Pulp	PM mg/Nm3	SO2 mg/Nm3	NOx mg/Nm3
0.1		10	
0.2	30		
0.4		50	
0.5	50		
0.7			80
1.1			120
m	66.667	133.33	100
y(2)	16.667	-3.333	10
Recovery Furnace Gas flow range	Low	High	
m3/Adt	7,000	9,000	
ft3/Adt	247,203	317,832	



European Mills Summary (Continued)
Plot of kg/ADt pulp based on values from IPPC Dec 2001 page 106-108

Lime Kiln BAT Ranges					
kg/ADt Pulp	PM (mg/Nm3)	SO2 (oil w/o neg incineration) (mg/Nm3)	SO2 (oil & neg incineration) (mg/Nm3)	NOx (oil fired) (mg/Nm3)	NOx (gas fired) (mg/Nm3)
0.005		5			
0.01					
0.02					
0.03	30	30			
0.05	50				
0.1			150	100	
0.2				200	
0.3			300		
0.4					380
0.6					600
0.7					
1.1					
m	1000	1000	750	1000	1100
y(2)	0	0	75	0	-60
Lime Kiln Gas flow range					
m3/Adt	1,000				
ft3/Adt	35,315				



Section A.2 Permit Limit Information

[This section contains the original format of the pulp mill survey and contains most of the permit limit information found. The full list of pulp mill limits is contained in the main body text of the RACT analysis.]

REGIONAL HAZE RACT ANALYSIS - SUPPORTING MATERIAL							
Pulp & Paper Mills							
Recovery Furnace and Lime Kiln Emission Limits and Rules							
State	Facility/ Unit	Pollutant	BACT	BACT Demonstrated in Practice? Yes/No (reference & date)	RACT	Summary of Other Rules (BART, LAER, NSPS, MACT, State rules, etc.)	
						Comments/Notes	
Louisiana	Port Hudson Operations Georgia-Pacific Consumer Operations, LLC; Zachary, East Baton Rouge Parish						State facility ID #:2617
	Recovery Furnace No 1. (2.81* MM lbs/day BLS)	PM/ PM10:	0.025 gr/dscf; 42.11 lbs/hr. ESP	Yes (Source test; Sept 19-20, 2012)	NA	PM<=4.0 lbs/equiv pulp ton : LAC 33:III.2301.D.1.a *PM<=0.044 gr/dscf@8%O2: NSPS 40CFR60.282 subpart BB. NESHAP 40CFR63.862 MM	*3.32 MM lbs/day max; Limit for combined furnaces = 1.216 MM tpy *Permit specifies this limit for PM10 (not PM), both CFRs however list the limit for PM (not PM10).
		NOx:	112 ppmv @8% O2; 156.20 lbs/hr. GED, PCT		NA	NA	
		SO2:	120 ppmv @8% O2; 5.88 lbs/hr	Stack test results not found	NA	<=2000 ppmv @ STP: LAC 33:III.1503.C	
	Recovery Furnace No 2. (3.96* MM lbs/day)	PM/ PM10:	0.025 gr/dscf; 64.57 lbs/hr. ESP	Yes (Source test; Sept 19-20, 2012)	NA	PM<=4.0 lbs/equiv pulp ton : LAC 33:III.2301.D.1.a *PM<=0.044 gr/dscf@8%O2: NSPS 40CFR60.282 subpart BB. NESHAP 40CFR63.862 MM	*4.6 MM lbs/day max; Limit for combined furnaces = 1.216 MM tpy *Permit specifies this limit for PM10 (not PM), both CFRs however list the limit for PM (not PM10).
		NOx:	112 ppmv @8% O2; 216.45 lbs/hr. GED, PCT.		NA	NA	
		SO2:	120 ppmv @8% O2; 7.86 lbs/hr	Stack test results not found	NA	<=2000 ppmv @ STP: LAC 33:III.1503.C	
	Lime Kiln No. 1 (340 TCaO/day)	PM/ PM10:	0.05 gr/dscf; 25.76 lbs/hr; wet scrubber	Yes, w/ replacement high dp scrubber (3/4/2010 test); [Not with orig AirPol H-K scrubber using pet coke per 8/12/2005 ltr]	NA	PM<=1.0 lbs/equiv pulp ton ("subsumed by BACT"): LAC 33:III.2301.D.1.c *PM<=0.066 gr/dscf@10%O2: NSPS 40CFR60.282 *PM<=0.064 gr/dscf@10%O2: NESHAP 40CFR63.862 MM	EPA allowed violation to go unfinned due to hurricane Rita (post Katrina) natural gas ration. EPA required the extra 8.6 tons PM that were emitted due to burning pet coke to be mitigated. Issued deadline for new scrubber. *Listed as 0.15 g/dscm in both CFRs cited. Difference in English units (0.066 gr/dscf vs 0.064 gr/dscf) assumed to be rounding error. Also, Permit specifies this limit for PM10 (not PM), both CFRs however apply the limit for PM (not PM10).
		NOx:	48.78 lbs/hr; GED* & PCT*		NA	NA	*GED = Good Equipment Design; *PCT = Proper Combustion Techniques
		SO2:	3.26 lbs/hr: Using wet scrubber and mud washing		NA	NA	
	Lime Kiln No. 2 (340 TCaO/day)	PM/ PM10:	0.033 gr/dscf; 20.45 lbs/hr; ESP + wet scrubber	Yes (GP ltr 8/12/2005)	NA	PM<=1.0 lbs/equiv pulp ton: LAC 33:III.2301.D.1.c *PM<=0.066 gr/dscf@10%O2: NSPS 40CFR60.282 *PM<=0.064 gr/dscf@10%O2: NESHAP 40CFR63.862 MM	*Listed as 0.15 g/dscm in both CFRs cited. Difference in English units (0.066 gr/dscf vs 0.064 gr/dscf) assumed to be rounding error. Also, Permit specifies this limit for PM10 (not PM), both CFRs however apply the limit for PM (not PM10).
		NOx:	38.75 lbs/hr; GED* & PCT*		NA	NA	*GED = Good Equipment Design; *PCT = Proper Combustion Techniques
		SO2:	2.59 lbs/hr: Using wet scrubber and mud washing		NA	NA	

Section A.2 Permit Limit Information (Continued)

Maine	Red Shield Acquisition LLC (formerly GP), Old Town, Maine, Penobscot County		:						
	#4 Recovery Boiler (2.57 MM lb/day black LS; 375 MMBtu/hr #6, #2, and/or diesel fuel)	PM:	*0.028 gr/dscf; ; **BPT(for PM and PM10): 34.3 lb/hr BLS, 37.4 lb/hr oil. Flakt dry bottom two field ESP (compliance obtained with just 1 field)	Yes. No current BACT (or RACT) non- demonstration issues in state for recovery furnaces and lime kilns per Eric Kennedy of MDEP (11/27/2012 conversation with Gary Huising of WA State Dept of Ecology).	NA	<=4.0 lbs/equiv pulp ton; : CMR 06-096.105.(2)	*Alternative to 0.044 gr/dscf allowed per MACT rule. **Best Practical Treatment (BPT) means that method which controls or reduces emissions of regulated pollutants to the lowest possible level considering: then existing state of technology, effectiveness of available alternatives for reducing emissions from the source being considered, and economic feasibility for the type establishment involved.		
						<=*0.044 gr/dscf@8%O2 : NSPS 40CFR60.282 subpart BB (NA due to cost); NESHAP 40CFR63.862 MM			
						0.3 lbs/MMBtu : CMR 06-096.103(2)(A)(4); [incorrect ref: should be CMR 06- 096.103(2)(A)(3)(b)]			
			NOx:		May 8, 1996 RACT appears to have replaced previous BACT determinations. **BPT: 154.4 lb/hr BLS, 182.2 lb/hr oil.		120 ppmv wet@8% O2 or 12%CO; *150 ppmv O2	RACT: CMR 06-096.138.3.C.1	*From State rule referenced in Permit. (120 ppm wet converted to dry basis). **(BPT = see definition above)
		SO2:	**BPT: 100 ppm; 143 lb/hr BLS, 196.5 lb/hr oil.		NA	NA	**BPT = see definition above)		
	Lime Kiln System (64 MMBtu/hr)	PM:	*0.13 gr/dscf; variable throat wet venturi scrubber. **BPT(for PM and PM10): 32.9 lb/hr.	Yes. No current BACT (or RACT) non- demonstration issues in state for recovery furnaces and lime kilns per Eric Kennedy of MDEP (11/27/2012 conversation with Gary Huising of WA State Dept of Ecology).	NA	<=1.0 lbs/equiv pulp ton: CMR 06-096.105.(2) PM<=*0.064 gr/dscf@10%O2 : NSPS 40CFR60.282; NESHAP 40CFR63.862 MM	*Alternative to 0.064 gr/dscf allowed per MACT rule. **(BPT = see definition above)		
			NOx:		May 8, 1996 RACT appears to have replaced previous BACT determinations. **BPT: 36.0 lb/hr.		120 ppmv wet@10 %O2; or *170	RACT: CMR 06-096.138.3.E.1	**BPT = see definition above)
			SO2:		**BPT: 7.1 lbs/hr (emission concentration not provided); variable throat wet venturi scrubber.		NA	NA	**BPT = see definition above)

Section A.2 Permit Limit Information (Continued)

North Caro	KapStone Kraft Paper Corporation, Roanoke Rapids, North Carolina, Halifax County			:			
	No. 7 Recovery Furnace	PM:	0.021 gr/dscf @8% O ₂ ; 144 tpy per consecutive 12-month period; ESP*	Yes, per Air Permit Review accompanying Permit (No. 01649T53)	NA	<=3.0 lbs/equiv pulp ton; : 15A NCAC 2D.0508	*Single stage, cold side 140k ft2 plate area.
						<=*0.044 gr/dscf@8%O ₂ : NSPS 40CFR60.282 subpart BB; 15A NCAC 2D.0524	
		NOx:	100 ppm @8%O ₂ (30-day rolling avg); 626 tpy (per 12-month consecutive period)			NA	:
		SO ₂ :	75 ppm @8%O ₂ (annual rolling avg); 110 ppm @8%O ₂ (3-hr avg); 571 tpy per consecutive 12-month period		NA	2.3 lbs/MMBtu : 15A NCAC 2D.0516	
	Lime Kiln System	PM:	0.14 gr/dscf @10%O ₂ ; Variable throat wet venturi scrubber.	Yes, per Air Permit Review accompanying Permit (No. 01649T53)	NA	<=0.5 lbs/equiv pulp ton: 15A NCAC 2D.0508	
						:	
		NOx:	NA				:
		SO ₂ :	Variable throat wet venturi scrubber.		NA	2.3 lbs/MMBtu : 15A NCAC 2D.0516	

Section A.2 Permit Limit Information (Continued)

Alabama	ALABAMA RIVER CELLULOSE LLC (PKA: ALABAMA RIVER PULP MILL CO INC); PO BOX 301463 MONTG :					
	No. 1 Recovery Boiler (2,600 tons dry BLS/day capacity)	PM:	0.025 gr/dscf @8%O ₂ ; 74 lb/hr; two ESPs in parallel	Yes, based on stack tests: 5/24/20012	NA	<=4.0 lbs/equiv pulp ton; : 335-3-4-.07.2.a
		NO _x :	90 ppmv @8% O ₂ ; 223 lb/hr		NA	<=0.044 gr/dscf@8%O ₂ : NSPS 40CFR60.282 subpart BB. NESHAP 40CFR63.862 MM 0.1 lbs/MMBtu : Not provided
		SO ₂ :	100 ppmv @8% O ₂ ; 345 lb/hr		NA	0.3 lbs/MMBtu : Not provided
	No. 2 Recovery Boiler (3,200 tons dry BLS/day capacity)	PM:	0.025 gr/dscf @8%O ₂ ; 77 lb/hr; ESP	Yes, based on stack tests: 4/12/20012; 2/29/20012	NA	<=4.0 lbs/equiv pulp ton; : 335-3-4-.07.2.a
		NO _x :	75 ppmv @8% O ₂ ; 192.7 lb/hr		NA	<=0.044 gr/dscf@8%O ₂ : NSPS 40CFR60.282 subpart BB. NESHAP 40CFR63.862 MM 0.1 lbs/MMBtu : Not provided
		SO ₂ :	100 ppmv @8% O ₂ ; 357.3 lb/hr (BLS) 0.3 lb/MMBtu (oil)		NA	0.3 lbs/MMBtu : Not provided
	No. 1 Lime Kiln (420 tons/day as CaO capacity)	PM:	0.035 gr/dscf @10%O ₂ (gas) and 14.7 lb/hr; 0.064 gr/dscf @10%O ₂ (oil/CTO/pet coke) and 24.6 lb/hr; venturi scrubber	Yes, based on stack tests: 5/24/2007; 5/25/2007	NA	<=1.0 lbs/equiv pulp ton: 335-3-4-.07.2.c
		NO _x :	175 ppmv @10%O ₂ and 58.9 lb/hr		NA	PM<=0.066 gr/dscf@10%O ₂ : NSPS 40CFR60.282 PM<=0.064 gr/dscf@10%O ₂ : NESHAP 40CFR63.862 MM
		SO ₂ :	50 ppmv @10% O ₂ and 23.3 lb/hr; venturi scrubber		NA	NA
	No. 2 Lime Kiln (540 tons/day as CaO capacity)	PM:	0.035 gr/dscf @10%O ₂ (gas) and 14.6 lb/hr; 0.064 gr/dscf @10%O ₂ (oil/CTO/pet coke) and 29.2 lb/hr; ESP	Yes, based on stack tests: 4/3/20012	NA	<=1.0 lbs/equiv pulp ton: 335-3-4-.07.2.c
		NO _x :	100 ppmv @10%O ₂ and 36.3 lb/hr		NA	PM<=0.066 gr/dscf@10%O ₂ : NSPS 40CFR60.282 PM<=0.064 gr/dscf@10%O ₂ : NESHAP 40CFR63.862 MM
		SO ₂ :	50 ppmv @10% O ₂ and 25.3 lb/hr		NA	NA

Section A.2 Permit Limit Information (Continued)

Florida	Palatka Mill; Georgia-Pacific Consumer Operations LLC, Palatka FL, Putnam County			:	:	:	
	No.4 Recovery Boiler (210,000 lbs/hr black LS; 1345 MMBtu/hr)	PM:	0.030 gr/dscf @8% O2; 75.6 lb/hr; ULSD=15ppmw; ESP (12 fields*).	Could not find testing data, but according to website, the facility passed the most recent 5-yr compliance inspection on 9/5/2012.	NA	<=3 lbs/3000 lbs BLS fed; : 62-296.404(2)a	* ESP has two chambers of 6 fields each. Tube replacement considerations.
		NOx:	80 ppmvd @8% O2 and 168.5 lb/hr.		NA	NA	
		SO2:	100 ppmvd @8% O2; 292.8 lbs/hr (cap = 153.9 tpy).		NA	NA	
	No. 4 Lime Kiln (41.5 tons/hr lime mud solids; 19.4 tons quicklime per hr)	PM:	0.55 lb/ton lime mud solids; 22.9 lb/hr; venturi scrubber.		NA	NA	8/21/2009 FDEP authorization to install dual orifice impingement tray and chevron mist eliminator in scrubber separator tank of No. 4 lime kiln. Purpose: to improve performance and pm removal efficiency of scrubber. Could not find information indicating noncompliance prior to this.
		NOx:	140 ppmvd @10% O2 and 52.4 lb/hr		NA	NA	
		SO2:	16.9 ppmvd @10%O2 and 9.1 lb/hr; venturi scrubber.		NA	NA	
Mississippi	Weyerhaeuser NR Company, Columbus Cellulose Fibers, Columbus, MS, Lowndes County			:	:	:	
	Recovery Boiler-AA- 100; (6.3 MM lbs BLS/day)	PM/ PM10:	0.023 gr/dscf @8% O2; not to exceed 93 lbs/hr and 407.3 tpy; ESP.	Information not provided on state website	NA	PM<=4.0 lbs/equiv pulp ton; : APC-S-1 Section 3.5 E(PM)=0.08808*1-0.1667: E=emission limit(lbs/MMBTU/hr); I=heat input(MMBTU/hr): APC-S-1 Section 3.4(a)(2); PM<=0.044 gr/dscf@8%O2: NSPS 40CFR60.282 subpart BB. NESHAP 40CFR63.862 MM	
		NOx:	80 ppmvd @8% O2 not to exceed 272.6 lbs/hr and 1193.9 tpy.		NA	NA	
		SO2:	200 ppmvd @4% O2; not to exceed 724.2 lbs/hr and 3172.1 tpy.		NA	4.8 lbs/MMBTU [*0.5 lb/MMBTU]: APC-S-1 Section 4.1(a) [*NSPS 40CFR60.42b(d) subpart Db]	*Applies for oil other than very low sulfur oil
	Lime Kiln-AA-110 (420 tons per day)	PM/ PM10:	0.033 gr/dscf @10% O2; not to exceed 12.67 lbs/hr and 55.5 tpy; ESP.		NA	PM<=*0.067 gr/dscf@10%O2: **0.13 gr/dscf@10%O2: NSPS 40CFR60.282 PM<=**0.064 gr/dscf@10%O2: NESHAP 40CFR63.862 MM E(PM)=4.1*p0.67: APC-S-1 Section 3.6(a)	*Applies when burning gaseous fossil fuel E=emission limit(lbs/hr); p=process weight input rate(tph)
		NOx:	300 ppmvd @3.6% O2 not to exceed 60.9 lbs/hr and 266.7 tpy.		NA	NA	
		SO2:	*50 ppmvd @10% O2; not to exceed 22.42 lbs/hr and 98.2 tpy.		NA	500 ppmv : APC-S-1 Section 4.2(a)	*When controlling NCG in lieu of the NCG incinerator, 450 ppmv@7%O2 not to exceed 110 lbs/hr and 98.2 tpy

Section A.2 Permit Limit Information (Continued)

Georgia	Weyerhaeuser Company - Port Wentworth Mill, Port Wetworth, GA, Chatham County		:						
	No. 3 Recovery Boiler with two stacks	PM	East and West ESP. (see comments regarding emissions)	11/13/2000 performance test results show emissions with less than 100% of allowable PM and NOx for the Recovery Boiler. Test results for SO2 and Lime kiln not found on state website.	NA	<=0.044 gr/dscf@8%O2: NSPS 40CFR60.282(a)(1)(i); NESHAP 40CFR63.862 (a)(1)(i)(A)			
					< 47 lbs/hr: 40CFR52.21 (PSD)		PSD limit: "The facility has accepted the following limits under PSD."		
					(a) E=4.1*p0.67; (b) E=55*P0.11- 40: Equipment SIP Rule Standards: 391-3-1-.02(2)(e)1(i); E=emission limit(lbs/hr); p=process weight input rate(tph) excluding moisture. (a) for p <= 30 tpy; (b) for p > 30tpy:				
			NOx:		NA	174.3 lbs/hr: Avoidance of 40CFR52.21 (PSD)	PSD avoidance: "The facility has accepted the following limits to avoid PSD review."		
				SO2:		NA	< *200 lbs/hr @8%O2 : *(see note)	PSD limit: "The facility has accepted the following limits under PSD." *Previously = 500 lbs/hr until 12/23/2009; The 500 lbs/hr limit was based on 40CFR52.21; the 200 lbs/hr limit was adapted to eliminate need to convert CEMS data to lbs/hr value.	
		No. 2 Lime Kiln	PM	ESP. (see comments regarding emissions)		NA	PM<=0.064 gr/dscf@10%O2: NSPS 40CFR60.282; NESHAP 40CFR63.862; 40CFR52.21	PSD limit: "The facility has accepted the following limits under PSD."	
						(a) E=4.1*p0.67; (b) E=55*P0.11- 40: Equipment SIP Rule Standards: 391-3-1-.02(2)(e)1(i)		E=emission limit(lbs/hr); p=process weight input rate(tph) excluding moisture. (a) for p <= 30 tpy; (b) for p > 30tpy:	
						NOx:	NA	NA	
						SO2:	NA	49.6 lbs/hr: 40CFR52.21 (PSD)	PSD limit: "The facility has accepted the following limits under PSD."

Section A.2 Permit Limit Information (Continued)

Georgia	Georgia-Pacific Cedar Springs LLC, Cedar Springs, GA, Early County				:			
	Recovery Boiler No. 1	PM:	*0.030 gr/dscf @8%O2 ESP.	Yes. Performance test results (year 2000): 0.0151 gr/dscf @8%O2	NA	*PM<=0.030 gr/dscf @8% O2: 40CFR52.21; NESHAP 40CFR63.862; NSPS 40CFR Subpart BB subsumed	MACT MM limit; *PSD limit: "The facility is a major source under PSD. The facility is subject to the following PSD limits." "This is the same as the PSD BACT limit."	
						PM<= 46 lbs/hr:	PSD limit: "The facility is a major source under PSD. The facility is	
		NOx:				NA	154 lbs/hr; 0.2 lbs MMBtu heat input:	PSD limit: "The facility is a major source under PSD. The facility is subject to the following PSD limits."
								PSD limit: "The facility is a major source under PSD. The facility is subject to the following PSD limits."
	Recovery Boiler No. 2	PM	*0.030 gr/dscf @8%O2 ESP.	Yes. Performance test results (year 2000): 0.0114 gr/dscf @8%O2	NA	*PM<=0.030 gr/dscf @8% O2: 40CFR52.21; NESHAP 40CFR63.862; NSPS 40CFR Subpart BB subsumed	MACT MM limit; *PSD limit: "The facility is a major source under PSD. The facility is subject to the following PSD limits." "This is the same as the PSD BACT limit."	
						PM<=46 lbs/hr:	PSD limit: "The facility is a major source under PSD. The facility is subject to the following PSD limits."	
		NOx:				NA	154 lbs/hr; 0.2 lbs MMBtu heat input:	PSD limit: "The facility is a major source under PSD. The facility is subject to the following PSD limits."
								PSD limit: "The facility is a major source under PSD. The facility is subject to the following PSD limits."
	Recovery Boiler No. 3	PM	See NESHAP limit ESP.	Yes. Performance test results (year 2000): 0.0066 gr/dscf @8%O2	NA	PM<=0.024 gr/dscf @8% O2: NESHAP 40CFR63.862 PM<= 49.7 lbs/hr:	Georgia rule subsumed by listed NESHAP. PSD limit: "The facility is a major source under PSD. The facility is subject to the following PSD limits."	
						:		
		NOx:				NA	:	
							SO2:	

Section A.2 Permit Limit Information (Continued)

Georgia	Georgia-Pacific Cedar Springs LLC, Cedar Springs, GA, Early County			:				
	Lime Kiln No. 1; (250 CaO tpd - unchanged per LK2 modification)	PM/PM10	See comments regarding emission limits listed in site Permit; Venturi Scrubber	Yes. Performance test results (year 2000): 0.0399 gr/drsc @10%O2	NA	<i>PM<=0.064 gr/dscf @10% O2: NESHAP 40CFR63.862</i>	PSD limit: "The facility has accepted the following limits under PSD." Georgia rule subsumed by listed NESHAP.	
						<i>PM<=17.62 lbs/hr; PM10<=15.18 lbs/hr: Avoidance of 40CFR52.21, 40CFR52.21 BACT subsumed</i>	PSD avoidance: "The facility has accepted the following limits to avoid PSD review." "PM emissions were limited to 20 lbs/hr. The limit was subsumed by more stringent PSD avoidance limits for PM/PM10."	
		NOx:				NA	<i>14.06 lbs/hr: Avoidance of 40CFR52.21</i>	PSD avoidance: The facility has accepted the following limits to avoid PSD review.
		SO2:	Venturi Scrubber			NA	<i>13.54 lbs/hr: Avoidance of 40CFR52.21, 40CFR52.21 BACT subsumed</i>	PSD avoidance: "The facility has accepted the following limits to avoid PSD review." "SO2 emissions were limited to 113 lbs/hr. The limit was subsumed by a more stringent PSD avoidance limit.
	Lime Kiln No. 2 (Previous capacity of 250 tpd CaO increased to 300 tpd due to preheating via new lime mud flash dryer per 4/18/2007 Permit)	PM	See comments regarding emission limits listed in site Permit; Micro Mist Scrubber [replaced Venturi Scrubber (per 4/18/2007 Permit). Later permit (1/10/2013) refers to venturi scrubber with no explanation (possibly in error using old permit template?)]	Yes for PM Performance test results (year 2000) 0.0354 gr/drsc @10%O2. SO2?, NOx?: No specific reason is provided for replacing the venturi scrubber by a Micro Mist scrubber in 2007 other than to "control emissions from the No. 2 Lime Kiln".	NA	<i>PM<=0.056 gr/dscf@10%O2: NESHAP 40CFR63.862</i>	PSD limit: "The facility has accepted the following limits under PSD." Georgia rule subsumed by listed NESHAP.	
						<i>PM<=12.28 lbs/hr; PM10<=10.71 lbs/hr: Avoidance of 40CFR52.21, 40CFR52.21 BACT subsumed</i>	PSD avoidance: "The facility has accepted the following limits to avoid PSD review." "PM emissions were limited to 20 lbs/hr. The limit was subsumed by more stringent PSD avoidance limits for PM/PM10."	
		NOx:				NA	<i>16.87 lbs/hr: Avoidance of 40CFR52.21</i>	PSD avoidance: The facility has accepted the following limits to avoid PSD review.
		SO2:				NA	<i>16.25 lbs/hr: Avoidance of 40CFR52.21, 40CFR52.21 BACT subsumed</i>	PSD avoidance: "The facility has accepted the following limits to avoid PSD review." "SO2 emissions were limited to 113 lbs/hr. The limit was subsumed by a more stringent PSD avoidance limit.
Georgia	International Paper - Augusta Mill, Augusta, GA, Richmond County				:			
		PM	(0.021 gr/dscf @8%O2)	Yes, demonstrated with 0.015 gr/dscf@8%O2 in March 2004		:		

Section A.2 Permit Limit Information (Continued)

Idaho	Clearwater Paper Corporation, Pulp and Paperboard Division (PKA Potlatch), Lewiston Idaho, Nez Perce County						
	Recovery Furnace No. 4	PM	0.040 gr/dscf @8% O2; ESP		NA	<i>PM<=0.044 gr/dscf @8% O2 : NESHAP 40CFR63.862(a)(1)(i)</i>	PM surrogate for HAPS
		NOx:	NA	NA	NA	NA	
		SO2:	NA	NA	NA	NA	
	Recovery Furnace No. 5	PM	0.03 gr/dscf; 58 lbs/hr; ESP (97.7% efficient)		NA	<i>PM<=0.044 gr/dscf @8% O2 : NSPS 40CFR60.282; NESHAP 40CFR63.862(a)(1)(i)</i>	PM surrogate for HAPS
		NOx:	100 ppm; 160 lb/hr; 700 tpy		NA	NA	
		SO2:	50 ppm; 112 lb/hr; 490 tpy		NA	NA	
	Lime Kiln No. 3	PM	5.2 lb/hr each kiln; (27 tpy combined with Lime Kiln No 4) ESP		NA	<i>PM<=0.064 gr/dscf @*10% O2 : NESHAP 40CFR63.862</i>	PM surrogate for HAPS; *(8% O2 listed in permit - assume 10% per 40CFR862)
		PM10	5.2 lb/hr each kiln; (17.3 tpy combined kilns) ESP			:	
		NOx:	766 lb/day (each kiln); 113 tpy (combined with Lime Kiln No 3)		NA	NA	
		SO2:	153 lb/3-hr; 21 tpy		NA	NA	
	Lime Kiln No. 4	PM	5.2 lb/hr each kiln; (27 tpy combined with Lime Kiln No 4) ESP		NA	<i>PM<=0.064 gr/dscf @*10% O2 : NESHAP 40CFR63.862</i>	PM surrogate for HAPS; *(8% O2 listed in permit - assume 10% per 40CFR862)
		PM10	5.2 lb/hr each kiln; (17.3 tpy combined kilns) ESP				
		NOx:	766 lb/day (each kiln); 113 tpy (combined with Lime Kiln No 3)		NA	NA NA	
		SO2:	20 ppmv; 10.4 lb/3-hr; 15 tpy Packed bed scrubber downstream of ESP		NA	NA NA	

Section A.2 Permit Limit Information (Continued)

Oregon	Cascade Pacific Pulp, LLC, Halsey OR, Linn County						
	Recovery Furnace RFEU	PM	2.77 lb/air dired ton (1.38 kg/mt) daily avg; 1.91 lb/air dired ton (0.95 kg/mt) monthly avg. ESP		NA	PM<=0.044 gr/dscf @8% O2 NESHAP 40CFR63.862(a)(1)(i)	PM surrogate for HAPS
		NOx:	NA	NA	NA	NA NA	
		SO2:	180 ppm@8%O2	NA	NA	300 ppm @8%O2 OAR 340-234-0240(4)	
	Lime Kiln LKEU	PM	0.50 lb/air dired ton (0.25 kg/mt) daily avg [NG]; 1.00 lb/air dired ton (0.50 kg/mt) daily avg [oil or pet coke. ESP		NA	PM<=0.064 gr/dscf @10% O2 NESHAP 40CFR63.862	
		NOx:	112 ppm @10%O2 [NG or oil with existing burner]; 185 ppm @10%O2 [with pet coke burner]; 1000 ppm @10%O2 [if different burner installed]		NA	NA NA	
		SO2:	NA		NA	NA NA	

Section A.2 Permit Limit Information (Continued)

Washington	LONGVIEW FIBRE PAPER AND PACKAGING, INC,(dba KapStone) Longview, WA, Cowlitz County.			:		
Recovery Furnace 18	PM/ PM10:	0.044 gr/dscf @8% O2 1-hr avg; 219 tpy 12-month total; ESP (no scrubber)		NA	PM<=0.10 gr/dscf @8% O2 1-hr avg: WAC 173-405-040(1)(a)	
					PM<=0.044 gr/dscf @8% O2 : NESHAP 40CFR63.862(a); 40CFR63.864(d)&(k); 40CFR63.6(h)(SSM exclusion)	PM surrogate for HAPS
	NOx:	95 ppmdv @8%O2, 24-hr avg; 452 TPY 12 month total		NA	:	
	SO2:	94 lbs/hr, 3-hr avg; 202 tpy 12 month total		NA	500 ppm@8%O2; 1-hr avg.: WAC 173-405- 040(11)(a)	
Recovery Furnace 19	PM/ PM10:	0.040 gr/dscf @8% O2 1-hr avg; 292 tpy 12-month total; ESP		NA	PM<=0.10 gr/dscf @8% O2 1-hr avg: WAC 173-405-040(1)(a)	
					PM<=0.044 gr/dscf @8% O2 : NESHAP 40CFR63.862(a); 40CFR63.864(d)&(k); 40CFR63.6(h)(SSM exclusion)	PM surrogate for HAPS
	NOx:	95 ppmdv @8%O2, 24-hr avg; 753 TPY 12 month total		NA	:	
	SO2:	149 lbs/hr, 3-hr avg; 301 tpy 12 month total		NA	500 ppm@8%O2; 1-hr avg.: WAC 173-405- 040(11)(a)	
Recovery Furnace 22	PM/ PM10:	0.027 gr/dscf @8% O2 1-hr avg; 256 tpy 12-month total; ESP		NA	PM<=0.10 gr/dscf @8% O2 1-hr avg: WAC 173-405-040(1)(a)	
					PM<=0.044 gr/dscf @8% O2 : NESHAP 40CFR63.862(a); 40CFR63.864(d)&(k); 40CFR63.6(h)(SSM exclusion)	PM surrogate for HAPS
	NOx:	95 ppmdv @8%O2, 24-hr avg; 735 TPY 12 month total		NA	:	
	SO2:	295 lbs/hr, 3-hr avg; 301 tpy 12 month total		NA	500 ppm@8%O2; 1-hr avg.: WAC 173-405- 040(11)(a)	

Section A.2 Permit Limit Information (Continued)

Washington		LONGVIEW FIBRE PAPER AND PACKAGING, INC,(dba KapStone) Longview, WA, Cowlitz County.				
Recovery Furnace 15 (out of service)	PM/ PM10:	0.033 gr/dscf @8% O2 1-hr avg; 182.5 tpy 12-month total; ESP & Scrubber		NA	PM<=0.10 gr/dscf @8% O2 1-hr avg: WAC 173-405-040(1)(a)	
					PM<=0.044 gr/dscf @8% O2 : 40CFR63.862(a); 40CFR63.864(d)&(k); 40CFR63.6(h)(SSM exclusion)	PM surrogate for HAPS
	NOx:	95 ppmdv @8%O2, 24-hr avg; 434 TPY 12-month total		NA	:	
	SO2:	60 ppmdv @8% O2, 3-hr avg; 365 tpy 12-month total		NA	500 ppm@8%O2; 1-hr avg.: WAC 173-405-040(11)(a)	
Lime Kiln 3	PM/ PM10:	0.030 gr/dscf @10% O2 1-hr avg; 34 tpy 12-month total; *venturi scrubber		NA	PM<=0.13 gr/dscf @10% O2, 1-hr avg: WAC 173-405-040(3)(a)	
					PM<=0.064 gr/dscf @10% O2 : NESHAP 40CFR63.862(a); 40CFR63.864(e)&(k); 40CFR63.6(f)(SSM exclusion)	PM surrogate for HAPS
	NOx:	340 ppmdv @10%O2, 24-hr avg; 238 TPY 12-month total		NA	:	
	SO2:	*20 ppmdv @10% O2, 3-hr avg; 27 tpy 12-month total; *venturi scrubber		NA	500 ppm @10%O2; 1-hr avg.: WAC 173-405-040(11)(a)	*SO2 is typically controlled using operational practices, but caustic addition to the scrubber water is used when operational conditions vary from established standards.
Lime Kiln 4	PM/ PM10:	0.030 gr/dscf @10% O2 1-hr avg; 35.6 tpy 12-month total; *venturi scrubber		NA	PM<=0.13 gr/dscf @10% O2, 1-hr avg: WAC 173-405-040(3)(a)	
					PM<=0.064 gr/dscf @10% O2 : NESHAP 40CFR63.862(a); 40CFR63.864(e)&(k); 40CFR63.6(f)(SSM exclusion)	PM surrogate for HAPS
	NOx:	340 ppmdv @10%O2, 24-hr avg; 248 TPY 12-month total		NA	:	
	SO2:	*20 ppmdv @10% O2, 3-hr avg; 28 tpy 12-month total; *venturi scrubber		NA	500 ppm @10%O2; 1-hr avg.: WAC 173-405-040(11)(a)	*SO2 is typically controlled using operational practices, but caustic addition to the scrubber water is used when operational conditions vary from established standards.

Section A.2 Permit Limit Information (Continued)

Washington	LONGVIEW FIBRE PAPER AND PACKAGING, INC.(dba KapStone) Longview, WA, Cowlitz County.	:			
Lime Kiln 5	PM/ PM10:	*0.035 gr/dscf @10% O2 1-hr avg; **0.060 gr/dscf @10% O2 1-hr avg; 69 tpy 12-month total; ESP	NA PM<=0.067 gr/dscf @10% O2 : NESHAP 40CFR63.862(a)3 PM<=**0.13 gr/dscf @10% O2, 1-hr avg: NSPS 40 CFR 60.282(a)3 PM<=0.13 gr/dscf @10% O2, 1-hr avg: WAC 173-405-040(3)(a) PM<=0.064 gr/dscf @10% O2 : NESHAP 40CFR63.862(a)i; 40CFR63.864(e)&(k); 40CFR63.6(f)(SSM exclusion)	*When firing natural gas. ** When firing oil. For both natural gas and oil PM surrogate for HAPS	
		NOx:	275 ppmdv @10%O2, 24-hr avg; 262 TPY 12 month total	NA :	
		SO2:	20 ppmdv @10% O2, 3-hr avg; 28 tpy 12 month total	NA 500 ppm @10%O2; 1-hr avg.: WAC 173-405- 040(11)(a)	
Lime Kiln 1 (out of service)	PM/ PM10	0.030 gr/dscf @10% O2 1-hr avg; 20 tpy 12-month total; *venturi scrubber	NA PM<=0.13 gr/dscf @10% O2, 1-hr avg: WAC 173-405-040(3)(a) PM<=0.064 gr/dscf @10% O2 : 40CFR63.862(a)i; 40CFR63.864(e)&(k); 40CFR63.6(f)(SSM exclusion)	PM-surrogate for HAPS	
		NOx:	340 ppmdv @10%O2, 24-hr avg; 139 TPY 12 month total	NA :	
	SO2:	*20 ppmdv @10% O2, 3-hr avg; 16 tpy 12-month total	NA 500 ppm @10%O2; 1-hr avg.: WAC 173-405- 040(11)(a)	*SO2 is typically controlled using operational practices, but caustic addition to the scrubber water is used when operational conditions vary from established standards.	
Lime Kiln 2 (out of service)	PM/ PM10:	0.030 gr/dscf @10% O2 1-hr avg; 20 tpy 12-month total; *venturi scrubber	NA PM<=0.13 gr/dscf @10% O2, 1-hr avg: WAC 173-405-040(3)(a) PM<=0.064 gr/dscf @10% O2 : 40CFR63.862(a)i; 40CFR63.864(e)&(k); 40CFR63.6(f)(SSM exclusion)	PM-surrogate for HAPS	
		NOx:	340 ppmdv @10%O2, 24-hr avg; 139 TPY 12 month total	NA :	
	SO2:	*20 ppmdv @10% O2, 3-hr avg; 16 tpy 12-month total	NA 500 ppm @10%O2; 1-hr avg.: WAC 173-405- 040(11)(a)	*SO2 is typically controlled using operational practices, but caustic addition to the scrubber water is used when operational conditions vary from established standards.	

Section A.2 Permit Limit Information (Continued)

Washington Georgia-Pacific Consumers Products (GP Camas) LLC, [PKA: JAMES RIVER CORP] Camas, WA, Clark							
No. 3 Kraft Recovery Furnace (tpy bubble emission limit for No. 3 and No 4 furnaces combined: PM10<=328; NOx <=609; SO2<=46.2)	PM10:	0.033 gr/dscf (0.075 g/dscm) @8% O2 avg of 3 one-hr runs; ESP-> caustic scrubber*-> wet heat recovery system	Yes, per support document (SUP DOC 031506FIN.doc) available on Ecology Industrial section website.	NA	PM<=0.044 gr/dscf (0.10 g/dscm) @8% O2 hourly avg.: NESHAP 40CFR63.862(a)i; 40CFR63.864(e)&(k); 40CFR63.6(f)(SSM exclusion)	PM surrogate for HAPS	
					PM10<=0.10 gr/dscf @8% O2; avg three 1-hr runs: WAC 173-405-040(1)(a)		*(packed bed, cross-flow AirPol)
	NOx:	1.3 lb/ton (0.65 kg/Mg) bls fired		NA	:		
	SO2:	10 ppm @8% O2, 24-hr avg; scrubber*		NA	:		
No. 4 Kraft Recovery Furnace (tpy bubble emission limit for No. 3 and No 4 furnaces combined: PM10<=328; NOx <=609; SO2<=46.2)	PM10:	0.033 gr/dscf (0.075 g/dscm) @8% O2 1-hr avg; ESP -> caustic scrubber -> wet heat recovery system	Yes, per support document (SUP DOC 031506FIN.doc) available on Ecology Industrial section website.	NA	PM<=0.044 gr/dscf (0.10 g/dscm) @8% O2 hourly avg.: NESHAP 40CFR63.862(a)i; 40CFR63.864(e)&(k); 40CFR63.6(f)(SSM exclusion)	PM surrogate for HAPS	
					:		
	NOx:	1.5 lb/ton (0.75 kg/Mg) bls fired		NA	:		
	SO2:	10 ppm @8% O2, 24-hr avg; caustic scrubber		NA	:		
Lime Kiln 4	PM10:	0.13 gr/dscf (0.295 g/dscm) @10% O2 1-hr avg; wet scrubber	Yes, per support document (SUP DOC 031506FIN.doc) available on Ecology Industrial section website.	NA	PM<=0.067 gr/dscf (0.152 d/dscm) @10% O2; 3 one-hr runs: NESHAP 40CFR63.862(a)3	*When firing natural gas (88 tpy limit).	
					PM<=**0.13 gr/dscf (0.295 g/dscm) @10% O2, 1-hr avg: NSPS 40 CFR 60.282(a)3	** When firing fuel oil (44 tpy limit).	
				NA	PM<=0.064 gr/dscf (0.15 g/dscm) @10% O2 hourly avg: NESHAP 40CFR63.862(a)i; 40CFR63.864(e)&(k); 40CFR63.6(f)(SSM exclusion)	PM surrogate for HAPS	
	NOx:	234 tpy annual average		NA	:		
	SO2:	36.1 tpy annual average; wet scrubber		NA	500 ppm @10%O2; 1-hr avg.: WAC 173-405-040(11)(a)		

Section A.2 Permit Limit Information (Continued)

Washington: Cosmo Specialty Fibers, Inc. (Cosmo) [Previously owned by Weyerhaeuser], Cosmopolis, WA, Grays						
Recovery Boilers No. 1, 2, and 3 (common stack)	PM:	(See Summary of Other Rules) multi-cyclones*	Yes, per permit support document (No. 000080-9) available on Ecology Industrial section website.	NA	0.10 gr/dscf @8% O ₂ ;; WAC 173-410-040(2)(a); and Order DE 95AQ-1034 (Attachment B)	
					*≤10.0 lbs/hr (4.535 kg/hr) : 40CFR63.862(d) (MACT rule dated February 18, 2003; effective May 19, 2003)	*Special site specific MACT rule for PM (as a surrogate for HAPS). PM is controlled through hog fuel boiler instead of recovery furnace
	NOx:	NA		NA	:	
	SO ₂ :	(See Summary of Other Rules) Absorption tower/ venturi absorbers*		NA	800 ppm hrly avg.: WAC 173-410-040(d); 40CFR64; and WAC 173-401-615(4)	*Recovery Boilers No. 1 and 2, flow from multicyclone to an absorption tower; *Recovery Boiler No. 3 flows from multicyclone to dual-purpose cooler/cyclone evaporator, and three venturi SO ₂ absorbers in
				NA	360 ppm hrly avg.: Order DE 95AQ-1034 (Attachment B)	
Washington: Port Townsend Paper Corporation (PTPC), Port Townsend, WA, Jefferson County						
Recovery Furnace	PM:	(See Summary of Other Rules) ESP	Yes. Multiple source tests per support document (PTSUPA20.DOC)	NA	0.08 gr/dscf @8% O ₂ ; 1-hr avg: Order 2892-05AQ; and 40 CFR 64.6 (c) for CAM 0.10 gr/dscf @8% O ₂ ;; WAC 173-405-040	
					PM≤0.044 gr/dscf @8% O ₂ hourly avg.: NESHAP 40CFR63.862	PM surrogate for HAPS
	NOx:	NA		NA	:	
	SO ₂ :	200 ppm @8%O ₂ 1-hr avg.	Yes. Multiple source tests per support document (PTSUPA20.DOC)	NA	500 ppm hrly avg.: WAC 173-410-040	
Lime Kiln	PM:	(See Summary of Other Rules) Venturi Scrubber	Yes. Multiple source tests per support document (PTSUPA20.DOC)	NA	0.13 gr/dscf @10% O ₂ ; 1-hr avg.: WAC 173-405-040; and 40 CFR 64.6 (c) for CAM PM≤0.064 gr/dscf @10% O ₂ hourly avg.: 40CFR63.862	PM surrogate for HAPS
	NOx:	NA		NA	:	
	SO ₂ :	(See Summary of Other Rules) Venturi Scrubber	Yes. Multiple source tests per support document (PTSUPA20.DOC)	NA	500 ppm hrly avg.: WAC 173-410-040	

Section A.2 Permit Limit Information (Continued)

Washington	WestRock, Tacoma, WA, Pierce County			:		
	Recovery Furnace # 4. (669 tpy as 12-month rolling avg)	PM:	(See Summary of Other Rules)	NA	0.10 gr/dscf @8% O2.; WAC 173-405-040	
			ESP		PM<=0.044 gr/dscf @8% O2 hourly avg.: NESHAP 40CFR63.862	PM surrogate for HAPS
		NOx:	85 ppm @8% O2, 30-day rolling avg; 515 tpy as 12-month rolling avg.	NA	:	
		SO2:	150 ppm @8%O2, 30-day rolling avg; 669 tons /yr as 12-month rolling avg.	NA	500 ppm hrly avg.: WAC 173-410-040	
	Lime Kilns #s 1 & 2.	PM:	(See Summary of Other Rules)	Yes, avg of three tests on 7/27/04 and 8/9/04	NA	0.13 gr/dscf @10% O2; 1-hr avg.: WAC 173-405-040
			Scrubber			PM<=0.064 gr/dscf @10% O2 hourly avg.: NESHAP 40CFR63.862
		NOx:	NA		NA	:
		SO2:	(See Summary of Other Rules); Scrubber		NA	500 ppm hrly avg.: WAC 173-410-040

Section A.2 Permit Limit Information (Continued)

Washington		Weyerhaeuser Longview, WA, Cowlitz County				
Recovery Furnace # 10.	PM/ PM10:	0.027 gr/dscf @8% O2 avg of three 1-hr runs; 0.020 gr/dscf @8% annually; 252 tpy; ESP		NA	Same as BACT limits: BART = "Current BACT limits in PSD 92-03, Ammendment 4"	
					PM<=0.10 gr/dscf @8% O2; avg of three 1-hr runs: WAC 173-405-040	
					PM<=0.044 gr/dscf @8% O2 hourly avg.: NESHAP 40CFR63.862	PM surrogate for HAPS
	NOx:	140 ppm @ 8% O2, 24 hr avg; 1179 tpy annual avg		NA	Same as BACT limit: BART = "Current BACT limit in PSD 92-03, Ammendment 4"	
	SO2:	75 ppm @8%O2, 3 hr avg (when not using suppl oil or when using suppl oil and BLS firing rate >150,000 lbs/hr); 500 ppm 3-hr avg (when BLS firing rate <120,000 lbs/hr and firing suppl oil); 586 tpy*			: WAC 173-410-040	
					Same as BACT limit: BART = "Current BACT limit in PSD 92-03, Ammendment 4"	Quote from WA State Regional Haze SIP, Dec 2010 (p.L-374)
				NA	1000 ppm hrly avg. (when firing oil): WAC 173-410-040(11)(b)	*586 tpy + 0.036 tpy for each hr of NCG incinerator operation. The combined total not to exceed 884 tpy.
Lime Kiln	PM	*0.035 gr/dscf @10% O2 (gas fired); 0.07 gr/dscf @10% O2 (oil fired); ESP		NA	PM<=*0.067 gr/dscf @10% O2 : NESHAP 40CFR63.862(a)3; WAC173-405-040	*When firing natural gas.
					PM<=**0.13 gr/dscf @10% O2, 1-hr avg: NSPS 40 CFR 60.282(a)3	**For liquid fossil fuel
					PM<=0.064 gr/dscf @10% O2 : NESHAP 40CFR63.862	PM surrogate for HAPS
	NOx:	NA		NA	NA	
	SO2:	NA		NA	500 ppm @10%O2; 1-hr avg.: WAC 173-405-040(11)(a)	

Section A.2 Permit Limit Information (Continued)

Washington		Boise White Wallula, WA, Walla Walla County				:		
No. 2 Recovery Furnace	PM	0.044 gr/dscf @8% O2 1-hr avg; 476 lbs/day rolling annual avg; ESP	Yes for Particulate (multiple years of data per support document file name: "1/7/2005 Boise Cascade AOP Fact Sheet.doc")	NA	PM<=0.1 gr/dscf @8% O2 avg three 1-hr tests: WAC 173-400-091			
					PM<=0.044 gr/dscf @8% O2 : NESHAP 40CFR63.862(a)(1)(i)	PM surrogate for HAPS		
					PM<=75 tpy; PM10<=63 tpy PM10 (12-month rolling avg);: Order No. DE 02AQ91S-5019;			
	NOx:	NA			NA			
	SO2:	5424 lbs/day rolling annual avg				500 ppm@8%O2; 1-hr avg.: WAC 173-405- 040(11)(a)		
						NA	585 tpy 12-month rolling avg.: Order No. DE 02AQ91S-5019; WAC 173-400-091	
No. 3 Recovery Furnace	PM/ PM10:	See Summary of Other Rules (LAER) ESP	Yes for Particulate (multiple years of data per support document file name: "1/7/2005 Boise Cascade AOP Fact Sheet.doc")	NA	0.027 gr/dscf @8% O2 avg of three 1-hr runs; 0.021 gr/dscf @8% annually; 186 tpy; : LAER for state non-attainment area NSR (per WAC 173-400-112)			
					PM<=0.1 gr/dscf @8% O2 avg three 1-hr tests: WAC 173-405-040			
					PM<=0.044 gr/dscf @8% O2 : NESHAP 40CFR63.862(a)(1)(i)	PM surrogate for HAPS		
	NOx:	112 ppmvd @ 8% O2, daily avg; 825 tpy			NA	NA		
	SO2:	*1301 12 month rolling annual avg				500 ppm@8%O2; 1-hr avg.: WAC 173-405- 040(11)(a)	*PSD condition as BACT avoidance limit.	

Section A.2 Permit Limit Information (Continued)

Washington		Boise White Wallula, WA, Walla Walla County				
Lime Kiln	PM	0.12 gr/dscf @10%O2 when firing fuel oil; 906 lbs/day for fuel oil; 466 lbs/day for natural gas (rolling annual avg) Scrubber	Yes for Particulate (multiple years of data per support document file name: "1/7/2005 Boise Cascade AOP Fact Sheet.doc")	NA	PM<=0.064 gr/dscf @10% O2 : NESHAP 40CFR63.862	PM surrogate for HAPS
					PM<=*0.066 gr/dscf @10% O2 : NESHAP 40CFR60.282	*When firing natural gas.
					PM<=**0.13 gr/dscf @10% O2: NSPS 40 CFR 60.282	**For liquid fossil fuel
					PM<=0.13 gr/dscf @10% O2: WAC 173-405-040(3)	
	NOx:	NA		NA	NA	
	SO2:	*5 ppmvd @10% O2; **19 lbs/day (rolling annual avg);		NA	500 ppm @10%O2; 1-hr avg.: WAC 173-405-040(11)(a)	*Order DE 96-AQ1078; **PSD-X-77-04 as consolidated in Order DE 96-AQ1078
		***1.55% sulfur content in fuel oil; ***15.8 ppmvd at 10%O2 and 147.7 lbs/day (rolling annual avg) for oil above 1 gpm			:	***PSD X-77-04 Amendment 2

Appendix B. Facility Operating and Emissions Data

Facility Specific Operating and Emissions Data

		Facility:	Port Hudson	Port Hudson	Boise White	Int'l Paper
			Zachary, LA	Zachary, LA	Int'l Falls MN.	Camti, LA
		Run ID or Unit ID:	1	2		1
Pressure (stack absolute)	Ps	in HG	30.057	30.069		29.926
Pressure (barometric)	Pbar	in HG	30.09	30.10		29.97
Pressure (stack)	Pa	in H2O	-0.45	-0.42		-0.6
Conversion Factor	F1	inH2O/inHg	13.6	13.6		13.6
Total water condensed	Vwstd	scf H2				
	f	scf H2O/gm	0.04715			
Total water condensed	Vw	std ft3	11.91010	12.46219		13.03316
total impinger wt						276.2
Impinger 1	Vi	g	187.6	206.2		
Impinger 2	Vii	g	45.2	36.3		
Impinger 3	Viii	g	6	5.7		
Impinger 4	Viv	g	13.6	15.9		
Ideal gas constant	R	(inHG)(ft3)/(R-lbmol)	21.85	21.85		21.85
Temperature abs	Tabs	R (459.67)	460	460		460
Temp std	Tstd	R (527.67)	528	528		528
Conversion Factor	F2	g/lb (should be	453.59	453.59		453.59
Pressure (std)	Pstd	in HG	29.92	29.92		29.92
MW of water	MH2O	lb/lbmole	18.015	18.015		18.015
Sample Volume	Vmstd	dscf	45.256	46.31779		44.31501
Sample Volume from meter	Vm	dscf	46.714	48.236		45.74
Dry gas mtr cal factor	Y	no units	0.991	0.991		0.996
Meter orifice pressure	dH	in H2O	1.9021	2.0938		1.9075
Dry gas meter temp	Tm	F	85.7	91.0		86.3
Stack Gas Moisture Fraction	Bws	vol%/100	0.20834	0.21201		0.22726
Saturation Moisture Fraction@STP	SBws	(sat vap press)/Ps	0.20834	0.21201		0.22726
same as BWS (because Bws>SBws)						
Stack Gas Mole weight dry	Md	lb/lbmole	30.560	30.506		30.412
Oxygen conc in stack	conc O2	%/100	0.0559	0.0599		0.06
CO2 conc in stack	conc CO2	%/100	0.1451	0.1409		0.135
N2 conc in stack	con N2	%/100	0.7991	0.7992		0.805
			1.0001			
Stack Gas Mole weight wet	Ms	lb/lbmole	27.946	27.858		27.594
Stack Area	A	ft2	80.5156	80.5156	75.9436	122.7185
Diameter of stack	D	inches	121.5	121.5	118	150
Conversion Factor	F3	in/ft	12	12	12	12
Stack Gas Velocity	Vs	ft/sec	53.5051	56.2279	61.44908	70.7728
Pitot tube constant	Kp	test Vs:	85.49	85.49		85.49
Pitot tube calibration coef	Cp		0.84	0.84		0.84
Stack Gas Velocity Head	dP	in H2O	0.549	0.603		0.963
Stack Gas Velocity Head	dP^0.5		0.741			0.9815
Stack gas temp	Ts	F	390	391.3	391	372.6667
flow check						
Stack Ht	Ht	Ft				
Actual Stack Gas Flow Rate	Acf	acfm	258480	271633	280000	521,108
		acfs				
Conversion Factor	F5	sec/min	60	60	60	60
Dry std Stack gas flow rate	Qstd	dscfm	127691	133417	145000	255,392
Dry std Stack gas flow rate	Qstd	dscf/hr	7661487	8005033		15,323,511
Conversion Factor	F4	sec/hr	3600	3600		3600
	Qstd	dscf/min				
Isokinetic percent	I	%	103.69	101.57		100.07
sample nozzle cross section	An	ft2	0.00045869	0.00045869		0.00035466
length of sample test	theta	minutes	60			
Mass of part: combined samples	Mn	mg	8.4	9.8		0.6
Mass of part: probe wash	Mp	mg	3.8	4.9		0.4
Mass of part: filter	Mf	mg	4.6	4.9		0.2
Unit Totals (tons per year)	PM10					
Unit Totals (tons per year)	SO2					
Unit Totals (tons per year)	NOx					
Facility Totals (tons per year)	PM10					
Facility Totals (tons per year)	TSP					
Facility Totals (tons per year)	SO2					
Facility Totals (tons per year)	NOx					

Facility Specific Operating and Emissions Data (PTPC)

			Facility: PTPC							
			2003	2004	2005	2006	2007	2008	2003-	
			Run ID or Unit ID: RF							
			29.92	29.92	29.92	29.92	29.92	29.92	29.92	
Pressure (stack absolute)	Ps	in HG								
Pressure (barometric)	Pbar	in HG								
Pressure (stack)	Pa	in H2O								
Conversion Factor	F1	inH2O/inHg								
Total water condensed	Vwstd	scf H2)								
	f	scf H2O/gm								
Total water condensed	Vw	std ft3								
total impinger wt										
Impinger 1	Vi	g								
Impinger 2	Vii	g								
Impinger 3	Viii	g								
Impinger 4	Viv	g								
Ideal gas constant	R	(inHG)(ft3)/(R-								
Temperature abs	Tab	R (459.67)	460	460	460	460	460	460		
Temp std	Tstd	R (527.67)	528	528	528	528	528	528		
Conversion Factor	F2	g/lb (should be								
Pressure (std)	Pstd	in HG	29.92	29.92	29.92	29.92	29.92	29.92		
MW of water	MH2O	lb/lbmole	18.015	18.015	18.015	18.015	18.015	18.015		
Sample Volume	Vmstd	dscf								
Sample Volume from meter	Vm	dcf								
Dry gas mtr cal factor	Y	no units								
Meter orifice pressure	dH	in H2O								
Dry gas meter temp	Tm	F								
Stack Gas Moisture Fraction	Bws	vol%/100	0.17	0.19	0.18	0.17	0.18	0.18	0.1783	
Saturation Moisture Fraction@STP	SBws	(sat vap press)/Ps								
same as BWS (because Bws>SBws)										
Stack Gas Mole weight dry	Md	lb/lbmole	29.867	29.675	30.035	29.879	29.651	29.771	AVG	
Oxygen conc in stack	conc O2	%/100	0.112	0.128	0.098	0.111	0.13	0.12	0.1165	
CO2 conc in stack	conc CO2	%/100	0.088	0.072	0.102	0.089	0.07	0.08		
N2 conc in stack	con N2	%/100	0.8	0.8	0.8	0.8	0.8	0.8		
Stack Gas Mole weight wet	Ms	lb/lbmole	27.852	27.460	27.872	27.862	27.556	27.655		
Stack Area	A	ft2	63.6173	63.6173	63.6173	63.6173	63.6173	63.6173		
Diameter of stack	D	inches	108	108	108	108	108	108		
Conversion Factor	F3	in/ft	12	12	12	12	12	12		
Stack Gas Velocity	Vs	ft/sec	78.1706	85.3982	96.2632	90.7615	89.5197	70.9399		
Pitot tube constant	Kp	test Vs:								
Pitot tube calibration coef	Cp									
Stack Gas Velocity Head	dP	in H2O								
Stack Gas Velocity Head	dP^0.5									
Stack gas temp	Ts	F	317	334	371	309	313	302	AVG 324	
flow check			298,380	325,968	367,440					
Stack Ht	Ht	Ft								
Actual Stack Gas Flow Rate	Acf	acfm	298380	325968	367440	346440	341700	270780	325118	
		acfs	4973	5432.8	6124	5774	5695	4513		
Conversion Factor	F5	sec/min	60	60	60	60	60	60		
Dry std Stack gas flow rate	Qstd	dscfm	168,291	175,579	191,440	197,430			AVG 179664	
Dry std Stack gas flow rate	Qstd	dscf/hr	10,097,456	10,534,760	11,486,413		11,483.24	9,231,253		
Conversion Factor	F4	sec/hr	3600	3600	3600	3600	3600	3600		
Isokinetic percent	I	%								
sample nozzle cross section	An	ft2								
length of sample test	theta	minutes								
Mass of part: combined samples	Mn	mg								
Mass of part: probe wash	Mp	mg								
Mass of part: filter	Mf	mg								
Unit Totals (tons per year)	PM10		100	75	150	144	139	85	AVG 116	
Unit Totals (tons per year)	SO2		106	102	196	195	26	4	105	
Unit Totals (tons per year)	NOx		178	176	193	185	264	242	206	
Facility Totals (tons per year)	PM10		331	301	333	346	340	292	324	
Facility Totals (tons per year)	TSP		515	478	514	589	580	512	531	
Facility Totals (tons per year)	SO2		351	349	410	287	123	50	262	
Facility Totals (tons per year)	NOx		516	544	581	551	565	519	546	

Facility Specific Operating and Emissions Data (PTPC - Continued)

Facility:			PTPC	PTPC	PTPC	PTPC	PTPC	PTPC	PTPC
Run ID or Unit ID:			LK	LK	LK	LK	LK	LK	LK Avg
Pressure (stack absolute)	Ps	in HG	29.92	29.92	29.92	29.92	29.92	29.92	
Pressure (barometric)	Pbar	in HG							
Pressure (stack)	Pa	in H2O							
Conversion Factor	F1	inH2O/inHg							
Total water condensed	Vwstd	scf H2)							
	f	scf H2O/gm							
Total water condensed	Vw	std ft3							
total impinger wt									
Impinger 1	Vi	g							
Impinger 2	Vii	g							
Impinger 3	Viii	g							
Impinger 4	Viv	g							
Ideal gas constant	R	(inHG)(ft3)/(R-lbmol)							
Temperature abs	Tab	R (459.67)	460	460	460	460	460	460	
Temp std	Tstd	R (527.67)	528	528	528	528	528	528	
Conversion Factor	F2	g/lb (should be							
Pressure (std)	Pstd	in HG	29.92	29.92	29.92	29.92	29.92	29.92	
MW of water	MH2O	lb/lbmole	18.015	18.015	18.015	18.015	18.015	18.015	
Sample Volume	Vmstd	dscf							
Sample Volume from meter	Vm	dcf							
Dry gas mtr cal factor	Y	no units							
Meter orifice pressure	dH	in H2O							
Dry gas meter temp	Tm	F							
Stack Gas Moisture Fraction	Bws	vol%/100	0.26	0.26	0.29	0.27	0.28	0.29	0.275
Saturation Moisture Fraction@STP	SBws	(sat vap press)/Ps							
same as BWS (because Bws>SBws)									
Stack Gas Mole weight dry	Md	lb/lbmole	30.131	30.119	30.179	30.264	30.348	30.492	AVG
Oxygen conc in stack	conc O2	%/100	0.09	0.091	0.086	0.079	0.072	0.06	0.07967
CO2 conc in stack	conc CO2	%/100	0.11	0.109	0.114	0.121	0.128	0.14	
N2 conc in stack	con N2	%/100	0.8	0.8	0.8	0.8	0.8	0.8	
Stack Gas Mole weight wet	Ms	lb/lbmole	26.981	26.972	26.652	26.956	26.894	26.873	
Stack Area	A	ft2	28.2743	28.2743	28.2743	28.2743	28.2743	28.2743	
Diameter of stack	D	inches	72	72	72	72	72	72	
Conversion Factor	F3	in/ft	12	12	12	12	12	12	
Stack Gas Velocity	Vs	ft/sec	17.6131	15.8448	15.8801	15.3850	16.8704	15.5618	
Pitot tube constant	Kp	test Vs:							
Pitot tube calibration coef	Cp								
Stack Gas Velocity Head	dP	in H2O							
Stack Gas Velocity Head	dP^0.5								AVG
Stack gas temp	Ts	F	156	155	155	153	155	155	155
flow check			29,880	26,880	26,940	26,100	28,620	6,400	
Stack Ht	Ht	Ft							
Actual Stack Gas Flow Rate	Acf	acfm	29880	26880	26940	26100	28620	26400	
		acfs	498	448	449	435	477	440	
Conversion Factor	F5	sec/min	60	60	60	60	60	60	AVG
Dry std Stack gas flow rate	Qstd	dscfm	18,952	17,077	16,422	16,411	17,691		
Dry std Stack gas flow rate	Qstd	dscf/hr	1,137,147	1,024,639	985,294	84,664	1,061,481		
Conversion Factor	F4	sec/hr	3600	3600	3600	3600	3600	3600	
Isokinetic percent	I	%							
sample nozzle cross section	An	ft2							
length of sample test	theta	minutes							
Mass of part: combined samples	Mn	mg							
Mass of part: probe wash	Mp	mg							
Mass of part: filter	Mf	mg							
Unit Totals (tons per year)	PM10		27	27	20	26	15	23	23
Unit Totals (tons per year)	SO2		1	2	2	1	1	1	1
Unit Totals (tons per year)	NOx		59	59	64	62	34	30	51
Facility Totals (tons per year)	PM10		331	301	333	346	340	292	324
Facility Totals (tons per year)	TSP		515	478	514	589	580	512	531
Facility Totals (tons per year)	SO2		351	349	410	287	123	50	262
Facility Totals (tons per year)	NOx		516	544	581	551	565	519	546

Facility Specific Operating and Emissions Data (WestRock)

Facility:			WestRock	WestRock	WestRock	WestRock	WestRock	WestRock
Run ID or Unit ID:			2005	2006	2007	2008	2009	2005-2009
			rf	rf	rf	rf	rf	RF AVG
Pressure (stack absolute)	Ps	in HG	29.92	29.92	29.92	29.92	29.92	
Pressure (barometric)	Pbar	in HG						
Pressure (stack)	Pa	in H2O						
Conversion Factor	F1	inH2O/inHg						
Total water condensed	Vwstd	scf H2)						
	f	scf H2O/gm						
Total water condensed	Vw	std ft3						
total impinger wt								
Impinger 1	Vi	g						
Impinger 2	Vii	g						
Impinger 3	Viii	g						
Impinger 4	Viv	g						
Ideal gas constant	R	(inHG)(ft3)/(R-lbmol)						
Temperature abs	Tabs	R (459.67)	460	460	460	460	460	
Temp std	Tstd	R (527.67)	528	528	528	528	528	
Conversion Factor	F2	g/lb (should be						
Pressure (std)	Pstd	in HG	29.92	29.92	29.92	29.92	29.92	
MW of water	MH2O	lb/lbmole	18.015	18.015	18.015	18.015	18.015	
Sample Volume	Vmstd	dscf						
Sample Volume from meter	Vm	dcf						
Dry gas mtr cal factor	Y	no units						
Meter orifice pressure	dH	in H2O						
Dry gas meter temp	Tm	F						
Stack Gas Moisture Fraction	Bws	vol%/100	0.247	0.228	0.25	0.229	0.231	0.237
Saturation Moisture Fraction@STP	SBws	(sat vap press)/Ps						
same as BWS (because Bws>SBws)								
Stack Gas Mole weight dry	Md	lb/lbmole	30.480	30.396	30.516	30.516	30.300	AVG
Oxygen conc in stack	conc O2	%/100	0.061	0.068	0.058	0.058	0.076	0.0642
CO2 conc in stack	conc CO2	%/100	0.139	0.132	0.142	0.142	0.124	
N2 conc in stack	con N2	%/100	0.8	0.8	0.8	0.8	0.8	
Stack Gas Mole weight wet	Ms	lb/lbmole	27.401	27.573	27.391	27.653	27.462	
Stack Area	A	ft2	153.9380	153.9380	153.9380	153.9380	153.9380	
Diameter of stack	D	inches	168	168	168	168	168	
Conversion Factor	F3	in/ft	12	12	12	12	12	
Stack Gas Velocity	Vs	ft/sec	37.3592	37.2358	38.5740	35.2739	37.9179	
Pitot tube constant	Kp	test Vs:						
Pitot tube calibration coef	Cp							
Stack Gas Velocity Head	dP	in H2O						
Stack Gas Velocity Head	dP^0.5							AVG
Stack gas temp	Ts	F	377	378	383	388	372	380
flow check			345,060	343,920	356,280	325,800	350,220	
Stack Ht	Ht	Ft						
Actual Stack Gas Flow Rate	Acf	acfm	345060	343920	356280	325800	350220	344,256
		acfs	5751	5732	5938	5430	5837	
Conversion Factor	F5	sec/min	60	60	60	60	60	AVG
Dry std Stack gas flow rate	Qstd	dscfm	163,907	167,288	167,363	156,402	170,914	165,175
Dry std Stack gas flow rate	Qstd	dscf/hr	9,834,433	10,037,276	10,041,77	9,384,146	10,254,84	
Conversion Factor	F4	sec/hr	3600	3600	3600	3600	3600	
Isokinetic percent	I	%						
sample nozzle cross section	An	ft2						
length of sample test	theta	minutes						
Mass of part: combined samples	Mn	mg						
Mass of part: probe wash	Mp	mg						
Mass of part: filter	Mf	mg						
Unit Totals (tons per year)	PM10		13	23	46	29	19	26
Unit Totals (tons per year)	SO2		293	238	400	390	110	286
Unit Totals (tons per year)	NOx		291	294	281	303	257	285
Facility Totals (tons per year)	PM10		103	75	117	87	76	92
Facility Totals (tons per year)	TSP		121	94	147	105	87	111
Facility Totals (tons per year)	SO2		378	503	693	635	319	506
Facility Totals (tons per year)	NOx		610	743	708	684	808	711

Facility Specific Operating and Emissions Data (WestRock - Continued)

Facility:			WestRock	WestRock	WestRock	WestRock	WestRock	WestRock
Run ID or Unit ID:			2005	2006	2007	2008	2009	2005-2009
			Lk 1	Lk1	Lk 1	Lk 1	Lk 1	LK 1 Avg
Pressure (stack absolute)	Ps	in HG	29.92	29.92	29.92	29.92	29.92	
Pressure (barometric)	Pbar	in HG						
Pressure (stack)	Pa	in H2O						
Conversion Factor	F1	inH2O/inHg						
Total water condensed	Vwstd	scf H2)						
	f	scf H2O/gm						
Total water condensed	Vw	std ft3						
total impinger wt								
Impinger 1	Vi	g						
Impinger 2	Vii	g						
Impinger 3	Viii	g						
Impinger 4	Viv	g						
Ideal gas constant	R	(inHG)(ft3)/(R-lbmol)						
Temperature abs	Tab	R (459.67)	460	460	460	460	460	
Temp std	Tstd	R (527.67)	528	528	528	528	528	
Conversion Factor	F2	g/lb (should be						
Pressure (std)	Pstd	in HG	29.92	29.92	29.92	29.92	29.92	
MW of water	MH2O	lb/lbmole	18.015	18.015	18.015	18.015	18.015	
Sample Volume	Vmstd	dscf						
Sample Volume from meter	Vm	dcf						
Dry gas mtr cal factor	Y	no units						
Meter orifice pressure	dH	in H2O						
Dry gas meter temp	Tm	F						
Stack Gas Moisture Fraction	Bws	vol%/100	0.291	0.346	0.284	0.345	0.346	0.322
Saturation Moisture Fraction@STP	SBws	(sat vap press)/Ps						
same as BWS (because Bws>SBws)								
Stack Gas Mole weight dry	Md	lb/lbmole	30.900	30.696	30.612	30.636	30.384	AVG
Oxygen conc in stack	conc O2	%/100	0.026	0.043	0.05	0.048	0.069	0.0472
CO2 conc in stack	conc CO2	%/100	0.174	0.157	0.15	0.152	0.131	
N2 conc in stack	con N2	%/100	0.8	0.8	0.8	0.8	0.8	
Stack Gas Mole weight wet	Ms	lb/lbmole	27.151	26.308	27.034	26.282	26.104	
Stack Area	A	ft2	12.5664	12.5664	12.5664	12.5664	12.5664	
Diameter of stack	D	inches	48	48	48	48	48	
Conversion Factor	F3	in/ft	12	12	12	12	12	
Stack Gas Velocity	Vs	ft/sec	48.3035	55.4655	47.1894	48.5423	56.3408	
Pitot tube constant	Kp	test Vs:						
Pitot tube calibration coef	Cp							
Stack Gas Velocity Head	dP	in H2O						
Stack Gas Velocity Head	dP^0.5							AVG
Stack gas temp	Ts	F	157	162	158	156	162	159
flow check			36,420	41,820	35,580	36,600	42,480	AVG
Stack Ht	Ht	Ft						
Actual Stack Gas Flow Rate	Acf	acfm	36420	41820	35580	36600	42480	38580
		acfs	607	697	593	610	708	
Conversion Factor	F5	sec/min	60	60	60	60	60	AVG
Dry std Stack gas flow rate	Qstd	dscfm	22,097	23,217	21,765	20,548	23,583	22,242
Dry std Stack gas flow rate	Qstd	dscf/hr	1,325,825	1,393,017	1,305,917	1,232,897	1,415,002	
Conversion Factor	F4	sec/hr	3600	3600	3600	3600	3600	
Isokinetic percent	I	%						
sample nozzle cross section	An	ft2						
length of sample test	theta	minutes						
Mass of part: combined samples	Mn	mg						
Mass of part: probe wash	Mp	mg						
Mass of part: filter	Mf	mg						
Unit Totals (tons per year)	PM10		30	19	28	22	19	AVG
Unit Totals (tons per year)	SO2		1	3	1	5	8	3.6
Unit Totals (tons per year)	NOx		42	42	39	37	54	42.8
Facility Totals (tons per year)	PM10		103	75	117	87	76	92
Facility Totals (tons per year)	TSP		121	94	147	105	87	111
Facility Totals (tons per year)	SO2		378	503	693	635	319	506
Facility Totals (tons per year)	NOx		610	743	708	684	808	711

Facility Specific Operating and Emissions Data (WestRock - Continued)

Facility:			WestRock	WestRock	WestRock	WestRock	WestRock	WestRock
Run ID or Unit ID:			2005	2006	2007	2008	2009	2005-2009
			lk2	lk2	lk2	lk2	lk2	LK 2 Avg
Pressure (stack absolute)	Ps	in HG	29.92	29.92	29.92	29.92	29.92	
Pressure (barometric)	Pbar	in HG						
Pressure (stack)	Pa	in H2O						
Conversion Factor	F1	inH2O/inHg						
Total water condensed	Vwstd	scf H2)						
	f	scf H2O/gm						
Total water condensed	Vw	std ft3						
total impinger wt								
Impinger 1	Vi	g						
Impinger 2	Vii	g						
Impinger 3	Viii	g						
Impinger 4	Viv	g						
Ideal gas constant	R	(inHG)(ft3)/(R-lbmol)						
Temperature abs	Tabs	R (459.67)	460	460	460	460	460	
Temp std	Tstd	R (527.67)	528	528	528	528	528	
Conversion Factor	F2	g/lb (should be						
Pressure (std)	Pstd	in HG	29.92	29.92	29.92	29.92	29.92	
MW of water	MH2O	lb/lbmole	18.015	18.015	18.015	18.015	18.015	
Sample Volume	Vmstd	dscf						
Sample Volume from meter	Vm	dcf						
Dry gas mtr cal factor	Y	no units						
Meter orifice pressure	dH	in H2O						
Dry gas meter temp	Tm	F						
Stack Gas Moisture Fraction	Bws	vol%/100	0.233	0.17	0.117	0.136	0.149	0.161
Saturation Moisture Fraction@STP	SBws	(sat vap press)/Ps						
same as BWS (because Bws>SBws)								
Stack Gas Mole weight dry	Md	lb/lbmole	30.504	30.672	30.720	30.432	30.492	AVG
Oxygen conc in stack	conc O2	%/100	0.059	0.045	0.041	0.065	0.06	0.054
CO2 conc in stack	conc CO2	%/100	0.141	0.155	0.159	0.135	0.14	
N2 conc in stack	con N2	%/100	0.8	0.8	0.8	0.8	0.8	
Stack Gas Mole weight wet	Ms	lb/lbmole	27.594	28.520	29.233	28.743	28.633	
Stack Area	A	ft2	12.5664	12.5664	12.5664	12.5664	12.5664	
Diameter of stack	D	inches	48	48	48	48	48	
Conversion Factor	F3	in/ft	12	12	12	12	12	
Stack Gas Velocity	Vs	ft/sec	26.4993	15.9951	12.0162	11.9366	12.7324	
Pitot tube constant	Kp	test Vs:						
Pitot tube calibration coef	Cp							
Stack Gas Velocity Head	dP	in H2O						
Stack Gas Velocity Head	dP^0.5							AVG
Stack gas temp	Ts	F	144	133	126	121	129	130.6
flow check			19,980	12,060	9,060	9,000	9,600	
Stack Ht	Ht	Ft						
Actual Stack Gas Flow Rate	Acf	acfm	19980	12060	9060	9000	9600	11940
		acfs	333	201	151	150	160	
Conversion Factor	F5	sec/min	60	60	60	60	60	AVG
Dry std Stack gas flow rate	Qstd	dscfm	13,396	8,913	7,208	7,067	7,324	8,781
Dry std Stack gas flow rate	Qstd	dscf/hr	803,783	534,756	432,490	423,999	439,411	
Conversion Factor	F4	sec/hr	3600	3600	3600	3600	3600	
Isokinetic percent	I	%						
sample nozzle cross section	An	ft2						
length of sample test	theta	minutes						
Mass of part: combined samples	Mn	mg						
Mass of part: probe wash	Mp	mg						
Mass of part: filter	Mf	mg						
Unit Totals (tons per year)	PM10		6	4	5	4	5	4.8
Unit Totals (tons per year)	SO2		1	1	2	2	0	1.2
Unit Totals (tons per year)	NOx		1	1	2	2	6	2.4
Facility Totals (tons per year)	PM10		103	75	117	87	76	92
Facility Totals (tons per year)	TSP		121	94	147	105	87	111
Facility Totals (tons per year)	SO2		378	503	693	635	319	506
Facility Totals (tons per year)	NOx		610	743	708	684	808	711

Facility Specific Operating and Emissions Data (Weyerhaeuser)

Facility:			Weyerhaeus	Weyerhaeus	Weyerhaeus	Weyerh	Weyerhae	Weyerhaeus
Run ID or Unit ID:			2003	2004	2005	2006	2007	2003-2007
			rf	rf	rf	rf	rf	RF Avg
Pressure (stack absolute)	Ps	in HG	29.92	29.92	29.92	29.92	29.92	
Pressure (barometric)	Pbar	in HG						
Pressure (stack)	Pa	in H2O						
Conversion Factor	F1	inH2O/inHg						
Total water condensed	Vwstd	scf H2)						
	f	scf H2O/gm						
Total water condensed	Vw	std ft3						
total impinger wt								
Impinger 1	Vi	g						
Impinger 2	Vii	g						
Impinger 3	Viii	g						
Impinger 4	Viv	g						
Ideal gas constant	R	(inHG)(ft3)/(R-lbmol)						
Temperature abs	Tab	R (459.67)	460	460	460	460	460	
Temp std	Tstd	R (527.67)	528	528	528	528	528	
Conversion Factor	F2	g/lb (should be						
Pressure (std)	Pstd	in HG	29.92	29.92	29.92	29.92	29.92	
MW of water	MH2O	lb/lbmole	18.015	18.015	18.015	18.015	18.015	
Sample Volume	Vmstd	dscf						
Sample Volume from meter	Vm	dcf						
Dry gas mtr cal factor	Y	no units						
Meter orifice pressure	dH	in H2O						
Dry gas meter temp	Tm	F						
Stack Gas Moisture Fraction	Bws	vol%/100	0.29	0.28	0.26	0.28	0.2775	0.2775
Saturation Moisture Fraction@STP	SBws	(sat vap press)/Ps						
same as BWS (because Bws>SBws)								
Stack Gas Mole weight dry	Md	lb/lbmole	30.372	30.492	30.312	30.504	30.420	AVG
Oxygen conc in stack	conc O2	%/100	0.07	0.06	0.075	0.059	0.066	0.0660
CO2 conc in stack	conc CO2	%/100	0.13	0.14	0.125	0.141	0.134	
N2 conc in stack	con N2	%/100	0.8	0.8	0.8	0.8	0.8	
Stack Gas Mole weight wet	Ms	lb/lbmole						
Stack Area	A	ft2	153.9380	153.9380	153.9380	153.938	153.9380	
Diameter of stack	D	inches	168	168	168	168	168	
Conversion Factor	F3	in/ft	12	12	12	12	12	
Stack Gas Velocity	Vs	ft/sec	58.6859	55.4314	55.5613	63.3956	63.5300	
Pitot tube constant	Kp	test Vs:						
Pitot tube calibration coef	Cp							
Stack Gas Velocity Head	dP	in H2O						
Stack Gas Velocity Head	dP^0.5							AVG
Stack gas temp	Ts	F	362	357	373	387	388	373
flow check			542,040	511,980	513,180	585,540	586,781	
Stack Ht	Ht	Ft						
Actual Stack Gas Flow Rate	Acf	acfm	542040	511980	513180	585540	586800	547,908
		acfs	9034	8533	8553	9759	9780	
Conversion Factor	F5	sec/min	60	60	60	60	60	AVG
Dry std Stack gas flow rate	Qstd	dscfm	247,202	238,230	240,708	262,809	263,968	250,583
Dry std Stack gas flow rate	Qstd	dscf/hr	14,832,114	14,293,830	14,442,475	15,768,	15,838,10	
Conversion Factor	F4	sec/hr	3600	3600	3600	3600	3600	
Isokinetic percent	I	%						
sample nozzle cross section	An	ft2						
length of sample test	theta	minutes						
Mass of part: combined samples	Mn	mg						
Mass of part: probe wash	Mp	mg						
Mass of part: filter	Mf	mg						
Unit Totals (tons per year)	PM10		50	45	32	50	40	43
Unit Totals (tons per year)	SO2		26	20	50	42	38	35
Unit Totals (tons per year)	NOx		627	541	483	601	666	584
Facility Totals (tons per year)	PM10		279	196	173	191	89	186
Facility Totals (tons per year)	TSP		375	278	244	211	na	277
Facility Totals (tons per year)	SO2		967	1047	854	719	775	872
Facility Totals (tons per year)	NOx		2487	2069	1959	2057	2630	2,240

Facility Specific Operating and Emissions Data (Weyerhaeuser - Continued)

Facility:			Weyerhaeus	Weyerhaeus	Weyerhaeus	Weyerh	Weyerhae	Weyerhaeus
Run ID or Unit ID:			2003	2004	2005	2006	2007	2003-2007
			lk	lk	lk	lk	lk	LK Avg
Pressure (stack absolute)	Ps	in HG	29.92	29.92	29.92	29.92	29.92	
Pressure (barometric)	Pbar	in HG						
Pressure (stack)	Pa	in H2O						
Conversion Factor	F1	inH2O/inHg						
Total water condensed	Vwstd	scf H2)						
	f	scf H2O/gm						
Total water condensed	Vw	std ft3						
total impinger wt								
Impinger 1	Vi	g						
Impinger 2	Vii	g						
Impinger 3	Viii	g						
Impinger 4	Viv	g						
Ideal gas constant	R	(inHG)(ft3)/(R-lbmol)						
Temperature abs	Tabs	R (459.67)	460	460	460	460	460	
Temp std	Tstd	R (527.67)	528	528	528	528	528	
Conversion Factor	F2	g/lb (should be						
Pressure (std)	Pstd	in HG	29.92	29.92	29.92	29.92	29.92	
MW of water	MH2O	lb/lbmole	18.015	18.015	18.015	18.015	18.015	
Sample Volume	Vmstd	dscf						
Sample Volume from meter	Vm	dcf						
Dry gas mtr cal factor	Y	no units						
Meter orifice pressure	dH	in H2O						
Dry gas meter temp	Tm	F						
Stack Gas Moisture Fraction	Bws	vol%/100	0.29	0.3	0.3	0.31	0.3	0.3
Saturation Moisture Fraction@STP	SBws	(sat vap press)/Ps						
same as BWS (because Bws>SBws)								
Stack Gas Mole weight dry	Md	lb/lbmole	30.252	30.252	30.011	30.252	30.191	AVG
Oxygen conc in stack	conc O2	%/100	0.08	0.08	0.1	0.08	0.085	0.0850
CO2 conc in stack	conc CO2	%/100	0.12	0.12	0.1	0.12	0.115	
N2 conc in stack	con N2	%/100	0.8	0.8	0.8	0.8	0.8	
Stack Gas Mole weight wet	Ms	lb/lbmole						
Stack Area	A	ft2	12,5664	12,5664	12,5664	12,5664	12,5664	
Diameter of stack	D	inches	48	48	48	48	48	
Conversion Factor	F3	in/ft	12	12	12	12	12	
Stack Gas Velocity	Vs	ft/sec	41.1416	94.2993	67.8000	74.3254	75.6000	
Pitot tube constant	Kp	test Vs:						
Pitot tube calibration coef	Cp							
Stack Gas Velocity Head	dP	in H2O						
Stack Gas Velocity Head	dP^0.5							AVG
Stack gas temp	Ts	F	388	396	380	390	391	389
flow check			31,020	71,100	51,120	56,040	57,001	
Stack Ht	Ht	Ft						
Actual Stack Gas Flow Rate	Acf	acfm	31020	71100	51120	56040	57000	53,256
		acfs	517	1185	852	934	950	
Conversion Factor	F5	sec/min	60	60	60	60	60	AVG
Dry std Stack gas flow rate	Qstd	dscfm	13,713	30,699	22,493	24,019	24,756	23,136
Dry std Stack gas flow rate	Qstd	dscf/hr	822,791	1,841,955	1,349,568	1,441,1	1,485,377	
Conversion Factor	F4	sec/hr	3600	3600	3600	3600	3600	
Isokinetic percent	I	%						
sample nozzle cross section	An	ft2						
length of sample test	theta	minutes						
Mass of part: combined samples	Mn	mg						
Mass of part: probe wash	Mp	mg						
Mass of part: filter	Mf	mg						
Unit Totals (tons per year)	PM10		88	2	1	9	1	AVG
Unit Totals (tons per year)	SO2		3	4	12	7	4	20
Unit Totals (tons per year)	NOx		104	100	158	147	135	129
Facility Totals (tons per year)	PM10		279	196	173	191	89	186
Facility Totals (tons per year)	TSP		375	278	244	211	na	277
Facility Totals (tons per year)	SO2		967	1047	854	719	775	872
Facility Totals (tons per year)	NOx		2487	2069	1959	2057	2630	2,240

Facility Specific Operating and Emissions Data (GP Camas)

Facility:			GP Camas	GPCamas	GPCamas	GPCam	GPCamas	avg
		Run ID or Unit ID:	2003 rf4	2004 rf4	2005 rf4	2006 rf4	2007 rf4	2003-2007 RF4 Avg
Pressure (stack absolute)	Ps	in HG	29.84	29.84	29.84	29.84	29.84	
Pressure (barometric)	Pbar	in HG						
Pressure (stack)	Pa	in H2O						
Conversion Factor	F1	inH2O/inHg						
Total water condensed	Vwstd	scf H2)						
	f	scf H2O/gm						
Total water condensed	Vw	std ft3						
total impinger wt								
Impinger 1	Vi	g						
Impinger 2	Vii	g						
Impinger 3	Viii	g						
Impinger 4	Viv	g						
Ideal gas constant	R	(inHG)(ft3)/(R-lbmol)						
Temperature abs	Tab	R (459.67)	460	460	460	460	460	
Temp std	Tstd	R (527.67)	528	528	528	528	528	
Conversion Factor	F2	g/lb (should be						
Pressure (std)	Pstd	in HG	29.92	29.92	29.92	29.92	29.92	
MW of water	MH2O	lb/lbmole	18.015	18.015	18.015	18.015	18.015	
Sample Volume	Vmstd	dscf						
Sample Volume from meter	Vm	dcf						
Dry gas mtr cal factor	Y	no units						
Meter orifice pressure	dH	in H2O						
Dry gas meter temp	Tm	F						
Stack Gas Moisture Fraction	Bws	vol%/100	0.2	0.2	0.23	0.21	0.28	0.224
Saturation Moisture Fraction@STP same as BWS (because Bws>SBws)	SBws	(sat vap press)/Ps						
Stack Gas Mole weight dry	Md	lb/lbmole	30.372	30.372	30.372	30.372	30.312	AVG
Oxygen conc in stack	conc O2	%/100	0.07	0.07	0.07	0.07	0.075	0.0710
CO2 conc in stack	conc CO2	%/100	0.13	0.13	0.13	0.13	0.125	
N2 conc in stack	con N2	%/100	0.8	0.8	0.8	0.8	0.8	
Stack Gas Mole weight wet	Ms	lb/lbmole						
Stack Area	A	ft2	63.6173	63.6173	63.6173	63.6173	63.6173	
Diameter of stack	D	inches	108	108	108	108	108	
Conversion Factor	F3	in/ft	12	12	12	12	12	
Stack Gas Velocity	Vs	ft/sec	31.9096	34.2046	30.8407	31.3437	36.1694	
Pitot tube constant	Kp	test Vs:						
Pitot tube calibration coef	Cp							
Stack Gas Velocity Head	dP	in H2O						
Stack Gas Velocity Head	dP [^] .5							AVG
Stack gas temp	Ts	F	139	140	145	143	154	144
flow check			121,800	130,560	117,720	119,640	138,060	
Stack Ht	Ht	Ft						
Actual Stack Gas Flow Rate	Acf	acfm	121800	130560	117720	119640	138060	125,556
Conversion Factor	F5	acfs	2030	2176	1962	1994	2301	
		sec/min	60	60	60	60	60	AVG
Dry std Stack gas flow rate	Qstd	dscfm	85,661	91,668	78,896	82,539	85,252	84,803
Dry std Stack gas flow rate	Qstd	dscf/hr	5,139,642	5,500,109	4,733,779	4,952,3	5,115,103	
Conversion Factor	F4	sec/hr	3600	3600	3600	3600	3600	
Isokinetic percent	I	%						
sample nozzle cross section	An	ft2						
length of sample test	theta	minutes						
Mass of part: combined samples	Mn	mg						
Mass of part: probe wash	Mp	mg						
Mass of part: filter	Mf	mg						
Unit Totals (tons per year)	PM10		74	74	52	50	75	65
Unit Totals (tons per year)	SO2		2	4	3	3	3	3
Unit Totals (tons per year)	NOx		173	166	224	223	251	207
Facility Totals (tons per year)	PM10		174	191	254	233	236	218
Facility Totals (tons per year)	TSP		188	195	259	240	239	224
Facility Totals (tons per year)	SO2		66	151	18	13	21	54
Facility Totals (tons per year)	NOx		772	709	783	765	660	738

Facility Specific Operating and Emissions Data (GP Camas - Continued)

Facility:			GP Camas	GP Camas	GP Camas	GPCam	GPCamas	avg
		Run ID or Unit ID:	2003	2004	2005	2006	2007	2003-2007
			rf3	rf3	rf3	rf3	rf3	RF3 Avg
Pressure (stack absolute)	Ps	in HG	29.84	29.84	29.84	29.84	29.84	
Pressure (barometric)	Pbar	in HG						
Pressure (stack)	Pa	in H2O						
Conversion Factor	F1	inH2O/inHg						
Total water condensed	Vwstd	scf H2)						
	f	scf H2O/gm						
Total water condensed	Vw	std ft3						
total impinger wt								
Impinger 1	Vi	g						
Impinger 2	Vii	g						
Impinger 3	Viii	g						
Impinger 4	Viv	g						
Ideal gas constant	R	(inHG)(ft3)/(R-lbmol)						
Temperature abs	Tabs	R (459.67)	460	460	460	460	460	
Temp std	Tstd	R (527.67)	528	528	528	528	528	
Conversion Factor	F2	g/lb (should be						
Pressure (std)	Pstd	in HG	29.92	29.92	29.92	29.92	29.92	
MW of water	MH2O	lb/lbmole	18.015	18.015	18.015	18.015	18.015	
Sample Volume	Vmstd	dscf						
Sample Volume from meter	Vm	dcf						
Dry gas mtr cal factor	Y	no units						
Meter orifice pressure	dH	in H2O						
Dry gas meter temp	Tm	F						
Stack Gas Moisture Fraction	Bws	vol%/100	0.22	0.18	0.21	0.2	0.19	0.2
Saturation Moisture Fraction@STP	SBws	(sat vap press)/Ps						
same as BWS (because Bws>SBws)								
Stack Gas Mole weight dry	Md	lb/lbmole	30.504	30.492	30.492	30.492	30.540	AVG
Oxygen conc in stack	conc O2	%/100	na	0.06	0.06	0.06	0.056	0.0590
CO2 conc in stack	conc CO2	%/100	na	0.14	0.14	0.14	0.144	
N2 conc in stack	con N2	%/100	0.8	0.8	0.8	0.8	0.8	
Stack Gas Mole weight wet	Ms	lb/lbmole						
Stack Area	A	ft2	63.6173	63.6173	63.6173	63.6173	63.6173	
Diameter of stack	D	inches	108	108	108	108	108	
Conversion Factor	F3	in/ft	12	12	12	12	12	
Stack Gas Velocity	Vs	ft/sec	22.1638	25.3076	19.8531	19.5702	19.1300	
Pitot tube constant	Kp	test Vs:						
Pitot tube calibration coef	Cp							
Stack Gas Velocity Head	dP	in H2O						
Stack Gas Velocity Head	dP^0.5							AVG
Stack gas temp	Ts	F	143	136	144	141	137	140
flow check			84,600	96,600	75,780	74,700	73,020	
Stack Ht	Ht	Ft						
Actual Stack Gas Flow Rate	Acf	acfm	84600	96600	75780	74700	73020	80,940
		acfs	1410	1610	1263	1245	1217	
Conversion Factor	F5	sec/min	60	60	60	60	60	AVG
Dry std Stack gas flow rate	Qstd	dscfm	57.626	69.987	52.193	52.361	52.170	56.867
Dry std Stack gas flow rate	Qstd	dscf/hr	3,457,563	4,199,205	3,131,606	3,141,6	3,130,220	
Conversion Factor	F4	sec/hr	3600	3600	3600	3600	3600	
Isokinetic percent	I	%						
sample nozzle cross section	An	ft2						
length of sample test	theta	minutes						
Mass of part: combined samples	Mn	mg						
Mass of part: probe wash	Mp	mg						
Mass of part: filter	Mf	mg						
Unit Totals (tons per year)	PM10		8	8	9	5	3	AVG
Unit Totals (tons per year)	SO2		2	2	3	2	2	7
Unit Totals (tons per year)	NOx		138	140	157	102	58	119
Facility Totals (tons per year)	PM10		174	191	254	233	236	218
Facility Totals (tons per year)	TSP		188	195	259	240	239	224
Facility Totals (tons per year)	SO2		66	151	18	13	21	54
Facility Totals (tons per year)	NOx		772	709	783	765	660	738

Facility Specific Operating and Emissions Data (GP Camas - Continued)

		Facility:	GP Camas	GP Camas	GP Camas	GPCam	GPCamas	avg
		Run ID or Unit ID:	2003	2004	2005	2006	2007	2003-2007
			lk	lk	lk	lk	lk	LK Avg
Pressure (stack absolute)	Ps	in HG	29.84	29.84	29.84	29.84	29.84	
Pressure (barometric)	Pbar	in HG						
Pressure (stack)	Pa	in H2O						
Conversion Factor	F1	inH2O/inHg						
Total water condensed	Vwstd	scf H2)						
	f	scf H2O/gm						
Total water condensed	Vw	std ft3						
total impinger wt								
Impinger 1	Vi	g						
Impinger 2	Vii	g						
Impinger 3	Viii	g						
Impinger 4	Viv	g						
Ideal gas constant	R	(inHG)(ft3)/(R-lbmol)						
Temperature abs	Tabs	R (459.67)	460	460	460	460	460	
Temp std	Tstd	R (527.67)	528	528	528	528	528	
Conversion Factor	F2	g/lb (should be						
Pressure (std)	Pstd	in HG	29.92	29.92	29.92	29.92	29.92	
MW of water	MH2O	lb/lbmole	18.015	18.015	18.015	18.015	18.015	
Sample Volume	Vmstd	dscf						
Sample Volume from meter	Vm	dcf						
Dry gas mtr cal factor	Y	no units						
Meter orifice pressure	dH	in H2O						
Dry gas meter temp	Tm	F						
Stack Gas Moisture Fraction	Bws	vol%/100	0.35	0.32	0.39	0.4	0.41	0.374
Saturation Moisture Fraction@STP	SBws	(sat vap press)/Ps						
same as BWS (because Bws>SBws)								
Stack Gas Mole weight dry	Md	lb/lbmole	30.732	30.852	30.852	30.852	30.996	AVG
Oxygen conc in stack	conc O2	%/100	0.04	0.03	0.03	0.03	0.018	0.0296
CO2 conc in stack	conc CO2	%/100	0.16	0.17	0.17	0.17	0.182	
N2 conc in stack	con N2	%/100	0.8	0.8	0.8	0.8	0.8	
Stack Gas Mole weight wet	Ms	lb/lbmole						
Stack Area	A	ft2	19.6350	19.6350	19.6350	19.6350	19.6350	
Diameter of stack	D	inches	60	60	60	60	60	
Conversion Factor	F3	in/ft	12	12	12	12	12	
Stack Gas Velocity	Vs	ft/sec	9.7276	11.0517	9.4729	7.7413	5.8569	
Pitot tube constant	Kp	test Vs:						
Pitot tube calibration coef	Cp							
Stack Gas Velocity Head	dP	in H2O						
Stack Gas Velocity Head	dP ^{0.5}							AVG
Stack gas temp	Ts	F	149	150	160	159	158	155
flow check			11,460	13,020	11,160	9,120	6,900	
Stack Ht	Ht	Ft						
Actual Stack Gas Flow Rate	Acf	acfm	11460	13020	11160	9120	6900	10,332
		acfs	191	217	186	152	115	
Conversion Factor	F5	sec/min	60	60	60	60	60	AVG
Dry std Stack gas flow rate	Qstd	dscfm	6.441	7.643	5.782	4.655	3.469	5.598
Dry std Stack gas flow rate	Qstd	dscf/hr	386,459	458,577	346,916	279,304	208,130	
Conversion Factor	F4	sec/hr	3600	3600	3600	3600	3600	
Isokinetic percent	I	%						
sample nozzle cross section	An	ft2						
length of sample test	theta	minutes						
Mass of part: combined samples	Mn	mg						
Mass of part: probe wash	Mp	mg						
Mass of part: filter	Mf	mg						
Unit Totals (tons per year)	PM10		17	15	18	8	8	13
Unit Totals (tons per year)	SO2		0	1	1	1	1	1
Unit Totals (tons per year)	NOx		83	77	150	132	79	104
Facility Totals (tons per year)	PM10		174	191	254	233	236	218
Facility Totals (tons per year)	TSP		188	195	259	240	239	224
Facility Totals (tons per year)	SO2		66	151	18	13	21	54
Facility Totals (tons per year)	NOx		772	709	783	765	660	738

Facility Specific Operating and Emissions Data (KapStone)

Facility:			KaptS	KaptSto	KaptSto	KaptStone	KaptStone	KaptStone	KaptSton	KaptSton
Run ID or Unit ID:			2005	2006	2007	2008	2009	2010	2011	2005-
			rf 18	rf 18	rf 18	rf 18	rf 18	rf 18	rf 18	RF 18 avg
Pressure (stack absolute)	Ps	in HG	29.92	29.92	29.92	29.92	29.92	29.92	29.92	
Pressure (barometric)	Pbar	in HG								
Pressure (stack)	Pa	in H2O								
Conversion Factor	F1	inH2O/inHg								
Total water condensed	Vwst	scf H2)								
	f	scf H2O/gm								
Total water condensed	Vw	std ft3								
total impinger wt										
Impinger 1	Vi	g								
Impinger 2	Vii	g								
Impinger 3	Viii	g								
Impinger 4	Viv	g								
Ideal gas constant	R	(inHG)(ft3)/(R-lbmol)								
Temperature abs	Tabs	R (459.67)	460	460	460	460	460	460	460	
Temp std	Tstd	R (527.67)	528	528	528	528	528	528	528	
Conversion Factor	F2	g/lb (should be								
Pressure (std)	Pstd	in HG	29.92	29.92	29.92	29.92	29.92	29.92	29.92	
MW of water	MH2O	lb/lbmole	18.01	18.015	18.015	18.015	18.015	18.015	18.015	
Sample Volume	Vmst	dscf								
Sample Volume from meter	Vm	dcf								
Dry gas mtr cal factor	Y	no units								
Meter orifice pressure	dH	in H2O								
Dry gas meter temp	Tm	F								
Stack Gas Moisture Fraction	Bws	vol%/100	0.254	0.283	0.312	0.271	na	0.244	0.255	0.26983
Saturation Moisture	SBws	(sat vap press)/Ps								
same as BWS (because										
Stack Gas Mole weight dry	Md	lb/lbmole	30.19	30.215	30.155	30.095		30.011	30.071	AVG
Oxygen conc in stack	conc	%/100	0.085	0.083	0.088	0.093	na	0.1	0.095	0.0907
CO2 conc in stack	conc	%/100	0.115	0.117	0.112	0.107		0.1	0.105	
N2 conc in stack	con	%/100	0.8	0.8	0.8	0.8	0.8	0.8	0.8	
Stack Gas Mole weight wet	Ms	lb/lbmole								
Stack Area	A	ft2	103.8	103.868	103.868	103.8689		103.8689	103.8689	
Diameter of stack	D	inches	138	138	138	138	138	138	138	
Conversion Factor	F3	in/ft	12	12	12	12	12	12	12	
Stack Gas Velocity	Vs	ft/sec	44.08	44.4118	41.1576	49.6395		48.8789	44.9028	
Pitot tube constant	Kp	test Vs:								
Pitot tube calibration coef	Cp									
Stack Gas Velocity Head	dP	in H2O								
Stack Gas Velocity Head	dP^0.5									AVG
Stack gas temp	Ts	F	243	256	244	247	na	206	237	239
flow check			274.7	276.780	256.500	309.360		304.620	279.840	
Stack Ht	Ht	Ft	214							
Actual Stack Gas Flow Rate	Acf	acfm	27474	276780	256500	309360	na	304620	279840	283,640
Conversion Factor	F5	acfs	4579	4613	4275	5156	na	5077	4664	
		sec/min	60	60	60	60	60	60	60	AVG
Dry std Stack gas flow rate	Qstd	dscfm	153.9	146.344	132.354	168.425	na	182.574	157.931	156,927
Dry std Stack gas flow rate	Qstd	dscf/hr	9,236	8,780.6	7,941.2	10,105.492	na	10,954.465	9,475.856	
Conversion Factor	F4	sec/hr	3600	3600	3600	3600	3600	3600	3600	
	Qstd	dscf/min								
Isokinetic percent	I	%								
sample nozzle cross section	An	ft2								
length of sample test	theta	minutes								
Mass of part: combined	Mn	mg								
Mass of part: probe wash	Mp	mg								
Mass of part: filter	Mf	mg								
Unit Totals (tons per year)	PM10		3	2	3	6	na	4	6	AVG
Unit Totals (tons per year)	SO2		17	12	10	9	na	12	13	12
Unit Totals (tons per year)	NOx		125	132	159	141	na	72	132	127
Facility Totals (tons per year)	PM10		163	121	114	76	81	87	81	103
Facility Totals (tons per year)	TSP		176	132	119	81	86	91	85	110
Facility Totals (tons per year)	SO2		239	274	275	281	201	239	202	244
Facility Totals (tons per year)	NOx		1493	1541	1488	1440	1164	1301	1372	1,400

Facility Specific Operating and Emissions Data (KapStone - Continued)

Facility:			KaptS	KaptSto	KaptSto	KaptStone	KaptStone	KaptStone	KaptSton	KaptSton
Run ID or Unit ID:			2005	2006	2007	2008	2009	2010	2011	2005-
			rf19	rf19	rf19	rf19	rf19	rf19	rf19	RF 19 avg
Pressure (stack absolute)	Ps	in HG	29.92	29.92	29.92	29.92	29.92	29.92	29.92	
Pressure (barometric)	Pbar	in HG								
Pressure (stack)	Pa	in H2O								
Conversion Factor	F1	inH2O/inHg								
Total water condensed	Vwst	scf H2)								
	f	scf H2O/gm								
Total water condensed	Vw	std ft3								
total impinger wt										
Impinger 1	Vi	g								
Impinger 2	Vii	g								
Impinger 3	Viii	g								
Impinger 4	Viv	g								
Ideal gas constant	R	(inHG)(ft3)/(R-lbmol)								
Temperature abs	Tabs	R (459.67)	460	460	460	460	460	460	460	
Temp std	Tstd	R (527.67)	528	528	528	528	528	528	528	
Conversion Factor	F2	g/lb (should be								
Pressure (std)	Pstd	in HG	29.92	29.92	29.92	29.92	29.92	29.92	29.92	
MW of water	MH2O	lb/lbmole	18.01	18.015	18.015	18.015	18.015	18.015	18.015	
Sample Volume	Vmst	dscf								
Sample Volume from meter	Vm	dcf								
Dry gas mtr cal factor	Y	no units								
Meter orifice pressure	dH	in H2O								
Dry gas meter temp	Tm	F								
Stack Gas Moisture Fraction	Bws	vol%/100	0.287	0.287	0.281	0.297	0.265	0.249	0.265	0.27586
Saturation Moisture	SBws	(sat vap press)/Ps								
same as BWS (because										
Stack Gas Mole weight dry	Md	lb/lbmole	30.31	30.312	30.240	30.215	30.131	30.095	30.095	AVG
Oxygen conc in stack	conc	%/100	0.075	0.075	0.081	0.083	0.09	0.093	0.093	0.0843
CO2 conc in stack	conc	%/100	0.125	0.125	0.119	0.117	0.11	0.107	0.107	
N2 conc in stack	con	%/100	0.8	0.8	0.8	0.8	0.8	0.8	0.8	
Stack Gas Mole weight wet	Ms	lb/lbmole								
Stack Area	A	ft2	143.1	143.138	143.138	143.1388	143.1388	143.1388	143.1388	
Diameter of stack	D	inches	162	162	162	162	162	162	162	
Conversion Factor	F3	in/ft	12	12	12	12	12	12	12	
Stack Gas Velocity	Vs	ft/sec	36.85	37.2436	39.8424	45.4664	40.6598	42.6858	41.4982	
Pitot tube constant	Kp	test Vs:								
Pitot tube calibration coef	Cp									
Stack Gas Velocity Head	dP	in H2O								
Stack Gas Velocity Head	dP^0.5									AVG
Stack gas temp	Ts	F	246	247	251	253	242	255	229	246
flow check			316.5	319.860	342.180	390.480	349.200	366.600	356.400	
Stack Ht	Ht	Ft	198							
Actual Stack Gas Flow Rate	Acf	acfm	31650	319860	342180	390480	349200	366600	356400	348,746
		acfs	5275	5331	5703	6508	5820	6110	5940	
Conversion Factor	F5	sec/min	60	60	60	60	60	60	60	AVG
Dry std Stack gas flow rate	Qstd	dscfm	168.7	170.319	182.704	203.282	193.045	203.311	200.743	188,882
Dry std Stack gas flow rate	Qstd	dscf/hr	10,12	10,219,	10,962,	12,196,908	11,582,695	12,198,643	12,044,56	
Conversion Factor	F4	sec/hr	3600	3600	3600	3600	3600	3600	3600	
	Qstd	dscf/min								
Isokinetic percent	I	%								
sample nozzle cross section	An	ft2								
length of sample test	theta	minutes								
Mass of part: combined	Mn	mg								
Mass of part: probe wash	Mp	mg								
Mass of part: filter	Mf	mg								
Unit Totals (tons per year)	PM10		10	33	13	6	16	11	6	14
Unit Totals (tons per year)	SO2		9	15	6	20	41	20	14	18
Unit Totals (tons per year)	NOx		302	182	137	61	172	182	173	173
Facility Totals (tons per year)	PM10		163	121	114	76	81	87	81	103
Facility Totals (tons per year)	TSP		176	132	119	81	86	91	85	110
Facility Totals (tons per year)	SO2		239	274	275	281	201	239	202	244
Facility Totals (tons per year)	NOx		1493	1541	1488	1440	1164	1301	1372	1,400

Facility Specific Operating and Emissions Data (KapStone - Continued)

Facility:			KaptS	KaptSto	KaptSto	KaptStone	KaptStone	KaptStone	KaptSton	KaptSton
Run ID or Unit ID:			2005	2006	2007	2008	2009	2010	2011	2005-2005-
			rf22	rf22	rf22	rf22	rf22	rf22	rf22	RF 22 avg
Pressure (stack absolute)	Ps	in HG	29.92	29.92	29.92	29.92	29.92	29.92	29.92	
Pressure (barometric)	Pbar	in HG								
Pressure (stack)	Pa	in H2O								
Conversion Factor	F1	inH2O/inHg								
Total water condensed	Vwst	scf H2)								
	f	scf H2O/gm								
Total water condensed	Vw	std ft3								
total impinger wt										
Impinger 1	Vi	g								
Impinger 2	Vii	g								
Impinger 3	Viii	g								
Impinger 4	Viv	g								
Ideal gas constant	R	(inHG)(ft3)/(R-lbmol)								
Temperature abs	Tabs	R (459.67)	460	460	460	460	460	460	460	
Temp std	Tstd	R (527.67)	528	528	528	528	528	528	528	
Conversion Factor	F2	g/lb (should be								
Pressure (std)	Pstd	in HG	29.92	29.92	29.92	29.92	29.92	29.92	29.92	
MW of water	MH2O	lb/lbmole	18.01	18.015	18.015	18.015	18.015	18.015	18.015	
Sample Volume	Vmst	dscf								
Sample Volume from meter	Vm	dcf								
Dry gas mtr cal factor	Y	no units								
Meter orifice pressure	dH	in H2O								
Dry gas meter temp	Tm	F								
Stack Gas Moisture Fraction	Bws	vol%/100	0.242	0.218	0.223	0.211	0.21	0.226	0.203	0.219
Saturation Moisture	SBws	(sat vap press)/Ps								
same as BWS (because										
Stack Gas Mole weight dry	Md	lb/lbmole	30.45	30.360	30.276	30.372	30.468	30.480	30.348	AVG
Oxygen conc in stack	conc	%/100	0.063	0.071	0.078	0.07	0.062	0.061	0.072	0.0681
CO2 conc in stack	conc	%/100	0.137	0.129	0.122	0.13	0.138	0.139	0.128	
N2 conc in stack	con	%/100	0.8	0.8	0.8	0.8	0.8	0.8	0.8	
Stack Gas Mole weight wet	Ms	lb/lbmole								
Stack Area	A	ft2	103.8	103.868	103.868	103.8689	103.8689	103.8689	103.8689	
Diameter of stack	D	inches	138	138	138	138	138	138	138	
Conversion Factor	F3	in/ft	12	12	12	12	12	12	12	
Stack Gas Velocity	Vs	ft/sec	47.82	43.3335	47.6273	46.1736	50.7563	44.1518	47.3674	
Pitot tube constant	Kp	test Vs:								
Pitot tube calibration coef	Cp									
Stack Gas Velocity Head	dP	in H2O								
Stack Gas Velocity Head	dP^0.5									AVG
Stack gas temp	Ts	F	271	267	264	281	291	572	341	327
flow check			298.0	270.060	296.820	287.760	316.320	275.160	295.200	
Stack Ht	Ht	Ft	246							
Actual Stack Gas Flow Rate	Acf	acfm	29808	270060	296820	287760	316320	275160	295200	291,343
		acfs	4968	4501	4947	4796	5272	4586	4920	
Conversion Factor	F5	sec/min	60	60	60	60	60	60	60	AVG
Dry std Stack gas flow rate	Qstd	dscfm	163.1	153.379	168.194	161.779	175.690	108.963	155.087	155.185
Dry std Stack gas flow rate	Qstd	dscf/hr	9,791,	9,202.7	10,091,	9,706.762	10,541,417	6,537,802	9,305,235	
Conversion Factor	F4	sec/hr	3600	3600	3600	3600	3600	3600	3600	
	Qstd	dscf/min								
Isokinetic percent	I	%								
sample nozzle cross section	An	ft2								
length of sample test	theta	minutes								
Mass of part: combined	Mn	mg								
Mass of part: probe wash	Mp	mg								
Mass of part: filter	Mf	mg								
Unit Totals (tons per year)	PM10		11	4	5	8	13	8	5	AVG
Unit Totals (tons per year)	SO2		58	53	47	60	48	87	66	8
Unit Totals (tons per year)	NOx		245	242	251	274	280	297	288	60
Facility Totals (tons per year)	PM10		163	121	114	76	81	87	81	268
Facility Totals (tons per year)	TSP		176	132	119	81	86	91	85	103
Facility Totals (tons per year)	SO2		239	274	275	281	201	239	202	110
Facility Totals (tons per year)	NOx		1493	1541	1488	1440	1164	1301	1372	244
										1,400

Facility Specific Operating and Emissions Data (KapStone - Continued)

			Facility:							
			KaptS	KaptSto	KaptSto	KaptStone	KaptStone	KaptStone	KaptSton	KaptSton
			2005	2006	2007	2008	2009	2010	2011	2005-
			lk3	lk3	lk3	lk3	lk3	lk3	lk3	LK 3 avg
			Run ID or Unit ID:							
Pressure (stack absolute)	Ps	in HG	29.92	29.92	29.92	29.92	29.92	29.92	29.92	
Pressure (barometric)	Pbar	in HG								
Pressure (stack)	Pa	in H2O								
Conversion Factor	F1	inH2O/inHg								
Total water condensed	Vwst	scf H2)								
	f	scf H2O/gm								
Total water condensed	Vw	std ft3								
total impinger wt										
Impinger 1	Vi	g								
Impinger 2	Vii	g								
Impinger 3	Viii	g								
Impinger 4	Viv	g								
Ideal gas constant	R	(inHG)(ft3)/(R-lbmol)								
Temperature abs	Tabs	R (459.67)	460	460	460	460	460	460	460	
Temp std	Tstd	R (527.67)	528	528	528	528	528	528	528	
Conversion Factor	F2	g/lb (should be								
Pressure (std)	Pstd	in HG	29.92	29.92	29.92	29.92	29.92	29.92	29.92	
MW of water	MH2O	lb/lbmole	18.01	18.015	18.015	18.015	18.015	18.015	18.015	
Sample Volume	Vmst	dscf								
Sample Volume from meter	Vm	dcf								
Dry gas mtr cal factor	Y	no units								
Meter orifice pressure	dH	in H2O								
Dry gas meter temp	Tm	F								
Stack Gas Moisture Fraction	Bws	vol%/100	0.252	0.265	0.296	0.273	0.256	0.165	0.221	0.2469
Saturation Moisture	SBws	(sat vap press)/Ps								
same as BWS (because										
Stack Gas Mole weight dry	Md	lb/lbmole	30.11	30.360	30.360	30.179	29.867	29.963	30.107	AVG
Oxygen conc in stack	conc	%/100	0.091	0.071	0.071	0.086	0.112	0.104	0.092	0.0896
CO2 conc in stack	conc	%/100	0.109	0.129	0.129	0.114	0.088	0.096	0.108	
N2 conc in stack	con	%/100	0.8	0.8	0.8	0.8	0.8	0.8	0.8	
Stack Gas Mole weight wet	Ms	lb/lbmole								
Stack Area	A	ft2	28.27	28.2743	28.2743	28.2743	28.2743	28.2743	28.2743	
Diameter of stack	D	inches	72	72	72	72	72	72	72	
Conversion Factor	F3	in/ft	12	12	12	12	12	12	12	
Stack Gas Velocity	Vs	ft/sec	14.96	10.9640	12.3080	12.5202	14.1117	13.0507	11.3884	
Pitot tube constant	Kp	test Vs:								
Pitot tube calibration coef	Cp									
Stack Gas Velocity Head	dP	in H2O								
Stack Gas Velocity Head	dP^0.5									AVG
Stack gas temp	Ts	F	149	148	155	153	151	135	148	148
flow check			25.38	18.600	20.880	21.240	23.940	22.140	19.320	
Stack Ht	Ht	Ft								
Actual Stack Gas Flow Rate	Acf	acfm	25380	18600	20880	21240	23940	22140	19320	21,643
Conversion Factor	F5	acfs	423	310	348	354	399	369	322	
		sec/min	60	60	60	60	60	60	60	AVG
Dry std Stack gas flow rate	Qstd	dscfm	16.45	11.872	12.620	13.300	15.392	16.405	13.070	14,160
Dry std Stack gas flow rate	Qstd	dscf/hr	987.5	712.331	757.205	798.020	923.509	984.311	784.199	
Conversion Factor	F4	sec/hr	3600	3600	3600	3600	3600	3600	3600	
	Qstd	dscf/min								
Isokinetic percent	I	%								
sample nozzle cross section	An	ft2								
length of sample test	theta	minutes								
Mass of part: combined	Mn	mg								
Mass of part: probe wash	Mp	mg								
Mass of part: filter	Mf	mg								
Unit Totals (tons per year)	PM10		13	2	2	3	2	2	0	AVG
Unit Totals (tons per year)	SO2		1	1	0	0	0	0	0	3
Unit Totals (tons per year)	NOx		54	56	12	21	12	8	3	24
Facility Totals (tons per year)	PM10		163	121	114	76	81	87	81	103
Facility Totals (tons per year)	TSP		176	132	119	81	86	91	85	110
Facility Totals (tons per year)	SO2		239	274	275	281	201	239	202	244
Facility Totals (tons per year)	NOx		1493	1541	1488	1440	1164	1301	1372	1,400

Facility Specific Operating and Emissions Data (KapStone - Continued)

Facility:			KaptS	KaptSto	KaptSto	KaptStone	KaptStone	KaptStone	KaptSton	KaptSton
Run ID or Unit ID:			2005	2006	2007	2008	2009	2010	2011	2005-2005-
			lk4	lk4	lk4	lk4	lk4	lk4	lk4	LK 4 avg
Pressure (stack absolute)	Ps	in HG	29.92	29.92	29.92	29.92	29.92	29.92	29.92	
Pressure (barometric)	Pbar	in HG								
Pressure (stack)	Pa	in H2O								
Conversion Factor	F1	inH2O/inHg								
Total water condensed	Vwst	scf H2)								
	f	scf H2O/gm								
Total water condensed	Vw	std ft3								
total impinger wt										
Impinger 1	Vi	g								
Impinger 2	Vii	g								
Impinger 3	Viii	g								
Impinger 4	Viv	g								
Ideal gas constant	R	(inHG)(ft3)/(R-lbmol)								
Temperature abs	Tabs	R (459.67)	460	460	460	460	460	460	460	
Temp std	Tstd	R (527.67)	528	528	528	528	528	528	528	
Conversion Factor	F2	g/lb (should be								
Pressure (std)	Pstd	in HG	29.92	29.92	29.92	29.92	29.92	29.92	29.92	
MW of water	MH2O	lb/lbmole	18.01	18.015	18.015	18.015	18.015	18.015	18.015	
Sample Volume	Vmst	dscf								
Sample Volume from meter	Vm	dcf								
Dry gas mtr cal factor	Y	no units								
Meter orifice pressure	dH	in H2O								
Dry gas meter temp	Tm	F								
Stack Gas Moisture Fraction	Bws	vol%/100	0.243	0.226	0.225	0.224	0.148	0.209	0.186	0.2087
Saturation Moisture	SBws	(sat vap press)/Ps								
same as BWS (because										
Stack Gas Mole weight dry	Md	lb/lbmole	30.67	30.552	30.504	30.576	30.360	30.540	30.660	AVG
Oxygen conc in stack	conc	%/100	0.045	0.055	0.059	0.053	0.071	0.056	0.046	0.0550
CO2 conc in stack	conc	%/100	0.155	0.145	0.141	0.147	0.129	0.144	0.154	
N2 conc in stack	con	%/100	0.8	0.8	0.8	0.8	0.8	0.8	0.8	
Stack Gas Mole weight wet	Ms	lb/lbmole								
Stack Area	A	ft2	38.48	38.4845	38.4845	38.4845	38.4845	38.4845	38.4845	
Diameter of stack	D	inches	84	84	84	84	84	84	84	
Conversion Factor	F3	in/ft	12	12	12	12	12	12	12	
Stack Gas Velocity	Vs	ft/sec	8.938	8.0292	9.0166	9.3804	8.7048	8.8347	8.2111	
Pitot tube constant	Kp	test Vs:								
Pitot tube calibration coef	Cp									
Stack Gas Velocity Head	dP	in H2O								
Stack Gas Velocity Head	dP^0.5									AVG
Stack gas temp	Ts	F	140	141	140	140	124	139	136	137
flow check			20.64	18.540	20.820	21.660	20.100	20.400	18.960	
Stack Ht	Ht	Ft								
Actual Stack Gas Flow Rate	Acf	acfm	20640	18540	20820	21660	20100	20400	18960	20,160
Conversion Factor	F5	acfs	344	309	347	361	335	340	316	
		sec/min	60	60	60	60	60	60	60	AVG
Dry std Stack gas flow rate	Qstd	dscfm	13.75	12.607	14.199	14.791	15.483	14.224	13.673	14,104
Dry std Stack gas flow rate	Qstd	dscf/hr	824.9	756.417	851.954	887.471	928.983	853.424	820.355	
Conversion Factor	F4	sec/hr	3600	3600	3600	3600	3600	3600	3600	
	Qstd	dscf/min								
Isokinetic percent	I	%								
sample nozzle cross section	An	ft2								
length of sample test	theta	minutes								
Mass of part: combined	Mn	mg								
Mass of part: probe wash	Mp	mg								
Mass of part: filter	Mf	mg								
Unit Totals (tons per year)	PM10		8	6	13	7	4	8	12	8
Unit Totals (tons per year)	SO2		3	4	1	1	1	1	1	2
Unit Totals (tons per year)	NOx		30	82	74	34	37	51	70	54
Facility Totals (tons per year)	PM10		163	121	114	76	81	87	81	103
Facility Totals (tons per year)	TSP		176	132	119	81	86	91	85	110
Facility Totals (tons per year)	SO2		239	274	275	281	201	239	202	244
Facility Totals (tons per year)	NOx		1493	1541	1488	1440	1164	1301	1372	1,400

Facility Specific Operating and Emissions Data (KapStone - Continued)

			Facility:							
			KaptS	KaptSto	KaptSto	KaptStone	KaptStone	KaptStone	KaptSton	KaptSton
			2005	2006	2007	2008	2009	2010	2011	2005-
			lk5	lk5	lk5	lk5	lk5	lk5	lk5	LK 5 avg
			Run ID or Unit ID:							
Pressure (stack absolute)	Ps	in HG	29.92	29.92	29.92	29.92	29.92	29.92	29.92	
Pressure (barometric)	Pbar	in HG								
Pressure (stack)	Pa	in H2O								
Conversion Factor	F1	inH2O/inHg								
Total water condensed	Vwst	scf H2)								
	f	scf H2O/gm								
Total water condensed	Vw	std ft3								
total impinger wt										
Impinger 1	Vi	g								
Impinger 2	Vii	g								
Impinger 3	Viii	g								
Impinger 4	Viv	g								
Ideal gas constant	R	(inHG)(ft3)/(R-lbmol)								
Temperature abs	Tabs	R (459.67)	460	460	460	460	460	460	460	
Temp std	Tstd	R (527.67)	528	528	528	528	528	528	528	
Conversion Factor	F2	g/lb (should be								
Pressure (std)	Pstd	in HG	29.92	29.92	29.92	29.92	29.92	29.92	29.92	
MW of water	MH2O	lb/lbmole	18.01	18.015	18.015	18.015	18.015	18.015	18.015	
Sample Volume	Vmst	dscf								
Sample Volume from meter	Vm	dcf								
Dry gas mtr cal factor	Y	no units								
Meter orifice pressure	dH	in H2O								
Dry gas meter temp	Tm	F								
Stack Gas Moisture Fraction	Bws	vol%/100	0.286	0.314	0.303	0.281	0.302	0.297	0.298	0.2973
Saturation Moisture	SBws	(sat vap press)/Ps								
same as BWS (because										
Stack Gas Mole weight dry	Md	lb/lbmole	30.42	30.312	30.588	30.576	30.504	30.564	30.612	AVG
Oxygen conc in stack	conc	%/100	0.066	0.075	0.052	0.053	0.059	0.054	0.05	0.0584
CO2 conc in stack	conc	%/100	0.134	0.125	0.148	0.147	0.141	0.146	0.15	
N2 conc in stack	con	%/100	0.8	0.8	0.8	0.8	0.8	0.8	0.8	
Stack Gas Mole weight wet	Ms	lb/lbmole								
Stack Area	A	ft2	15.90	15.9043	15.9043	15.9043	15.9043	15.9043	15.9043	
Diameter of stack	D	inches	54	54	54	54	54	54	54	
Conversion Factor	F3	in/ft	12	12	12	12	12	12	12	
Stack Gas Velocity	Vs	ft/sec	23.51	27.0996	25.1504	15.7819	17.4795	18.6742	17.1023	
Pitot tube constant	Kp	test Vs:								
Pitot tube calibration coef	Cp									
Stack Gas Velocity Head	dP	in H2O								
Stack Gas Velocity Head	dP^0.5									AVG
Stack gas temp	Ts	F	281	284	275	333	326	338	341	311
flow check			22.44	25.860	24.000	15.060	16.680	17.820	16.320	
Stack Ht	Ht	Ft								
Actual Stack Gas Flow Rate	Acf	acfm	22440	25860	24000	15060	16680	17820	16320	19,740
Conversion Factor	F5	acfs	374	431	400	251	278	297	272	
		sec/min	60	60	60	60	60	60	60	AVG
Dry std Stack gas flow rate	Qstd	dscfm	11.41	12.590	12.017	7.210	7.821	8.289	7.552	9,556
Dry std Stack gas flow rate	Qstd	dscf/hr	684.9	755.379	721.011	432.579	469.261	497.331	453.117	
Conversion Factor	F4	sec/hr	3600	3600	3600	3600	3600	3600	3600	
	Qstd	dscf/min								
Isokinetic percent	I	%								
sample nozzle cross section	An	ft2								
length of sample test	theta	minutes								
Mass of part: combined	Mn	mg								
Mass of part: probe wash	Mp	mg								
Mass of part: filter	Mf	mg								
Unit Totals (tons per year)	PM10		2	0	0	2	3	1	2	AVG
Unit Totals (tons per year)	SO2		1	1	1	2	1	2	2	1
Unit Totals (tons per year)	NOx		26	20	47	61	35	37	58	41
Facility Totals (tons per year)	PM10		163	121	114	76	81	87	81	103
Facility Totals (tons per year)	TSP		176	132	119	81	86	91	85	110
Facility Totals (tons per year)	SO2		239	274	275	281	201	239	202	244
Facility Totals (tons per year)	NOx		1493	1541	1488	1440	1164	1301	1372	1,400

Facility Specific Operating and Emissions Data (Boise While Wallula)

			Facility:							
			Boise	Boise	Boise	Boise	Boise	Boise	Boise	Boise
			2005	2006	2007	2008	2009	2010	2011	2005-
			rf2	rf2	rf2	rf2	rf2	rf2	rf2	Rf2 avg
Pressure (stack absolute)	Ps	in HG	29.92	29.92	29.92	29.92	29.92	29.92	29.92	29.92
Pressure (barometric)	Pbar	in HG								
Pressure (stack)	Pa	in H2O								
Conversion Factor	F1	inH2O/inHg								
Total water condensed	Vwst	scf H2)								
	f	scf H2O/gm								
Total water condensed	Vw	std ft3								
total impinger wt										
Impinger 1	Vi	g								
Impinger 2	Vii	g								
Impinger 3	Viii	g								
Impinger 4	Viv	g								
Ideal gas constant	R	(inHG)(ft3)/(R-lbmol)								
Temperature abs	Tabs	R (459.67)	460	460	460	460	460	460	460	
Temp std	Tstd	R (527.67)	528	528	528	528	528	528	528	
Conversion Factor	F2	g/lb (should be								
Pressure (std)	Pstd	in HG	29.92	29.92	29.92	29.92	29.92	29.92	29.92	
MW of water	MH2O	lb/lbmole	18.01	18.015	18.015	18.015	18.015	18.015	18.015	
Sample Volume	Vmst	dscf								
Sample Volume from meter	Vm	dcf								
Dry gas mtr cal factor	Y	no units								
Meter orifice pressure	dH	in H2O								
Dry gas meter temp	Tm	F								
Stack Gas Moisture Fraction	Bws	vol%/100	0.222	0.251	0.267	0.246	0.237	0.23	0.253	0.2437
Saturation Moisture	SBws	(sat vap press)/Ps								
same as BWS (because										
Stack Gas Mole weight dry	Md	lb/lbmole	29.98	30.119	30.011	30.059	29.867	29.975	30.191	AVG
Oxygen conc in stack	conc	%/100	0.102	0.091	0.1	0.096	0.112	0.103	0.085	0.0984
CO2 conc in stack	conc	%/100	0.098	0.109	0.1	0.104	0.088	0.097	0.115	
N2 conc in stack	con	%/100	0.8	0.8	0.8	0.8	0.8	0.8	0.8	
Stack Gas Mole weight wet	Ms	lb/lbmole								
Stack Area	A	ft2	62.21	62.2114	62.2114	62.2114	62.2114	62.2114	62.2114	
Diameter of stack	D	inches	106.8	106.8	106.8	106.8	106.8	106.8	106.8	
Conversion Factor	F3	in/ft	12	12	12	12	12	12	12	
Stack Gas Velocity	Vs	ft/sec	23.25	21.2501	22.4396	22.4235	22.4557	24.3846	25.1883	
Pitot tube constant	Kp	test Vs:								
Pitot tube calibration coef	Cp									
Stack Gas Velocity Head	dP	in H2O								
Stack Gas Velocity Head	dP^0.5									AVG
Stack gas temp	Ts	F	327	333	283	305	335	342	344	324
flow check			86.82	79.320	83.760	83.700	83.820	91.020	94.020	
Stack Ht	Ht	Ft								
Actual Stack Gas Flow Rate	Acf	acfm	86820	79320	83760	83700	83820	91020	94020	86,066
Conversion Factor	F5	acfs	1447	1322	1396	1395	1397	1517	1567	
		sec/min	60	60	60	60	60	60	60	AVG
Dry std Stack gas flow rate	Qstd	dscfm	45.31	39.557	43.630	43.558	42.476	46.141	46.123	43,829
Dry std Stack gas flow rate	Qstd	dscf/hr	2,719.	2,373.4	2,617.8	2,613.488	2,548.533	2,768.461	2,767.387	
Conversion Factor	F4	sec/hr	3600	3600	3600	3600	3600	3600	3600	
	Qstd	dscf/min								
Isokinetic percent	I	%								
sample nozzle cross section	An	ft2								
length of sample test	theta	minutes								
Mass of part: combined	Mn	mg								
Mass of part: probe wash	Mp	mg								
Mass of part: filter	Mf	mg								
Unit Totals (tons per year)	PM10		20	8	6	7	10	10	5	AVG
Unit Totals (tons per year)	SO2		255	239	268	358	255	332	352	294
Unit Totals (tons per year)	NOx		65	64	63	73	59	74	71	67
Facility Totals (tons per year)	PM10		213	218	184	157	131	131	127	166
Facility Totals (tons per year)	TSP		295	300	270	227	156	156	149	222
Facility Totals (tons per year)	SO2		793	1247	684	780	713	802	793	830
Facility Totals (tons per year)	NOx		764	778	771	1073	841	859	861	850

Facility Specific Operating and Emissions Data (Boise While Wallula - Continued)

Facility:			Boise	Boise	Boise	Boise	Boise	Boise	Boise	Boise
Run ID or Unit ID:			2005	2006	2007	2008	2009	2010	2011	2005-
			rF3	rF3	rF3	rF3	rF3	rF3	rF3	Rf3 avg
Pressure (stack absolute)	Ps	in HG	29.92	29.92	29.92	29.92	29.92	29.92	29.92	
Pressure (barometric)	Pbar	in HG								
Pressure (stack)	Pa	in H2O								
Conversion Factor	F1	inH2O/inHg								
Total water condensed	Vwst	scf H2)								
	f	scf H2O/gm								
Total water condensed	Vw	std ft3								
total impinger wt										
Impinger 1	Vi	g								
Impinger 2	Vii	g								
Impinger 3	Viii	g								
Impinger 4	Viv	g								
Ideal gas constant	R	(inHG)(ft3)/(R-lbmol)								
Temperature abs	Tabs	R (459.67)	460	460	460	460	460	460	460	
Temp std	Tstd	R (527.67)	528	528	528	528	528	528	528	
Conversion Factor	F2	g/lb (should be								
Pressure (std)	Pstd	in HG	29.92	29.92	29.92	29.92	29.92	29.92	29.92	
MW of water	MH2O	lb/lbmole	18.01	18.015	18.015	18.015	18.015	18.015	18.015	
Sample Volume	Vmst	dscf								
Sample Volume from meter	Vm	dcf								
Dry gas mtr cal factor	Y	no units								
Meter orifice pressure	dH	in H2O								
Dry gas meter temp	Tm	F								
Stack Gas Moisture Fraction	Bws	vol%/100	0.223	0.246	0.239	0.24	0.247	0.245	0.238	0.239714
Saturation Moisture	SBws	(sat vap press)/Ps								
same as BWS (because										
Stack Gas Mole weight dry	Md	lb/lbmole	30.44	30.444	30.324	30.456	30.456	30.540	30.624	AVG
Oxygen conc in stack	conc	%/100	0.064	0.064	0.074	0.063	0.063	0.056	0.049	0.0619
CO2 conc in stack	conc	%/100	0.136	0.136	0.126	0.137	0.137	0.144	0.151	
N2 conc in stack	con	%/100	0.8	0.8	0.8	0.8	0.8	0.8	0.8	
Stack Gas Mole weight wet	Ms	lb/lbmole								
Stack Area	A	ft2	132.7	132.732	132.732	132.7323	132.7323	132.7323	132.7323	
Diameter of stack	D	inches	156	156	156	156	156	156	156	
Conversion Factor	F3	in/ft	12	12	12	12	12	12	12	
Stack Gas Velocity	Vs	ft/sec	40.41	39.6512	40.7964	42.0696	43.9531	24.3874	42.3032	
Pitot tube constant	Kp	test Vs:								
Pitot tube calibration coef	Cp									
Stack Gas Velocity Head	dP	in H2O								
Stack Gas Velocity Head	dP^0.5									AVG
Stack gas temp	Ts	F	357	365	358	382	409	394	401	381
flow check			321.8	315,780	324,900	335,040	350,040	194,220	336,900	
Stack Ht	Ht	Ft								
Actual Stack Gas Flow Rate	Acf	acfm	32184	315780	324900	335040	350040	194220	336900	311,246
Conversion Factor	F5	sec/min	5364	5263	5415	5584	5834	3237	5615	
			60	60	60	60	60	60	60	AVG
Dry std Stack gas flow rate	Qstd	dscfm	161.6	152,383	159,593	159,673	160,150	90,660	157,430	148,786
Dry std Stack gas flow rate	Qstd	dscf/hr	9,696,	9,142.9	9,575.6	9,580.393	9,608.997	5,439,616	9,445.784	
Conversion Factor	F4	sec/hr	3600	3600	3600	3600	3600	3600	3600	
	Qstd	dscf/min								
Isokinetic percent	I	%								
sample nozzle cross section	An	ft2								
length of sample test	theta	minutes								
Mass of part: combined	Mn	mg								
Mass of part: probe wash	Mp	mg								
Mass of part: filter	Mf	mg								
Unit Totals (tons per year)	PM10		29	13	12	12	12	14	12	15
Unit Totals (tons per year)	SO2		506	968	333	374	428	441	420	496
Unit Totals (tons per year)	NOx		286	274	244	294	297	306	292	285
Facility Totals (tons per year)	PM10		213	218	184	157	131	131	127	166
Facility Totals (tons per year)	TSP		295	300	270	227	156	156	149	222
Facility Totals (tons per year)	SO2		793	1247	684	780	713	802	793	830
Facility Totals (tons per year)	NOx		764	778	771	1073	841	859	861	850

Facility Specific Operating and Emissions Data (Boise While Wallula - Continued)

			Facility:								
			Boise	Boise	Boise	Boise	Boise	Boise	Boise	Boise	
			2005	2006	2007	2008	2009	2010	2011	2005-	
			LK	LK	LK	LK-oil	LK	LK	LK	LK avg	
			Run ID or Unit ID:								
Pressure (stack absolute)	Ps	in HG	29.92	29.92	29.92	29.92	29.92	29.92	29.92	29.92	
Pressure (barometric)	Pbar	in HG									
Pressure (stack)	Pa	in H2O									
Conversion Factor	F1	inH2O/inHg									
Total water condensed	Vwst	scf H2)									
	f	scf H2O/gm									
Total water condensed	Vw	std ft3									
total impinger wt											
Impinger 1	Vi	g									
Impinger 2	Vii	g									
Impinger 3	Viii	g									
Impinger 4	Viv	g									
Ideal gas constant	R	(inHG)(ft3)/(R-lbmol)									
Temperature abs	Tabs	R (459.67)	460	460	460	460	460	460	460		
Temp std	Tstd	R (527.67)	528	528	528	528	528	528	528		
Conversion Factor	F2	g/lb (should be									
Pressure (std)	Pstd	in HG	29.92	29.92	29.92	29.92	29.92	29.92	29.92		
MW of water	MH2O	lb/lbmole	18.01	18.015	18.015	18.015	18.015	18.015	18.015	18.015	
Sample Volume	Vmst	dscf									
Sample Volume from meter	Vm	dcf									
Dry gas mtr cal factor	Y	no units									
Meter orifice pressure	dH	in H2O									
Dry gas meter temp	Tm	F									
Stack Gas Moisture Fraction	Bws	vol%/100	0.327	0.359	0.341	0.351	0.339	0.359	0.326	0.3431	
Saturation Moisture	SBws	(sat vap press)/Ps									
same as BWS (because											
Stack Gas Mole weight dry	Md	lb/lbmole	30.60	30.576	30.332	30.576	30.552	30.720	30.648	AVG	
Oxygen conc in stack	conc	%/100	0.051	0.053	0.0733	0.053	0.055	0.041	0.047	0.1	
CO2 conc in stack	conc	%/100	0.149	0.147	0.1267	0.147	0.145	0.159	0.153		
N2 conc in stack	con	%/100	0.8	0.8	0.8	0.8	0.8	0.8	0.8		
Stack Gas Mole weight wet	Ms	lb/lbmole									
Stack Area	A	ft2	28.27	28.2743	28.2743	28.2743	28.2743	28.2743	28.2743		
Diameter of stack	D	inches	72	72	72	72	72	72	72		
Conversion Factor	F3	in/ft	12	12	12	12	12	12	12		
Stack Gas Velocity	Vs	ft/sec	23.55	27.4808	20.1596	19.9121	18.7803	18.7803	16.6228		
Pitot tube constant	Kp	test Vs:									
Pitot tube calibration coef	Cp										
Stack Gas Velocity Head	dP	in H2O									
Stack Gas Velocity Head	dP^0.5									AVG	
Stack gas temp	Ts	F	164	162	152	161	159	160	161	160	
flow check			39.96	46.620	34.200	33.780	31.860	31.860	28.200		
Stack Ht	Ht	Ft									
Actual Stack Gas Flow Rate	Acf	acfm	39960	46620	34200	33780	31860	31860	28200	35,211	
Conversion Factor	F5	acfs	666	777	570	563	531	531	470		
		sec/min	60	60	60	60	60	60	60		
Dry std Stack gas flow rate	Qstd	dscfm	22.75	25.367	19.444	18.640	17.963	17.392	16.160	19,675	
Dry std Stack gas flow rate	Qstd	dscf/hr	1,365	1,522.0	1,166.6	1,118.402	1,077,809	1,043,512	969,622		
Conversion Factor	F4	sec/hr	3600	3600	3600	3600	3600	3600	3600		
	Qstd	dscf/min									
Isokinetic percent	I	%									
sample nozzle cross section	An	ft2									
length of sample test	theta	minutes									
Mass of part: combined	Mn	mg									
Mass of part: probe wash	Mp	mg									
Mass of part: filter	Mf	mg									
			used oil for part of 2007-2008								AVG
Unit Totals (tons per year)	PM10		50	74	45	49	41	42	37	48	
Unit Totals (tons per year)	SO2		2	10	0	1	2	3	0	3	
Unit Totals (tons per year)	NOx		86	82	42	52	48	51	54	59	
Facility Totals (tons per year)	PM10		213	218	184	157	131	131	127	166	
Facility Totals (tons per year)	TSP		295	300	270	227	156	156	149	222	
Facility Totals (tons per year)	SO2		793	1247	684	780	713	802	793	830	
Facility Totals (tons per year)	NOx		764	778	771	1073	841	859	861	850	

Facility Specific Operating and Emissions Data (Cosmo)

		Facility:	Cosmo	Cosmo	Cosmo	avg
			2005	2006	2011	(not used)
		Run ID or Unit ID:	RB(1-3)	RB(1-3)	RB(1-3)	2011 data used
Pressure (stack absolute)	Ps	in HG	29.92	29.92	29.92	
Pressure (barometric)	Pbar	in HG				
Pressure (stack)	Pa	in H2O				
Conversion Factor	F1	inH2O/inHg				
Total water condensed	Vwst	scf H2)				
	f	scf H2O/gm				
Total water condensed	Vw	std ft3				
total impinger wt						
Impinger 1	Vi	g				
Impinger 2	Vii	g				
Impinger 3	Viii	g				
Impinger 4	Viv	g				
Ideal gas constant	R	(inHG)(ft3)/(R-lbmol)				
Temperature abs	Tabs	R (459.67)	460	460	460	
Temp std	Tstd	R (527.67)	528	528	528	
Conversion Factor	F2	g/lb (should be				
Pressure (std)	Pstd	in HG	29.92	29.92	29.92	
MW of water	MH2O	lb/lbmole	18.015	18.015	18.015	
Sample Volume	Vmst	dscf				
Sample Volume from meter	Vm	dcf				
Dry gas mtr cal factor	Y	no units				
Meter orifice pressure	dH	in H2O				
Dry gas meter temp	Tm	F				
Stack Gas Moisture Fraction	Bws	vol%/100	0.204	0.19	0.2	
Saturation Moisture	SBws	(sat vap press)/Ps				
same as BWS (because						
Stack Gas Mole weight dry	Md	lb/lbmole	30.576	30.372	30.312	AVG
Oxygen conc in stack	cconc	%/100	0.053	0.07	0.075	0.0660
CO2 conc in stack	conc	%/100	0.147	0.13	0.125	
N2 conc in stack	con	%/100	0.8	0.8	0.8	
Stack Gas Mole weight wet	Ms	lb/lbmole				
Stack Area	A	ft2	50.2655	50.2655	50.2655	
Diameter of stack	D	inches	96	96	96	
Conversion Factor	F3	in/ft	12	12	12	
Stack Gas Velocity	Vs	ft/sec	48.4826	51.7453	58.5889	
Pitot tube constant	Kp	test Vs:				
Pitot tube calibration coef	Cp					
Stack Gas Velocity Head	dP	in H2O				
Stack Gas Velocity Head	dP^0.5					AVG
Stack gas temp	Ts	F	140	141	140	140
flow check			146,220	156,060	176,700	
Stack Ht	Ht	Ft	140	140	140	140
Actual Stack Gas Flow Rate	Acf	acfm	146220	156060	176700	159,660
Conversion Factor	F5	acfs	2437	2601	2945	
		sec/min	60	60	60	
Dry std Stack gas flow rate	Qstd	dscfm	102,424	111,054	124,397	112,625
Dry std Stack gas flow rate	Qstd	dscf/hr	6,145,451	6,663,269	7,463,808	
Conversion Factor	F4	sec/hr	3600	3600	3600	
	Qstd	dscf/min				
Isokinetic percent	I	%				
sample nozzle cross section	An	ft2				
length of sample test	theta	minutes				
Mass of part: combined	Mn	mg				
Mass of part: probe wash	Mp	mg				
Mass of part: filter	Mf	mg				
Unit Totals (tons per year)	PM10		220	109	195	175
Unit Totals (tons per year)	SO2		211	187	169	189
Unit Totals (tons per year)	NOx		308	128	348	261
Facility Totals (tons per year)	PM10		313	145	272	243
Facility Totals (tons per year)	TSP		314	146	273	244
Facility Totals (tons per year)	SO2		286	274	214	258
Facility Totals (tons per year)	NOx		341	149	367	286

Facility Specific Operating and Emissions Data (Graymont)

			Facility:	Gray	Graymo	Graymo	Graymont-	Graymont-	Graymont	Graymont	Graymont
			Run ID or Unit ID:	2001	2002	2003	2004	2005	2006	2007	2008
				clk	clk	clk	clk	clk	clk	clk	clk
Pressure (stack absolute)	Ps	in HG		29.92	29.92	29.92	29.92	29.92	29.92	29.92	29.92
Pressure (barometric)	Pbar	in HG									
Pressure (stack)	Pa	in H2O									
Conversion Factor	F1	inH2O/inHg									
Total water condensed	Vwst	scf H2)									
	f	scf H2O/gm									
Total water condensed	Vw	std ft3									
total impinger wt											
Impinger 1	Vi	g									
Impinger 2	Vii	g									
Impinger 3	Viii	g									
Impinger 4	Viv	g									
Ideal gas constant	R	(inHG)(ft3)/(R-lbmol)									
Temperature abs	Tabs	R (459.67)		460	460	460	460	460			
Temp std	Tstd	R (527.67)		528	528	528	528	528			
Conversion Factor	F2	g/lb (should be									
Pressure (std)	Pstd	in HG		29.92	29.92	29.92	29.92	29.92			
MW of water	MH2O	lb/lbmole		18.01	18.015	18.015	18.015	18.015			
Sample Volume	Vmst	dscf									
Sample Volume from meter	Vm	dcf									
Dry gas mtr cal factor	Y	no units									
Meter orifice pressure	dH	in H2O									
Dry gas meter temp	Tm	F									
Stack Gas Moisture Fraction	Bws	vol%/100									
Saturation Moisture	SBws	(sat vap press)/Ps									
same as BWS (because											
Stack Gas Mole weight dry	Md	lb/lbmole									
Oxygen conc in stack	conc	%/100									
CO2 conc in stack	conc	%/100									
N2 conc in stack	con	%/100									
Stack Gas Mole weight wet	Ms	lb/lbmole									
Stack Area	A	ft2									
Diameter of stack	D	inches									
Conversion Factor	F3	in/ft									
Stack Gas Velocity	Vs	ft/sec									
Pitot tube constant	Kp	test Vs:									
Pitot tube calibration coef	Cp										
Stack Gas Velocity Head	dP	in H2O									
Stack Gas Velocity Head	dP^0.5										
Stack gas temp	Ts	F									
Stack Ht	Ht	Ft									
Actual Stack Gas Flow Rate	Acf	acfm									
Conversion Factor	F5	acfs									
		sec/min									
Dry std Stack gas flow rate	Qstd	dscfm									
Dry std Stack gas flow rate	Qstd	dscf/hr									
Conversion Factor	F4	sec/hr									
	Qstd	dscf/min									
Isokinetic percent	I	%									
sample nozzle cross section	An	ft2									
length of sample test	theta	minutes									
Mass of part: combined	Mn	mg									
Mass of part: probe wash	Mp	mg									
Mass of part: filter	Mf	mg									
Unit Totals (tons per year)	PM10			146					83	81	82
Unit Totals (tons per year)	SO2			103					10	9	10
Unit Totals (tons per year)	NOx			195					58	57	57
Facility Totals (tons per year)	PM10								150	148	148
Facility Totals (tons per year)	TSP				151	154	148	139	na	na	na
Facility Totals (tons per year)	SO2				109	109	101	37	10	9	10
Facility Totals (tons per year)	NOx				263	284	283	268	58	57	57

Facility Specific Operating and Emissions Data (Graymont - Continued)

		Facility:	Graymont	Graymont	Graymont	Graymont	gm avg	compliance	compliance	
		Run ID or Unit ID:	2009	2010	2011	2012		Nov/2009	Aug/2011	Nov/20
			clk	clk	clk	clk		avg	avg	run 1
Pressure (stack absolute)	Ps	in HG	29.92	29.92	29.92	29.92	avg of	29.80	30.2	29.60
Pressure (barometric)	Pbar	in HG								29.6
Pressure (stack)	Pa	in H2O								0
Conversion Factor	F1	inH2O/inHg								13.6
Total water condensed	Vwst	scf H2)						1.87		1.6
	f	scf H2O/gm								0.04715
Total water condensed	Vw	std ft3						1.884		1.633
total impinger wt								34.6		34.6
Impinger 1	Vi	g								
Impinger 2	Vii	g								
Impinger 3	Viii	g								
Impinger 4	Viv	g								
Ideal gas constant	R	(inHG)(ft3)/(R-						21.85		21.85
Temperature abs	Tabs	R (459.67)						460		460
Temp std	Tstd	R (527.67)						528		528
Conversion Factor	F2	g/lb (should be						453.59		453.59
Pressure (std)	Pstd	in HG						29.92		29.92
MW of water	MH2O	lb/lbmole						18.015		18.015
Sample Volume	Vmst	dscf					62	67.038	57.121	62.891
Sample Volume from meter	Vm	dscf								
Dry gas mtr cal factor	Y	no units								
Meter orifice pressure	dH	in H2O								
Dry gas meter temp	Tm	F								
Stack Gas Moisture Fraction	Bws	vol%/100					0.0271	0.0273	0.0268	0.0253
Saturation Moisture	SBws	(sat vap press)/Ps								
same as BWS (because										
Stack Gas Mole weight dry	Md	lb/lbmole						29.33	29.55	29.15
Oxygen conc in stack	conc	%/100					0.181	0.187	0.174	0.196
CO2 conc in stack	conc	%/100								0.022
N2 conc in stack	con	%/100								0.782
Stack Gas Mole weight wet	Ms	lb/lbmole						29.02	29.24	28.86
Stack Area	A	ft2								
Diameter of stack	D	inches								
Conversion Factor	F3	in/ft						12	12	12
Stack Gas Velocity	Vs	ft/sec						1.45		1.39
Pitot tube constant	Kp	test Vs:						85.49		85.49
Pitot tube calibration coef	Cp							0.84		0.84
Stack Gas Velocity Head	dP	in H2O						0.0005		0.0005
Stack Gas Velocity Head	dP^0.5							0.022		0.022
Stack gas temp	Ts	F					217	183.9	250.5	187.1
Stack Ht	Ht	Ft								
Actual Stack Gas Flow Rate	Acf	acfm					82690	88331	77049	0
Conversion Factor	F5	acfs						60		60
Dry std Stack gas flow rate	Qstd	dscfm					63224	70191	56257	0
Dry std Stack gas flow rate	Qstd	dscf/hr						0		0
Conversion Factor	F4	sec/hr						3600		3600
	Qstd	dscf/min						0		0
Isokinetic percent	I	%						96.23		95.08
sample nozzle cross section	An	ft2						0.0084		0.0084
length of sample test	theta	minutes						120		120
Mass of part: combined	Mn	mg								
Mass of part: probe wash	Mp	mg								
Mass of part: filter	Mf	mg						23.68		23.68
							AVG			
Unit Totals (tons per year)	PM10		77	78	21	21	63			
Unit Totals (tons per year)	SO2		9	9	9	5	9			
Unit Totals (tons per year)	NOx		54	54	54	58	56			
Facility Totals (tons per year)	PM10		141	142	85	101	131			
Facility Totals (tons per year)	TSP		na	na	na	na	na			
Facility Totals (tons per year)	SO2		9	9	9	5	9			
Facility Totals (tons per year)	NOx		54	54	54	58	56			

Washington State Pulp Mills and Graymont Facility Information

Facility/Equip Type	Unit ID	Avg flow rate (acfm):	Date Constructed	Control Details	Date modified or rebuilt	Modification or Rebuild details	Additional Modified/ Rebuild Dates	Additional Modification/ Rebuild Details
GP Camas (Recovery Furnace)	No. 3	80,940	1957	2 chamber, 3 field ESP + venturi & Teller scrubbers	1990-1992	new 2-chamber, 3-fld ESP + AirPol cross flow packed bed SCRUBBER + wet heat rcvy	2005/2006	Secondary air incineration of HVLC
GP Camas (Recovery Furnace)	No. 4	125,556	1975	ESP	1981-1984, (ESP rebuilt in 1998)	2 chamber, 4 field ESP + Teller SCRUBBER + wet heat rcvy	2005/2006	Secondary air incineration of HVLC
KapStone (Recovery Furnace)	RF18	283,640	1965	ESP	(a)	To be permntly shut down (a)	na	na
KapStone (Recovery Furnace)	RF19	348,746	1975	ESP	(a)	Steam modifications. More efficient dry bottom ESP (a)	na	na
KapStone (Recovery Furnace)	RF22	291,343	1992	ESP	na	na	na	na
PTPC (Recovery Furnace)	RF	325,118	1968	ESP	1968-1976	na	na	na
WestRock (Recovery Furnace)	No. 4	344,256	1973	ESP	na	na	na	na
WestRock (Recovery Furnace)	No. 3	301,000	1961	1st ESP	1965, '73 1981-85	2nd ESP inst ('65), scrbr ('73), rblt ('81); 1st ESP rblt ('85)	1998	permntly shut down
Weyerhaeuser (Recovery Furnace)	No. 10	547,908	1975	RF No. 10 w/ESP replaced DCE 3,4,5 inst 1948, '52-'56)	1995	Kraft modernization project: Upgrade to hi-conc BL firing and added 3rd ESP chamber	1978	Sulphite mill installed 1931 discontinued. Kraft RF10 continues
Boise White Wallula (Recovery Furnace)	No. 2	86,066	1962	ESP	1995	tri-level air equip (PSD-95-04) is now stand alone rqmt	na	na
Boise White Wallula (Recovery Furnace)	No. 3	311,246	1978-80	ESP	1995	tri-level air equip (PSD-95-04) is now stand alone rqmt	1996	3rd ESP cell added to allow maintenance on primary cells during operation
Cosmo (Recovery Furnace)	(1,2 & 3)	159,660	1957 (1&2); '66 (#3)	(1&2 mltclones + 3 abs twrs; 3: mltclones +cyclone+3 vent scrubbers) 1,2,3; combined thru vent scrbr	2003	MACT II site specific: Control PM in hogged fuel dryer instead of RFs as surragte for HAPS	na	na
GP Camas (Lime Kiln)	No.4	10,332	1977-79	Ducon x-section variable throat vent scrbr. New "state of the art" lime kiln (No.4) replaced 3 old lime kilns from 1955-57.	na	na	na	na
KapStone (Lime Kiln)	LK3	21,643	1970	Ducon vent scr, lime mud oxidation	na	na	na	na
KapStone (Lime Kiln)	LK4	20,160	1955	AirPol HydroKenetic vent scr, lime mud oxidation	????	Scrubber modified	na	na
KapStone (Lime Kiln)	LK5	19,740	1982	ESP: H2O2 added to shower water on mud filters	na	na	na	na
PTPC (Lime Kiln)	LK	27,470	1975	Venturi scrubber	na	na	na	na
WestRock (Lime Kiln)	No.1	38,580	1960	Venturi scrubber	na	na	na	na
WestRock (Lime Kiln)	No.2	11,940	1973	Venturi scrubber	na	na	na	na
Weyerhaeuser (Lime Kiln)	#4	53,256	1986	ESP (LK#4 replaced Lime	na	na	na	na
Boise White Wallula (Lime Kiln)	LK	35,211	1978-79	Scrubber	1998	baghouse added to hot end of LK to reduce dust.	2012	Modified scrubber
Graymont (Lime Kiln)	Calcining (Lime) Kiln #1	82,690	<1969 (6/20/69 = earliest NOC found)	Baghouse	Various: See 5/4/07 Statement of Basis table: p.25 of 33.			

Notes:
(a) "Within 7 days after the modified RF19 is placed in operation, a letter informing Ecology of the date the modified unit was placed in operation and the date by which RF18 ... must be permanently retired." Source: June 2, 2011 Ecology letter and NOC 8429. Based on condition of modifying RF19 Date: TBD.

Appendix C. WSU Report

APPENDIX C Regional Haze RACT Analysis: Modeling Protocol and Results

Section C.0 Summary	1
Section C.1 Introduction	2
Section C.2 Technical Note: Choosing an Efficient Period to Model for Regional Haze.....	2
Section C.3 Models and Methods	11
C.3.1 Brief Model Description.....	11
C.3.2 Calculation of Deciview in CMAQ.....	12
Section C.4 Description of Modeling Scenarios.....	13
C.4.1 Baseline Emissions (1 st Modeling Scenario).....	13
C.4.2 RACT Limited Emissions (2 nd Modeling Scenario)	15
Section C.5 Regional Haze Modeling Results and Discussion.....	17
C.5.1 PM _{2.5} Model Performance Evaluation Results.....	17
C.5.2 Visibility Modeling Results	22
Section C.6 Conclusions	35
Section C.7 References	36

Section C.0 Summary

This report discusses impacts on regional visibility associated with the implementation of Reasonably Available Control Technology (RACT) for emissions of SO₂ and PM_{2.5} from pulp and paper facilities in Washington State. Facilities considered include: Boise White Paper, LLC, (Boise White Wallula), WestRock CP, LLC (WestRock), Cosmo Specialty Fibers Inc., (Cosmo), Port Townsend Paper Corporation (PTPC), Weyerhaeuser Longview Liquid Packaging (Weyerhaeuser), Georgia Pacific Consumer Products (Camas) LLC (GP Camas), and Longview Fibre Paper and Packaging, Inc. dba KapStone Kraft Paper Corporation (KapStone). Washington State University's AIRPACT4 modeling framework which is based on WRF-SMOKE-CMAQ is employed for modeling visibility improvements attributable to RACT. Based on visibility data from the Interagency Monitoring of Protected Visual Environments (IMPROVE) sites in the Pacific Northwest (PNW), May 2009 – April 2010 was identified as a suitable period for which baseline and RACT emissions were modeled. While model performance criteria for particulate sulfate were met at all 20 IMPROVE sites in the PNW, they were satisfied at 16 and 7 of these

sites for PM_{2.5} and organic carbon, respectively. The mean fractional bias calculated over all IMPROVE sites was -31% for PM_{2.5} and was largest for organic carbon (-70%). Results from this modeling study show that RACT implementation in the pulp and paper industry does little to improve visibility in Class I areas. Only Alpine Lakes Wilderness and Glacier Peak Wilderness have modeled 8th highest delta deciviews greater than 0.1 dv. The 8th highest deciview change was less than 0.05 dv at all of the IMPROVE sites. The largest deciview change at a non- IMPROVE site in Washington was 0.6 dv at Mesa.

Section C.1 Introduction

Visibility impairment due to fine particles which scatter and absorb light is termed as regional haze. Regional haze is formed due to multitude of sources both anthropogenic and natural- such as motor vehicles, industrial activities, power plants, wildfires, windblown dust etc. and are located across a large geographical area. Under the Clean Air Act, EPA is required to protect the visibility in mandatory class I areas from impairment due to anthropogenic air pollution. States are required to submit progress towards regional haze rule as a part of the State Implementation Plan (SIP). Washington Department of Ecology contracted with Washington State University (WSU) for the modeling portion of this RACT analysis. In the sections below we describe the rationale for selecting the modeling period; a brief description of the model and its various components, and a description of Baseline emission (BASE) and Reasonably Available Control Technology limited emission (RACT) cases. An analysis of model evaluation for PM_{2.5} and visibility and potential changes in visibility due to the emission changes are then presented.

Section C.2 Technical Note: Choosing an Efficient Period to Model for Regional Haze

By Clint Bowman

The analysis described in this note seeks to find a data set suitable for the air quality modeling necessary to support the next phase of the Regional Haze SIP. It seeks to find a period that is both representative of the prevailing visibility in the Class I areas and is efficient in resource

requirements. Because the metrics that determine an acceptable SIP consider only the best and worst quintiles of the distribution of visibility, this analysis seeks to find 365 day periods that have greater than average numbers of observations in those quintiles. It uses IMPROVE monitoring data from 20 western sites for the years 2007 through 2012.

Figure C.1 shows the location of 23 IMPROVE sites in the Northwest. They are color coded to show sites that have a strong seasonal variability (15 yellow markers)--specifically they have a higher proportion of poor visibility days in the winter and a lower proportion of poor visibility days in the summer compared with the incidence of good visibility days. The other set (5 red markers) seem to have a long six year period that peaks during the winter of 2009-2010 and a weak to non-existent seasonal component. The three sites with grey symbols were not used in this analysis.




Figure C.1: IMPROVE Sites in the Pacific Northwest

Observations are classified in the extreme quintiles by computing the 20th and 80th percentile extinction using the entire six years of observations at each site. Figure C.2, C.3, and C.4 are

time series of aerosol extinction coded so that observations falling in the middle three quintiles are plotted as zero, the worst visibilities are plotted as ones, and the best are plotted as minus one. The red line running through each timeseries is a running sum beginning with January 1, 2007. Time periods when there was a preponderance of poor visibility days show clearly as a positive slope. Conversely, periods of better visibility are shown by a negative slope.

Figure C.2 groups together sites that have a six month period of poor visibility beginning in 2009 followed by six months of good visibility. These sites also show a strong seasonal component. Figure C.3 is a similar time series for the sites that have a lesser seasonal component. The red lines show the boundaries of the period defined by the first group. Figure C.4 shows the three sites that can be best characterized as having a three year long period of worsening visibility followed by three years of improving visibility. Puget Sound (PUSO1) and White Pass (WHPA1) could be reasonably correlated but the site in Glacier National Park doesn't seem to fit.




Figure C.2: Time series of IMPROVE sites that exhibit strong seasonality.




Figure C.3: Time series of IMPROVE sites with weak seasonality.




Figure C.4: Time series of IMPROVE sites with multi-year trends.

One additional goal is to find a one year period that will be computationally efficient. The ideal would be to find a twelve month period that minimizes the number of average observations by

having only observations in the two extreme quintiles. To find periods that maximize the population of observations in the extreme quintiles, a running 365 day (122 of every third day observations) count of observations falling in the central three quintiles (between the 20th and 80th percentiles) was computed for each site and plotted in Figure C.5, C.6 and C.7 for the three groups of sites. The points are plotted at the 365th day. Most of the sites seem to reach a minimum in April 2010 which implies that the period from May 1, 2009 through April 30, 2010 may be the most efficient consecutive 12 month period.




Figure C.5: Time series of running sum of middle quintile occurrences and observed species contributing to visibility degradation.

The lower portion of each of these figures shows the time series of extinction using the daily maximum observation of all 20 sites produced by the six species known to contribute to visibility degradation: ammonium sulfate, ammonium nitrate, elemental carbon, coarse mass, organic matter (OMC), and sea salt. The wintertime increase in ammonium nitrate (the red series) is prominent in nearly every panel. The wildfires of 2007 and 2012 show prominently in the OMC time series. The two vertical black lines, drawn at May 1, 2009 and April 30, 2010, delineate the proposed twelve month period that can be used for air quality modeling to support the Regional Haze SIP analysis.

Table C.1: Number of occurrences of the best and worst quintile visibilities. Sites with fewer than 74 in the Neutral column are better than the long-term average when analyzing for the extreme quintiles

Site	Best	Neutral	Worst
PASA1	22	70	28
OLYM1	25	66	29
NOCA1	29	64	27
MORA1	27	65	28
MONT1	15	90	15
GAMO1	18	72	30
CRLA1	22	76	22
MOHO1	28	66	26
SNPA1	27	61	32
SULA1	16	85	19
THSI1	21	63	36
CORI1	17	72	31
CRMO1	18	88	14
HECA1	13	94	13
KALM1	23	73	24
SAWT1	8	86	26
STAR1	18	71	31
PUSO1	23	68	29
WHPA1	23	59	38
GLAC1	20	80	20




Figure C.6: Time series of cumulative days with visibilities in the middle quintiles




Figure C.7: Time series of cumulative days with visibilities in the middle quintiles.

Section C.3 Models and Methods

For this study, WSU's air quality forecasting system AIRPACT-4 (<http://lar.wsu.edu/airpact>) was used in a retrospective mode. Different components of the model and data used for each are briefly described in the sections below.

C.3.1 Brief Model Description

Spatial Domain: The modeling study uses the 4-km AIRPACT-4 domain of 258 cells east-west by 285 cells north-south, composed of cells of 4 km by 4 km, as shown in Figure C.8.




Figure C.8: The 4-km domain used in AIRPACT-4 is 258 cells east-west and 285 cells north-south, with the grid-cells being 4 km by 4 km. (from Vaughan et al., manuscript under review)

Time Duration: The period for this study was May 2009 – April 2010. The rationale for selecting this time period is given in Section C.2. AIRPACT-4 model reruns were performed for both the base case and RACT case.

Meteorology: The meteorological data for the study were acquired from the UW Pacific Northwest Environmental Forecasts and Observations mesoscale forecasting system, which runs nested domains of 36, 12, 4 and 1.33-km grid spacing. For the current work, archived 4-km WRF forecasts were reprocessed using MCIP v 3.6. It is important to recognize that the meteorological model output represents forecast conditions and is not based on any re-analysis incorporating weather observations. Performance of meteorological model is continuously evaluated and evaluation results are available at the website:

<http://www.atmos.washington.edu/mm5rt/>

Chemical Transport Modeling: The Community Multi-scale Air Quality Model, (CMAQ v4.7.1) was used on a 4-km grid with SAPRC99 chemistry and AE5 aerosol treatment.

Boundary conditions: The chemical boundary conditions were monthly mean chemical concentrations at the boundaries obtained by downscaling hourly output from MOZART-4 simulations (Emmons *et al.*, 2010).

Initial conditions: For the first day of the modeling period (May 1, 2009), initial conditions were based on idealized initial conditions. Subsequent daily runs in both the base case and RACT case used prior day results as initial conditions.

Emissions: Emissions for the model were taken from 2007 inventories provided by state agencies via NW-AIRQUEST. Emissions were processed using the SMOKE modeling system for point, area, mobile and biogenic sources. Emissions from forest fires were not included during any of the model runs. Two different emission scenarios were used which are described in Section C.4

C.3.2 Calculation of Deciview in CMAQ

CMAQ uses two different approaches for calculation of extinction coefficients: the Mie theory method and the reconstructed extinction method. The reconstructed extinction coefficient calculation method is similar to the IMPROVE method (Byun & Ching, 1999), and uses the following formula:

$$\beta_{ext} = 3 * f(RH) * \{ [(NH_4)_2SO_4] + [(NH_4NO_3)] \} + 4 * [OM] + 10 * [EC] + 1 * [Soil] + 0.6 * [Coarse Mass] + \beta_{Ray} \quad (C1)$$

Where $[SO_4^{2-}]$, $[NO_3^-]$, $[NH_4^+]$, $[OM]$, $[EC]$ and $[Soil]$ are the concentrations ($\mu\text{g}/\text{m}^3$) of sulfate, nitrate, ammonia, organic mass, elemental carbon and, soil respectively in $PM_{2.5}$. $f(RH)$ is a dimensionless relative humidity adjustment factor. $[CM]$ is the concentration of coarse particulate matter, which is not used because of the large uncertainties in the coarse particulate matter emission inventory. β_{Ray} is the Rayleigh extinction coefficient. β_{ext} is converted to deciviews using the following relationship:

$$DCV = 10 * \ln(\beta_{ext}/10) \quad (C2)$$

Under many conditions, a change of 1 deciview is perceptible by humans. However, a similar decrease in particle loading during a hazy condition will have less impact on visibility compared to a clean day. Natural visibility in Western US is estimated to be 178 - 186 km which corresponds to approximate deciview value of 8 dv (Malm, 1999) (Figure C.9)




Figure C.9: Comparison of extinction, deciviews and visual range (Source: Malm, 1999)

Section C.4 Description of Modeling Scenarios

The pre-RACT baseline and the post-RACT model runs are summarized in Sections C.4.1 and C.4.2:

C.4.1 Baseline Emissions (1st Modeling Scenario)

The 2007 emission inventory was used for this scenario except for an adjustment to the Cosmo facility. Because Cosmo did not operate from 2007 -2010, emission inventories indicate that there were no emissions from this facility for those years. After an evaluation of emission inventories for the years 2005, 2006, and 2011, the 2011 data were used to represent Cosmo's emissions in the base case. However, an error in processing the emission files resulted in no base case emissions for the Cosmo facility. This was addressed, without re-running the base case, as described below.

For Cosmo the RACT case involves both SO₂ and PM_{2.5} reductions. The net reduction in emissions is calculated between base case and RACT case as shown in Table C.2. Weighing of PM emissions by particulate species fraction for the SCC codes associated with Cosmo and their respective extinction coefficients don't result in significant changes to this percentage.

Table C.2: Cosmo emissions for the Base and RACT cases.

Case	PM ₁₀	NO _x	PM _{2.5}	SO ₂
BASE emissions	272	367.13	272	214
RACT emissions	272	367.13	174.5	50.07
Net reduction of emissions	$= 1 - \frac{(PM_{10} + NO_x + PM_{2.5} + SO_2)_{RACT}}{(PM_{10} + NO_x + PM_{2.5} + SO_2)_{BASE}}$ $= 1 - (864.33/1125.13) * 100 = 23.2\%$			

The BASE case with Cosmo emissions included (i.e. true baseline) is then approximated by linearly upscaling the RACT case deciviews attributable to Cosmo, by the net emissions change:

$$\text{BASE with Cosmo impacts} = (\text{RACT} - \text{BASE without Cosmo}) / (1 - 0.232).$$

This increase in deciviews is applied to an array of grid cells around the Cosmo facility (all cells lying between row 165-225 and column 15-60) (Figure C.10). The deciview results after adjustment for these grid cells are then incorporated into the overall BASE case results and this adjusted BASE case is used for calculating the 8th highest delta deciviews.




Figure C.10: Area in the domain where base case deciview is increased is shown in the red box

C.4.2 RACT Limited Emissions (2nd Modeling Scenario)

For this scenario, Ecology applied RACT limit adjustments to the baseline scenario described in Section C.4.1. As detailed in Chapter 4, measured or calculated emissions are averages of compliance tests or are calculated from averages of multi-year emission inventory emissions and other stack parameter information. Estimated emission reductions are the difference between average annual emissions and the average annual emissions multiplied by the ratio of emission at the proposed RACT limit to measured or calculated emission. Ecology’s approach is based on a survey of average emission reductions using average emission inventory emissions from multiple years, so that the average individual unit percent reduction is assumed to be applicable to approximately any given year that the facility operated around this timeframe.

Based on Table 4.2.1, Figures 4.2.1, 4.2.2, and Section 4.4.1, the following maximum potential emission reductions using the lowest demonstrated limits in Washington State were used in this scenario:

- For recovery furnaces, the lowest SO₂ emission limit demonstrated in Washington State is 10 parts per million (ppm),
- For recovery furnaces, the lowest PM emission limit demonstrated in Washington State is 0.027 gr/dscf @ 8% O₂.

Recovery furnace NO_x emission reductions and lime kiln emission reductions for SO₂, PM, and NO_x were less than these two emission reductions, and therefore, were set aside for potential future modeling scenarios depending on the results of the second scenario. Based on the results of the second scenario presented in the next section (Section C.5), Ecology determined that additional modeling scenarios were not needed.

The following percentage reductions from the baseline emissions were used:

Table C.3: Facility Emissions and Post-RACT Adjustments

Facility	Total Facility Emissions (tpy) for SO ₂ and PM _{2.5}		Percent Emission Reductions below Individual Recovery Furnace Unit SO ₂ Baseline using Potential RACT limit(a)(b)	Percent Emission Reductions below Individual Recovery Furnace Unit PM Baseline using Potential RACT limit (a)(b)
	SO ₂ BASE (RACT)	PM _{2.5} BASE (RACT)		
Boise White Wallula	684 (157)	179 (179)	(94% / 80%)	0%
WestRock	693 (313)	105 (105)	(95%)	0%
Cosmo	214 (50)	272 (174.5)	(97%)	(50%)
PTPC	123 (106)	261 (261)	(64%)	0%
Weyerhaeuser	-	-	0%	0%
GP Camas	-	-	0%	0%
KapStone	275 (223)	109 (109)	(67%/64%/88%)	0%

(a) Total facility emission reductions below baseline emissions are based on each facility's recovery furnace emission reductions from each unit specific baseline emissions. For facilities with multiple recovery furnaces, the respective recovery furnace identifiers are as follows: Boise White Wallula (Recovery Furnace No. 2/Recovery Furnace No. 3); Kapstone (Recovery Furnace 18/ Recovery Furnace 19/ Recovery Furnace 22)

(b) These emission reductions are based on using a potential 10 parts per million (ppm) SO₂ RACT limited emission and a potential 0.027 gr/dscf @ 8% O₂ PM RACT limited emission.

These emissions, including the Cosmo facility, were included in the RACT simulation case.

Section C.5 Regional Haze Modeling Results and Discussion

In the sections below, we describe the results from model performance evaluation for different PM_{2.5} species. This is followed by presentation of the effects of the RACT implementation on visibility in wilderness areas in Washington, Oregon, Idaho and Montana.

C.5.1 PM_{2.5} Model Performance Evaluation Results

The mean contribution of different species to total PM_{2.5} mass at all the sites for different seasons for years 2009-10 is shown in Figure C.11. OC and (NH₄)₂SO₄ are the dominate species contributing to total PM_{2.5} mass for summer and fall months. The contribution of NH₄NO₃ becomes significant during winter months. While there are obvious differences in total PM_{2.5} mass concentration between the observations and the model results, the relative contributions of different species is approximately the same.




Figure C.11: Observed and modeled seasonal mean of PM_{2.5} for the 2009-10 modeling period. The Mean Fractional Bias (MFB) and Mean Fractional Error (MFE) (Table C.4) were used for model performance evaluation; these measures have been suggested to be the preferred model performance measures for PM_{2.5} evaluation purposes (Boylan and Russell, (2009).

Table C.4: Metric used for model performance evaluation

Metric	Equation
Mean Fractional Bias (%) (-200% to +200%)	$FB = \frac{1}{N} \sum_{i=1}^N \frac{(C_m - C_o)}{(C_m + C_o)/2}$

Mean Fractional Error (%) (0% to +200%)	$FE = \frac{1}{N} \sum_{i=1}^N \frac{ C_m - C_o }{(C_m + C_o)/2}$
--	---

MFB and MFE were calculated over all IMPROVE sites for each of the model species shown in the Table C.5. Elemental carbon and sulfate have low bias compared to other species and MFB is close to the median MFB from various model studies reported in Simon et. al. (2012) (Figure C.12). Organic carbon and ammonium aerosols each have a large negative bias and a much lower than the median MFB reported in Simon et al. (2012). However, Simon et. al. report larger negative bias for nitrate and ammonium in the western US compared to the eastern US. In general, the model performance summarized here is similar to results from other air quality model evaluation studies.

Table C.5: MFB and MFE for all PM_{2.5} species (calculated over all IMPROVE sites)

PM Species	MFB (%)	MFE
Total PM _{2.5}	-31	72
Organic Carbon (OC)	-70	103
Elemental Carbon (EC)	-12	75
Sulfate (SO ₄ ²⁻)	9	52
Nitrate (NO ₃ ⁻)	-42	115
Ammonium (NH ₄ ⁺)	-37	67




Figure C.12: PM MFB/MFE from various modeling studies reported in Simon et. al. (2012)

The MFB and MFE at each individual IMPROVE site in the modeling domain is shown in the Table C.6.

Table C.6: PM_{2.5} Mean Fractional Bias (MFB) and Mean Fractional Error (MFE) at each IMPROVE site in the model domain

Site No.	Site Name	Site ID	PM _{2.5}		PM OC		PM SO ₄		# Obs N
			MFB (%)	MFE (%)	MFB (%)	MFE (%)	MFB (%)	MFE (%)	
1.	Craters of the Moon	160230101	-48	83	-86	104	0	43	115
2.	Sawtooth	160370002	-83	88	-164	164	3	45	102
3.	Glacier	300299001	-13	54	-90	93	-11	48	115
4.	Gates of the Mountains	300499000	-24	85	-69	106	11	54	104
5.	Monture	300779000	-75	88	-125	126	-8	51	113
6.	Sula Peak	300819000	41	71	-48	95	1	42	108
7.	Mt Hood	410050010	29	65	38	101	34	59	115
8.	Kalmiopsis	410330010	-67	72	-118	119	20	58	119
9.	Crater Lake	410358001	-54	72	-84	103	11	50	117
10.	Three Sisters	410390070	-17	73	-54	92	26	57	115
11.	Starkey	410610010	-66	82	-107	120	-8	44	122
12.	Hells Canyon	410630002	-60	78	-109	111	-5	38	115
13.	Olympic	530090020	-15	55	-20	83	13	46	120
14.	Snoqualmie Pass	530370004	-31	75	-71	99	5	57	121
15.	Wishram CORI	530390011	-43	60	-76	81	-14	47	122
16.	White Pass	530410007	-18	75	-36	106	34	65	118
17.	Pasayten	530470012	-38	84	-73	115	20	59	113
18.	Mt Rainier	530530014	-35	55	-38	78	13	56	117
19.	North Cascades	530730022	-53	76	-73	115	3	56	120
20.	Seattle Beacon Hill	530330080	38	53	11	48	39	58	119

The MFB and MFE for total PM_{2.5}, organics carbon and sulfate are shown in Figure C.13, where the MFB and MFE are compared to performance goals and criteria. These graphs show that the model has reasonably good performance with 16 out of 20 IMPROVE sites within the performance criteria¹ for PM_{2.5}, 7 out of 20 sites within the performance criteria for OC and all sites within the criteria for sulfate.

The MFB and MFE show strong seasonal behavior for all PM_{2.5} species (Figure C.14). In general, the MFB (calculated for all sites) shows an underprediction during summer and slight overprediction during winter. Also the interquartile range is largest during the winter months,

¹ Sites outside MFB are: Sawtooth, Monture, Kalmiopsis, Starkey

whereas summer months exhibit a relatively small interquartile range, with most MFB values being negative, indicating that model performance is a strong function of the site location.

Summary of the model performance evaluation results:

1. Organic carbon and ammonium sulfate dominate $PM_{2.5}$ mass for most part of the year. Ammonium nitrate also becomes important during winter months.
2. The model performance evaluation against MFB and MFE goals and criteria indicates that model demonstrates reasonable performance for $PM_{2.5}$, EC, SO_4^{2-} and NH_4^+ .
3. The model overpredicts $PM_{2.5}$ during winter and underpredicts during other times of year. This seasonality is observed for all PM species.
4. The negative bias in OC during late summer and early fall may be due to the omission of wildfire emissions from CMAQ during June-September.




Figure C.13: MFB and MFE in PM_{2.5}, OC and sulfate aerosol mass prediction for all IMPROVE sites for the study period




Figure C.14: Box-whisker plots showing monthly variation in MFB and MFE in PM_{2.5} aerosol mass prediction at all IMPROVE sites

C.5.2 Visibility Modeling Results

C.5.2.1 Visibility Model Evaluation

Modeled visibility data were extracted and the reconstructed deciviews and extinction coefficients were compared to these visibility parameters based on the IMPROVE data. Time series of modeled and observed deciviews, shown in Figure C.15-C.16, exhibit a high degree of variability over time and by site. At some times and sites, the modeled deciview is much higher than observed, while at other times and sites, the reverse is true.




Figure C.15: Time series for comparison of modeled and observed deciviews at North Cascades (top), and Pasayten (bottom)



Figure C.16: Comparison of modeled and observed deciviews at Wishram (top), and Mt. Rainier (bottom)

Figure C.17 shows the QQ plot of observed and modeled deciviews for all the IMPROVE sites. The model underpredicts deciviews by 2-5 deciviews when deciviews between 5-20 are observed. The predictions are closer to observations at higher deciviews. The differences between model and observations for visibility are, in part, related to errors in meteorological model results for relative humidity (see discussion in C.5.2.4).




Figure C.17: QQ plot of observed and modeled deciviews at all IMPROVE sites

C5.2.2 Deciview differences between RACT and BASE case model runs

Table C.7 shows the deciview differences for the worst and 8th worst visibility days between the RACT and BASE case model runs for IMPROVE sites in Washington. The differences between the RACT and BASE cases are very small relative to BASE case deciviews in the range from 3 to 25. Thus, effectively there is no observable difference between BASE and RACT visibility at IMPROVE sites in Washington.

Table C.7: Deciview difference for 1st highest and 8th highest observed deciview for sites in Washington

	Site name	Observed dv	Modeled dv		Δdv
			BASE	RACT	
1 st Highest	North Cascades	25.552	5.460	5.458	0.002
	MtRainier	18.795	6.832	6.827	0.004
	Pasayten	24.482	3.182	3.181	0.001
	White Pass	29.939	5.518	5.516	0.002
	Wishram CORI	28.791	25.488	25.486	0.002
	Snoqualmie Pass	20.421	5.709	5.707	0.002
	Seattle Beacon	25.437	18.946	18.946	0.000
	Olympic	19.903	10.866	10.866	0.000
8 th Highest	North Cascades	15.958	4.695	4.693	0.002
	MtRainier	16.827	11.787	11.779	0.008
	Pasayten	12.450	2.177	2.176	0.001
	White Pass	13.417	7.311	7.308	0.003
	Wishram CORI	22.946	6.921	6.918	0.003
	Snoqualmie Pass	16.960	5.336	5.336	0.000
	Seattle Beacon	22.564	14.369	14.369	0.000
	Olympic	15.038	5.770	5.769	0.000

Since no meaningful difference was observed between the RACT and BASE case visibility at the IMPROVE sites during the days of 1st and 8th highest deciviews, we also show the 1st and 8th highest deciview differences between RACT and BASE case (Table C.8). While these results show that the improvement in visibility due to RACT emissions reduction does not necessarily occur during the worst visibility days, even the largest differences are quite small. The highest Δdv was 0.287 at White Pass in Washington, followed by 0.155 at Snoqualmie Pass.

In Table C.9, we also show highest deciview differences between the RACT and BASE cases for Non-IMPROVE sites (AIRNOW sites). Only those sites where the maximum Δdv was greater than 0.10 were tabulated. At these sites, larger visibility improvements are seen compared to IMPROVE sites, with the maximum Δdv equal to 0.61 at Mesa in Washington. However, for these maximum differences, the change between the RACT and BASE cases is still quite small.

Table C.8: 1st Highest and 8th highest deciview differences at IMPROVE sites in WA and OR
(Adv may not correspond to worst visibility days)

IMPROVE Sites in WA & OR		Adv (BASE case – RACT case)	
Site ID	Site Name	1 st highest	8 th highest
530410007	White Pass (WA)	0.2869	0.0173
530370004	Snoqualmie Pass (WA)	0.1553	0.049
530470012	Pasayten (WA)	0.0803	0.0157
530530014	Mt Rainier (WA)	0.062	0.0112
530330080	Seattle Beacon (WA)	0.0601	0.0167
530390011	Wishram CORI (WA)	0.037	0.0129
410358001	Crater Lake (OR)	0.0294	0.0038
530730022	North Cascades (WA)	0.0183	0.0136
530090020	Olympic (WA)	0.0113	0.0023
410330010	Kalmiopsis (OR)	0.0181	0.0015
410390070	Three Sisters (OR)	0.0247	0.0057
410610010	Starkey (OR)	0.0418	0.0168
410630002	Hells Canyon (OR)	0.0123	0.0045

Table C.9: 1st Highest and 8th highest deciview differences at selected Non IMPROVE sites in WA and OR
(Adv may not correspond to worst visibility days)

Non-IMPROVE Sites in WA & OR		Adv (BASE case – RACT case)	
Site ID	Site Name	1 st highest	8 th highest
530210002	Mesa-Pepoit Way	0.61	0.09
410591003	Hermiston - Municipal Airport	0.48	0.20
530272002	Aberdeen-Division St	0.42	0.26
410590121	Pendleton - McKay Creek	0.39	0.15
530750005	Lacrosse-Hill St	0.32	0.06
530710005	Walla Walla-12th St	0.31	0.07
530010003	Ritzville-Alder St	0.27	0.07
530750006	Rosalia-Josephine St	0.27	0.04
530332004	Kent-James & Central	0.24	0.06
530330023	Enumclaw Mud Mt (SO)	0.19	0.02
530330017	North Bend Way (SO)	0.17	0.05
530330039	Seattle-Queen Anne Hill	0.17	0.04
530630001	Cheney-Turnbull	0.15	0.05
530270008	Oakville-Chehalis Tribe	0.15	0.10
530130002	Dayton-W Main	0.15	0.05
530330024	Lake Forest Park-Town Center	0.14	0.04
530530012	Mt Rainier- Jackson Visitor Ctr	0.13	0.01
530330037	Bellevue-Bellevue Way	0.13	0.05

Non-IMPROVE Sites in WA & OR		Δdv (BASE case – RACT case)	
Site ID	Site Name	1 st highest	8 th highest
530670013	Lacey-College St	0.12	0.06
530490002	Raymond Commercial St.	0.12	0.05
530530031	Tacoma-Alexander Ave	0.12	0.06
530450007	Shelton-W Franklin	0.11	0.07
410170122	Bend - Road Department	0.11	0.01
530251002	Moses Lake-Balsam St	0.11	0.06
530639999	Airway Heights-West 12th	0.10	0.04

C.5.2.3 Impact on Visibility in National Parks and Wilderness Areas

The modeled visibility data for the BASE and RACT cases were extracted and the 8th highest deciview difference was calculated for grid cells where at least half of the area of the cell was within any Class I wilderness area or national park. The maximum 8th highest Δdv occurring within each Class I area is shown in Table C.10. Modeled Δdv are small with improvements greater than 0.1 dv occurring at only two locations – Alpine Lake Wilderness, and Glacier Peak Wilderness as shown in the table below. Thus, improvements in these areas due to potential RACT limits on emissions are very small.

Table C.10: 8th highest delta deciview over modeled period (98th percentile delta deciview)

S. No.	Class I / Wilderness areas in WA/OR/ID	Row # in model domain	Column # in model domain	Δdv Visibility Impacts due to Potential RACT limit
1.	Alpine Lakes Wilderness	200	83	0.127
2.	Columbia River Gorge NP	144	82	0.029
3.	Crater Lake NP	76	64	0.017
4.	Craters of the Moon NP	94	232	0.011
5.	Diamond Peak Wilderness	90	64	0.018
6.	Eagle Cap Wilderness	136	159	0.030
7.	Gearhart Mountain Wilderness	61	89	0.007
8.	Glacier Peak Wilderness	208	85	0.117
9.	Goat Rocks Wilderness	168	78	0.038
10.	Hells Canyon Wilderness	150	168	0.033
11.	Kalmiopsis Wilderness	54	28	0.006
12.	Mount Adams Wilderness	161	77	0.030
13.	Mount Baker Wilderness	228	69	0.057
14.	Mount Hood Wilderness	140	72	0.022

S. No.	Class I / Wilderness areas in WA/OR/ID	Row # in model domain	Column # in model domain	Δdev Visibility Impacts due to Potential RACT limit
15.	Mount Jefferson Wilderness	117	71	0.031
16.	Mount Rainier NP	179	72	0.037
17.	Mount Washington Wilderness	111	70	0.041
18.	Mountail Lakes Wilderness	58	64	0.009
19.	North Cascades NP	223	83	0.080
20.	Olympic National Park	198	35	0.023
21.	Pasayten Wilderness	228	93	0.045
22.	Sawtooth Wilderness	109	200	0.021
23.	Selway Bitterroot Wilderness	167	194	0.053
24.	Spokane Tribe Class I area	209	138	0.053
25.	Strawberry Mt Wilderness	110	132	0.015
26.	Three Sisters Wilderness	104	72	0.044
27.	Yellowstone National Park	124	277	0.016

8th Highest delta deciview




Figure C.18: Map of 8th highest deciview difference due to potential RACT emission limits. Class I boundaries are also shown

A map of the 8th highest deciview difference is shown in Figure C.18. Most of the change in 8th highest Δdv occurs in southwestern Washington, potentially due to RACT emissions reduction from the Cosmo facility. Similar to this, Figure C.19- C.20 show the delta deciviews observed at various grid cells lying in National Parks or wilderness areas in PNW and Washington. As seen from Figure C.19 - C.20, a deciview change of more than 0.1 is observed only at a few grid cells all in Alpine Lake Wilderness and Glacier Peak Wilderness.




Figure C.19: 8th highest change in deciviews observed at grid cells in National Parks / Class I Wilderness Areas in PNW




Figure C.20: 8th highest change in deciviews observed at grid cells in National Parks / Class I Wilderness Areas in WA

C.5.2.4 Deciview dependence on Relative Humidity Factor [$f(RH)$] during summer and winter

Because the model did a reasonably good job in predicting individual PM_{2.5} species and total PM_{2.5} mass concentration, but had poor performance for visibility, we investigated model performance for humidity in terms of the relative humidity factor ($f(RH)$) used to calculate deciviews. We used constant mean concentrations for summer and winter for each species (Table C.11) with a range of $f(RH)$ values from 1 to 21. With the fixed concentrations and varying $f(RH)$, deciviews were calculated according to equations C1 and C2. As shown in Figure C.21, the deciview depends strongly on $f(RH)$; errors in predicting $f(RH)$ will be exhibited as errors in predicting visibility. Since $f(RH)$ varied significantly for some days at some locations (Figure C.22) during winter months and was consistently underpredicted at all sites during summer months, these differences dominate errors in predicted concentrations.

Table C.11: Concentrations used for showing $f(RH)$ dependence of deciview

S. No.	Species	Case 1 (Summer)		Case 2 (Winter)	
		Modeled Concentration ($\mu\text{g}/\text{m}^3$)	Observed Concentration ($\mu\text{g}/\text{m}^3$)	Modeled Concentration ($\mu\text{g}/\text{m}^3$)	Observed Concentration ($\mu\text{g}/\text{m}^3$)
1.	EC	0.15	0.2	0.2	0.15
2.	NH4	0.2	0.35	0.2	0.15
3.	SO4	0.6	1	0.5	0.2
4.	NO3	0.05	0.15	0.4	0.2
5.	OC	0.3	1.5	0.5	0.5
6.	Others	0.6	2	1	0.1
7.	Total	1.9	5.2	2.8	1.3




Figure C.21: Illustrating dependence of deciviews on $f(\text{RH})$ with fixed PM concentration




Figure C.22: Observed versus modeled RH factor at two locations in Washington

Section C.6 Conclusions

AIRPACT-4 model performance was evaluated for total $PM_{2.5}$ and PM species at all IMPROVE sites. Comparison of MFB and MFE against the MFB/MFE goals and criteria show that AIRPACT-4 does a good job, except for PM-OC, which also impacts total $PM_{2.5}$ prediction

performance. Based on the CMAQ modeling results presented in the previous sections, we can conclude that predicted improvements in visibility due to potential RACT limits at Washington Pulp and Paper facilities are negligible in national parks and the Class I wilderness areas . Modeled 8th highest Δdv are small with the improvement greater than 0.1dv occurring at only two locations – Alpine Lake Wilderness (0.127 Δdv) and Glacier Peak Wilderness (0.117 Δdv). Maximum modeled improvement doesn't occur on the days of worst visibility for any of the IMPROVE sites in Washington. At some Non-IMPROVE sites, the change in dv is relatively large compared to IMPROVE sites. The relative humidity factor, $f(RH)$ plays significant role in the visibility determination and, poor model performance for $f(RH)$ is inhibiting model performance for visibility.

Section C.7 References

- Boylan, James W., and Armistead G. Russell. "PM and light extinction model performance metrics, goals, and criteria for three-dimensional air quality models." *Atmospheric environment* 40.26 (2006): 4946-4959.
- Byun D. W. and Ching J.K.S. (editors). "Science Algorithms of the EPA Models-3 Community Multiscale Air Quality Modelling (CMAQ) System". Accessed from USEPA website: <http://www.epa.gov/amad/CMAQ/CMAQdocumentation.html>
- Joseph. K. Vaughan, Serena H. Chung, Farren L. Herron-Thorpe, Emmons Louisa, Lamb Brian K., Zhang Rui, Jaffe Daniel A., Nicole L. Wigder, George H. Mount. "Assessing the Effect of Boundary Ozone Inflow for the Pacific Northwest Region using the AIRPACT-4 Air-Quality Forecast System" Manuscript under preparation (2015).
- Simon, Heather, Kirk R. Baker, and Sharon Phillips. "Compilation and interpretation of photochemical model performance statistics published between 2006 and 2012." *Atmospheric Environment* 61 (2012): 124-139.
- Emmons, L. K., Walters, S., Hess, P. G., Lamarque, J.-F., Pfister, G. G., Fillmore, D., Granier, C., Guenther, A., Kinnison, D., Laepple, T., Orlando, J., Tie, X., Tyndall, G., Wiedinmyer, C., Baughcum, S. L., and Kloster, S. Description and evaluation of the Model for Ozone and Related chemical Tracers, version 4 (MOZART-4), (2010) *Geosci. Model Dev.*, 3, 43-67.
- Malm, W. C. "Introduction to Visibility". (1999). Cooperative Institute for Research in the Atmosphere, Colorado State University.

Appendix D. Cost Estimates

Appendix D Cost Estimates

Cost estimates in Chapter 6 were based on references provided in Tables 37 and 38 of Chapter 6.

Wet electrostatic precipitator estimates provided below:

WESP	Capital Cost		O&M Costs		Annualized Costs	
	Low range \$/scfm	High range \$/scfm	Low range \$/scfm	High range \$/scfm	Low range \$/scfm	High range \$/scfm
Recovery Furnaces	\$20	\$40	\$5	\$40	\$9	\$47
PTPC	\$4,373,153	\$8,746,307	\$1,093,288	\$8,746,307	\$1,967,919	\$10,276,911
WestRock 4	\$4,329,617	\$8,659,235	\$1,082,404	\$8,659,235	\$1,948,328	\$10,174,601
Weyerhaeuser 10	\$6,936,567	\$13,873,133	\$1,734,142	\$13,873,133	\$3,121,455	\$16,300,931
GP Camas 4	\$2,185,649	\$4,371,298	\$546,412	\$4,371,298	\$983,542	\$5,136,275
GP Camas 3	\$1,421,687	\$2,843,375	\$355,422	\$2,843,375	\$639,759	\$3,340,966
KapStone 18	\$4,298,397	\$8,596,794	\$1,074,599	\$8,596,794	\$1,934,279	\$10,101,233
KapStone 19	\$5,216,699	\$10,433,398	\$1,304,175	\$10,433,398	\$2,347,514	\$12,259,242
KapStone 22	\$3,973,999	\$7,947,997	\$993,500	\$7,947,997	\$1,788,299	\$9,338,897
Boise White Wallula 2	\$1,159,055	\$2,318,109	\$289,764	\$2,318,109	\$521,575	\$2,723,779
Boise White Wallula 3	\$3,913,946	\$7,827,893	\$978,487	\$7,827,893	\$1,761,276	\$9,197,774
Cosmo 1,2,3	\$3,109,920	\$6,219,840	\$777,480	\$6,219,840	\$1,399,464	\$7,308,312
Min	\$1,159,055	\$2,318,109	\$289,764	\$2,318,109	\$521,575	\$2,723,779
Max	\$6,936,567	\$13,873,133	\$1,734,142	\$13,873,133	\$3,121,455	\$16,300,931
Lime Kilns	Capital Cost	Capital Cost	O&M Costs	O&M Costs	Annualized Costs	Annualized Costs
PTPC LK	\$471,936	\$943,873	\$117,984	\$943,873	\$212,371	\$1,109,051
WestRock 1	\$656,499	\$1,312,999	\$164,125	\$1,312,999	\$295,425	\$1,542,773
WestRock 2	\$209,332	\$418,664	\$52,333	\$418,664	\$94,199	\$491,930
Weyerhaeuser 4	\$661,034	\$1,322,068	\$165,258	\$1,322,068	\$297,465	\$1,553,429
GP Camas 4	\$178,848	\$357,697	\$44,712	\$357,697	\$80,482	\$420,294
KapStone 3	\$376,020	\$752,040	\$94,005	\$752,040	\$169,209	\$883,646
KapStone 4	\$356,477	\$712,954	\$89,119	\$712,954	\$160,415	\$837,721
KapStone 5	\$271,984	\$543,969	\$67,996	\$543,969	\$122,393	\$639,163
Boise White Wallula	\$599,056	\$1,198,113	\$149,764	\$1,198,113	\$269,575	\$1,407,783
Graymont	\$1,299,635	\$2,599,270	\$324,909	\$2,599,270	\$584,836	\$3,054,143
Min	\$178,848	\$357,697	\$44,712	\$357,697	\$80,482	\$420,294
Max	\$1,299,635	\$2,599,270	\$324,909	\$2,599,270	\$584,836	\$3,054,143