

Class 2 (Mobile Facility) Transfer Reminders

Spills Prevention, Preparedness & Response

These items are required to be on-site during a transfer ([Chapter 173-180 WAC](#)).

- Air horn** - Must be handheld and stationed at the point of transfer (e.g.: vessel manifold).



- Two intrinsically safe portable communication devices** - One for deliverer and one for receiver.



- Sorbent materials for a 2-barrel (84 gallon) spill**

This can be a combination of sorbent pads, pillows, socks, or booms. 150 - 200 standard 18" square sorbents have capacity of about 25 gallons.



- Storage capacity for a 2-barrel spill**

Options include drums or 6 mil clear drum liner bags. Waste bags should be double bagged, staged on a visqueen liner, and be not more than a third full.

- Means to contain drips from connection points**



- Non-sparking buckets**
- 2 recommended



- Non-sparking scoops**
- 2 recommended



- Non-sparking shovels**
- 2 recommended



- Operations Manual**
- Current version, Ecology approved, immediately accessible.

- Response Manual**
- Current version, Ecology approved, immediately accessible.

- Portable containment** for each tank vent on the vessel if the vessel doesn't have its own fixed containment.



Jason Reichert
jason.reichert@ecy.wa.gov
(360) 584-2799



To request an ADA accommodation, contact Ecology by phone at 360-407-6831 or ecyadacoordinator@ecy.wa.gov, or visit <https://ecology.wa.gov/accessibility>. For Relay Service or TTY call 711 or 877-833-6341.