

Washington State Department of Ecology

Refrigerant Management Program



Do you own, operate, or service refrigeration or air conditioning equipment with 50 pounds or more of refrigerant?

If you answered yes, the refrigerant management program (RMP) requirements apply to you!

Beginning January 1, 2024, Washington owners/operators are required to conduct and report periodic leak inspections, promptly repair leaks, and keep service records on site.

This applies to ALL refrigeration and air conditioning equipment with 50 or more pounds of refrigerant with a global warming potential (GWP) greater than 150.

Equipment owners/operators must also register their equipment and submit periodic reports through the refrigeration and air conditioning management platform (RAMP) beginning:

| Equipment Size Category | Effective Date |
|--|-----------------------|
| Large (1,500+ pounds of refrigerant) | January 1, 2024 |
| Medium (200-1,499 pounds of refrigerant) | January 1, 2026 |
| Small (50-199 pounds of refrigerant) | January 1, 2028 |

The largest piece of equipment at your facility determines when your facility is required to register in RAMP.

Are you a refrigerant wholesaler, distributor, or reclaimer?

Beginning January 1, 2024, you are required to register with Ecology through RAMP.

Publication #24-14-037



Visit website

www.ecology.wa.gov/hydrofluorocarbons



Register in RAMP guide

[Step-by-step user guide](#)



View a video of RAMP registration

[RAMP registration visual guide](#)



Contact Ecology

CPRRAMP@ECY.WA.GOV



Stay Informed

[Sign up for our HFC email list](#)



DEPARTMENT OF
ECOLOGY
State of Washington

Climate Pollution Reduction Program

P.O. Box 47600

Olympia, WA 98504-7600

Accommodation Requests: To request ADA accommodation including materials in a format for the visually impaired, visit ecology.wa.gov/accessibility or call Ecology at 425-324-5901. People with impaired hearing may call Washington Relay Service at 711. People with speech disability may call TTY at 877-833-6341.