

TO: Stew Messman
FROM: Darrel Anderson
SUBJECT: Diablo STP
DATE: March 19, 1973

State of
Washington
Department of
Ecology



On February 22, 1973, an efficiency survey was conducted at the Diablo STP. The survey period was from 0930 to 1600 hours, compositing every hour. This plant, as well as Newhalem, is owned and operated by Seattle City Light. Plant appearance, housekeeping, and security are very good.

The Diablo STP is also new and has a problem of decreasing population. Definite changes are eminent for the plant because nearly the whole population will be removed in the near future.

Influent samples were difficult to take due to intermittent pump action of holding tank. COD reduction is 48 percent while BOD is 86 percent. PH was high (8.8) during the monitoring and tapered off in the afternoon.

Plant efficiency was generally low and engineering changes are recommended in the near future.

DLA:bj

WATER QUALITY SURVEY

City Diablo Plant Type Secondary Population <150 Design 204 at 120 gpd
 Served Capacity
 Receiving Water Skagit River Engineer Don Simms
 Date 2-21-73 Survey Period 0930-1630 Survey Personnel Darrel Anderson
 Comp. Sampling Frequency every hour Weather Conditions clear, warm
 (last 48 hours)
 Sampling Aliquot 1000 ml

PLANT OPERATION

Total Flow 1,154.40 g/hr How Measured "V" notch weir
 Max. (Flow) 45.0 g/min. Time of Max. 1230 Min. 1.1 g/min. Time of Min. 1500
 Pre Cl₂ 0 #/day Post Cl₂ 1 #/day

FIELD RESULTS

Determinations	Influent				Effluent			
	Max.	Min.	Mean	Median	Max.	Min.	Mean	Median
Temp. °C	8	7	7.5	8	7.5	6.0	6.9	7.5
pH	8.8	7.6	8.1	8.2	6.5	6.0	6.3	6.4
Conductivity (umhos/cm)	NOT DETERMINED				NOT DETERMINED			
Settleable Solids	7	2	5	7	4	3	3.6	3

LABORATORY RESULTS ON COMPOSITE IN PPM

Laboratory Number	Influent	Effluent	% Reduction
	73-784	73-785	
5-Day BOD	252	34	86
COD	310	160	48
T.S.	--*	313	--
T.N.V.S.	--*	180	--
T.S.S.	--*	93	--
N.V.S.S.	--*	18	--
pH	8.2	6.6	--
Conductivity	510	400	--
Turbidity	44	44	--

* Insufficient sample

Dfablo STP

BACTERIOLOGICAL RESULTS

Na₂S₂O₃ added to sample before sample ~~XXXX~~ was taken. XXX.

LAB #	SAMPLING TIME	COLONIES/100 MLS (MF)	Cl Residual	
			ppm	(after secs)
73-786	0930	20,000	0.15	3 min.
73-787	1130	10,000	0.10	3 min.
73-788	1330	12,000	0.35	3 min.
73-789	1530	2,000	0.35	3 min.

Operator's Name Melvin Mohn Phone # _____

Comments: _____

STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY

WATER QUALITY LABORATORY

DATA SUMMARY

ORIGINAL TO:
COPIES TO:
.....
LAB FILES

Source Diablo STP

Collected By D.A.

Date Collected 1-21-73

Goal, Pro./Obj.

Log Number:	73	784	785	786	787	788	789	STORET
Station:	inf	eff	EFF	EFF	EFF	EFF		
			0930	1130	1330	1530		
pH	8.2	6.6	-	-	-	-		00493
Turbidity (JTU)	44	44	-	-	-	-		00070
Conductivity (umhos/cm)@25°C	510	400	-	-	-	-		00095
COD	310	160	-	-	-	-		00300
BOD (5 day)	252	34	-	-	-	-		00310
Total Coliform (Col./100ml)	-	-	20,000	10,000	12,000	2,000		31504
Fecal Coliform (Col./100ml)	-	-	<200	<200	200	<200		31616
NO3-N (Filtered)								00620
NO2-N (Filtered)								00615
NH3-N (Unfiltered)								00610
T. Kjeldahl-N (Unfiltered)								00625
O-PO4-P (Filtered)								00671
Total Phos.-P (Unfiltered)								00665
Total Solids	* 313							00500
Total Non Vol. Solids	* 150							
Total Suspended Solids	* 93							00530
Total Sus. Non Vol. Solids	* 18							
Fecal Strept (col./100ml)	-	-	200	270	500	110		

Note: All results are in PPM unless otherwise specified. ND is 'None Detected'
Convert those marked with a * to PPB (PPM X 10³) prior to entry into STORET
* Environmental Sample

Summary By Stephen J. Hall Date 1-15-73

U.S. DEPARTMENT OF THE INTERIOR
 FEDERAL WATER POLLUTION CONTROL ADMINISTRATION
**SEWAGE TREATMENT PLANT OPERATION AND MAINTENANCE
 PRACTICES QUESTIONNAIRE**

FORM # 400-21-D
 AUGUST 1964-65 NO. 42-11527

CHECK ONE: <input checked="" type="checkbox"/> 1ST AUDIT <input type="checkbox"/> RE-AUDIT	DATE OF AUDIT 2-21-73	PLANT DESCRIPTION CODE (For Official Use Only)
---	---------------------------------	--

A. GENERAL INFORMATION

1. PROJECT (Name, Number) A1-4-72-2A	SCOPE OF PROJECT (New plant, addition, etc.) FROM PLANT #1 IN 1971 TO 1971
2. PLANT LOCATION (City, County) DIABLO, WHATCOM COUNTY	IDENTIFICATION OF AREA SERVED DIABLO, WHATCOM COUNTY - 1945, DIABLO

3. POPULATION

3A. FRACTION OF AREA POPULATION SERVED (%)	3B. PLANT DESIGN (Population equivalent) 204 at 120 mg/l per capita	3C. SERVED BY PLANT (domestic) - DIABLO, CA - 1971 POPULATION
--	---	---

4. TYPE OF COLLECTION SYSTEM

4A. <input type="checkbox"/> COMBINED <input checked="" type="checkbox"/> SEWER <input type="checkbox"/> OTHER	4B. ESTIMATED FLOW CONTRIBUTED BY SURFACE OR GROUND WATER (gal/day, mgd) 1 mgd
--	--

5. YEAR PRESENT SYSTEM PLACED IN OPERATION

5A. SEWER 1971	5B. PLANT 1971	5C. ANCILLARY WORKS
--------------------------	--------------------------	---------------------

3A. SIZE OF PLANT SITE (acres) 1.2 ACRES	4D. APPROXIMATE AREA LEFT FOR EXPANSION (acres)
--	---

6A. IN THE SPACE PROVIDED BELOW FURNISH A DETAILED FLOW DIAGRAM OR A WRITTEN DESCRIPTION OF THE PLANT UNITS IN THE SEQUENCE OF FLOW. SHOW THE METHOD OF FLOW, THE METHOD OF FLOW MEASUREMENT, SHOW APPROXIMATE FLOW RATES, AND THE STABILIZATION POND OR BOD CELL. INDICATE WHETHER FLOW TO AND FROM PLANT IS BY PUMP OR GRAVITY.

PLANT IS DIVIDED INTO 2 RESIDENTIAL SECTIONS - 1000 CAPACITY EACH. SECTION BAR. IN SECTION A PUMPING STATION PLACES THE WASTE INTO A 1000 GALLON TANK. IN SECTION B, FROM WHERE IT FLOWS INTO A 1000 GALLON WELL AT THE WORKS PLANT. THE PUMPING STATION IS 100 FEET FROM THE WELL. WASTE UNDER GRAVITY INTO THE WASTE TANK. FROM THE WASTE TANK, PUMPS LIFT THE WASTE INTO THE TREATMENT PLANT. THE CURRENT FLOW FROM THE WASTE TANK TO THE CHECKING CONTACT TANK AND IS KEPT AT A CONSTANT FLOW. FLOW TO THE RIVER IS KEPT AT A CONSTANT FLOW UNTIL SUCH TIME WHEN IT IS KEPT AT A CONSTANT FLOW.

6B. NOTE ANY SIGNIFICANT OR UNIQUE PROCESSING CONDITIONS:
PLANT IS KEPT AT A CONSTANT FLOW UNTIL SUCH TIME WHEN IT IS KEPT AT A CONSTANT FLOW.

9. RECEIVING STREAM

9A. NAME OF STREAM
WAGIT RIVER

9B. STREAM FLOW IS: PERMANENT INTERMITTENT NATURAL REGULATED CRITICAL

B. CURRENT PERFORMANCE AND PLANT LOADING INFORMATION

1A. ANNUAL AVERAGE DAILY FLOW RATE (MGD) 1.2 MGD	1B. PEAK FLOW RATE (MGD) 1.2 MGD	1C. NO. OF PEAK FLOWS PER YEAR 1
2. AVERAGE BOD OF RAW SEWAGE (2 DAY 20°C) (mg/l)	3. AVERAGE BOD LOADING RATE (lb BOD/1000 GPD)	4. AVERAGE SOLIDS LOADING RATE (lb SOLIDS/1000 GPD)
1.2	1.2	1.2

<p>4. IS PLANT HAV. STANDBY POWER GENERATOR FOR MAJOR PUMPING FACILITIES? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO</p> <p>5. ARE CHLORINATION FACILITIES PROVIDED? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO IF YES, ANSWER 8A THRU G</p>	<p>7B. ADEQUATE ALARM SYSTEM FOR LOW FLOW OR EQUIPMENT FAILURE? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO</p> <p>8. IF YES, IS CHLORINATION CONTINUOUS? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO IF NO, EXPLAIN REASON FOR INTERMITTENT CHLORINATION</p>	
<p>9A. PURPOSE OF CHLORINATION <i>DISINFECTING EFFLUENT TO CONFORM WITH PUBLIC HEALTH STANDARDS</i></p>		
<p>9B. TYPE OF CHLORINATOR <i>WHAUSE & TIERNAN MSP</i></p>		
<p>9C. POINT OF APPLICATION OF CHLORINE <i>CHLORINE CONTACT TANK</i></p>	<p>9D. CAN BYPASSED SEWAGE BE CHLORINATED? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO</p>	
<p>9E. AVERAGE FEED RATE OF CHLORINE (lb./day) <i>1.5</i></p>	<p>9F. CHLORINE RESIDUAL IN EFFLUENT <i>0.4 ppm AT END OF 15 MINUTES</i></p>	
<p>9G. MINIMUM SUPPLY OF CHLORINE STORED ON PREMISES (lb) <i>ONLY 15 LBS. BEING STORED IN ROOM - 100 LB. SUPPLY AVAILABLE AT ALL TIMES</i></p>		
<p>9. ARE FACILITIES PROVIDED FOR COMPLETE BYPASS OF RAW SEWAGE? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO IF YES, ANSWER A THRU G BELOW, ANSWER H IN EITHER CASE.</p>		
<p>9A. FREQUENCY (times/week) <i>SEE CHLORINE ROOM</i></p>	<p>9B. AVERAGE DURATION (hours) <i>24-36 HRS</i></p>	<p>9C. REASON FOR BYPASSING <i>OVERFLOW</i></p>
<p>9D. ESTIMATED FLOW RATE DURING BYPASS IS <input checked="" type="checkbox"/> WITHIN HYDRAULIC CAPACITY OF PLANT <input type="checkbox"/> BEYOND HYDRAULIC CAPACITY OF PLANT BY</p>	<p>9E. DOES SEWAGE OVERFLOW IN DRY WEATHER? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO</p>	
<p>9F. TYPE OF DIVERSION STRUCTURE <i>OVERFLOW LINE FROM WET WELL</i></p>	<p>9G. AGENCIES NOTIFIED OF BYPASS ACTION <i>STATE & CITY</i></p>	
<p>9H. DO OPERATORS HAVE OPTION TO BYPASS INDIVIDUAL PLANT UNITS? (If no, has this caused any operational problems?) <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO <i>NO PROBLEMS</i></p>		
<p>10A. ARE BACK FLOW DEVICES PROVIDED AT ALL CONNECTIONS TO CITY WATER SUPPLY? (If no, explain) <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO <i>NO DIRECT CONNECTIONS</i></p>		
<p>10B. CHECK TYPE OF BACK FLOW PREVENTION DEVICE <input type="checkbox"/> DOUBLE CHECK VALVE <input type="checkbox"/> PRESSURE OPERATED <input type="checkbox"/> PHYSICAL DISCONNECT <input type="checkbox"/> OTHER (specify)</p>		
<p>11. USES OF TREATMENT PLANT EFFLUENT <i>FOR FISHES</i></p>		
<p>12. USES OF RECEIVING STREAM WITHIN 10 MILES OF OUTFALL <i>RIVER RECREATION, FISHING</i></p>		
<p>13. HAVE THERE BEEN ANY ODOR COMPLAINTS BEYOND THE PLANT PROPERTY? (If yes, explain) <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO</p>		
<p>14. OBSERVED APPEARANCE AND CONDITION OF EFFLUENT, RECEIVING STREAM, OR DRAINAGE WAY <i>WATER CLEAR</i></p>		

UTILIZATION POINTS *As per attached sheet*

1. EFFLUENT AND VEGETATIVE GROWTH IN PONDS ELIMINATED? YES NO

2. BANKS AND DIRT'S MAINTAINED (REMOVED)? YES NO

3. FENCING AND TRAINING - POLLUTED WATER? SIGNS PRESENT AND IN GOOD REPAIR? YES NO

4. FREQUENCY OF INSPECTION BY OPERATOR

5. WATER DEPTH (feet) _____ HIGH _____ LOW _____ MEDIUM

6. ADEQUATE CONTROL OF DEPTH? YES NO

7. SEEPAGE REPORTED? YES NO

8. ANY REPORTS OF GROUND WATER CONTAMINATION FROM POND (if yes, give details)? YES NO

9. ESCORTED FISHING PROHIBITED? YES NO

10. IF YES, NAME OF SPECIES IF KNOWN _____

11. CAN SURFACE RUN-OFF ENTER POND? YES NO

C. SUPERVISORY SERVICES

1. IS A CONSULTING ENGINEER RETAINED OR AVAILABLE FOR CONSULTATION ON OPERATING AND MAINTENANCE PROBLEMS? YES NO

IF YES IS IT ON: CONTINUING BASIS OR UPON REQUEST BASIS

IF CONTINUING BASIS, WHAT IS THE FREQUENCY OF VISITS _____

2. DO OPERATORS AND OTHER PERSONNEL ROUTINELY ATTEND SHORT COURSES, SCHOOLS OR OTHER TRAINING ACTIVITIES? YES NO

IF YES, CITE COURSE SPONSOR AND DATE OF LAST COURSE ATTENDED _____

IF NO, DO YOU KNOW OF ANY COURSES AVAILABLE TO SERVE THIS AREA? *NOT AT PRESENT*

3A. ARE ALL EQUIPMENT AND PARTS OF THE PRESENT PLANT STILL IN OPERATION? YES NO (If no, explain)

B. ARE PROCESSING UNITS OPERATING AT DESIGN EFFICIENCY? YES NO (If no, explain)

AT PRESENT, THE QUESTION RATES A QUALIFIED YES. WILL BE A SUBSTANTIAL REDUCTION IN THE FUTURE

4. HAVE THERE BEEN ANY DIFFICULTIES WITH THE SEWAGE TREATMENT PLANT?

A. STRUCTURAL YES NO (If yes, explain)

B. MECHANICAL YES NO (If yes, explain)

C. OPERATIONAL YES NO (If yes, explain)

D. BASED ON OPERATING EXPERIENCE TO DATE WHAT IF ANY CHANGES WOULD YOU RECOMMEND TO IMPROVE OPERATION OF THE PLANT?

NONE TO DATE, BUT AS THE POPULATION DIABLO DECREASES, THERE MIGHT BE CHANGES REQUIRED

4. THE METHODS OF RECORDS MAINTAINED BY YOU (manual, check, printed forms included) YES NO

RECORDS BY YES NO TO WHOM *self*

FREQUENCY	WEATHER	FLOW	SLUDGE HANDLED	CHEMICALS USED	DIGESTER	GRIT HANDLED	ELEC. USED	COST DATA	AIR USED	MAINTENANCE	OTHER
DAILY	<input checked="" type="checkbox"/>									<input checked="" type="checkbox"/>	
WEEKLY											
MONTHLY											
ANNUALLY											

5. ARE LABORATORY RECORDS MAINTAINED? (check appropriate box)
 NOT AT ALL DAILY WEEKLY MONTHLY ANNUALLY

IF MAINTAINED CHECK FORM OF RECORD BELOW:
 LOG BOOK TABULAR SHEET SEPARATE BY OPERATION CONTROL CHARTS GRAPHS
 WHAT PLANT AND/OR LABORATORY EQUIPMENT, GAUGES AND METERS ARE CALIBRATED PERIODICALLY?

7. IS LABORATORY TESTING ADEQUATE FOR THE CONTROL REQUIRED FOR THIS SIZE AND TYPE OF PLANT?
 YES NO (if no, explain)

B. INDUSTRIAL WASTES DISCHARGED TO MUNICIPAL SYSTEM	A. NUMBER AND TYPES OF INDUSTRIES DISCHARGING TO SYSTEM <i>text</i>
B. POPULATION EQUIVALENT (POD) OF INDUSTRIAL WASTES (per)	C. POPULATION EQUIVALENT (SE) OF INDUSTRIAL WASTES (per)
D. VOLUME OF INDUSTRIAL WASTES (mgd)	E. COMPOSITION AND CHARACTERISTICS OF INDUSTRIAL WASTES
F. MAIN DIFFICULTY EXPERIENCED WITH INDUSTRIAL WASTE (explain)	

8. HAVE INDUSTRIAL EFFLUENT PROBLEMS BEEN SOLVED? YES NO (if yes, how?)

9A. METHOD OR METHODS USED TO ASSESS INDUSTRIAL WASTE TREATMENT COST (check appropriate box)
 NO CHARGE BY CITY PROPERTY TAX WATER USE ASSESSMENT CHARGE BASED ON FLOW
 CHARGED BASED ON BOD CHARGE BASED ON SS OTHER METHODS (describe)
 COMMENT ON HOW CHARGE IS COLLECTED (fixed charge, sliding scale, etc.)

9B. IS INDUSTRIAL WASTE ORDINANCE IN EFFECT AND ENFORCED? YES NO

10. WHO PROVIDED INITIAL INSTRUCTION IN THE OPERATION OF THE PLANT?
text

11. IS A MANUAL OF PRACTICE OR INSTRUCTIONS AVAILABLE? YES NO
 IF YES, WHO WROTE AND PROVIDED IT? *text*

12. ESTIMATE OF MAN-HOURS PER WEEK DEVOTED TO LABORATORY WORK AND MAINTENANCE OF RECORDS AND REPORTS
20 HOURS

D. PLANT PERSONNEL - Annual Average Staff for Last Business Year Reported in Section 9A-11

JOB CATEGORY	NUMBER	TOTAL MAN-HOURS PER WEEK	TOTAL NUMBER CERTIFIED OR LICENSED	PERCENTAGE OF EMPLOYEES PRESENT DURING	PERCENTAGE OF LABOR HOURS
1. SUPERINTENDENT					
2. OPERATORS					
3. LABORATORY TECHNICIAN					
4. LABORERS					
5. PART-TIME EMPLOYEES					
6. TOTAL					

E. LABORATORY CONTROL

Enter test codes opposite appropriate items. If any of the below tests are used to monitor industrial wastes, place an "X" in addition to the test code.

COD/F5

1 - 7 or more per week 3 - 1, 2, or 3 per week 5 - 2 or 3 per month 7 - Quarterly 9 - Annually
 2 - 4, 5 or 6 per week 4 - as required 6 - 1 per month 8 - Semi-Annually

ITEM	RAW	PRIMARY EFFLUENT	MIXED LIQUOR	FINAL	SLUDGE		DIGESTOR	RECEIVING STREAM
					RAW	DIPPED-NATANT		
1. BOD								
2. SUSPENDED SOLIDS								
3. SETTLEABLE SOLIDS			3	3				
4. SUSPENDED VOLATILE								
5. DISSOLVED OXYGEN			4					
6. TOTAL SOLIDS								
7. VOLATILE SOLIDS								
8. pH				3				
9. TEMPERATURE			3					
10. COLIFORM DENSITY								
11. RESIDUAL CHLORINE				3				
12. VOLATILE ACIDS								
13. M. D. STABILITY								
14. ALKALINITY								
15.								
16.								
17.								
18.								
19.								

F. OPERATION AND MAINTENANCE COST FOR PLANT

YEAR OF OPERATION	SALARIES/WAGES	ELECTRICITY	CHEMICALS	MAINTENANCE	OTHER ITEMS	TOTAL
MOST CURRENT YEAR 19						
PRIOR YEAR 19						
PRIOR YEAR 19						
PRIOR YEAR 19						

EVALUATION PERFORMED BY	TITLE	ORGANIZATION

INFORMATION FURNISHED BY	TITLE	ORGANIZATION	DATE

6. ROTATIONS BY EVALUATOR

ADDITIONAL REMARKS: (If remarks refer to a particular item, identify by number)

2. GENERAL COMMENTS ON HOUSEKEEPING

no general comments

MAINTENANCE

no major maintenance
to plant

3. REQUIREMENTS OF HIGHER AUTHORITY

3A. DOES THE PLANT PROVIDE THE DEGREE OF TREATMENT PRESENTLY REQUIRED BY THE STATE? (If no, explain)

YES NO

3B. ARE THERE ANY PENDING ACTIONS (enforcement conferences, change in water quality standards, etc.) THAT WOULD REQUIRE UPGRADING OF TREATMENT BY THIS PLANT?

YES NO (If yes, explain)

3C. NUMBER OF STATE INSPECTIONS OF PRESENT PLANT TO DATE:

4. IS ANY FOLLOW-THRU ACTION REQUIRED TO (1) CORRECT DEFICIENCIES IN THE PLANT OR ITS OPERATION OR (2) RESOLVE INDUSTRIAL WASTE PROBLEMS? (If yes, describe required corrective action) YES NO