

December 11, 1973

Memo to: Gerry Calkins  
 From: Ron Devitt  
 Subject: Longview Sewage Lagoons Survey.

State of  
 Washington  
 Department  
 of Ecology



On October 25, 1973, an efficiency survey was conducted on Longview Lagoons. Since there were flow recorders on both the influent and the effluent, composites were portioned based on each respective flow rate.

The system was not working very well based on BOD<sub>5</sub> reduction. Also the BOD<sub>5</sub> of 129 ppm in the effluent is rather high. The prevailing overcast weather, combined with rain, was less than optimal for lagoon performance.

Serious hydraulic overloading occurred at the headworks from 1200-1300 hours (see pictures). Jim Thom said that one of their lift stations had probably plugged and that the excessive flow was caused by continuous pumping. The flow was 28 inches head height through a six inch Parshall flume; this exceeded the capacity of the flow meter. The influent channel flooded out and splashed over. The color of the influent was extremely dark, but no offensive odor or acidic condition was present to indicate septicity.



The lagoons were being operated in series with the influent entering the #2 cell first. Dissolved oxygen determinations were made using the YSI probe at various locations in the system. Highest concentrations of oxygen correlated with the obvious abundant concentrations of algae.

Excepting station #E, all oxygen values were taken about 3 feet from shore. At #E, measurements were taken from the cat walk. The data are for near the surface of the lagoon and should be considered maximum values. The wind was blowing in a North-easterly direction. The height of the dikes permitted algae to be in a quiescent state at stations B, D, G and H. It is also at these stations where high oxygen values were recorded.



RD:jmh

WIND


	D.O. ppm	Temp C°
A	4.4	13.0
B	>15	13.5
C	6.3	13.2
D	>15	14.0
E	12	13.5
F	4.1	14.0
G	13.5	13.5
H	8.4	13.5
I	3.3	13.5



Head Works



= ALGAE  
 = SEWAGE FLOW  
 = SAMPLING STATION



STP SURVEY REPORT FORM

(EFFICIENCY STUDY)

City Longview Plant Type Lagoons Population 4,000 Design                       
 Served                      Capacity                       
 Receiving Water Coal Creek Engineer H. Steeley  
 Date 10-25-73 Survey Period 0930-1730 hour Survey Personnel R.C. Devitt  
 Comp. Sampling Frequency 1/2 hour Weather Conditions Sprinkles, rain, overcast.  
 (last 48 hours)  
 Sampling Alequot Maximum influent flow on cycle + 2 mls.

Influent = :251900 MG in 8 PLANT OPERATION  
 Total Flow Effluent = .103300 MG in 8 hrs. How Measured Parshall flume recorders  
 \*Max. (Flow) >2.3 MGD Time of Max. 1200-1300 hrs Min. 1.4 MGD Time of Min. 1700 hrs.  
 Pre Cl<sub>2</sub> NA #/day Post Cl<sub>2</sub> 28 #/day  
 \* Head height of 6" Parshall Flume = 28"

FIELD RESULTS

17 Determinations	Influent				Effluent			
	Max.	Min.	Mean	Median	Max.	Min.	Mean	Median
Temp. °C	16.9	15.9	16.5	16.5	13.5	11.8	12.5	12.6
pH	7.3	7.0	7.1	7.1	7.8	7.0	7.2	7.2
Conductivity (umhos/cm)	550	350	450	450	350	350	350	350
Settleable Solids	25	2.0	---	---	Nil	Nil	----	----

LABORATORY RESULTS ON COMPOSITE IN PPM

Laboratory Number	Influent	Effluent	% Reduction
	73-3957	73-3958	
5-Day BOD	212	129	39%
COD	350	140	60%
T.S.	651	376	42%
T.N.V.S.	287	191	33%
T.S.S.	352	71	79%
N.V.S.S.	134	9	93%
pH	7.2	7.4	
Conductivity	550	450	
Turbidity	70	20	
Color	258	183	

Longview Lagoons

BACTERIOLOGICAL RESULTS

Na<sub>2</sub>S<sub>2</sub>O<sub>3</sub> added to sample in Bottle After \_\_\_\_\_ min.

LAB #	SAMPLING TIME	COLONIES/100 MLS (MF)		15 Sec. 3 Min. Cl Residual	
		Total	Fecal	ppm	(after secs)
73-3959	1030	<400	<200	.35	.5
3960	1130	<400	<200	.2	.35
3961	1230	<400	<200	.35	.5
3962	1330	<400	<200	.30	.35
3963	1600	<400	<200	.30	.5

Operator's Name Jim Thom Phone # \_\_\_\_\_

Parameters:	Nutrient	Effluent - ppm
	NO <sub>2</sub> -N (Filtered)	1.02
	NO <sub>3</sub> -N (Filtered)	1.88
	NH <sub>3</sub> -N	5.2
	T. Kjeldahl-N	7.8
	O-PO <sub>4</sub> -P (Filtered)	7.00
	Total Phos.-P	28.0

Exhibit P

U.S. DEPARTMENT OF THE INTERIOR  
FEDERAL WATER POLLUTION CONTROL ADMINISTRATION  
SEWAGE TREATMENT PLANT OPERATION AND MAINTENANCE  
PRACTICES QUESTIONNAIRE

FORM APPROVED  
BUDGET BUREAU NO. 42-01527

CHECK ONE:  1ST AUDIT  RE-AUDIT  
DATE OF AUDIT: 10-24  
PLANT DESCRIPTION CODE (For Official Use Only)

A. GENERAL INFORMATION

1. PROJECT (State, Number): LONGVIEW LAGOONS  
2. PLANT LOCATION (City, county): LONGVIEW - COWLITZ  
SCOPE OF PROJECT (new plant, additions, etc.):  
IDENTIFICATION OF AREAS SERVED: West Longview


3. POPULATION  
3A. FRACTION OF AREA POPULATION SERVED (%):  
3B. PLANT DESIGN (population equivalent):  
3C. SERVED BY PLANT (domestic): 4,000

4. TYPE OF COLLECTION SYSTEM  
4A.  COMBINED  SEPARATE  BOTH  
4B. ESTIMATE FLOW CONTRIBUTED BY SURFACE OR GROUND WATER (infiltration, mgd): .5

5. YEAR COMMUNITY BEGAN SEWAGE TREATMENT:  
6. YEAR PRESENT SYSTEM PLACED IN OPERATION:  
6A. SEWER: 1966  
6B. PLANT: 1966  
6C. ANCILLARY WORKS:

7A. SIZE OF PLANT SITE (acres): 20  
7B. APPROXIMATE AREA LEFT FOR EXPANSION (acres): 40

8A. IN THE SPACE PROVIDED BELOW FURNISH A SIMPLIFIED FLOW DIAGRAM OR A WRITTEN DESCRIPTION OF THE PLANT UNITS IN FLOW SEQUENCE. INCLUDE THE METHOD OF ULTIMATE SLUDGE DISPOSAL. SHOW APPROXIMATE SURFACE AREA OF STABILIZATION PONDS AND NUMBER OF CELLS. INDICATE WHETHER FLOW TO AND FROM PLANT IS BY PUMPING OR GRAVITY.



8B. NOTE ANY SIGNIFICANT OR UNIQUE PROCESSING CONDITIONS.

9. RECEIVING STREAM

9A. NAME OF STREAM: GOAL CR.

9B. STREAM FLOW IS:  
 PERENNIAL  INTERMITTENT  NATURAL  REGULATED  
 INTERSTATE  INTRASTATE  
 COASTAL

B. CURRENT PERFORMANCE AND PLANT LOADING INFORMATION

1A. ANNUAL AVERAGE DAILY FLOW RATE (mgd): 500 MGD  
1B. PEAK FLOW RATE (mgd):  
DRY WEATHER: .120  
WET WEATHER: 1.5  
1C. MINIMUM FLOW RATE (mgd): .112

2. AVERAGE BOD OF RAW SEWAGE (5 DAY 20°C) (ppm): 104  
3. AVERAGE SETTLEABLE SOLIDS OF RAW SEWAGE (mg/l): 45

4. AVERAGE SUSPENDED SOLIDS OF RAW SEWAGE (mg/l): 130  
5. AVERAGE COLIFORM DENSITY OF RAW SEWAGE (100 ml):

6. ANNUAL AVERAGE PLANT PERFORMANCE

6A. BOD (%): 61  
6B. SETTLEABLE SOLIDS (%):  
6C. SUSPENDED SOLIDS (%): 24  
6D. COLIFORM DENSITY (%):

7A. DOES PLANT HAVE STANDBY POWER GENERATOR FOR MAJOR PUMPING FACILITIES?  YES  NO

7D. ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES?  YES  NO

8. ARE CHLORINATION FACILITIES PROVIDED?  YES  NO IF YES, ANSWER 8A THRU G

IF YES, IS CHLORINATION CONTINUOUS?  YES  NO IF NO, EXPLAIN REASON FOR INTERMITTENT CHLORINATION

8A. PURPOSE OF CHLORINATION  
*disinfection*

8D. TYPE OF CHLORINATOR  
*MANUAL - GAS*

8C. POINT OF APPLICATION OF CHLORINE  
*after 2nd lagoon*

8D. CAN BYPASSED SEWAGE BE CHLORINATED?  YES  NO

8E. AVERAGE FEED RATE OF CHLORINE (lb/day)  
*40*

8F. CHLORINE RESIDUAL IN EFFLUENT  
 \_\_\_\_\_ PPM AT END OF \_\_\_\_\_ MINUTES

8G. MINIMUM SUPPLY OF CHLORINE STORED ON PREMISES (lb)  
*3,000*

9. ARE FACILITIES PROVIDED FOR COMPLETE BYPASS OF RAW SEWAGE?  
 YES  NO IF YES, ANSWER A THRU G BELOW, ANSWER H IN EITHER CASE.

9A. FREQUENCY (times monthly)  
*1*

9B. AVERAGE DURATION (hours)

9C. REASON FOR BYPASSING

9D. ESTIMATED FLOW RATE DURING BYPASS IS  
 WITHIN HYDRAULIC CAPACITY OF PLANT  
 BEYOND HYDRAULIC CAPACITY OF PLANT BY

9E. DOES SEWAGE OVERFLOW IN DRY WEATHER?  YES  NO

9F. TYPE OF DIVERSION STRUCTURE

9G. AGENCIES NOTIFIED OF BYPASS ACTION

9H. DO OPERATORS HAVE OPTION TO BYPASS INDIVIDUAL PLANT UNITS? (If no, has this caused any operational problems?)  
 YES  NO

10A. ARE BACK FLOW DEVICES PROVIDED AT ALL CONNECTIONS TO CITY WATER SUPPLY? (If no, explain)  
 YES  NO

10B. CHECK TYPE OF BACK FLOW PREVENTION DEVICE  
 DOUBLE CHECK VALVE  PRESSURE OPERATED  PHYSICAL DISCONNECT  OTHER (specify) *vacuum break*

11. USES OF TREATMENT PLANT EFFLUENT  
*NONE*

12. USES OF RECEIVING STREAM WITHIN 10 MILES OF OUTFALL  
*to Columbia - same*

13. HAVE THERE BEEN ANY ODOR COMPLAINTS BEYOND THE PLANT PROPERTY? (If yes, explain)  
 YES  NO

14. OBSERVED APPEARANCE AND CONDITION OF EFFLUENT, RECEIVING STREAM, OR DRAINAGE WAY

15. STABILIZATION POND

A. WEEDS CUT AND VEGETATIVE GROWTH IN PONDS ELIMINATED?  YES  NO

D. BANKS AND DIKES MAINTAINED (erosion etc.)?  YES  NO

C. FENCING AND "WARNING - POLLUTED WATER" SIGNS PRESENT AND IN GOOD REPAIR?  YES  NO

E. FREQUENCY OF INSPECTION BY OPERATOR 2x/week

E. WATER DEPTH (feet) 4 HIGH 4 LOW 4 MEDIUM

F. ADEQUATE CONTROL OF DEPTH?  YES  NO

G. SEEPAGE REPORTED?  YES  NO

H. ANY REPORTS OF GROUND WATER CONTAMINATION FROM POND (if yes, give details)?  YES  NO

I. MOSQUITO BREEDING PROBLEM?  YES  NO

IF YES, NAME OF SPECIES IF KNOWN

J. CAN SURFACE RUN-OFF ENTER POND?  YES  NO

C. SUPERVISORY SERVICES

1. IS A CONSULTING ENGINEER RETAINED OR AVAILABLE FOR CONSULTATION ON OPERATING AND MAINTENANCE PROBLEMS?

YES  NO IF YES IS IT ON:  CONTINUING BASIS OR  UPON REQUEST BASIS  
IF CONTINUING BASIS, WHAT IS THE FREQUENCY OF VISITS:

2. DO OPERATORS AND OTHER PERSONNEL ROUTINELY ATTEND SHORT COURSES, SCHOOLS OR OTHER TRAINING ACTIVITIES?

YES  NO

IF YES, CITE COURSE SPONSOR AND DATE OF LAST COURSE ATTENDED

presently

IF NO, DO YOU KNOW OF ANY COURSES AVAILABLE TO SERVE THIS AREA?

3A. ARE ALL EQUIPMENT AND PARTS OF THE PRESENT PLANT STILL IN OPERATION?  YES  NO (if no, explain)

B. ARE PROCESSING UNITS OPERATING AT DESIGN EFFICIENCY?  YES  NO (if no, explain)

4. HAVE THERE BEEN ANY DIFFICULTIES WITH THE SEWAGE TREATMENT PLANT?

A. STRUCTURAL  YES  NO (if yes explain)

high water floods into channel

B. MECHANICAL  YES  NO (if yes, explain)

C. OPERATIONAL  YES  NO (if yes, explain)

D. BASED ON OPERATING EXPERIENCE TO DATE WHAT IF ANY CHANGES WOULD YOU RECOMMEND TO IMPROVE OPERATION OF THE PLANT?

influent structure bypass to cells (eliminate comminutor)

5. ARE OPERATING RECORDS MAINTAINED? (If maintained, check general items included)  YES  NO

REPORTED?  YES  NO  
TO WHOM? *DOE*

FREQUENCY	WEATHER	FLOW	SLUDGE HANDLED	CHEMICALS USED	DIGESTER	GRIT HANDLED	ELEC. USED	COST DATA	AIR USED	MAINTENANCE	OTHER
DAILY		<i>X</i>									
WEEKLY				<i>X</i>							
MONTHLY											
ANNUALLY											

6. ARE LABORATORY RECORDS MAINTAINED? (check appropriate box)

NOT AT ALL  DAILY  WEEKLY  MONTHLY  ANNUALLY

IF MAINTAINED CHECK FORM OF RECORD BELOW:

LOG BOOK  TABULAR SHEET  SEPARATE BY OPERATION  CONTROL CHARTS  GRAPHS

WHAT PLANT AND/OR LABORATORY EQUIPMENT, GAGES AND METERS ARE CALIBRATED PERIODICALLY?

7. IS LABORATORY TESTING ADEQUATE FOR THE CONTROL REQUIRED FOR THIS SIZE AND TYPE OF PLANT?

YES  NO (If no, explain)

B. INDUSTRIAL WASTES DISCHARGED TO MUNICIPAL SYSTEM?	A. NUMBER AND TYPES OF INDUSTRIES DISCHARGING TO SYSTEMS <i>AAA</i>
B. POPULATION EQUIVALENT (BOD) OF INDUSTRIAL WASTES (pc)	C. POPULATION EQUIVALENT (SS) OF INDUSTRIAL WASTES (pc)
D. VOLUME OF INDUSTRIAL WASTES (mgd)	E. COMPOSITION AND CHARACTERISTICS OF INDUSTRIAL WASTES
F. MAIN DIFFICULTY EXPERIENCED WITH INDUSTRIAL WASTE (explain)	

8. HAVE INDUSTRIAL EFFLUENT PROBLEMS BEEN SOLVED?  YES  NO (If yes, how?)

9A. METHOD OR METHODS USED TO ASSESS INDUSTRIAL WASTE TREATMENT COST (check appropriate box)

NO CHARGE BY CITY  PROPERTY TAX  WATER USE ASSESSMENT  CHARGE BASED ON FLOW

CHARGED BASED ON BOD  CHARGE BASED ON SS  OTHER METHODS (describe)

COMMENT ON HOW CHARGE IS COLLECTED (fixed charge, sliding scale, etc.)

9B. IS INDUSTRIAL WASTE ORDINANCE IN EFFECT AND ENFORCED?  YES  NO

10. WHO PROVIDED INITIAL INSTRUCTION IN THE OPERATION OF THE PLANT?

11. IS A MANUAL OF PRACTICE OR INSTRUCTIONS AVAILABLE?  YES  NO

IF YES, WHO WROTE AND PROVIDED IT?

12. ESTIMATE OF MAN-HOURS PER WEEK DEVOTED TO LABORATORY WORK AND MAINTENANCE OF RECORDS AND REPORTS

*2 mo*

D. PLANT PERSONNEL (Annual Average Staff for Most Recent Year Reported in Section "F")

JOB CATEGORY	NUMBER	TOTAL MAN-HOURS PER WEEK	TOTAL NUMBER CERTIFIED OR LICENSED	RANGE IN YEARS EMPLOYED AT PRESENT PLANT	RANGE IN YEARS OF EXPERIENCE IN TREATMENT
1. SUPERINTENDENT					
2. OPERATORS					
3. LABORATORY TECHNICIANS					
4. LABORERS					
5. PART-TIME LABORERS					
6. TOTAL					

*SAME AS ABOVE*



E. LABORATORY CONTROL

Enter test codes opposite appropriate items. If any of the below tests are used to monitor industrial wastes place an "X" in addition to the test code.

CODES

- 1 - 7 or more per week      3 - 1, 2, or 3 per week      5 - 2 or 3 per month      7 - Quarterly      9 - Annually  
 2 - 4, 5 or 6 per week      4 - as required      6 - 1 per month      8 - Semi-Annually

ITEM	RAW	PRIMARY EFFLUENT	MIXED LIQUOR	FINAL	SLUDGE		DIGESTOR	RECEIVING STREAM
					RAW	SUPER-NATANT		
1. BOD	6			6				
2. SUSPENDED SOLIDS	6			6				
3. SETTLEABLE SOLIDS	2			2				
4. SUSPENDED VOLATILE	1			1				
5. DISSOLVED OXYGEN	2			2				
6. TOTAL SOLIDS								
7. VOLATILE SOLIDS								
8. pH	2			2				
9. TEMPERATURE	2			2				
10. COLIFORM DENSITY	1			3				
11. RESIDUAL CHLORINE	2			2				
12. VOLATILE ACIDS								
13. M. B. STABILITY								
14. ALKALINITY								
15.								
16.								
17.								
18.								
19.								

F. OPERATION AND MAINTENANCE COST FOR PLANT

YEAR OF OPERATION	SALARIES/WAGES	ELECTRICITY	CHEMICALS	MAINTENANCE	OTHER ITEMS	TOTAL
MOST CURRENT YEAR 19						
PRIOR YEAR 19						
PRIOR YEAR 19						
PRIOR YEAR 19						

EVALUATION PERFORMED BY	TITLE	ORGANIZATION
RON DEWITT		DOE

INFORMATION FURNISHED BY	TITLE	ORGANIZATION	DATE
JIM KEM		CMG	10-21

G. NOTATIONS BY EVALUATOR

1. ADDITIONAL REMARKS (If remarks refer to a particular item, identify by number)

2. GENERAL COMMENTS ON HOUSEKEEPING AND MAINTENANCE

good - clean - small lab in ch house

3. REQUIREMENTS OF HIGHER AUTHORITY

3A. DOES THE PLANT PROVIDE THE DEGREE OF TREATMENT PRESENTLY REQUIRED BY THE STATE? (If no, explain)

YES  NO

3B. ARE THERE ANY PENDING ACTIONS (enforcement conferences, change in water quality standards, etc.) THAT WOULD REQUIRE UPGRADING OF TREATMENT BY THIS PLANT?

YES  NO (If yes, explain)

3C. NUMBER OF STATE INSPECTIONS OF PRESENT PLANT TO DATE.

4. IS ANY FOLLOW-THRU ACTION REQUIRED TO (1) CORRECT DEFICIENCIES IN THE PLANT OR ITS OPERATION OR (2) RESOLVE INDUSTRIAL WASTE PROBLEMS? (If yes, describe required corrective action)

YES  NO