

TO: John Glynn

FROM: Pat Lee

SUBJECT: Survey @ Monroe Reformatory

DATE: April 25, 1974

State of
Washington
Department
of Ecology



An efficiency study was conducted at the Monroe Reformatory on March 5, 1974. The influent and effluent were composited proportionate to flow for seven hours. The Laboratory and field results are summarized on the accompanying STP survey report form. The operator, Wilbur (not Orville) Weir was very knowledgeable of how his plant should work but wasn't, due to a faulty design. The plant was designed to have 2 cells in series, one anaerobic, the other aerobic. Unfortunately, the effluent from the anaerobic cell operates on an overflow basis thereby allowing scum to escape to the 2nd cell and not building up in the first cell. With no scum blanket, it is very hard to achieve anaerobic conditions. Mr. Weir said they were even aerating the first cell before he started work there. Mr. Weir also stated he was having problems with the large amounts of undigested food coming through the lagoon system.

PL:bjj

Attachment

STP Survey Report Form

Efficiency Study

City Monroe Reformatory Plant Type 2-cell lagoon Pop. Served 1,000 Design -- Capacity --
 Receiving Water Skykomish River Perennial X Intermittent
 Date 3-5-74 Survey Period 0900-1600 Survey Personnel Pat Lee
 Comp. Sampling Frequency half hour Sampling Alequot (flow in gpm) (5)
 Weather Conditions (24 hr) clear-hail Are facilities provided for complete by-pass of raw sewage? X Yes No/Frequency of bypass none
 Reason for bypass -- Is bypass chlorinated? Yes X No
 Was DOE Notified? -- Discharge - Intermittent Continuous X

Plant Operation

Total flow 68,200 gallons/7 hrs How measured Totalizer
 Maximum flow .29 mgd Time of Max. 1300 (right after lunch)
 Minimum flow .09 mgd Time of Min. 1500
 Pre Cl₂ 0 #/day Post Cl₂ 7 #/day

Field Results

<u>8</u> Determinations	Influent				Effluent			
	Max.	Min.	Mean	Median	Max.	Min.	Mean	Median
Temp °C	24.6	19.6		21.5	6.2	4.1		5.2
pH (Units)	10.0	7.0		7.4	7.2	6.9		6.9
Conductivity (µmhos/cm ²)	1000	250		360	400	250		300
Settleable Solids (mls/l)	16	4	7.1	7.0	Tr.	Tr.	Tr.	Tr.

Laboratory Results on Composites

	Influent	Effluent	% Reduction
Laboratory No.	<u>74-693</u>	<u>74-694</u>	
5-Day BOD ppm	<u>300</u>	<u>36</u>	<u>--</u>
COD ppm	<u>530</u>	<u>89</u>	<u>83</u>
T.S. ppm	<u>696</u>	<u>202</u>	<u>71</u>
T.N.V.S. ppm	<u>212</u>	<u>94</u>	<u>56</u>
T.S.S. ppm	<u>248</u>	<u>58</u>	<u>77</u>
N.V.S.S. ppm	<u>16</u>	<u>Tr.</u>	<u>100</u>
pH (Units)	<u>8.8</u>	<u>7.1</u>	
Conductivity (µmhos/cm ²)	<u>410</u>	<u>310</u>	
Turbidity (JTU's)	<u>85</u>	<u>30</u>	

Laboratory Bacteriological Results


Lab No.	Sampling Time	Colonies/100 ml (MF)			Cl ₂ Residual
		Total Coliform	Fecal Coliform	Fecal Strep	
74-695	0930	240	< 10	Not Reported	> 1.0
74-696	1030	220	< 10	Not Reported	> 1.0
74-697	1130	620	< 10	Not Reported	> 1.0
74-698	1330	550	< 10	Not Reported	1.0
74-699	1430	820	< 10	Not Reported	1.0
74-700	1530	680	< 10	Not Reported	1.0

Additional Laboratory Results

NO ₃ -N ppm	-	Not Reported
NO ₂ -N ppm	-	Not Reported
NH ₃ -N ppm	-	10.8
T. Kjeldahl-N ppm	-	14.3
O-PO ₄ -P ppm	-	Not Reported
T-PO ₄ -P ppm	-	

Operator's Name Wilbur Weir Phone No. 794-8077 Ext. 246

Furnish a flow diagram with sequence and relative size and points of chlorination.



Type of Collection System

Combined Separate Both

Estimate flow contributed by surface or ground water (infiltration)

Nil MGD

Plant Loading Information

Annual average daily flow rate (mgd)

Peak flow rate (mgd)

Dry 110,000

Dry 190,000

Wet 190,000

Wet 380,000

COMMENTS: _____

STP Survey Report Form

Efficiency Study

City Monroe Plant Type Primary Pop. Served 2700 Design .6 MGD
 Capacity
 Receiving Water Skykomish River Perennial X Intermittent _____
 Date 17 Nov. 75 Survey Period 0930 - 1600 Survey Personnel Allen Moore
 Comp. Sampling Frequency Hourly Sampling Alequot 1000 ml x $\frac{\text{flow}}{\text{peak flow}}$
 Weather Conditions (24 hr) frost-little snow Are facilities provided for complete by-
 pass of raw sewage? X Yes _____ No/Frequency of bypass Every normal rainfall
 Reason for bypass rain-storm sewers Is bypass chlorinated? X Yes _____ No
 Was DOE Notified? _____ Discharge - Intermittent _____ Continuous _____

Plant Operation

Total flow 95,667 gal How measured 90° V-notch - manual
 Maximum flow .419 MGD Time of Max. 1110
 Minimum flow .286 MGD Time of Min. 1400 - 1600
 Pre Cl₂ ----- #/day Post Cl₂ 14 #/day

Field Results

Influent

Effluent

Determinations	Max.	Min.	Mean	Median	Max.	Min.	mean	Median
Temp °C	15.0	13.5		14.0	13.5	13.0		13.5
pH (Units)	6.9	6.6		6.7	6.7	6.5		6.6
Conductivity (µmhos/cm ²)	625	400		537	475	350		450
Settleable Solids (mls/l)	14.0	5.0	8.3	6.0	1	.3	.8	1

Laboratory Results on Composites

	Influent	Effluent	% Reduction	lbs/day
Laboratory No.	<u>75-5329</u>	<u>75-5330</u>		
5-Day BOD ppm	<u>180</u>	<u>120</u>	<u>33%</u>	<u>328</u>
COD ppm	<u>380</u>	<u>260</u>	<u>31%</u>	
T.S. ppm	<u>380</u>	<u>290</u>	<u>24%</u>	
T.N.V.S. ppm	<u>160</u>	<u>130</u>	<u>19%</u>	
T.S.S. ppm	<u>100</u>	<u>72</u>	<u>28%</u>	<u>197</u>
N.V.S.S. ppm	<u>18</u>	<u>24</u>		
pH (Units)	<u>7.3</u>	<u>7.1</u>		
Conductivity (µmhos/cm ²)	<u>410</u>	<u>360</u>		
Turbidity (JTU's)	<u>52</u>	<u>41</u>		

Laboratory Bacteriological Results


Lab No.	Sampling Time	Colonies/100 ml (MF)			Cl ₂ Residual
		Total Coliform	Fecal Coliform	Fecal Strep	
75-160	0938		< 100		0.3
75-166	1200		< 50		0.3
75-159	1600		< 100		.75

Additional Laboratory Results

NO ₃ -N ppm	-	0.2	
NO ₂ -N ppm	-	ND	
NH ₃ -N ppm	-	13.	
T. Kjeldahl-N ppm	-	27.	
O-PO ₄ -P ppm	-	3.8	
T-PO ₄ -P ppm	-	6.4	

Operator's Name Mel Morse Phone No. 794-6558

Furnish a flow diagram with sequence and relative size and points of chlorination.



Type of Collection System

Combined Separate Both

Estimate flow contributed by surface or ground water (infiltration)

_____ MGD

Plant Loading Information

Annual average daily flow rate (mgd)

Peak flow rate (mgd)

Dry _____

Dry _____

Wet .328 (for 17 Nov. 1975 only)

Wet _____

COMMENTS: Sewage bypasses everytime it rains. The pumps will handle up to about .55 to .60 MGD before bypassing starts. Bypassed sewage flows to chlorination chamber then to outfall

M E M O R A N D U M

January 13, 1976

To: John Glynn

From: Allen Moore

Subject: Monroe STP Efficiency Survey

An efficiency survey was conducted at the Monroe STP on November 17, 1975. The plant was fairly clean although the office area was disorderly. The plant becomes hydraulically overloaded at every rainfall. The flow meter and totalizer appear to read about 43% too low according to numerous checks. For example, the flow meter would indicate .18 MGD while it should be .33 MGD. Mel Morse, the plant operator said that the flow meter had been calibrated recently by a local person although he could not remember the person's name.

The lab data shows poor reductions. Low coliform counts show good disinfection. The amount of time from point of chlorination until effluent discharge to the Skykomish River is thirty minutes. The operator also said that the sludge is never pumped from the clarifier chambers.

AWM:ee

STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY

WATER QUALITY LABORATORY

DATA SUMMARY

ORIGINAL TO:

.Awm.....

COPIES TO:

.....
.....

LAB FILES.....

Source Monroe STP

Collected By A. Mone

Date Collected 11-18-75

Log Number:	75-5329	30	31	32	33								
Station:	1NF	244	woods Creek	Above STP	below STP								
pH	7.3	7.1											
Turbidity (JTU)	52.	41.											
Conductivity (umhos/cm)@25°C	410.	360.											
COD	380.	260.											
BOD (5 day)	180.	120.											
Total Coliform (Col./100ml)													
Fecal Coliform (Col./100ml)													
NO3-N (Filtered)		.02	1.3	.24	.37								
NO2-N (Filtered)		ND	ND	ND	ND								
NH3-N (Unfiltered)		13.	.03	ND	ND								
T. Kjeldahl-N (Unfiltered)		27.	.28	.06	.08								
O-PO4-P (Filtered)		3.8	.04	.02	.01								
Total Phos.-P (Unfiltered)		6.4	.07	.03	.04								
Total Solids	380.	290.											
Total Non Vol. Solids	160.	130.											
Total Suspended Solids	100.	72.											
Total Sus. Non Vol. Solids	18.	24.											

Note: All results are in PPM unless otherwise specified. ND is "None Detected"

Summary By _____ Date _____