

MEMORANDUM

May 4, 1976

To: Ron Robinson

From: Douglas Houck

Subject: Cherrywood Mobile Manor STP  
Class II Inspection

On December 10, 1975 we arrived at the Cherrywood Mobile Manor and met with Mr. Sharp, the owner, and Bill Ireys, the plant operator.

Composite samplers were set up at the influent before the primary clarifier and at the discharge pipe to the stream. From both samplers a 250 ml aliquot was taken every 30 minutes.

As the facilities have no flow measuring device no flow calibration check could be made.

On the 11th I returned to pick up the composite samplers and took a grab sample for fecal coliform. As can be seen from the following table Bill Ireys was operating the treatment plant in a very efficient manner. They easily met all permit limitations.

	DOE		NPDES
	Influent	Effluent	Monthly Average
BOD <sub>5</sub> (mg/l)	96	<4	15
T.S.S. (mg/l)	128	2	15
Fecal Coliform (colonies/100 ml)		Est. 8.3	200

DH:ee

STP Survey Report Form

Efficiency Study

City Cherrywood Mobile Manor Plant Type Secondary Pop. Served \_\_\_\_\_ Design Capacity \_\_\_\_\_  
 Receiving Water Wapato Creek Perennial X Intermittent \_\_\_\_\_  
 Date ? Survey Period 24 hrs. Survey Personnel Houck, Robinson  
 Comp. Sampling Frequency 30 min. Sampling Alequot 250 ml  
 Weather Conditions (24 hr) overcast Are facilities provided for complete by-pass of raw sewage? Yes No/Frequency of bypass \_\_\_\_\_  
 Reason for bypass \_\_\_\_\_ Is bypass chlorinated? Yes No  
 Was DOE Notified? \_\_\_\_\_ Discharge - Intermittent \_\_\_\_\_ Continuous \_\_\_\_\_

Plant Operation

Total flow \_\_\_\_\_ How measured \_\_\_\_\_  
 Maximum flow \_\_\_\_\_ Time of Max. \_\_\_\_\_  
 Minimum flow \_\_\_\_\_ Time of Min. \_\_\_\_\_  
 Pre Cl<sub>2</sub> \_\_\_\_\_ #/day Post Cl<sub>2</sub> \_\_\_\_\_ #/day

Field Results

Influent

Effluent

<u>Determinations</u>	<u>Max.</u>	<u>Min.</u>	<u>Mean</u>	<u>Median</u>	<u>Max.</u>	<u>Min.</u>	<u>Mean</u>	<u>Median</u>
Temp °C								
pH (Units)								
Conductivity (µmhos/cm <sup>2</sup> )								
Settleable Solids (mls/l)								

Laboratory Results on Composites

	<u>Influent</u>	<u>Effluent</u>	<u>% Reduction</u>
Laboratory No.	<u>75-5625</u>	<u>-5626</u>	
5-Day BOD ppm	<u>96</u>	<u>&lt; 4</u>	<u>&gt; 96%</u>
COD ppm	_____	_____	_____
T.S. ppm	_____	_____	_____
T.N.V.S. ppm	_____	_____	_____
T.S.S. ppm	<u>128</u>	<u>2</u>	<u>98%</u>
N.V.S.S. ppm	_____	_____	_____
pH (Units)	_____	_____	_____
Conductivity (µmhos/cm <sup>2</sup> )	_____	_____	_____
Turbidity (JTU's)	_____	_____	_____

Laboratory Bacteriological Results

Lab No.	Sampling Time	Colonies/100 ml (MF)			Cl <sub>2</sub> Residual
		Total Coliform	Fecal Coliform	Fecal Strep	
75-5627			Est. 8.3		

Additional Laboratory Results

NO <sub>3</sub> -N ppm -	8.9
NO <sub>2</sub> -N ppm -	ND
NH <sub>3</sub> -N ppm -	1.1
T. Kjeldahl-N ppm -	
O-PO <sub>4</sub> -P ppm -	0.55
T-PO <sub>4</sub> -P ppm -	0.75

Operator's Name Bill Irey Phone No. \_\_\_\_\_

Furnish a flow diagram with sequence and relative size and points of chlorination.

Type of Collection System

Combined  Separate  Both

Estimate flow contributed by surface or ground water (infiltration)

\_\_\_\_\_ MGD

Plant Loading Information

Annual average daily flow rate (mgd)

Peak flow rate (mgd)

Dry \_\_\_\_\_

Dry \_\_\_\_\_

Wet \_\_\_\_\_

Wet \_\_\_\_\_

COMMENTS: It's a small package treatment plant for a large mobile home court.

