

MEMORANDUM

March 23, 1976

To: John Glynn

From: Douglas Houck

Subject: Mt. Vernon STP
Class II Inspection

On November 20 John Glynn, Phil Williams and I met with Mt. Vernon's sewage treatment plant personnel. A tour of the plant was given after which composite samplers were set up to take 24 hour composites of the influent and effluent. A 250 ml sample was taken every 30 minutes by both samplers. The location of the influent sampler was just before the comminutor. The location of the effluent sampler was in a wet well located right after the chlorine contact chamber. The pH meet their NPDES permit requirements and there was no way to check the flow measuring device. They use an in-line turbine type meter. The "Weir" at the end of the chlorine contact chamber was broad-crested and had a high approach velocity. Another problem was the scum line was situated so close to the weir that it was impossible to take a head reading that was not affected by the draw down of the discharging effluent. Although two bacteriological samples were taken they did not arrive at DOE's laboratory in time for analyses. A sample of the plant's distilled water was taken to be analyzed for copper. The plant's laboratory procedures were reviewed and found acceptable. The laboratory did have a few problems. They were experiencing a larger than normal D.O. drop in their BOD dilution water. They were not using a blank fecal coliform sample to check their sterilization technique and they kept their thiosulfate in a clear container located near a window.

The next day Phil Williams and I returned to pick up the samples and split the composites. Due to a sampler malfunction the influent sample was only a 13 hour composite. The following table shows both DOE's and Mt. Vernon's results along with the weekly average limitations.

	<u>DOE</u>		<u>Mt. Vernon</u>		<u>NPDES Permit</u>
	<u>Influent</u>	<u>Effluent</u>	<u>Influent</u>	<u>Effluent</u>	<u>Effluent</u>
BOD ₅ (mg/l)	160	13	164	8	45
T.S.S. (mg/l)	210	10	269	13	45

The results show that they are well within their permit limitations.

DH:ee

STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY

WATER QUALITY LABORATORY

DATA SUMMARY

ORIGINAL TO: DH
COPIES TO:
.....
.....
LAB FILES

Source Mt. Vernon STP

Collected By D. Houck

Date Collected 11-20/21-75

Log Number: 75-5415 12 17 18 19

Station:	0300	1500	1NF	2FF	Dist. H ₂ O								
pH													
Turbidity (JTU)													
Conductivity (umhos/cm)@25°C													
COD													
BOD (5 day)			160.	13.									
Total Coliform (Col./100ml)													
Fecal Coliform (Col./100ml)	42	30											
NO ₃ -N (Filtered)													
NO ₂ -N (Filtered)													
NH ₃ -N (Unfiltered)													
T. Kjeldahl-N (Unfiltered)													
O-PO ₄ -P (Filtered)													
Total Phos.-P (Unfiltered)													
Total Solids													
Total Non Vol. Solids													
Total Suspended Solids			210	10									
Total Sus. Non Vol. Solids													
Copper					6.02								
Chlorides													

Note: All results are in PPM unless otherwise specified. ND is "None Detected"
 * Retained due to possible contamination of samples arrived too late in the week
 Summary By Arthur P. Roll Date 12-1-75

Efficiency Study

City Mt. Vernon Plant Type Secondary Pop. Served _____ Design Capacity _____
 Receiving Water Skagit River Perennial X Intermittent _____
 Date 11-20/21-75 Survey Period 24 hrs. Survey Personnel Houck, Williams, Glynn
 Comp. Sampling Frequency 30 min. Sampling Alequot 250 ml
 Weather Conditions (24 hr) clear Are facilities provided for complete by-pass of raw sewage? Yes No/Frequency of bypass _____
 Reason for bypass _____ Is bypass chlorinated? Yes No
 Was DOE Notified? _____ Discharge - Intermittent _____ Continuous _____

Plant Operation

Total flow _____ How measured _____
 Maximum flow _____ Time of Max. _____
 Minimum flow _____ Time of Min. _____
 Pre Cl₂ _____ #/day Post Cl₂ _____ #/day

Field Results

Determinations	Influent				Effluent			
	Max.	Min.	Mean	Median	Max.	Min.	Mean	Median
Temp °C								
pH (Units)								
Conductivity (µmhos/cm ²)								
Settleable Solids (mls/l)								

Laboratory Results on Composites

	Influent	Effluent	% Reduction	lbs/day
Laboratory No.	<u>75-5417</u>	<u>75-5418</u>		
5-Day BOD ppa	<u>160</u>	<u>13</u>	<u>92%</u>	
BOD ppa				
F.S. ppa				
S.N.V.S. ppa				
F.S.S. ppa	<u>210</u>	<u>10</u>	<u>95%</u>	
T.V.S.S. ppa				
pH (Units)				
Conductivity (µmhos/cm ²)				
Hardness (JTU's)				


Lab No.	Sampling Time	Colonies/100 ml (MF)			Cl ₂ Residual
		Total Coliforma	Fecal Coliforma	Fecal Strep	

Additional Laboratory Results

NO ₃ -N ppm -	Cu (distilled H ₂ O) -	<0.02 mg/l
NO ₂ -N ppm -		
NH ₃ -N ppm -		
T. Kjeldahl-N ppm -		
O-PO ₄ -P ppm -		
T-PO ₄ -P ppm -		

Operator's Name _____ Phone No. _____

Furnish a flow diagram with sequence and relative size and points of chlorination.



Type of Collection System

Combined Separate Both

Estimate flow contributed by surface or ground water (infiltration)

_____ MGD

Plant Loading Information

Annual average daily flow rate (mgd)

Peak flow rate (mgd)

Dry _____

Dry _____

Wet _____

Wet _____

COMMENTS: _____