

M E M O R A N D U M

June 24, 1976

To: Ken Mauermann

From: Mike Morhous

Subject: Richmond Beach STP (Metro)
Class II Inspection

On May 6, 1976 I arrived at Metro's Richmond Beach STP to conduct the above referenced inspection.

Composite samplers were installed at the influent and pre- and post-chlorinated effluents. The influent and pre-chlorinated effluent samplers were installed adjacent to the treatment plant's composite samplers located immediately downstream from the Parshall flume and at the clarifier outfall line. The post-chlorinated sampler was installed immediately below the weir located just downstream from the chlorine injection point. All three samplers were adjusted to take a 250 ml aliquot every 30 minutes.

The Parshall flume and stilling well appeared well maintained. An instantaneous flow through the flume was calculated and compared with the corresponding flow reading on the recorder located inside the plant. The accuracy of the flow recorder was 98% of the calculated flow.

On May 7 I returned to pick up the samplers and split the influent and pre-chlorinated effluent composites with Richmond Beach STP. The following table lists the results from the DOE and Richmond Beach together with the NPDES permit limitations.

	DOE			Richmond Beach		NPDES (monthly avg.)
	<u>Inf.</u>	<u>Unchl. Eff.</u>	<u>Chl. Eff.</u>	<u>Inf.</u>	<u>Unchl. Eff.</u>	
BOD ₅ (mg/l)	120	100	84	166	123	120
TSS (mg/l)	138	60	38	76	24	70
Fecal Coliforms (colonies/100 ml)			>4000			700
pH			7.1			6.5 - 8.5
Chlorine Residual (ppm)			3.5			

Page 2
Memo to Ken Mauermann
From Mike Morhous
June 25, 1976

The above list shows a 60% difference between the DOE and Richmond Beach TSS results (unchlorinated effluent). In conjunction with the unusually high fecal count, Richmond Beach indicated their highest fecal count for the week of May 2-8 was 1500/100 mls. It should also be noted the Richmond Beach lab uses the MPN technique for fecal coliform analysis.

Additional grab samples will be taken in the near future for fecal coliforms and TSS with DOE's Redmond lab and Richmond Beach conducting the analyses. This will provide an additional check of the Richmond Beach lab techniques and a follow-up on fecal coliform data previously mentioned.

The laboratory techniques appeared to be in order with no major discrepancies. However, during the inspection the following observations and suggestions were made.

BOD₅:

High initial D.O. readings of the unseeded blank with as much as 1-2 ppm D.O. drop in the final D.O. reading (unseeded blank).

Suggested reducing the amount of time the dilution water is aerated and storing the dilution water at 20°C.

TSS:

Using a Reeves Angel glass fiber filter, the effluent sample filtering time averaged 3-5 seconds.

Suggested using more sample in order to increase filtering time to approximately 1-3 minutes.

Fecal Coliforms - MPN:

Hot bath thermometer had 1° increments and was too short. In order to read the thermometer it had to be pulled up and out of the water.

Suggested a longer thermometer with at least 1/2° increments.

MM:ee

Enclosure

cc: Ron Pine
Doug Houck
Central Files

STP Survey Report Form

Efficiency Study

Seattle (Metro) 3.2 mgd/
 City Richmond Beach Plant Type Primary Pop. Served 18,000 Design dry flow
 Capacity
 Receiving Water Puget Sound Perennial X Intermittent _____
 Date May 6-7, 1976 Survey Period 24 hr. Survey Personnel Morhous/Glynn
 Comp. Sampling Frequency 30 min. Sampling Alequot 250 mls.
 Weather Conditions (24 hr) Clear & dry Are facilities provided for complete by-
 pass of raw sewage? X Yes _____ No/Frequency of bypass None
 Reason for bypass N/A Can X be bypass/chlorinated? X Yes Pre'+ No Post
 Was DOE Notified? N/A Discharge - Intermittent N/A Continuous N/A

Plant Operation

during 24-hr. comp
 Total flow 1,531,000 gals. How measured Parshall flume
 (X1000) Tot.
 Maximum flow 2.5 Time of Max. 0815
 Minimum flow 0.6 Time of Min. 0515
 Pre Cl₂ only when disch. supernate/not in operation #/day Post Cl₂ 100 #/day

Field Results

Influent

Effluent

Determinations	Max.	Min.	Mean	Median	Max.	Min.	Mean	Median
Temp °C								
pH (Units)								
Conductivity (µmhos/cm ²)								
Settleable Solids (mls/l)								

Laboratory Results on Composites

Laboratory No.	Influent	Effluent Chlorinated	% Reduction	lbs/day
	<u>76-1503</u>	<u>76-1504</u>		
5-Day BOD ppm	<u>120</u>	<u>84</u>	<u>30%</u>	
TSS ppm	<u>260</u>	<u>200</u>	<u>23%</u>	
F.S. ppm	<u>331</u>	<u>283</u>	<u>15%</u>	
F.N.V.S. ppm	<u>166</u>	<u>159</u>	<u>4%</u>	
F.S.S. ppm	<u>138</u>	<u>38</u>	<u>73%</u>	
L.V.S.S. ppm	<u>24</u>	<u>17</u>	<u>29%</u>	
pH (Units)				
Conductivity (µmhos/cm ²)				
Turbidity (JTU's)				

Lab No.	Sampling Time	Colonies/100 ml (MF)			Cl ₂ Residual
		Total Coliform	Fecal Coliform	Fecal Strep	
76-1491	5/6 1050		>4,000		
76-1492	5/6 1430		>4,000		

Additional Laboratory Results

Chl. Eff.

NO ₃ -N ppm	-	0.32	
NO ₂ -N ppm	-	0.01	
NH ₃ -N ppm	-	17.0	
T. Kjeldahl-N ppm	-		
O-PO ₄ -P ppm	-	4.7	
T-PO ₄ -P ppm	-	7.2	

Operator's Name Dave Hall Phone No. 546-2826

Furnish a flow diagram with sequence and relative size and points of chlorination.

Type of Collection System

Combined Separate Both

Estimate flow contributed by surface or ground water (infiltration)

Very little if any-new lines (1962) MGD

Plant Loading Information

Daily or instan.

Annual average daily flow rate (mgd)

Peak flow rate (mgd) within last 2 yr

Dry 2.2

Dry .03 (instan)

Wet 3.1

Wet 6.8 mgd (instan)

COMMENTS: _____



DATA SUMMARY

ORIGINAL TO: D. Houch
COPIES TO: MM
LAB FILES

Source Richmond Beach STA

Collected By MORHOS

Date Collected 5/6-7/76

Log Number: 76-1491 1492 1503 1504 1505

Station:	@10:50	@14:30	INF	CHLOR. EFF.	UNCHLOR. EFF.					
pH										
Turbidity (NTU)										
Sp. Conductivity (umhos/cm)										
COD			260	200	180					
BOD (5 day)			120	84	100	(157) - IPR (124) - EFF Under				
Total Coliform (Col./100ml)										
Fecal Coliform (Col./100ml)	>4000	>4000								
NO3-N (Filtered)				0.32	0.07					
NO2-N (Filtered)				0.01	0.02					
NH3-N (Unfiltered)				17.	19.					
T. Kjeldahl-N (Unfiltered)										
O-PO4-P (Filtered)				4.7	4.7					
Total Phos.-P (Unfiltered)				7.2	7.8					
Total Solids			331	283	274					
Total Non. Vol. Solids			166	159	158					
Total Suspended Solids			138	38	60					
Total Sus. Non Vol. Solids			24	17	17					

Note: All results are in PPM (mg/L) unless otherwise specified. ND is "None Detected"
" < " is "Less Than" and " > " is "Greater Than"