

SPOKANE INDUSTRIAL PARK CLASS II INSPECTION,  
MAY 18-20, 1992

---

by  
Guy Hoyle-Dodson

Washington State Department of Ecology  
Environmental Investigations and Laboratory Services Program  
Toxics, Compliance and Ground Water Investigations Section  
Olympia, Washington 98504-7710

---

Water Body No. WA-57-1010  
Segment No. 24-57-04

March 1993

TABLE OF CONTENTS

	<u>Page</u>
ABSTRACT . . . . .	ii
INTRODUCTION . . . . .	1
SETTING . . . . .	1
PROCEDURE . . . . .	3
QUALITY ASSURANCE/QUALITY CONTROL . . . . .	3
Sampling . . . . .	3
General Chemistry Analysis . . . . .	5
Metals Analysis . . . . .	5
VOAs, BNAs, and Pesticide/PCBs . . . . .	5
Bioassays . . . . .	5
RESULTS AND DISCUSSION . . . . .	5
Flow Measurements . . . . .	5
NPDES Permit Comparison . . . . .	6
General Chemistry/Plant Operation . . . . .	6
Priority Pollutant Scans . . . . .	12
Bioassays . . . . .	15
Visits To Industries . . . . .	15
Split Samples . . . . .	17
CONCLUSIONS AND RECOMMENDATIONS . . . . .	19
Flow Measurement . . . . .	19
NPDES Permit Comparison . . . . .	19
General Chemistry/Plant Operation . . . . .	19
Priority Pollutant Scans . . . . .	20
Bioassays . . . . .	20
Visits To Industries . . . . .	20
Split Samples . . . . .	21
REFERENCES . . . . .	23

## ABSTRACT

A Class II Inspection was conducted May 18-20, 1992, at the Spokane Industrial Park Sewage Treatment Plant. The Spokane Industrial Park facility treats wastewater from a variety of industrial tenants with an oxidation ditch facility. Effluent quality during the inspection generally met weekly and monthly NPDES permit limits; or, in the case of metals, met interim limits. Three target organic compounds were detected in the influent or effluent. The pesticide heptachlor was found in the effluent at a concentration of about eight times the EPA criteria to protect against chronic toxicity in receiving waters. The effluent copper concentration exceeded EPA acute toxicity criteria for receiving waters by roughly ten times. Also, lead, cadmium, mercury, and silver effluent concentrations exceeded the EPA chronic toxicity criteria. Rainbow trout, *Daphnia magna*, *Ceriodaphnia dubia* bioassays found no measurable toxicity in the Spokane Industrial Park effluent.

## INTRODUCTION

A Class II Inspection was conducted at the Spokane Industrial Park (SIP) Sewage Treatment Plant (STP) on May 18-20, 1992. Guy Hoyle-Dodson and Marc Heffner, environmental engineers for the Washington State Department of Ecology (Ecology) Toxics, Compliance and Ground Water Investigations Section, conducted the inspection. Donald G. Nichols, permit manager for the Washington State Department of Ecology Eastern Regional Office, requested the inspection and provided background information on SIP's previous compliance history. Assisting onsite at the Sewage Treatment Plant was plant superintendent Al Willner. Scott Brown, SIP's park manager, acted as a contact person and provided information on the park's operation. Two of the park's tenants were visited during the inspection. Tom Crawford, chief industrial engineer at Columbia Lighting, Inc. and Shaun Tadino, at Boise Cascade Corporation Packaging Plant, represented their respective companies.

The SIP operates an industrial sewage treatment facility that provides secondary treatment for the park's sanitary and industrial wastewater. The facility is regulated by NPDES permit #WA-000095-7 (issue date: April 20, 1992). A companion Administrative Order was issued with the permit to give interim discharge limits for several parameters until improvements recommended in a forth-coming required engineering report are made. The new NPDES permit and Administrative Order have no percent removal requirements. Effluent is discharged into the Spokane River.

Three SIP tenants discharge pretreated process wastewater regulated by state waste discharge permits (SWDP) to the SIP STP. These industries include Columbia Lighting (SWDP #5222), Ketrionics Inc. (SWDP #5284), and Johnson Matthey (SWDP # 5359).

The Class II Inspection was conducted after the issuance of the current permit and prior to an impending engineering study. The inspection helped determine the present plant operating status and will aid in evaluating the engineering report. Specific objectives include:

1. Verify compliance with both NPDES permit limits and with interim limits set forth by the Washington State Department of Ecology in an administrative order.
2. characterize wastewater toxicity with chemical scans and bioassays;
3. assess discharge to the plant by selected tenants for parameters of concern;
4. assess plant operation and ability to treat wastewater flows.

## SETTING

The Spokane Industrial Park is located within Spokane County, east of the city of Spokane (Figure 1). The site encompasses 490 acres, zoned for light to heavy industry. The park is





Figure 1  
Sewage Treatment Plant  
Site Map

owned and operated by Pentzer Development Corporation, a subsidiary of Washington Water Power Company. There are approximately 100 tenants in the park.

The site was originally built as a U.S. Navy supply depot during WWII. The initial sewage treatment facility consisted of a trickling filter system designed to treat only sanitary wastes generated onsite. After conversion to an industrial park in the early 1960s an engineering study in 1969 showed that the STP was hydraulically overloaded and subjected to toxic effects from industrial discharge. In 1970 the current facility was constructed.

Treatment units at the facility during the inspection were: 1) a comminutor, 2) an oval oxidation ditch, 3) a secondary clarifier, and 4) a chlorine contact chamber (Figure 2). Influent flow was measured by a flow meter at a weir downstream of the comminutor. Discharge of treated wastewater to the Spokane River was via a single port diffuser. A small sludge drying bed was available but not in use due to infrequency of sludge wasting.

## PROCEDURE

Ecology collected both grab and composite samples at the STP. Composite samples were collected at the influent weir and at the end of the chlorine contact chamber. Ecology Isco composite samplers collected equal volumes of sample every 30 minutes for 24 hours. Grab samples were collected from the headworks, from the oxidation ditch, and from the chlorine contact tank discharge. A grab sample was also taken of the SIP water supply. Sampler locations are summarized in Appendix A.

SIP also collected influent and effluent composite samples. Sampling locations corresponded to those of Ecology samples. Sampling periods and volumes replicated Ecology sampling procedures. Ecology and SIP samples were split for analysis by both Ecology and SIP labs. Parameters, samples collected, and schedules are summarized in Appendix B.

Samples for Ecology analysis were placed on ice and delivered to the Manchester Laboratory. Chain-of-custody procedures were observed throughout. Appendix C summarizes analytical procedures and the laboratories performing the analysis.

## QUALITY ASSURANCE/QUALITY CONTROL

### **Sampling**

Sampling quality assurance included priority pollutant cleaning of sampling equipment (Appendix D). Sampling in the field followed all protocols for holding times, preservation, and chain-of-custody set forth in the Manchester Laboratory Users Manual (Ecology, 1991).




FIGURE 2  
SPOKANE INDUSTRIAL PARK  
TREATMENT PLANT SCHEMATIC

## **General Chemistry Analysis**

Holding times and procedural blanks were acceptable. Instrument calibrations, precision data, external verification standards, and standard reference material were within appropriate control limits.

## **Metals Analysis**

Holding times and procedural blanks were generally acceptable. Instrument calibration, spike recoveries, duplicate spike recoveries, standard reference materials, and external verification standards were generally within acceptable control limits. Exceptions were:

1. Nickel was detected in the procedural blank. Nickel concentrations above detection limits and less than ten times the amount in the blank are assigned a "B" qualifier to indicate blank contamination.
2. Spike recoveries for mercury and silver were not in an acceptable range. These parameters are assigned an "N" qualifier to indicate poor spike recovery.

## **VOAs, BNAs, and Pesticide/PCBs**

Holding times and method blanks were acceptable. Instrument calibrations were acceptable and met minimum and maximum response criteria. Matrix spike, precision data, and surrogate recoveries were acceptable and within QC control limits.

## **Bioassays**

Negative control results, positive control results using a reference toxicant, and test environment data (*i.e.* dissolved oxygen, pH, etc.) were within acceptable ranges for all organisms tested.

# **RESULTS AND DISCUSSION**

## **Flow Measurements**

Ecology's evaluation of instantaneous flow through the weir corresponded closely with SIP plant flow meter measurement. The plant meter recorded an instantaneous flow of 0.822 MGD compared to a calculated instantaneous flow of 0.848 MGD. The meter flow reading was within 3% of the calculated flow. The average flow recorded by the plant meter for May 19, 1992, was 0.602 MGD. Maximum and minimum flows recorded on that day were 0.83 MGD and 0.41 MGD, respectively.



## NPDES Permit Comparison

Inspection results were generally less than weekly and monthly permit limits; or for metals less than interim limits (Table 1). The TSS concentration was slightly greater than the monthly permit limits, but less than the weekly permit limits. The copper, lead, and zinc concentrations exceeded final permit limits, but met interim limits. Reduction of effluent metals concentrations is to be addressed in the forthcoming SIP engineering study.

Also, one of the fecal coliform samples slightly exceed the monthly permit limit. The geometric mean of the two samples collected (79/100 mL) was less than the monthly limit. The effluent chlorine residual was 0.1-0.2 mg/L, slightly less than or equal to the weekly limit, but greater than the monthly limit. Dechlorination will likely be necessary to meet both fecal coliform and chlorine residual monthly average limits.

## General Chemistry/Plant Operation

Inspection general chemistry data are summarized in Table 2.

During the inspection the plant influent was very weak in comparison to domestic sewage for several parameters (Table 3). The oxygen demand parameters (BOD<sub>5</sub>, TOC, and COD), NH<sub>3</sub>-N, and total-P were all approximately one half the strength of weak domestic sewage. Because concentrations of all three of the oxygen demand parameters were low, it appears BOD<sub>5</sub> test inhibition due to toxicants is unlikely; and in fact, the waste has a low BOD<sub>5</sub>.

As is expected with a low strength waste, treatment percent removals were fairly low (Table 3). The plant appeared to be actively nitrifying. The influent NH<sub>3</sub>-N concentration (7 mg/L) was reduced to <0.2 mg/L in the effluent. A concurrent increase in NO<sub>2</sub>+NO<sub>3</sub>-N and decrease in alkalinity occurred as expected. Nitrification indicates biological activity is occurring in the oxidation ditch.

Comparison of typical design loading and operational parameters for extended aeration type activated sludge systems with SIP data suggests the plant is organically underloaded (Table 4 and Appendix E: Metcalf and Eddy, 1991). The sludge age is near the high end of the expected range. The MLSS concentration is 21% of the lower end of the usual design range. The operator had not wasted sludge for several months prior to the inspection and the MLSS concentration was still low. The MLVSS(microorganisms) is typically 70-90% of the MLSS (organic substances) (WEF, 1991) but was only 56% at the SIP STP suggesting a low level of biological activity in the system. The organic loading rate was about 20% of the lower end of the usual design range.

Reduced water usage and reduced cooling water usage in the park may increase the wastewater strength. A stronger influent may result in improved treatment efficiency (higher percent removals). A reduced hydraulic load would likely have little effect on effluent quality

Table 1 – NPDES Limits/Inspection Results Comparison – Spokane Industrial Park, 1992

Parameter	NPDES Permit Limits		NPDES Interim Permit Limits *		Inspection Data						
					Ecology Composite		STP Composite	Grab Samples			
					Location:	Ef-E	Ef-S	Ef-1	Ef-2	Ef-3	Ef-4
					Type:	E-comp	S-comp	grab	grab	grab	grab
Date:	5/19-20	5/19-20	5/19	5/19	5/20	5/20					
Time:	@	@	0955	1525	0950	1050					
Lab #:	218237	218238	218235	218236	218255	218256					
Monthly Average	Weekly Average	Monthly Average	Weekly Average								
BOD5 (mg/L)	10.4	20			8	7	-	-	-	-	
(lbs/D)	65	125			40	35	-	-	-	-	
TSS (mg/L)	15.2	30.4			17	16	18	18	-	-	
(lbs/D)	95	190			85	80	90	90	-	-	
Fecal coliform (#/100 mL)	200	400			-	-	-	-	27	230	
pH (S.U.)	6.0 < pH < 9.0				-	-	7.4	7.5	7.6	-	
Flow (MGD)**	0.75	-----			0.602	0.602	0.602	0.602	-	-	
Ammonia (NH3) (mg/L)	8.5	17.0			0.17	0.10	0.09	0.12	-	-	
(lbs/D)	53.2	106.3			0.85	0.51	0.43	0.60	-	-	
Total Residual Chloride (mg/L)	0.05	0.2	Sufficient, but not in excess of that needed to attain fecal coliform limits in NPDES permit.		0.1	-	0.1	0.2	0.2	0.2	
Phosphorus (mg/L)	3.0	-----			1.76	1.76	1.72	1.81	-	-	
(lbs/D)	18.6	-----			8.84	8.84	8.64	9.09	-	-	
Copper (µg/L)	20	30	400	500	332	356	-	-	-	-	
Lead (µg/L)	3	8	80	180	40.1	41.3	-	-	-	-	
Nickel (µg/L)	3000	5000			170 B	187 B	-	-	-	-	
Zinc (µg/L)	60	100	150	200	72.4	72.8	-	-	-	-	
1,1,1 trichloroethane (µg/L)	100	-----			-	-	10 U	10 U	-	-	

E Ecology Sample.

S Spokane STP sample.

@ Composite sampling time: 0800-0800.

\* Administrative Order in effect until remedial actions are taken to comply with permit.

comp Composite sample.

grab Grab sample.

Ef Effluent.

B Analyte was found in the analytic method blank indicating the sample may have been contaminated.

U The analyte was not detected above the reported amount.

\*\* The reported value is an average flow.

Table 2 – Ecology General Chemistry Results – Spokane Industrial Park, 1992

Parameter	Location:	Inf-1	Inf-2	Inf-E	Inf-S	Ef-1	Ef-2	Ef-3	Ef-4	Ef-E	Ef-S
	Type:	grab	grab	E-comp	S-comp	grab	grab	grab	grab	E-comp	S-comp
	Date:	5/19	5/19	5/19-20	5/19-20	5/19	5/19	5/20	5/20	5/19-20	5/19-20
	Time:	0925	1510	@	@	0955	1525	0950	1050	@	@
	Lab Log #:	218231	218232	218233	218234	218235	218236	218255	218256	218237	218238
<b>GENERAL CHEMISTRY</b>											
Conductivity (umhos/cm)		592	681	776	772	575	601			612	634
Alkalinity (mg/L CaCO3)				182	179					128	128
Hardness (mg/L CaCO3)				176	172					170	168
<b>SOLIDS 4</b>											
TS (mg/L)				622	598					442	498
TNVS (mg/L)				384	389					272	316
TSS (mg/L)		80	39	68	100	18	18			17	16
TNVSS (mg/L)				26	30					8	7
<b>OXYGEN DEMAND PARAMETERS</b>											
BOD5 (mg/L)				36	47					8	7
COD (mg/L)		78	73	110	130	41	44			42	42
TOC (water mg/L)		17.8	20	26.8	30.7	8.3	9.5			10.3	11.3
<b>NUTRIENTS</b>											
Total Persulfate N(TPN) (mg/L)				13.8	14.8					9.98	10.3
NH3-N (mg/L)				6.62	7.31	0.086	0.119			0.169	0.102
NO2+NO3-N (mg/L)				1.74	1.63	9.07	8.97			9.1	9.46
Total-P (mg/L)				1.98	2.87	1.72	1.81			1.76	1.76
<b>MISCELLANEOUS</b>											
Oil and Grease (mg/L)		8 J	4 J			1 UJ	1 UJ				
F-Coliform MF (#/100mL)								27	230		
Cyanide total (ug/L)				4	2					2	4
Cyanide (wk & dis ug/L)				2 U	2 U					2 U	2 U
<b>FIELD OBSERVATIONS</b>											
Temperature (C)		16.7	17.5			16.4	17.7	15.4			
Temp-cooled (C)*+				3.1	4.7					3.1	0.8
pH		7.68	7.45	7.76	7.93	7.44	7.51	7.58		7.8	7.8
Conductivity (umhos/cm)		667	587	652	650	591	506			557	565
Total Chlorine Residual (mg/L)						0.1	0.2	0.2	0.2	0.1	0.1

E Ecology Sample.  
 S Spokane STP sample.  
 @ Composite sampling time: 0800-0800.  
 comp Composite sample.  
 grab Grab sample.  
 gr-comp Grab-composite sample.  
 J The analyte was positively identified and the associated result is an estimate.  
 U The analyte was not detected above the reported value.

UJ The analyte was not detected at or above the reported estimate result.  
 Tr Bk Transfer blank  
 Inf Influent  
 Ef Effluent  
 Intake SIP water supply  
 MLSS Oxidation Ditch Solids  
 CoLtg Columbia Lighting discharge  
 \*+ Refrigerated temperature.

Table 2 – Ecology General Chemistry Results – Spokane Industrial Park, 1992

Parameter II	Locatn:	Ef-GC	MLSS-1	MLSS-2	Intake	CoLtg-1	CoLtg-2
	Type:	gr-comp	grab	grab	grab	grab	grab
	Date:	5/19	5/19	5/19	5/19	5/19	5/19
	Time:	1550	1050	1520	1620	1355	1405
	Lab Log #:	218239	218240	218241	218243	218246	218247
<b>GENERAL CHEMISTRY</b>							
Conductivity (umhos/cm)		589			292	365	744
Alkalinity (mg/L CaCO3)		128			137		
Hardness (mg/L CaCO3)		169			174		
<b>SOLIDS 4</b>							
TS (mg/L)							
TNVS (mg/L)							
TSS (mg/L)			330	310		3	159
TNVSS (mg/L)			150	130			
<b>OXYGEN DEMAND PARAMETERS</b>							
BOD5 (mg/L)						39	750
COD (mg/L)						12.3	304
TOC (water mg/L)							
<b>NUTRIENTS</b>							
Total Persulfate N(TPN) (mg/L)							
NH3-N (mg/L)						0.039	2.08
NO2+NO3-N (mg/L)						1.3	0.059
Total-P (mg/L)						8.59	99.4
<b>MISCELLANEOUS</b>							
Oil and Grease (mg/L)							
F-Coliform MF (#/100mL)							
Cyanide total (ug/L)							
Cyanide (wk & dis ug/L)							
<b>FIELD OBSERVATIONS</b>							
Temperature (C)					10.7	24.4	23
Temp-cooled (C)*+							
pH					7.78	8.06	7.39
Conductivity (umhos/cm)					255	312	647
Total Chlorine Residual (mg/L)						0.1	

E Ecology Sample.  
 S Spokane STP sample.  
 @ Composite sampling time: 0800-0800.  
 comp Composite sample.  
 grab Grab sample.  
 gr-comp Grab-composite sample.  
 U The analyte was not detected above the reported value.

Tr Blk Transfer blank  
 Inf Influent  
 Ef Effluent  
 Intake SIP water supply  
 MLSS Oxidation Ditch Solids  
 CoLtg Columbia Lighting discharge  
 \*+ Refrigerated temperature.

6

Table 3 – Comparison to Typical Untreated Domestic Wastewater/Percent Removal – Spokane Industrial Park, 1992

PARAMETER	SAMPLER: **	CONCENTRATION (mg/L)				Percent Removal (%)		CONCENTRATION (mg/L)	
		SIP-INF		SIP-EF		Ecology	Spokane	Typical* Domestic Weak	Typical* Domestic Average
		Ecology	Spokane	Ecology	Spokane				
<u>Total Solids (TS)</u>		622	598	442	498	28.9	16.7	350	757
<u>Total Suspended Solids (TSS)</u>		68	100	17	16	75.0	84.0	100	223
<u>Total NonVolatile Suspended Solids (TNVSS)</u>		26	30	8	7	69.2	76.7	20	50
<u>Biological Oxygen Demand (BOD5)</u>		36	47	8	7	77.8	85.1	110	243
<u>Total Organic Carbon (TOC)</u>		26.8	30.7	10.3	11.3	61.6	63.2	80	177
<u>Chemical Oxygen Demand (COD)</u>		110	130	42	42	61.8	67.7	250	583
<u>Total Nitrogen (Total Persulfate)</u>		13.8	14.8	9.98	10.3	27.7	30.4	20	48
<u>Organic Nitrogen</u>		5.44	5.86	0.71	0.74	86.9	87.4	8	19
<u>Ammonia (NH3-N)</u>		6.62	7.31	0.17	0.1	97.4	98.6	12	29
<u>Nitates &amp; Nitrites (NO2&amp;NO3-N)</u>		1.74	1.63	9.1	9.5	-423.0	-482.8	0	0
<u>Total Phosphorus</u>		1.98	2.87	1.8	1.8	9.1	37.3	4	9

SIP Spokane Industrial Park  
 INF Influent Wastewater  
 EF Effluent Wastewater

Ecology Ecology sample  
 Spokane Spokane Spokane Industrial Park sample  
 \* Typical domestic wastewater (Metcalf & Eddy, 1991)  
 \*\* Ecology laboratory results

Table 4 – Typical Activated Sludge Design Parameters – Spokane Industrial Park, 1992

Parameters	Design Parameters for Activated Sludge Processes □	Spokane SIP
Process Modification:	Extended Aeration	Extended Aeration
Flow Regime:	Plug or Complete Mix	Complete Mix
Food-to- Microorganism Ratio (F/M) (lb BOD/[lb MLVSS/day])	0.05 – 0.15	0.18
Sludge Age (Days)	10 – 30	27
Mixed-Liquor Suspended Solids (MLSS) (mg/L)	2000 – 6000	320
Detention Time (hydraulic) (hours)	10 – 20	32
Aerator Loading (lb BOD/1000 cu ft)	10 – 25	2.0

□ Table from: Metcalf & Eddy, 1991

(concentrations of pollutants), although effluent pollutant loads (pounds discharged) may be less with the lower flow. One potential concern at the facility has been toxics. Reduced flows to the plant may result in higher concentrations of potential toxicants in the influent and effluent unless pollutant loads to the STP are reduced at their sources.

Plant operation consisted primarily of monitoring to satisfy NPDES requirements. The low plant loading has allowed permit compliance with minimal time expenditure by the plant operator. Compliance with the new permit after the required engineering study is completed will likely require more process control and/or an active pretreatment program to meet metals limits. Either of these items will require more time for STP operation and park tenant discharge monitoring/control by the SIP STP owner, Pentzer Development Corporation. During the inspection an "Operation and Maintenance Manual" for the plant could not be located. Locating or compiling an "Operation and Maintenance Manual" is recommended to provide guidance to the plant operator.

### **Priority Pollutant Scans**

Acetone, bis(2-ethylhexyl)phthalate, and heptachlor were the only three target organic compounds detected in the influent or effluent (Table 5). Acetone was the organic found at the highest concentration in both the influent (540 to 2500  $\mu\text{g/L}$ ) and effluent (27 to 42  $\mu\text{g/L}$ ). There are no EPA water quality criteria for acetone, although the effluent concentration was less than threshold concentrations (8300-14250 mg/L) found to cause immobilization in several aquatic invertebrates and fishes by the Water Quality Board of California (Mckee & Wolf, 1963).

The effluent concentration of heptachlor (0.03  $\mu\text{g/L}$ ) exceeded the EPA chronic criteria for receiving waters of 0.0038  $\mu\text{g/L}$  (EPA, 1986). Identifying the source as past use or present use of the material and taking any appropriate action is suggested.

Several metals exceeded chronic or acute EPA water quality criteria in the effluent (Table 5: EPA, 1986). The effluent copper concentration exceeded acute toxicity criteria by roughly ten times. Also, lead, cadmium, mercury, and silver effluent concentrations exceeded the EPA chronic water quality criteria. The SIP water supply sample had low metals concentrations indicating the metals observed in the influent and effluent came from SIP tenant wastewaters (Table 6). A study currently underway by the Ecology Watershed Assessments Section appraising the biological impact of metals in the Spokane River system may help define the significance of metals concentrations in the SIP discharge.

Changes in metals concentrations across the plant ranged from moderate increases to moderate decreases (Table 6). Association of metals with the MLSS and subsequent loss of MLSS in the effluent is likely responsible for this observation. Collecting a sample of the sludge (perhaps settling and spinning down a MLSS sample) for metals analysis is suggested to determine metals concentrations in the oxidation ditch solids.

Table 5 – VOA, Pesticides/PCB, and Metals Detected – Spokane Industrial Park, 1992

Parameter	Location:	Tr Blk	Inf-1	Inf-2	Inf-E	Inf-S	Ef-1	Ef-2	Ef-E	Ef-S	Intake	CoLtg-1	CoLtg-2	EPA Water Quality	
	Type:		grab	grab	E-comp	S-comp	grab	grab	E-comp	S-comp	grab	grab	grab	Criteria Summary	
	Date:	5/18	5/19	5/19	5/19-20	5/19-20	5/19	5/19	5/19-20	5/19-20	5/19	5/19	5/19	Acute	Chronic
	Time:	1540	0925	1510	@	@	0955	1525	@	@	1620	1355	1405	Fresh	Fresh
Lab Log#:	218230	218231	218232	218233	218234	218235	218236	218237	218238	218243	218246	218247			
<b>VOA Compounds</b>															
(UNITS:)		(µg/L)	(µg/L)			(µg/L)	(µg/L)				(µg/L)	(µg/L)	(µg/L)	(µg/L)	
Acetone		2500 D	540 D			27	42				27	48			
4-Methyl-2-Pentanone (MIBK)		10 U	10 U			10 U	10 U				10 U	7 J			
Toluene		10 U	10 U			10 U	10 U				1 J	10 U		17,500 *	
Ethylbenzene		10 U	10 U			10 U	10 U				7 J	8 J		32,000 *	
Total Xylenes		10 U	10 U			10 U	10 U				42	50			
<b>BNA Compounds</b>															
(UNITS:)				(µg/L)				(µg/L)							
Bis(2-Ethylhexyl)Phthalate				2 J				2 J						940 *(i)	3 *(i)
<b>Pesticides/PCBs Compounds</b>															
(UNITS:)				(µg/L)				(µg/L)							
Heptachlor				0.018 JP				0.03 JP						0.52 (r)	0.0038 (r)
<b>Metals (Total)</b>															
(UNITS:)	Hardness = 170	(µg/L)		(µg/L)	(µg/L)			(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)		
Antimony		30 U		30 U	30 U			30 U	30 U	30 U	30 U	35 P		9,000 *	1,600 *
Arsenic		1.5 U		2.8 P	2.9 P			3.1 P	3.6 P	4.2 P	3.7 P	15.4			
Pentavalent														850 *	48 *
Trivalent														360	190
Cadmium		0.1 U		2.5 P	2.12			2.87	2.64	0.12 P	0.1 U	0.6		7.1 +	1.7 +
Copper		3.0 U		564	505			332	356	3 U	3.5 P	48.7		29 +	19 +
Lead		1.0 U		10.5	30.6			40.1	41.3	1 U	1 U	55.4		160 +	6.3 +
Mercury		0.13 PN		0.973 N	0.671 N			0.552 N	0.651 N	0.1 UN	0.24 PN	0.45 PN		2.4	0.012
Nickel		10 U		399	366			170 B	187 B	10 U	10 U	24 PB		2,222 +	247 +
Silver		0.5 UN		1.2 N	0.5 UN			1.9 N	2.2 N	0.5 UN	0.5 UN	0.5 UN		10.1 +	0.12
Zinc		4.0 U		56.5	85.7			72.4	72.8	17 P	8.6 P	63.8		183 +	166 +

- B Analyte was found in the analytic method blank, indicating the sample may have been contaminated.
- J The analyte was positively identified, but the associated result is an estimate.
- N For metals analytes the spike sample recovery is not within control limits.
- P Analyte was detected above the instrument detection limits, but below the minimum qualification limits.
- U The analyte was not detected above the reported result.
- D Analysis of sample used a dilution.
- E Ecology Sample.
- S Spokane STP sample.
- @ Composite sampling time: 0800-0800.
- comp Composite sample.
- grab Grab sample.
- gr-comp Grab-composite sample.
- Tr Blk Transfer blank
- Inf Influent
- Ef Effluent
- Intake SIP water supply
- MLSS Oxidation Ditch Solids
- CoLtg Columbia Lighting disc
- \* Insufficient data to develop criteria. Value presented is the LOEL – Lowest Observed Effect Level.
- \*\* pH dependent criteria (7.8 pH used).
- + Hardness dependent criteria (170 mg/L used).
- i Total Phthalate Esters
- r Heptachlor



Table 6 – Increase and Removal of BNAs, Pesticides/PCB, and Metals – Spokane Industrial Park, 1992

Parameter	Location:	Inf-E	Inf-S	Ef-E	Ef-S	Percent Removal		Intake grab 5/19 1620 218243
	Type:	E-comp	S-comp	E-comp	S-comp	Across STP		
	Date:	5/19-20	5/19-20	5/19-20	5/19-20	Ecology	Spokane	
Time:	@	@	@	@	Sample	Sample		
Lab Log#:	218233	218234	218237	218238	%	%		
<b>BNA Compounds</b>								
(UNITS:)		(µg/L)		(µg/L)				
Bis(2-Ethylhexyl)Phthalate		2 J		2 J		0.0	N.A.	
<b>Pesticides/PCBs Compounds</b>								
(UNITS:)		(µg/L)		(µg/L)				
Heptachlor		0.018 JP		0.03 JP		-66.7	N.A.	
<b>Metals (Total)</b>								
(UNITS:)		(µg/L)	(µg/L)	(µg/L)	(µg/L)			(µg/L)
Antimony		30 U	30 U	30 U	30 U	0.0	0.0	30 U
Arsenic		2.8 P	2.9 P	3.1 P	3.6 P	-10.7	-24.1	4.2 P
Cadmium		2.5 P	2.12	2.87	2.64	-14.8	-24.5	0.12 P
Copper		564	505	332	356	41.1	29.5	3 U
Lead		10.5	30.6	40.1	41.3	-281.9	-35.0	1 U
Mercury		0.973 N	0.671 N	0.552 N	0.651 N	43.3	3.0	0.1 UN
Nickel		399	366	170 B	187 B	57.4	48.9	10 U
Silver		1.2 N	0.5 UN	1.9 N	2.2 N	-58.3	-340.0	0.5 UN
Zinc		56.5	85.7	72.4	72.8	-28.1	15.1	17 P

B Analyte was found in the analytic method blank, indicating the sample may have been contaminated.  
 N For metals analytes the spike sample recovery is not within control limits.  
 P Analyte was detected above the instrument detection limits, but below the minimum qualification limits.  
 U The analyte was not detected above the reported result.

Inf Influent  
 Ef Effluent  
 Intake SIP water supply  
 E Ecology sample  
 S Spokane sample  
 @ Composite collection time: 08:00-08:00  
 N.A. Not available

comp Composite sample.  
 grab Grab sample.

Complete organics and metals scan results are tabulated in (Appendix F). Also, several tentatively identified compounds (TICs - non target compounds detected with the scan) were found at concentrations less than 100  $\mu\text{g/L}$ . TICs are summarized in Appendix G.

## Bioassays

The rainbow trout and *Daphnia magna* acute toxicity tests found no toxicity in the SIP effluent (Table 7). The *Ceriodaphnia dubia* survival and reproduction test indicated no acute or chronic toxicity.

The fathead minnow chronic toxicity test data show little correlation between effects and concentration. Laboratory notes were double-checked, but a source of error could not be identified. The data are presented but are inconclusive.

Lack of toxicity in the effluent was somewhat surprising given the high concentration of copper in the effluent (332-356  $\mu\text{g/L}$ ). At SIP effluent hardness concentrations, the expected  $\text{LC}_{50}$  for rainbow trout and *Daphnia magna* would be 10% and 33-50% of the effluent concentration, respectively (EPA, 1980).

It is possible that the copper is adsorbed or bound reducing its biological availability. Another possibility is  $\text{CaCO}_3$  (alkalinity) reacting with free  $\text{Cu}^{2+}$  to form  $\text{Cu}(\text{CO}_3)_2^{2+}$ ,  $\text{CuHCO}_3^+$ , and  $\text{CuCO}_3^0$  (EPA, 1987). These three species are soluble, generally not toxic, and are formed at the observed pH and alkalinity concentrations (Miller & Mackay, 1979).

A prior investigation of high copper concentrations in SIP wastewater considered a copper dye used in printing ink (Leber, 1984). A representative of Leber Ink, the dye manufacturer, pointed out the copper is tightly bound within the copper phthalocyanine molecule and not available to cause toxic effects. The company using the ink is no longer listed as a tenant of Spokane Industrial Park. Other firms in the facility might be using this particular printing ink, but during the inspection none were identified.

The source of copper remains unknown. Determining the source(s) could help explain the unusual bioassay results and help SIP meet final NPDES permit limits.

## Visits To Industries

Two industries in the SIP were visited during the inspection. They were the Boise Cascade Corporation Packaging Plant and Columbia Lighting, Inc.

Interest in the Boise Cascade facility was due to frequent color change occurring in the SIP STP influent and the past history of dyes in the SIP (see discussion in priority pollutant section). The Boise Cascade facility labels packaging boxes (primarily corrugated cardboard). Ink used for

Table 7 – Effluent Bioassay Results – Spokane Industrial Park, 1992.

NOTE: all tests were run on the effluent (Ef-GC sample) – lab log # 218239.

Ceriodaphnia dubia – 7-day Partial Life Cycle Test  
(*Ceriodaphnia dubia*)

Sample	# Tested *	Percent Survival	Total Reproduction	Mean Number Young/Female
Control	10	90	226	21
6.25% Effluent	10	90	284	23
12.5% Effluent	10	90	225	24
25% Effluent	10	90	241	23
50% Effluent	10	100	226	28
100 % Effluent	10	90	210	23

<u>Acute</u>	<u>Chronic</u>
LC50 = >100 % effluent	LOEC = >100 % effluent
LOEC = 100 % effluent	NOEC = >100 % effluent
NOEC = 100 % effluent	

\* 10 replicates of 1 organism

Daphnia magna – Acute Toxicity Test (48 hour LC50)  
(*Daphnia magna*)

Sample	# Tested	Percent Survival
Control	10	100
6.25 % Effluent	10	100
12.5 % Effluent	10	100
25 % Effluent	10	100
50 % Effluent	10	100
100 % Effluent	10	100

LC50 > 100 % effluent  
NOEC > 100 % effluent  
LOEC > 100 % effluent

Fathead Minnow – 7-day Larval Fish Survival and Growth Test  
(*Pimephales promelas*)

Sample	# Tested *	Percent Survival	Average Growth per Fish (mg)
Control	40	81	0.53
6.25 % Effluent	40	18	0.93
12.5 % Effluent	40	50	0.79
25 % Effluent	40	30	1.30
50 % Effluent	40	40	0.99
100 % Effluent	40	75	0.46

<u>Acute</u>	<u>Chronic</u>
LOEC: N.A.**	NOEC: N.A.**
LC50: N.A.**	LOEC: N.A.**

\* four replicates of 10 organisms

\*\* Not Available due to negative dose response relationship of organisms.

Rainbow Trout – 96 hour Acute Toxicity Test  
(*Oncorhynchus mykiss*)

Sample	# Tested	Percent Survival
Control	30	100
100% Effluent	30	97

NOEC – no observable effects concentration  
LOEC – lowest observable effects concentration  
LC50 – lethal concentration for 50% of the organisms  
EC50 – effect concentration for 50% of the organisms

labelling was distributed by a roller with micro-pores to minimize ink used and wasted. Clean-up was with water by an automated roller clean-up unit. The amount of water used was approximated at less than ten gallons per clean-up by the Boise Cascade representative. Based on the small amount of water used and the type of ink being used, no samples were collected.

Two grab samples were collected at Columbia Lighting, Inc. One sample (CoLtg-1) was collected from the plant discharge. The second sample (CoLtg-2) was collected from the washer-wastewater neutralization tank. Contents of the tank are occasionally bled into the plant discharge, but this was not being done when samples were collected.

General chemistry parameters for the plant discharge (CoLtg-1 - Table 2) were present in fairly low concentrations, although the total-P concentration was moderately elevated (8.6 mg/L). Metals concentrations approximated the concentrations found in the SIP water supply (Table 5). Acetone (27  $\mu\text{g/L}$ ) and total xylenes (42  $\mu\text{g/L}$ ) were detected. A system of flow measurement was being investigated for installation. Accurate flows would help determine if the total-P amount is significant.

The neutralization tank (CoLtg-2 - Table 2) sample had higher COD, TSS, and total-P concentrations than the plant discharge. Acetone and total xylenes concentrations were similar to the plant discharge (Table 5). Metals concentrations were all less than either the SIP STP effluent concentration or water quality criteria. The volume of the neutralization tank is fairly small (4800 gallons) with an average daily discharge of 860 gallons per day.

### **Split Samples**

Ecology laboratory results of the Ecology and SIP samples were similar (Table 8). The Ecology influent sample BOD<sub>5</sub> and TSS were slightly weaker than the SIP sample. SIP sampling appeared appropriate.

SIP analyzes pH and total chlorine residual at the small laboratory at the STP. A split sample found good agreement between Ecology and SIP total chlorine residual results and poor agreement for pH results. The SIP pH meter allowed only single point calibration and was difficult to operate. Replacement of the pH meter is recommended.

Since the inspection, the Ecology Laboratory Accreditation program issued the SIP STP provisional accreditation for pH and chlorine residual analysis. SIP agreed to replace their pH meter and to provide additional total chlorine residual test training for the operator to attain accreditation.

The balance of the SIP analyses are sent out to a contract laboratory. Ecology and SIP results for COD, total-P, fecal coliform, copper, and zinc compared well. Nickel, NH<sub>3</sub>-N, effluent TSS, and effluent BOD<sub>5</sub> results showed some differences, but were in the same range. The influent TSS and influent BOD<sub>5</sub> results were far enough apart to be of concern. Attention should

Table 8 – Split Sample Results Comparison – Spokane Industrial Park, 1992

Parameter	Location:	Inf-E	Inf-S	Ef-2	Ef-3	Ef-E	Ef-S
	Type:	E-comp	S-comp	grab	grab	E-comp	S-comp
	Date:	5/19-20	5/19-20	5/19	5/20	5/19-20	5/19-20
	Time:	@	@	1525	0950	@	@
	Lab Log #:	218233	218234	218236	218255	218237	218238
Laboratory*							
<u>TSS (mg/L)</u>	Ecology	68	100			17	16
	Spokane	27.9	74.7			14.4	18.5
<u>BOD5 (mg/L)</u>	Ecology	36	47			8	7
	Spokane	53.8	85.5			13.6	12.3
<u>COD (mg/L)</u>	Ecology	110	130			42	42
	Spokane	89.2	118.7			39.3	39.3
<u>NH3-N (mg/L)</u>	Ecology	6.62	7.31			0.169	0.102
	Spokane	4.55	6.3			0.38	0.03
<u>Total-P (mg/L)</u>	Ecology	1.98	2.87			1.76	1.76
	Spokane	2.11	2.73			1.95	1.91
<u>F-Coliform MF (#/100mL)</u>	Ecology				27		
	Spokane				50		
<u>PP Metals (water)</u>							
<u>Copper (µg/L)</u>	Ecology	564	505			332	356
	Spokane	543	572			383	409
<u>Lead (µg/L)</u>	Ecology	10.5	30.6			40.1	41.3
	Spokane	30	30			56	55
<u>Nickel (µg/L)</u>	Ecology	399	366			170 B	187 B
	Spokane	246	263			125	147
<u>Zinc (µg/L)</u>	Ecology	56.5	85.7			72.4	72.8
	Spokane	40	76			85	81
<u>pH</u>	Ecology			7.51			
	Spokane			6.8			
<u>Total Chlorine Residual (mg/L)</u>	Ecology			0.2			
	Spokane			0.19			
	Inf	Influent		B	Analyte was also found in the analytic method blank indicating the sample may have been contaminated.		
	Ef	Effluent		*	SIP analyzed pH and total chlorine residual at the STP lab.		
	grab	Single grab.			Other SIP analyses were contracted to Inland Environmental Laboratories.		
	comp	Composite sample					
	Ecology	Ecology analysis.					
	Spokane	Spokane analysis.					
	@	Sample period: 08:00-08:00.					

be paid to the contract laboratory's accreditation program performance evaluation results for BOD<sub>5</sub>, TSS, NH<sub>3</sub>-N and nickel to help determine if there is a problem. Additional sample splits for these parameters should be considered as possible.

## CONCLUSIONS AND RECOMMENDATIONS

### Flow Measurement

The STP in-plant flow meter was accurate in comparison to Ecology instantaneous flow measurements.

### NPDES Permit Comparison

Based on inspection results, SIP effluent quality generally met weekly and monthly permit limits. Metals concentrations were less than interim limits, but copper, lead, and zinc concentrations exceeded final permit limits. The TSS concentration and one fecal coliform result were slightly greater than the monthly average permit limits.

- Dechlorination will likely be necessary to meet both fecal coliform and chlorine residual monthly average limits.

### General Chemistry/Plant Operation

During the inspection the plant influent was very weak in comparison to domestic sewage for several parameters. All concentrations of oxygen-demanding substances were low. The plant appeared to be actively nitrifying.

- Low influent BOD<sub>5</sub> concentrations due to test inhibition by toxicants appears unlikely; and in fact the waste has a low BOD<sub>5</sub>.

Comparison of typical loading and operational parameters with SIP data suggests the plant is organically underloaded. The low plant loading has allowed permit compliance with minimal plant operation.

- Compliance with the new permit metals limits will likely require more operator effort for process control and/or an active pretreatment program.
- Locating or compiling an "Operation and Maintenance Manual" is recommended to provide guidance to the plant operator.

Percent removals for most parameters were fairly low. Reduced water usage and/or reduced cooling water discharges in the SIP may increase the wastewater strength and result in higher percent removals. Reducing wastewater flows is likely to increase removal efficiency, however,

effluent concentrations of most pollutants will probably change little. Note that flow reduction could increase influent concentrations of potential toxicants. To prevent adverse impacts from this potential increase, the sources of toxics should be identified and reduced (see below).

### **Priority Pollutant Scans**

Three target organic compounds were detected in the influent or effluent. The effluent concentration of heptachlor, which exceeded chronic criteria by about eight times, was the only organic compound exceeding EPA water quality criteria (EPA, 1986).

- Identifying the heptachlor source as past use or present use and taking appropriate action is recommended.

The effluent copper concentration exceeded EPA acute toxicity criteria by roughly ten times (EPA, 1986). Also, lead, cadmium, mercury, and silver effluent concentrations exceeded the EPA chronic water quality criteria.

- Collecting a sample of the sludge (perhaps settling and spinning down a MLSS sample) for metals analysis is suggested to determine metals concentrations in the oxidation ditch solids.

### **Bioassays**

The rainbow trout and *Daphnia magna* acute toxicity tests found no toxicity in the SIP effluent. The *Ceriodaphnia dubia* survival and reproduction test indicated no acute or chronic toxicity. The fathead minnow test data show little correlation between effects and concentration and are likely of little value. Lack of toxicity in the effluent was somewhat surprising given the high concentration of copper in the effluent.

- Determining the source(s) of copper could help explain the unusual bioassay results and help SIP meet final NPDES permit limits.
- A study currently underway by the Ecology Watershed Assessment Section appraising the biological impact of metals in the Spokane River system may help define the significance of metals concentrations in the SIP discharge.

### **Visits To Industries**

The Boise Cascade discharge appeared capable of causing only minimal impacts at the SIP STP, so no samples were collected.

The significance of analytes detected in samples of the Columbia Lighting, Inc. discharge is unclear without corresponding flow data.

- A flow meter should be installed by Columbia Lighting to measure discharge to the SIP sewer system.

### **Split Samples**

SIP sampling appeared acceptable.

SIP pH results showed poor agreement with Ecology results.

- Replacement of the pH meter is recommended.

SIP contract laboratory results were similar to Ecology results for most parameters.

- Attention should be paid to the contract laboratory's accreditation program performance evaluation results for BOD<sub>5</sub>, TSS, NH<sub>3</sub>-N and nickel. Additional sample splits for the parameters noted above should be considered as possible.



## REFERENCES

- APHA, AWWA, WPCF, 1989. Standard Methods for the Examination of Water and Wastewater, 17th edition. American Public Health Association. Washington DC.
- EPA, 1980. Ambient Water Quality Criteria for Copper. United States Environmental Protection Agency, EPA 440/5-80-036. Pg. B-20.
- EPA, 1986. Quality Criteria for Water. EPA 440/5-86-001.
- EPA, 1987. Process, Coefficients, and Models for Simulating Toxics Organics and Heavy Metals in Surface Waters. EPA/600/3-87/015.
- EPA, 1989. Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms, 2nd edition. U.S. Environmental Protection Agency, Cincinnati, OH, EPA/600/4-89/001.
- EPA, 1991. Methods for Measuring the Acute Toxicity of Effluents and Receiving waters to freshwater and Marine Organisms. Weber, C.I. (ed.), U.S. Environmental Protection Agency, Environmental Monitoring Systems Laboratory, Cincinnati, OH, 4th Edition, EPA/600/4-90/027.
- Leber, L., 1984. Letter to Ray Roger of the Department of Ecology's Eastern Regional Office, October 3, 1984, 7 pages.
- Mckee, J.E. and H.W. Wolf, Ed., 1963. Water Quality Criteria, 2nd Edition. The Resources Agency of California, State Water Quality Control Board.
- Metcalf and Eddy, 1991. Wastewater Engineering Treatment Disposal Reuse, Third Edition. McGraw-Hill, New York.
- Miller, T.G. and Mackay, W.C., 1979. The Effects of Hardness, Alkalinity, and pH on Test Water in the Toxicity of Copper to Rainbow Trout. University of Alberta, Dept. of Zoology.
- Verschueren, K., 1983. Handbook of Environmental Data on Organic Chemicals, Second Edition. Van Nostrand Reinhold Co., New York.
- Washington State Department of Ecology, 1985. Criteria for Sewage Works Design. DOE 78-5.
- WEF, 1991. Design of Municipal Wastewater Treatment Plants Volume I, Manual of Practice No. 8. Joint Task Force of the Water Environmental Federation, Book Press, Inc.

Windholz, Martha, Ed., 1983. The Merck Index, Tenth Edition. Merck & Co., Inc. Rahway, N.J.

## APPENDICES

## Appendix A - Sampling Locations - Spokane Industrial Park, 1992

Inf-1 & Inf-2:

Influent grab samples collected at the headworks just past the weir.

Inf-S & Ef-E:

Spokane Industrial Park STP and Ecology composite influent sample collected at the headworks.

Ef-1 & Ef-2:

Effluent grab samples collected at the discharge from the chlorine contact chamber.

Ef-3 & Ef-4:

Effluent fecal coliform grab samples collected at the discharge from the chlorine contact chamber.

Ef-S & Ef-E:

Spokane Industrial Park STP and Ecology composite effluent sample collected from the end of the channel in the chlorine contact chamber.

EF-GC:

Effluent bioassay grab-composite samples collected at the discharge from the chlorine contact chamber.

MLSS-1 & MLSS-2:

Grab samples from the mixed liquor in the aeration ditch.

Intake:

Grab samples taken from the well supplying water to the Spokane Industrial Park.

CoLgt-1 :

Grab samples taken from the wastewater discharge channel at Columbia Lighting, Inc.

CoLgt-2

Grab sample taken from the Columbia Lighting, Inc. "Ecology Tank" (washer - wastewater neutralization tank).

## Appendix B – Sampling Schedule – Spokane Industrial Park, 1992

Parameter	Location:	Tr Blk	Inf-1	Inf-2	Inf-E	Inf-S	Ef-1	Ef-2	Ef-3	Ef-4	Ef-E	Ef-S	Ef-GC
	Type:		grab	grab	E-comp	S-comp	grab	grab	grab	grab	E-comp	S-comp	gr-comp
	Date:	5/18	5/19	5/19	5/19-20	5/19-20	5/19	5/19	5/20	5/20	5/19-20	5/19-20	5/19
	Time:	1540	0925	1510	@	@	0955	1525	0950	1050	@	@	1550
	Lab Log #:	218230	218231	218232	218233	218234	218235	218236	218255	218256	218237	218238	218239
<b>GENERAL CHEMISTRY</b>													
Conductivity			E	E	E	E	E	E			E	E	E
Alkalinity					E	E					E	E	E
Hardness					E	E					E	E	E
Chloride													
Sulfate													
<b>SOLIDS 4</b>													
TS					E						E		
TNVS					E						E		
TSS			E	E	ES	ES	E	E			ES	ES	
TNVSS					E						E		
TDS													
<b>OXYGEN DEMAND PARAMETERS</b>													
BOD5					ES	ES					ES	ES	
COD			E	E	ES	ES	E	E			ES	ES	
TOC (water)			E	E	E	E	E	E			E	E	
<b>NUTRIENTS</b>													
Total Persulfate N					E	E					E	E	
NH3-N					E	E	EE	E			ES	ES	
NO2+NO3-N					E	E	E	E			E	E	
Total-P					ES	ES	E	E			ES	ES	
<b>MISCELLANEOUS</b>													
Oil and Grease (water)			E	E			ES	E					
F-Coliform MF									ES	ES			
Cyanide (total)					E	E					E	E	
Cyanide (wk & dis)					E	E					E	E	
<b>ORGANICS</b>													
VOC (water)			E	E			ES	E					
BNAs (water)					E						E		
Pest/PCB (water)					E						E		
<b>METALS</b>													
PP Metals (water)			E		E	E					ES	ES	
Metals 6 + Hg (tot rec)													
Metals 6 + Hg (dis)													
<b>BIOASSAYS</b>													
Salmonid (acute 100%)													E
Daphnia magna (acute)													E
Ceriodaphnia (chronic)													E
Fathead Minnow (chronic)													E
<b>FIELD OBSERVATIONS</b>													
Temperature			E	E			E	E					
Temp-cooled*+					E	E					E	E	
pH			E	E	E	E	ES	ES			E	E	
Conductivity			E	E	E	E	E	E			E	E	
Chlorine							ES	ES	ES	ES			

@ Collection Period: 0800-0800.  
 S-comp Spokane Industrial Park composite sample  
 E-comp Ecology composite sample  
 S SIP lab analysis  
 E Ecology lab analysis

Tr Blk Transfer blank  
 Inf Influent  
 Ef Effluent  
 grab Grab sample

## Appendix B – Sampling Schedule – Spokane Industrial Park, 1992

Parameter II	Locatn:	MLSS-1	MLSS-2	Intake	CoLtg-1	CoLtg-2	River-1	River-2	River-3	River-4
	Type:	grab	grab	grab	grab	grab	grab	grab	grab	grab
	Date:	5/19	5/19	5/19	5/19	5/19	5/20	5/20	5/20	5/20
	Time:	1050	1520	1620	1355	1405	1255	1400	1500	1500
	Lab Log #:	218240	218241	218243	218246	218247	218248	218249	218250	218251
<b>GENERAL CHEMISTRY</b>										
Conductivity				E	E	E	E	E	E	E
Alkalinity				E			E	E	E	E
Hardness				E			E	E	E	E
Chloride							E	E	E	E
Sulfate							E	E	E	E
<b>SOLIDS 4</b>										
TS										
TNVS										
TSS		E	E		E	E	E	E	E	E
TNVSS		E	E							
TDS							E	E	E	E
<b>OXYGEN DEMAND PARAMETERS</b>										
BOD5										
COD					E	E				
TOC (water)					E	E	E	E	E	E
<b>NUTRIENTS</b>										
Total Persulfate N										
NH3-N					E	E				
NO2+NO3-N					E	E	E	E	E	E
Total-P					E	E	E	E	E	E
<b>MISCELLANEOUS</b>										
Oil and Grease (water)										
F-Coliform MF										
Cyanide (total)										
Cyanide (wk & dis)										
<b>ORGANICS</b>										
VOC (water)					E	E				
BNAs (water)										
Pest/PCB (water)										
<b>METALS</b>										
PP Metals (water)				E	E	E				
Metals 6 + Hg (tot rec)							E	E	E	E
Metals 6 + Hg (dis)							E	E	E	E
<b>BIOASSAYS</b>										
Salmonid (acute 100%)										
Daphnia magna (acute)										
Ceriodaphnia (chronic)										
Fathead Minnow (chronic)										
<b>FIELD OBSERVATIONS</b>										
Temperature		E	E	E	E	E				
Temp-cooled*+										
pH		E	E	E	E	E				
Conductivity		E	E	E	E	E				
Chlorine					E	E				

# Composite Collection Period: 0800–0800.  
 S-comp Spokane Industrial Park composite sample  
 E-comp Ecology composite sample  
 S SIP lab analysis  
 E Ecology lab analysis

Intake SIP water supply  
 MLSS Oxidation Ditch Solids  
 River Spokane River Ambient Sample  
 CoLtg Columbia Lighting discharge  
 grab Grab sample

## APPENDIX C – ECOLOGY ANALYTICAL METHODS – Spokane Industrial Park, 1992

PARAMETER	MANCHESTER_METHODS	LAB USED
<b>GENERAL CHEMISTRY</b>		
Conductivity	EPA, Revised 1983: 120.1	ECOLOGY
Alkalinity	EPA, Revised 1983: 310.1	ECOLOGY
Hardness	EPA, Revised 1983: 130.2	ECOLOGY
Chloride	EPA, Revised 1983: 330.0	ECOLOGY
<b>SOLIDS 4</b>		
TS	EPA, Revised 1983: 160.3	ECOLOGY
TNVS	EPA, Revised 1983: 106.3	ECOLOGY
TSS	EPA, Revised 1983: 160.2	ECOLOGY
TNVSS	EPA, Revised 1983: 106.2	ECOLOGY
<b>OXYGEN DEMAND PARAMETERS</b>		
BOD5	EPA, Revised 1983: 405.1	ECOLOGY
COD	EPA, Revised 1983: 410.1	SOUND ANALYTICAL SERVICES, INC.
TOC (water)	EPA, Revised 1983: 415.1	ECOLOGY
<b>NUTRIENTS</b>		
Total Persulfate N	EPA, Revised 1983: 351.3	ECOLOGY
NH3-N	EPA, Revised 1983: 350.1	ECOLOGY
NO2+NO3-N	EPA, Revised 1983: 353.2	ECOLOGY
Total-P	EPA, Revised 1983: 365.3	ECOLOGY
<b>MISCELLANEOUS</b>		
Oil and Grease (water)	EPA, Revised 1983: 413.1	ECOLOGY
F-Coliform MF	APHA, 1989: 9222D.	ECOLOGY
Cyanide (total)	EPA, Revised 1983: 335.2	ECOLOGY
Cyanide (wk & dis)	APHA, 1989: 4500-CNI.	ECOLOGY
<b>ORGANICS</b>		
VOC (water)	EPA, 1986: 8260	WEYERHAEUSER
BNAs (water)	EPA, 1986: 8270	WEYERHAEUSER
Pest/PCB (water)	EPA, 1986: 8080	WEYERHAEUSER
<b>METALS</b>		
PP Metals (water)	EPA, Revised 1983: 200-299	ECOLOGY
Metals 6 + Hg (tot rec)		ECOLOGY
Metals 6 + Hg (dis)		ECOLOGY
<b>BIOASSAYS</b>		
Salmonid (acute 100%)	Ecology, 1981.	EVS CONSULTANTS
Daphnia magna (acute)	EPA 1985	EVS CONSULTANTS
Ceriodaphnia (chronic)	EPA 1989: 1002.0	EVS CONSULTANTS
Fathead Minnow (chronic)	EPA 1989: 1000.0	EVS CONSULTANTS

### METHOD BIBLIOGRAPHY

- APHA-AWWA-WPCF, 1989. Standard Methods for the Examination of Water and Wastewater, 17th Edition.
- Ecology, 1981. Static Acute Fish Toxicity Test, WDOE 80-12, revised July 1981.
- EPA, Revised 1983. Methods for Chemical Analysis of Water and Wastes, EPA-600/4-79-020 (Rev. March, 1983).
- EPA, 1985. Methods for Measuring the Acute Toxicity of Effluents to Freshwater and Marine Organisms. EPA/600/4-85/013.
- EPA, 1986: SW846. Test Methods for Evaluating Solid Waste Physical/Chemical Methods, SW-846, 3rd. ed., November, 1986.
- EPA, 1989. Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving waters to Freshwater Organisms. Second edition. EPA/600/4-89/100.

**APPENDIX D - Cleaning Procedures Prior to Sampling for Priority  
Pollutants - Spokane Industrial Park, 1992.**

1. Wash with laboratory detergent
2. Rinse several times with tap water
3. Rinse with 10% HNO<sub>3</sub> solution
4. Rinse three (3) times with distilled/deionized water
5. Rinse with high purity methylene chloride
6. Rinse with high purity acetone
7. Allow to dry and seal with aluminum foil



## Appendix E - F/M Calculations - Spokane Industrial Park, 1992

### I. Calculation of Food-to-Microorganism Ratio (F/M Ratio)

#### A. Equation:


$$1. F/M = S_o/\theta X$$

#### 2. Where:

- a.  $F/M$   $\equiv$  Food-to-Microorganism Ratio:  $\text{day}^{-1}$
- b.  $S_o$   $\equiv$  Influent  $BOD_5$  or COD:  $\text{mg/L}$  or  $\text{lb/day}$
- c.  $\theta$   $\equiv$  Hydraulic detention time ( $\theta = V/Q$ ): day
- d.  $V$   $\equiv$  Aeration tank volume: Mgal
- e.  $Q$   $\equiv$  Influent and effluent flow rate: MGD
- f.  $X$   $\equiv$  Concentration of volatile suspended solids in the aeration ditch ( $X = \text{TSS} - \text{TNVSS}$ ): Averages in  $\text{mg/L}$  or  $\text{lb/day}$
- g.  $X_c$   $\equiv$  Concentration of volatile suspended solids in the effluent stream ( $X_c = \text{TSS} - \text{TNVSS}$ ): Averages in  $\text{mg/L}$  or  $\text{lb/day}$
- h.  $\theta_c$   $\equiv$  Mean Cell-Residence Time in days

Note: The ditch was measured by Ecology using measuring tape to determine volumes.

#### B. Cross Section of Aeration Ditch:




**Figure 1**

$$a. A_c = 5'(26') + 2((5')(5')/2)$$

$$b. A_c = 155 \text{ ft}^2$$

#### C. Volume of Aeration ditch:




**Figure 2**

Appendix E - F/M Calculations (cont.) - Spokane Industrial Park, 1992

1. Inner sections:

- a.  $V_1 = V_2 \cong \text{Length} \times \text{Cross section} = (260\text{ft}) \times (155\text{ft}^2) = 40,300\text{ft}^3$
- b.  $V_1 + V_2 = 80,600 \text{ ft}^3$

2. End sections:



**Figure 3**

$$r_1 = 87'/2 = 43.5'$$

$$r_2 = (87'/2 - 5') = 38.5'$$

$$\text{Area of Inner Island} = \pi(15/2)^2 = 176.7 \text{ ft}^2$$

$$\text{a. } V_3 + V_4 \cong [5' \times (\pi \times (r_2)^2 - 176.7\text{ft}^2)] + [5' \times [\pi \times ((r_1)^2 - (r_2)^2) / 2]]$$

$$\text{b. } V_3 + V_4 = 25,619.8 \text{ ft}^3$$

$$3. \text{ Total } V = V_1 + V_2 + V_3 + V_4 = 106,219.8 \text{ ft}^3$$

$$4. \text{ Total } V \text{ in gal} = 794,577 \text{ gal}$$

D. Influent flow rate and hydraulic detention time:

$$1. \text{ Average flow: } Q = 0.602 \text{ MGD}$$

$$2. \theta = V/Q = 794,577 \text{ gal} / 602,000 \text{ gal/day} = 1.32 \text{ day}$$

E. Concentration of volatile suspended solids:

$$X = \text{TSS} - \text{TNVS} = 320 \text{ mg/L} - 140 \text{ mg/L} = 180 \text{ mg/L}$$

F. Concentration of Influent BOD<sub>5</sub>

$$\text{Average BOD}_5 = (36 \text{ mg/L} + 47 \text{ mg/L}) / 2 = 41.5 \text{ mg/L}$$

G. F/M ratio

$$F/M = S_o / \theta X = 41.5 \text{ mg/L} / (180 \text{ mg/L} \times 1.32 \text{ day}) = 0.18 \text{ day}^{-1}$$

Appendix E - F/M Calculations (cont.) - Spokane Industrial Park, 1992

H. Mean Cell-Residence Time (Sludge Age)

1.  $\theta_c = V \cdot X / Q \cdot X_c$
2.  $V \cdot X = 0.795 \text{Mgal} * [180 \text{mg/L} * (8.34 \text{ lbs/gal/mg/L})] = 1193 \text{ lbs}$
3.  $Q \cdot X_c = [((17-8) + (16-7))/2] * (\text{mg/L}) * (8.34 \text{ lbs/gal/mg/L}) * 0.602 \text{MGD} = 45 \text{ lbs/day}$
4.  $\theta_c = 1193 \text{ lbs} / 45 \text{ lbs/day} = 26.5 \text{ days}$

I. Volumetric Loading

1. Loading = lbs BOD<sub>5</sub>/Volume(10<sup>3</sup>ft<sup>3</sup>)\*day
2. Loading =  $[41.5 \text{mg/L} * (8.34 \text{ Lbs/gal/mg/L}) * 0.602 \text{ MGD}] / [106,219 \text{ ft}^3 / (1000/10^3)] = 1.96 \text{ lbBOD}_5 / (10^3 \text{ft}^3) * \text{day}$

Appendix F – VOA, BNA, Pesticide/PCB and Metals Scan Results – Spokane Industrial Park – 1992.

Parameter	Location:	Inf-1	Inf-2	Ef-1	Ef-2	CoLtg-1	CoLtg-2
	Type:	grab	grab	grab	grab	grab	grab
	Date:	5/19	5/19	5/19	5/19	5/19	5/19
	Time:	0925	1510	0955	1525	1355	1405
	Lab Log#:	218231	218232	218235	218236	218246	218247

VOA Compounds (UNITS:)	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L
Chloromethane	10 U	10 U	10 U	10 U	10 U	10 U	10 U
Bromomethane	10 U	10 U	10 U	10 U	10 U	10 U	10 U
Vinyl Chloride	10 U	10 U	10 U	10 U	10 U	10 U	10 U
Chloroethane	10 U	10 U	10 U	10 U	10 U	10 U	10 U
Methylene Chloride	10 U	10 U	10 U	10 U	10 U	10 U	10 U
Acetone	2500 D	540 D	27	42	27	48	
Carbon Disulfide	10 U	10 U	10 U	10 U	10 U	10 U	10 U
1,1-Dichloroethene	10 U	10 U	10 U	10 U	10 U	10 U	10 U
1,1-Dichloroethane	10 U	10 U	10 U	10 U	10 U	10 U	10 U
1,2-Dichloroethene (total)	10 U	10 U	10 U	10 U	10 U	10 U	10 U
Chloroform	10 U	10 U	10 U	10 U	10 U	10 U	10 U
1,2-Dichloroethane	10 U	10 U	10 U	10 U	10 U	10 U	10 U
2-Butanone (MEK)	10 U	10 U	10 U	10 U	10 U	10 U	10 U
1,1,1-Trichloroethane	10 U	10 U	10 U	10 U	10 U	10 U	10 U
Carbon Tetrachloride	10 U	10 U	10 U	10 U	10 U	10 U	10 U
Bromodichloromethane	10 U	10 U	10 U	10 U	10 U	10 U	10 U
1,2-Dichloropropane	10 U	10 U	10 U	10 U	10 U	10 U	10 U
cis-1,3-Dichloropropene	10 U	10 U	10 U	10 U	10 U	10 U	10 U
Trichloroethene	10 U	10 U	10 U	10 U	10 U	10 U	10 U
Dibromochloromethane	10 U	10 U	10 U	10 U	10 U	10 U	10 U
1,1,2-Trichloroethane	10 U	10 U	10 U	10 U	10 U	10 U	10 U
Benzene	10 U	10 U	10 U	10 U	10 U	10 U	10 U
trans-1,3-Dichloropropene	10 U	10 U	10 U	10 U	10 U	10 U	10 U
Bromoform	10 U	10 U	10 U	10 U	10 U	10 U	10 U
4-Methyl-2-Pentanone (MIBK)	10 U	10 U	10 U	10 U	10 U	10 U	7 J
2-Hexanone	10 U	10 U	10 U	10 U	10 U	10 U	10 U
Tetrachloroethene	3 J	10 U	10 U	10 U	10 U	10 U	10 U
1,1,2,2-Tetrachloroethane	10 U	10 U	10 U	10 U	10 U	10 U	10 U
Toluene	10 U	10 U	10 U	10 U	10 U	1 J	10 U
Chlorobenzene	10 U	10 U	10 U	10 U	10 U	10 U	10 U
Ethylbenzene	10 U	10 U	10 U	10 U	10 U	7 J	8 J
Styrene	10 U	10 U	10 U	10 U	10 U	10 U	10 U
Total Xylenes	3 J	5 J	10 U	10 U	42	50	

- D Analysis of sample used a dilution.
- J The analyte was positively identified. The associated numerical result is an estimate.
- U The analyte was not detected above the reported result.

Parameter	Location: Type: Date: Time: Lab Log#:	Inf-E E-comp 5/19-20 @ 218233	Ef-E E-comp 5/19-20 @ 218237
-----------	---	---	--

**BNA Compounds**

(UNITS:)	$\mu\text{g/L}$	$\mu\text{g/L}$
1		
Phenol	10 U	10 U
Bis(2-Chloroethyl)Ether	10 U	10 U
2-Chlorophenol	10 U	10 U
1,3-Dichlorobenzene	10 U	10 U
1,4-Dichlorobenzene	10 U	10 U
1,2-Dichlorobenzene	10 U	10 U
2-Methylphenol	10 U	10 U
Bis(2-Chloroisopropyl)Ether	10 U	10 U
4-Methylphenol	10 U	10 U
N-Nitroso-di-n-Propylamine	10 U	10 U
Hexachloroethane	10 U	10 U
Nitrobenzene	10 U	10 U
Isophorone	10 U	10 U
2-Nitrophenol	10 U	10 U
2,4-Dimethylphenol	10 U	10 U
Bis(2-Chloroethoxy)Methane	10 U	10 U
2,4-Dichlorophenol	10 U	10 U
1,2,4-Trichlorobenzene	10 U	10 U
Naphthalene	10 U	10 U
4-Chloroaniline	10 U	10 U
Hexachlorobutadiene	10 U	10 U
4-Chloro-3-Methylphenol	10 U	10 U
2-Methylnaphthalene	10 U	10 U
Hexachlorocyclopentadiene	10 U	10 U
2,4,6-Trichlorophenol	10 U	10 U
2,4,5-Trichlorophenol	25 U	25 U
2-Chloronaphthalene	10 U	10 U
2-Nitroaniline	25 U	25 U
Dimethyl Phthalate	10 U	10 U
Acenaphthylene	10 U	10 U
2,6-Dinitrotoluene	10 U	10 U
3-Nitroaniline	25 U	25 U
Acenaphthene	10 U	10 U
2,4-Dinitrophenol	25 U	25 U
4-Nitrophenol	25 U	25 U
Dibenzofuran	10 U	10 U
2,4-Dinitrotoluene	10 U	10 U
Diethyl Phthalate	10 U	10 U
4-Chlorophenyl Phenylether	10 U	10 U
Fluorene	10 U	10 U
4-Nitroaniline	25 U	25 U
4,6-Dinitro-2-Methylphenol	25 U	25 U
N-Nitrosodiphenylamine	10 U	10 U
4-Bromophenyl Phenylether	10 U	10 U
Hexachlorobenzene	10 U	10 U
Pentachlorophenol	25 U	25 U
Phenanthrene	10 U	10 U

U The analyte was not detected above the reported result.

Appendix F (cont'd) – Spokane Industrial Park – 1992.

Parameter	Location:	Inf-E	Ef-E
	Type:	E-comp	E-comp
	Date:	5/19-20	5/19-20
	Time:	@	@
	Lab Log#:	218233	218237

**BNA Compounds**

(UNITS:)	µg/L	µg/L
Anthracene	10 U	10 U
Di-n-Butyl Phthalate	10 U	10 U
Fluoranthene	10 U	10 U
Pyrene	10 U	10 U
Butylbenzyl Phthalate	10 U	10 U
3,3'-Dichlorobenzidine	10 U	10 U
Benzo(a)Anthracene	10 U	10 U
Chrysene	10 U	10 U
Bis(2-Ethylhexyl)Phthalate	2 J	2 J
Di-n-Octyl Phthalate	10 U	10 U
Benzo(b)Fluoranthene	10 U	10 U
Benzo(k)Fluoranthene	10 U	10 U
Benzo(a)Pyrene	10 U	10 U
Indeno(1,2,3-cd)Pyrene	10 U	10 U
Dibenzo(a,h)Anthracene	10 U	10 U
Benzo(g,h,i)Perylene	10 U	10 U
Carbazole	10 U	10 U
Pyridine	10 U	10 U

Parameter	Location:	Inf-E	Ef-E
	Type:	E-comp	E-comp
	Date:	5/19-20	5/19-20
	Time:	@	@
	Lab Log#:	218233	218237

**Pesticides/PCBs Compounds**

(UNITS:)	µg/L	µg/L
alpha-BHC	0.05 U	0.05 U
beta-BHC	0.05 U	0.05 U
delta-BHC	0.05 U	0.05 U
gamma-BHC (Lindane)	0.05 U	0.05 U
Heptachlor	0.018 JP	0.03 JP
Aldrin	0.05 U	0.05 U
Heptachlor Epoxide	0.05 U	0.05 U
Endosulfan I	0.05 U	0.05 U
Dieldrin	0.1 U	0.1 U
4,4'-DDE	0.1 U	0.1 U
Endrin	0.1 U	0.1 U
Endosulfan II	0.1 U	0.1 U
4,4'-DDD	0.1 U	0.1 U
Endosulfan Sulfate	0.1 U	0.1 U
4,4'-DDT	0.1 U	0.1 U
Methoxychlor	0.5 U	0.5 U
Endrin Ketone	0.1 U	0.1 U
alpha-Chlordane	0.1 U	0.1 U
gamma-Chlordane	0.1 U	0.1 U
Toxaphene	5 U	5 U

- J The analyte was positively identified. The associated numerical result is an estimate.
- P Analyte was detected above the instrument detection limits, but below the minimum qualification limits.
- U The analyte was not detected above the reported result.

Appendix F (cont'd) – Spokane Industrial Park – 1992.

Location:	Inf-E	Ef-E
Type:	E-comp	E-comp
Date:	5/19-20	5/19-20
Time:	@	@
Lab Log#:	218233	218237

**Pesticides/PCBs Compounds**  
(UNITS:)

	µg/L	µg/L
Aroclor-1016	1 U	1 U
Aroclor-1221	2 U	2 U
Aroclor-1232	1 U	1 U
Aroclor-1242	1 U	1 U
Aroclor-1248	1 U	1 U
Aroclor-1254	1 U	1 U
Aroclor-1260	1 U	1 U
Endrin Aldehyde	0.1 U	0.1 U

Location:	Tr Blk	Inf-E	Inf-S	Ef-E	Ef-S	Intake	CoLtg-1	CoLtg-2
Type:		E-comp	S-comp	E-comp	S-comp	grab	grab	grab
Date:	5/18	5/19-20	5/19-20	5/19-20	5/19-20	5/19	5/19	5/19
Time:	1540	@	@	@	@	1620	1355	1405
Lab Log#:	218230	218233	218234	218237	218238	218243	218246	218247

**Metals (Total)**  
(UNITS:)

	Hardness = 170	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L
Antimony		30 U	30 U	30 U	30 U	30 U	30 U	30 U	35 P
Arsenic		1.5 U	2.8 P	2.9 P	3.1 P	3.6 P	4.2 P	3.7 P	15.4
Pentavalent									
Trivalent									
Beryllium		1.0 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Cadmium		0.1 U	2.5 P	2.12	2.87	2.64	0.12 P	0.1 U	0.6
Chromium		5.0 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Hexavalent									
Trivalent									
Copper		3.0 U	564	505	332	356	3 U	3.5 P	48.7
Lead		1.0 U	10.5	30.6	40.1	41.3	1 U	1 U	55.4
Mercury		0.13 PN	0.973 N	0.671 N	0.552 N	0.651 N	0.1 UN	0.24 PN	0.45 PN
Nickel		10 U	399	366	170 B	187 B	10 U	10 U	24 PB
Selenium		2.0 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U
Silver		0.5 UN	1.2 N	0.5 UN	1.9 N	2.2 N	0.5 UN	0.5 UN	0.5 UN
Thallium		2.5 U	2.5 U	2.5 U	2.5 U	2.5 U	2.5 U	2.5 U	2.5 U
Zinc		4.0 U	56.5	85.7	72.4	72.8	17 P	8.6 P	63.8

- B Analyte was found in the analytic method blank, indicating the sample may have been contaminated.
- J The analyte was positively identified, but the associated result is an estimate.
- N For metals analytes the spike sample recovery is not within control limits.
- P Analyte was detected above the instrument detection limits, but below the minimum qualification limits.
- U The analyte was not detected above the reported result.

- E Ecology Sample.
- S Spokane STP sample.
- @ Composite sampling time: 0800-0800.
- comp Composite sample.
- grab Grab sample.
- gr-comp Grab-composite sample.

- Tr Blk Transfer blank
- Inf Influent
- Ef Effluent
- Intake SIP water supply
- MLSS Oxidation Ditch Solids
- CoLtg Columbia Lighting discharge





Sample Location:	EF-1		
Type:	grab		
Date:	5/19/92		
Time:	0955		
Sample ID:	218235		
Compound Name		Estimated Concentration ( $\mu\text{g/L}$ )	Qualifier
1. HEXAMETHYLCYCLOTRISILOXANE		21	JN
2. Cyclotetrasiloxane, octameth-		27	JN

Sample Location:	EF-2		
Type:	grab		
Date:	5/19/92		
Time:	1525		
Sample ID:	218236		
Compound Name		Estimated Concentration ( $\mu\text{g/L}$ )	Qualifier
1. Cyclotetrasiloxane, octameth-		97	NJ

Sample Location:	EF-E	
Type:	comp	
Date:	5/19-20/92	
Time:	24 hours	
Sample ID:	218237	
Compound Name	Estimated Concentration ( $\mu\text{g/L}$ )	Qualifier
1. UNKNOWN	15	J
2. UNKNOWN	33	J
3. ETHANOL, 2-[2-(2-PHENOXYETHO)]-	9	NJ
4. UNKNOWN	8	J
5. UNKNOWN	20	J
6. UNKNOWN	15	J
7. UNKNOWN	14	J
8. UNKNOWN	15	J
9. UNKNOWN	43	J
10. UNKNOWN	7	J
11. UNKNOWN	8	J
12. UNKNOWN	18	J
13. UNKNOWN	7	J
14. UNKNOWN	12	J
15. UNKNOWN	19	J
16. UNKNOWN	38	J
17. PHOSPHINE OXIDE, TRIPHENYL-	15	NJ
18. UNKNOWN	15	J
19. PHOSPHINE SULFIDE < TRIPHENYL-	25	NJ
20. UNKNOWN	28	J

Sample Location:	CoLtg-1	
Type:	grab	
Date:	5/19/92	
Time:	1355	
Sample ID:	218246	
Compound Name	Estimated Concentration ( $\mu\text{g/L}$ )	Qualifier
1. Cyclotetrasiloxane	49	NJ

Sample Location:	CoLtg-2	
Type:	grab	
Date:	5/19/92	
Time:	1405	
Sample ID:	218247	
Compound Name	Estimated Concentration ( $\mu\text{g/L}$ )	Qualifier
1 1-propanol, 2-methyl-	12	NJ
2. HEXAMETHYLCYCLOTRISILOXANE	9	NJ
3. Cyclotetrasiloxane	22	NJ