

**CITY OF MEDICAL LAKE
SEWAGE TREATMENT FACILITY
CLASS II INSPECTION**

September 1994

Water Body N. WA-54-1020

Publication No. 94-156

printed on recycled paper




The Department of Ecology is an Equal Opportunity and Affirmative Action employer and shall not discriminate on the basis of race, creed, color, national origin, sex, marital status, sexual orientation, age, religion, or disability as defined by applicable state and/or federal regulations or statutes.

If you have special accommodation needs, please contact the Environmental Investigations and Laboratory Services Program, Toxics Investigations Section, Kelly Carruth at (206) 407-6764 (voice). Ecology's telecommunications device for the deaf (TDD) number at Ecology Headquarters is (206) 407-6006.

*For additional copies of this publication,
please contact:*

*Department of Ecology
Publications Distributions Office
at P.O. Box 47600
Olympia, Washington 98504-7600
(206) 407-7472
Refer to Publication Number 94-156*



City of Medical Lake Sewage Treatment Facility Class II Inspection

by
Guy Hoyle-Dodson

Environmental Investigations and Laboratory Services Program
Olympia, Washington 98504-7710

September 1994

Water Body No. WA-54-1020
Publication No. 94-156
printed on recycled paper



Table of Contents

	Page
Abstract	ii
Summary	iii
Flow Measurements	iii
Wastewater General Chemistry	iii
NPDES Comparisons	iii
Split Samples	iii
Detected Organics and Priority Pollutant Metals	iv
Sludge	iv
Recommendations	iv
Flow Measurements	iv
NPDES Comparisons	iv
Split Samples	iv
Introduction	1
Setting	1
Procedure	2
Quality Assurance/Quality Control	3
Results and Discussion	3
Flow Measurements	3
Wastewater General Chemistry	4
Influent	4
Effluent	4
Treatment/Settling Lagoons	5
Discharge Ditch	5
NPDES Permit Comparisons	5
Split Samples	6
Sample Comparisons	6
Laboratory Comparisons	6
Wastewater Priority Pollutant Metals	7
Sludge	7
References	8

Abstract

A Class II Inspection was conducted September 20-22, 1993, at the city of Medical Lake Wastewater Treatment facility in Spokane County, Washington. The Medical Lake facility operates an aerated lagoon connected in series with two large unaerated treatment/settling lagoons. The plant discharge flows several miles in an open channel before discharging to Deep Creek. Effluent flow meter calibration was checked and the meter was found to be accurate. Recalibration of pump flow measurements or, if necessary, the addition of an influent flow measurement device is recommended. A higher than typical BOD₅/TOC ratio was found for influent samples. TSS removal efficiency was moderate likely due to algae growth in the settling ponds. NH₃-N removal occurred in the system. Most effluent results are within the Ecology compliance order load and concentration limits, but several exceed NPDES permit limits. Effluent pH exceeded both NPDES permit and compliance order limits. Effluent TSS concentration exceeded the percent of influent concentration stipulated by the monthly NPDES permit limit. Chlorine residual appeared high and it is recommended that the minimal concentration and optimal retention time be determined to reliably achieve permit fecal coliform limits. Split sample analyses found good correspondence between samples and good correspondence between laboratories for most parameters except BOD₅. Wastewater metal concentrations were all within EPA and state water quality criteria for receiving waters. Concentrations of sludge metals did not exceed EPA criteria for the land application of municipal sludge, although fecal coliform densities exceeded Class A land application standards.

Summary

Flow Measurements

Medical Lake's effluent flow measurement device accurately reflected the Ecology flow measurements at the effluent weir. Effluent flow is reported to be only 36% of influent flow. The discrepancy may be attributed in part to evaporation and infiltration, but inaccuracies in influent flow measurement may also contribute.

Wastewater General Chemistry

Influent parameters were generally within typical ranges. A BOD₅ removal of 79% and a TSS removal of 33% were calculated with Ecology analytical results. Most NH₃-N was removed in the system. Most TOC and TSS removal occurred in the aeration basin. Low overall TSS removal efficiency and TSS increases across the treatment/settling lagoons basins suggest excessive algae growth in the two basins.

NPDES Comparisons

Effluent BOD₅ and TSS concentrations and loads were all within the compliance order monthly and weekly average limits. BOD₅ results exceeded the NPDES permit monthly concentration limit. One TSS result exceeded the NPDES permit monthly load limit, and all TSS results exceeded the permit monthly and weekly concentration limits. Plant TSS effluent concentration was greater than the 15% of influent concentration required by the monthly NPDES permit limit. Effluent pH exceeded the upper range of the permit limit and the compliance order. High pH was likely due to algae growth in the treatment/settling lagoons.

Plant flow rate and fecal coliform densities were within NPDES permit and compliance order limits. Chlorine residual appeared high and may be excessive to meet NPDES permit fecal coliform limits.

Split Samples

Comparison of Ecology lab results for Ecology and Medical Lake effluent samples showed good correspondence. Medical Lake lab results for the two BOD₅ effluent samples had a relative percent error of 39%. Both Ecology and Medical Lake influent samples correlated well for BOD₅, but showed more variability for TSS.

Comparisons between laboratories showed close TSS results, but the Medical Lake lab BOD₅ results did not closely match Ecology lab results. Fecal coliform results for both labs were uniformly low. The Cheney STP lab, which performed the analyses for the Medical Lake

facility, is not accredited. It is reported that they do not dechlorinate BOD₅ samples before testing.

Detected Organics and Priority Pollutant Metals

Arsenic, copper, selenium, and zinc were detected in the effluent. None exceeded the EPA or state water quality criteria for receiving waters.

Sludge

Sludge nutrient concentrations produce a nitrogen loading rate for land application to field crops of 1.8 to 7.3 tons dry solids/acre-year. The sludge fecal coliform density exceeds the EPA Class A pathogen limitation for the land application of municipal sludge by a factor of 36. Sludge sample VOAs and BNAs were detected in low concentrations with the exception of Bis(2-Ethylhexyl)Phthalate. A land application criteria is not available for this compound. Concentrations of detected priority pollutant metals in the sludge did not exceed the EPA metals criteria for the land application of municipal sludge.

Recommendations

Flow Measurements

- Recalibration of pump measurements or the addition of an influent flow measurement device is recommended to provide more accurate plant loading measurements.

NPDES Comparisons

- Rectify excessive effluent TSS and low TSS removal efficiency by reducing retention time in the treatment/settling lagoons as a means to control algae growth.
- Confirm algae growth as the source of excessive pH in the effluent.
- Identify and maintain the minimal chlorine concentration and optimal contact time to achieve fecal coliform limits.

Split Samples

- An influent composite or grab composite sample is recommended.
- The lab which does the Medical Lake analysis needs to be accredited by July 1, 1994 to conform to Washington Administrative Code 173-220.

Introduction

A Class II Inspection was conducted at the City of Medical Lake Sewage Treatment Plant (STP) on September 20-22, 1993. Guy Hoyle-Dodson of the Washington State Department of Ecology's Toxics Investigations Section conducted the investigation. Pat Hallinan, municipal permit manager for the Department of Ecology's Eastern Regional Office, provided background information on facility operation. Medical Lake City Public Works Superintendent, Earl Davis; Public Works Maintenance Supervisor, Dan Dorshorst; and facility operator, Bill Ahlf provided information and assistance on site.

The Medical Lake STP serves a population of approximately 2900, consisting mainly of private residences and small retail businesses. The plant discharges effluent to Deep Creek a tributary of the Spokane River. An NPDES Permit (No. WA-002114-3) was issued July 1, 1977, with an expiration date of June 30, 1982. The facility is operating under an administrative extension of that permit. An additional administrative order (No. DE 91WQ-E376) was issued December 31, 1991, providing new, less stringent limitations for several permit parameters. The order will remain in effect until the construction of a planned system upgrade to be completed by October 1, 1996.

The Class II Inspection was initiated by the Department of Ecology to evaluate permit compliance and to provide information about facility loading and lagoon bottom sludge composition. Specific objectives of the inspection included:

1. Assess NPDES permit compliance;
2. Assess wastewater toxicity with priority pollutant metal scans;
3. Characterize solids and nutrient composition of lagoon bottom sludge;
4. Assess sludge toxicity with fecal coliform tests, priority pollutant organic scans, and metals scans;
5. Evaluate treatment facility performance;
6. Evaluate permittee's self-monitoring with split samples.

Setting

The Medical Lake treatment facility is located in Spokane County, Washington, just north of the city of Medical Lake (*Figure 1*). The facility uses an aerated lagoon system followed by chlorination. The city began operation of the lagoon system in 1977 and incorporated minor

modifications through the years. In 1992 aerators were added to lagoon #1 to improve secondary treatment.

The system consists of influent wetwell, a mechanically aerated primary lagoon (4.48 acres), two facultative treatment/settling lagoons (3.41 and 3.12 acres) operated in series, and a chlorine contact chamber (*Figure 2*). Raw wastewater from the wetwell is pumped to a splitter box and diverted into the primary lagoon. Pump records are used to estimate influent flow volumes.

Lagoon #1 is the principal secondary treatment unit. Five floating agitators provide aeration and also promote counterclockwise flow through lagoon #1. Flow enters at the north bank, completes a 270 degree circuit, and discharges to lagoon #2. Sludge accumulates on the lagoon bottom and has not been dredged during the life of the system.

Lagoons #2 and #3 are used primarily for settling. Mechanical agitation of their surfaces is limited to the prevention of ice build-up during the winter. Accumulated sludge has never been dredged.

Effluent from lagoon #3, the last in the series, is chlorinated and discharged to a chlorine contact chamber. A 45° V-notch weir with a Polysonics ultrasound flow meter records effluent flow rates. Discharge from the contact chamber cascades onto a rock spillway then flows down an open channel.

The discharge is atypical in that it flows for about four miles through surrounding agricultural land before emptying into Deep Creek (*Figure 1*). This connecting channel is open to a variety of non-point pollution sources. Farm animals have direct contact with the channel. Agricultural and residential runoff likely contribute additional contamination. Flow in this channel is seasonal, and during the dry season surface volumes recharge into the ground for short distances then resurface. The channel's confluence with Deep Creek was not accessible during the inspection.

Ecology's compliance order mandates that an upgraded treatment system, capable of meeting NPDES treatment limits, will be built to replace the current system no later than October 1, 1996. A new mechanical system which discharges to Medical Lake is presently under design.

Procedure

Ecology collected both grab and composite samples at the STP. Composite samples were collected from wastewater at two stations (*Figure 2 & Appendix A*); the influent wetwell and the effluent from the chlorination chamber. All composite samples were collected using Ecology ISCO composite samplers with equal volumes of the sample collected every 30 minutes over a 24 hour period. Grab samples were collected at all composite stations as well as several other sites.

Medical Lake personnel collected grab samples at the influent splitter box and from the effluent at the outfall from the chlorine contact chamber. Medical Lake samples were not equivalent to those collected by Ecology's composite samplers, but represented the STP's typical sampling procedures.

Ecology composite samples and Medical Lake grab samples were split for analysis by both Ecology and Medical Lake laboratories. Parameters analyzed, samples collected, and the sampling schedule appear in Appendix B.

Samples for Ecology analysis were put in appropriate containers and preserved as necessary. The samples were packed in ice and delivered to the Ecology Manchester Laboratory. Analytical procedures and laboratories performing the analyses are summarized in Appendix C.

Quality Assurance/Quality Control

Sampling quality assurance included priority pollutant cleaning of sampling equipment (*Appendix D*). One duplicate of a composite sample was analyzed to assess sample splitting and analytic consistency. Sampling in the field followed all protocols for holding times, preservation, and chain-of-custody set forth in the Manchester Lab Laboratory Users Manual (Ecology, 1991).

Laboratory QA/QC including holding times, spike and duplicate spike sample analyses, precision data, and control sample (LCS) analyses were typically within appropriate ranges. Initial and continuing calibration verification standards were within relevant USEPA (CLP) control limits. Procedural blanks were predominantly free from contamination. Qualifiers are included in the data table where appropriate. Specific QA/QC concerns are noted in Appendix D.

Results and Discussion

Flow Measurements

Effluent flows were measured by ultrasonic meter in conjunction with a 45° V-notch weir located at the end of the chlorine contact chamber. At the time of the inspection, the flow recorded by the effluent totalizer was generally used as the plant flow for NPDES permit reporting. The effluent weir was inspected by Ecology and it appeared to be properly configured. An instantaneous flow measurement by Ecology taken at the weir (0.091 MGD) compared closely with the Medical Lake metered instantaneous measurement (0.086 MGD). The daily flow rate calculated from totalizer values over a two-day period was 0.092 MGD.

Medical Lake estimated influent flow through pump records. Estimated average influent flow during the inspection was 0.25 MGD. Apparent average daily losses across the system for the month of September ranged from 0.1 MGD to 0.15 MGD and may be attributed in part to evaporation and infiltration. The lack of steady state flow makes verification difficult, but inaccurate flow measurements could produce a sizeable portion of the discrepancy between influent and effluent flows. Recalibration of pump flow measurements is recommended to produce greater accuracy and allow a better evaluation of plant loading. If necessary, a direct influent flow measurement device should be considered.

Wastewater General Chemistry

Influent

BOD₅ concentration in the influent (207 mg/L) fell within the typical medium concentration range for untreated domestic wastewater (*Table 1*). TOC influent concentration (104 mg/L) fell into the "weak" range and BOD₅ /TOC ratio was higher than typical (Metcalf & Eddy, 1991, pg. 83).

Influent total solids (600 mg/L) and total non-volatile solids (311 mg/L) (*Table 1*) fell into a "medium" concentration range for typical domestic influent (Metcalf & Eddy, 1991).

Effluent

Due to the long retention time in the facility (\approx 95 days), fairly uniform influent quality is assumed in order to estimate treatment. Inspection results showed a BOD₅ reduction from 207 mg/L in the influent to 44 mg/L in the effluent (79% removal) (*Tables 1&2*). BOD₅ removal efficiency compared well with other modified aeration designs (Metcalf & Eddy, 1991). Other oxygen demand parameters, TOC and COD, did not display comparable removal efficiencies.

Ecology composite samples showed a decrease in total suspended solids (TSS) from 144 mg/L to 98 mg/L with a removal efficient of approximately 33% across the plant (*Tables 1&2*). Ammonia nitrogen (NH₃-N) concentrations decreased from an average of 25.5 mg/L in the influent to 0.135 mg/L in the effluent (*Table 1*). Nitrification was accompanied by a greater than expected reduction in alkalinity. Nitrite-Nitrate nitrogen (NO₂+NO₃-N) concentrations increased, but was still less than 0.5 mg/L in the effluent (*Table 1*). Denitrification and/or incorporation of nitrogen into algae are likely explanations for the low NO₂+NO₃-N in the effluent. Total phosphorous removal efficiency exceeded 52%.

Treatment/Settling Lagoons

TSS and TOC removal occurred in the aerated lagoon. TSS increased across the two treatment/settling basins 6% and 16% respectively, and TOC increased 43% (Table 2). BOD₅ was not measured between lagoons. These increases and the relatively low removal efficiency across the STP most likely result from the growth of algae in the two settling basins. During the inspection the basins' waters were noticeably green. Calculated retention time for the two basins was about 95 days. Limiting the retention time in the basins may reduce algae growth, although this could also effect nutrient reduction.

Discharge Ditch

Little change was detected in TSS and TOC concentrations at the open channel 100 yards downstream of the effluent discharge (Table 2). Moderate increases in NH₃-N and large increases in NO₂+NO₃-N were seen at the same location. This may reflect a non-point discharge or the decomposition of algae and surrounding plant life in the channel.

NPDES Permit Comparisons

Table 3 compares inspection results to NPDES permit limits and compliance order limits. The compliance order acts as a guide for the Department of Ecology to exercise its prosecutorial discretion, but does not amend NPDES permit limits. This is intended to control discharges and still allow the present Medical Lake facility to continue operation until completion of the proposed facility upgrade.

Effluent BOD₅ and TSS concentrations and loads were all within compliance order monthly and weekly average limits (Table 4). Effluent loads for BOD₅ (32 lb/day & 28 lb/day) were all within NPDES permit limits (Table 3). The Ecology effluent TSS concentration and the Medical Lake effluent BOD₅ concentration failed to meet the NPDES monthly permit limit which restricts the effluent concentration to no more than 15% of the influent concentration if the influent concentration is less than 200 mg/L. The Ecology TSS effluent sample concentration was 67% and the Medical Lake BOD₅ effluent sample concentration was 20% of each respective influent concentration. The Medical Lake effluent sample produced a TSS load (78 lb/day) that exceeded the NPDES permit monthly average limit, but was within the weekly average limit. BOD₅ effluent concentrations were all greater than monthly NPDES permit limits, but within weekly average limits. TSS effluent concentrations were above both monthly and weekly NPDES permit limits. Effluent pH averaged 9.0 and exceeded the upper range of the permit limit by more than 6% (Table 3). The high pH is likely associated with the high algae population. It is suggested that Medical Lake determine the extent of this relationship.

An effluent flow rate of 0.09 MGD was well below the NPDES permit limit of 0.3 MGD (Table 3). The effluent fecal coliform count was well within compliance order and NPDES

permit limits. Ecology grab sample results were below detection and Medical Lake grab sample results were 20 and 40 colonies/100ml. Although chlorination achieved the desired fecal coliform levels, the total chlorine residual in the effluent composite sample was high (6.0 mg/L). A grab sample taken previous to the composite sample found total chlorine residual to be below detection (< 0.1 mg/L). Large variations in effluent chlorine residual concentrations appeared to have occurred. Chlorine concentration was also high in the open channel (0.6 mg/L). It is suggested that chlorine concentrations and contact time be modified to determine the lowest chlorine concentration which will achieve compliance with permit fecal coliform limits.

Split Samples

Sample Comparisons

Comparisons of the Ecology lab's results for all effluent samples and BOD₅ influent samples collected by Ecology and Medical Lake were good (*Table 4*). Medical Lake results were similar for the two effluent TSS samples and the two influent BOD₅ samples.

The Medical Lake laboratory effluent BOD₅ samples produced a relative percent difference of 39% between the Ecology and Medical Lake samples. Relative percent differences between the Medical Lake sample influent TSS and the Ecology sample influent TSS were 33% for Ecology lab results and 27% for the Medical Lake lab results. It is recommended that Medical Lake conduct influent composite or grab-composite sampling to improve representativeness.

Laboratory Comparisons

Agreement between Ecology and Medical Lake analytical results were mixed. Influent and effluent TSS results from both laboratories agreed closely (*Table 5*). Relative percent differences did not exceed 3% between influent pairs and 16% between effluent pairs.

BOD₅ composite influent and effluent comparisons were somewhat more divergent (*Table 4*). Medical Lake's influent results were generally higher, and effluent results generally lower than Ecology's results. Relative percent differences exceeded 50% between influent pairs and remained above 35% for any effluent pairs. It is reported that the lab performing the analyses does not dechlorinate BOD₅ samples before testing. Review of protocols for BOD₅ testing is advised.

The Medical Lake and the Ecology lab's fecal coliform results were similar, with the former reporting very low counts and the later reporting counts below detection (*Table 4*).

Testing for Medical Lake is currently performed by the city of Cheney Public Wastewater Treatment Plant Laboratory. This lab is not accredited. All testing laboratories need to be accredited by July 1, 1994 (173-220 WAC, 1992).

Wastewater Priority Pollutant Metals

Wastewater was analyzed for metals only. Arsenic, copper, selenium, and zinc were all detected in the effluent (*Table 5*). None exceeded either the EPA hardness adjusted water quality criteria for receiving waters (EPA, 1986) or the State of Washington Water Quality Standards for Surface Waters (173-201A WAC, 1992). Appendix E contains the results of all target metals.

Sludge

Characterization of lagoon sludge was done to determine its impact for potential land application. Kjeldahl-N concentrations for the sludge ranged from 10,100 - 22,000 mgN/Kg-dry wt. (*Table 1*). The composite total Kjeldahl-N concentration for all three basins was 20,700 mgN/Kg-dry wt. The calculated nitrogen limitation application rate based on nutrient uptake for selected field crops range from 1.8 to 7.3 tons dry solid/acre-year (Metcalf & Eddy, 1991). Assuming a sludge depth of one-third meter, a specific gravity of 1.01, and an average percent weight dry solids of 10%, the total weight of dry sludge from the three lagoons is approximately 1,654 tons. For a one time disposal to land under cultivation for wheat and alfalfa, this would require 227 and 918 acres of farmland, respectively.

Fecal coliform densities ranged from 450/100g-wet wt. (64 colonies/g - dry wt.) in lagoon #3 to an average of 1,400,000/100g-wet wt. (100,000/g - dry wt.) in lagoon #1 (*Table 1*). The later density exceeds the Class A pathogen limitation for the land application of municipal sewage sludge of 1,000/g-dry wt. (EPA, 1993 - 40 CFR Part 503). The composite sample density of 220,000/100g-wet wt. (36,700/g - dry wt.) exceeds the limitation by a factor of 36.

Sludge samples were analyzed for VOAs and BNAs as well as metals. Detected VOAs were all found in low concentrations (*Table 5*). Bis(2-Ethylhexyl)Phthalate was the BNA detected in the highest concentration (12,000 μ g/Kg-dry wt.). A complete list of target compounds and results is included in Appendix E. Tentatively identified compounds are presented in Appendix F.

Most priority pollutant metals were detected in all sludge samples (*Table 5*). None were detected in concentrations that exceeded the EPA metals criteria for the land application of municipal sludge (*Table 6*) (EPA, 1993).

References

- APHA, AWWA, WPCF, 1989. Standard Methods for the Examination of Water and Wastewater, 17th edition. American Public Health Association, Washington DC.
- Ecology, 1991. Manchester Environmental Laboratory, Laboratory Users Manual, Third Revision. Dickey Huntamer and Janet Hyre, Ed. Washington State Department of Ecology, 1991.
- 173-201A WAC, 1992. Water Quality Standards for Surface Waters of the State of Washington, Chapter 173-201A WAC. Washington State Administrative Code, 1992.
- 173-220 WAC, 1992. National Pollutant Discharge Elimination System Permit Program Chapter 173-220 WAC. Washington State Administrative Code, 1992.
- EPA, 1986. Quality Criteria for Water. EPA 440/5-86-001.
- EPA, 1993. Standards for the Use or Disposal of Sewage Sludge. Environmental Protection Agency, Federal Register 40 CFR Part 257 and Part 503, 1993
- Metcalf and Eddy, 1991. Wastewater Engineering Treatment Disposal Reuse, Third Edition. McGraw-Hill, New York.

Figure 2 - Class II Inspection, 1993
 Medical Lake Sewage Treatment Facility
 Facility Schematic




Table 1 - General Chemistry Results - Medical Lake Class II Inspection, 1993

Parameter I	Location:	Inf-E-1	Inf-E-2	Inf-E	Ef-pond-1	Ef-pond-2	Ef-E-1 & Ef-E-3	Ef-E-2 & Ef-E-4	Ef-E	Duplicate	Ef-M
Type:		grab	grab	comp	grab	grab	grab	grab	comp	comp	grab
Date:		09/21	09/21	09/21-22	09/21	09/21	09/21	09/21	09/21-22	09/21-22	09/22
Time:		0935	1710	@	1040	1045	1010	1725	@	@	1048
Lab Log #:		398130	398131	398132	398134	398135	398136 & 398138	398137 & 398139	398140	398149	398141
GENERAL CHEMISTRY											
Conductivity (umhos/cm)		810	759	750	709	869	602	603	609	601	805
Alkalinity (mg/L CaCO3)				270					207	207	209
Hardness (mg/L CaCO3)				125					143	140	144
SOLIDS											
TS (mg/L)				600 J	833 J				549 J	544 J	563 J
TNVS (mg/L)				311 J	308 J				306 J	304 J	335 J
TSS (mg/L)		125 J	140 J	144 J	200 J	83 J	68 J	42 J	96 J	100 J	109 J
TNVS (mg/L)				37 J	43 J				26 J	27 J	27 J
% Solids											
% Volatile Solids											
OXYGEN DEMAND PARAMETERS											
BOD5 (mg/L)				207					44	35	39
COD (mg/L)				422	435				369	231	238
TOC (water mg/L)		90.2	119	104	116	72.8	78.1	77.8	86.5	86.7	86.3
TOC (soil/seed - % C dry wt.)											
NUTRIENTS											
Total Kjeldahl-N (mg/L)											
Total Kjeldahl-N (soil/seed - mg N/Kg - dry wt.)											
NH3-N (mg/L)				25.5	32.7		0.459	1.46	0.135	0.763	1.59
NH3-N (soil/seed - mg N/Kg - dry wt.)											
NO2+NO3-N (mg/L)				0.080	0.078		0.510	0.481	0.487	0.496	0.471
NO2+NO3-N (soil/seed - mg N/Kg - dry wt.)											
Total-P (mg/L)				5.81	6.82		2.76	2.24	2.81	2.86	2.86
Total-P (soil/seed - mg/Kg - dry wt.)											
MISCELLANEOUS											
Oil and Grease (mg/L)											
F - Coliform MF (#/100mL)		32 J	41 J				3 J	2 J			
Faecal Coliform MPN (seed #/100g-wet)							3 U	3 U			
FIELD OBSERVATIONS											
Temperature (C)		16.7	17.1		11.0	10.7	11.0	12.1			10.1
Temp-cooled (C) +				3.4	15.2				4.1	4.3	
pH		8.3	7.8	8.0	8.6	8.9	9.1	9.0	9.2	9.2	9.2
Conductivity (umhos/cm)		807	774	798	786	672	626	616	630	618	614
Chlorine (mg/L)							<= 0.1		6.0	6.0	6.0

E Ecology sample
M Medical Lake sample
Inf Influent sample
Ef Effluent sample
grab Grab sample
comp Composite sample
ab/composite Grab - composite sample

Duplicate Duplicate of Ef-E sample for blind analysis
Pond-1 Lagoon #1 effluent
Pond-2 Lagoon #2 effluent
J The analyte was positively identified. The associated numerical value is an estimate.
U The analyte was not detected at or above the reported result.
@ 24-hour composite sample period: 07:00-07:00
*+ Refrigerated sample

Table 1 - General Chemistry Results - Medical Lake Class II Inspection, 1993

Parameter II	Location	Out-E	Sludge-2	Sludge-3	Matrix-1	Matrix-2	Matrix-3	Sludge-123
	Type:	grab	grab/comp	grab/comp	grab	grab	grab	grab/comp
	Date:	09/22	09/21	09/21	09/21	09/21	09/21	09/21
	Time:	1115	1130	1330	1415	1430	1450	1520
	Lab Log #:	398142	398143	398144	398145	398146	398147	398148
GENERAL CHEMISTRY								
Conductivity (umhos/cm)		601						
Alkalinity (mg/L CaCO3)		209						
Hardness (mg/L CaCO3)		148						
SOLIDS 4								
TS (mg/L)								
TNVS (mg/L)								
TSS (mg/L)								
TNVS (mg/L)								
% Solids			8.0	7.0	11.0	14.0	17.0	6.0
% Volatile Solids			2.8	2.2	3.0	3.5	3.6	2.3
OXYGEN DEMAND PARAMETERS								
BOD5 (mg/L)								
COD (mg/L)								
TOC (water mg/L)		83.2						
TOC (soil/seed - % C dry wt)			11.7	12.3	10.6	7.78	7.66	12.9
NUTRIENTS								
Total Kjeldahl-N (mg/L)								
Total Kjeldahl-N (soil/seed - mg N/Kg -dry wt)			22,000	17,200	15,300	18,200	10,100	20,700
NH3-N (mg/L)		2.27						
NH3-N (soil/seed - mg N/Kg -dry wt)			875	735	798	1,160	530	1,580
NO2+NO3-N (mg/L)		4.75						
NO2+NO3-N (soil/seed - mg N/Kg -dry wt)			6.7	5.2	4.6	3.8	2.4	5.9
Total-P (mg/L)		2.75						
Total-P (soil/seed - mg/Kg -dry wt)			2,820	3,980	2,080	2,150	1,790	4,170
MISCELLANEOUS								
Oil and Grease (mg/L)								
F - Coliform MF (#/100mL)		17						
Fecal Coliform MPN (seed #/100g - wet)			33,000	450	1,100,000	330,000	2,800,000	220,000
FIELD OBSERVATIONS								
Temperature (C)		12.8						
Temp - cooled (C)++								
pH		8.6						
Conductivity (umhos/cm)		601						
Chlorine (mg/L)		0.6						
<p>Sludge 2 Sludge composite sample from Lagoon #2</p> <p>Sludge 3 Sludge composite sample from Lagoon #3</p> <p>Matrix Sludge samples from a matrix in pond #1</p> <p>Sludge-123 Composite sludge sample from all three lagoons</p> <p>grab/composite Grab - composite sample</p> <p>++ Refrigerated sample</p>								
<p>J The analyte was positively identified. The associated numerical value is an estimate</p> <p>Out Outfall into channel which flows to Deep Creek</p> <p>grab Grab sample</p> <p>comp Composite sample</p>								

Table 2 - General Chemistry Percent Reduction - Medical Lake Class II Inspection, 1993

Parameter I	Location:	Inf-E	Ef-Pond-1	Percent Reduction Across Pond-1	Ef-pond-2	Percent Reduction Across Pond-2	Percent Reduction Across Pond-3	Ecology Percent Reduction Across STP	Out-E	Percent Reduction In Ditch*	Inf-M	Ef-M	Medical Lake Percent Reduction Across STP
	Type: Date: Time: Lab Log #:	comp 09/21-22 @ 398132	grab 09/21 1040 398134		grab 09/21 1045 398135				grab 09/22 1115 398142		grab 09/22 0915 398133	grab 09/22 1048 398141	
GENERAL CHEMISTRY													
Alkalinity (mg/L CaCO ₃)		270						23%	209	-1%	318	209	34%
Hardness (mg/L CaCO ₃)		125						-14%	148	-3%	128	144	-13%
SOLIDS 4													
TSS (mg/L)		144 J	78 J	46%	83 J	-6%	-16%	33%	100 J	-4%	200 J	109 J	46%
OXYGEN DEMAND PARAMETERS													
BOD ₅ (mg/L)		207						79%			196	39	60%
COD (mg/L)		422						13%			435	238	45%
TOC (water mg/L)		104	59	43%	73	-23%	-22%	15%	83	6%	116	86	26%
NUTRIENTS													
NH ₃ -N (mg/L)		26						99%	2	-1581%	33	2	95%
NO ₂ +NO ₃ -N (mg/L)		0.08						-509%	4.75	-875%	0.078	0.471	-504%
Total-P (mg/L)		6						52%	3	2%	7	3	57%

E Ecology sample
M Medical Lake sample
Inf Influent sample
Ef Effluent sample
grab Grab sample
comp Composite sample
grab/composite Grab - composite sample

Out Outfall into Deep Creek
J The analyte was positively identified. The associated numerical value is an estimate.
Pond-1 Lagoon #1 effluent - South Lagoon
Pond-2 Lagoon #2 effluent - East Lagoon
***** 100 yards downstream from chlorine contact chamber discharge.
@ 24-hour composite sample period: 07:00-07:00

Table 3 – NPDES Limits Inspection Results – Medical Lake, 1993

Parameter	NPDES Permit Limits		NPDES Compliance Order Limits*		Inspection Data					
	Monthly Average	Weekly Average	Monthly Average	Weekly Average	Ecology Composite	STP Composite	STP Composite	STP Composite		
BOD5 (mg/L) (lbs/D)	30 75	45 113	85 215	105 265	Inf-E comp 09/21-22 @ 398132	Inf-M grab 09/22 0915 398133	Ef-M grab 09/22 1048 398141	Ef-E-1 & Ef-E-3 grab 09/21 1725 398136 & 398138	Ef-E-2 & Ef-E-4 grab 09/21 1115 398137 & 398139	Out-E grab 09/22 1115 398142
% of Influent	Monthly and weekly average effluent BOD5 concentration shall be 15% of influent BOD5 concentration if influent BOD5 concentration is 200 mg/L or less.	Monthly and weekly average effluent BOD5 concentration shall not exceed 100 mg/L or 42% of influent concentration**	Monthly average effluent BOD5 concentration shall not exceed 100 mg/L or 42% of influent concentration**	Monthly average effluent BOD5 concentration shall not exceed 100 mg/L or 42% of influent concentration**	207 148	44 32 21	196 141	39 28 20		
TSS (mg/L) (lbs/D)	30 75	45 113	115 290	160 400	144 J 103	96 J 69 67	200 J 143	109 78 55		
Fecal coliform (#/100 mL)	200	400	200	400	0.086	0.086	0.086	0.086	3 U	3 U
pH (S.U.)	6.5 < pH < 8.5	6.5 < pH < 8.5	6.5 < pH < 8.5	6.5 < pH < 8.5					9.1	9.0
Flow (MGD)	0.3									
Total Chlorine Residual (mg/L)	N.A.	N.A.	Total residual chlorine shall be maintained at a level sufficient to attain fecal coliform limits.	Total residual chlorine shall be maintained at a level sufficient to attain fecal coliform limits.	0.086	0.086	0.086	0.086	6.0	6.0

E Ecology sample
M Medical Lake sample
Inf Influent sample
Ef Effluent sample
grab Grab sample
comp Composite sample
grab/Grab -composite sample

Out Outfall into Deep Creek
J The analyte was positively identified. The associated numerical value is an estimate.
U The analyte was not detected at or above the reported result.
* Administrative order in effect December 31, 1991.
** The 100 mg/L monthly limit represents a discrepancy with the compliance order's previous 85 mg/L monthly limit.
@ 24-hour composite sample period: 07:00-07:00
Exceeds monthly average permit limit

Table 4 – Split Sample Result Comparison – Medical Lake, 1993

Parameter		Location:	Inf-E	Inf-M	EF-E	EF-M	Ef-E-3	Ef-E-4
		Type:	comp	grab	comp	grab	grab	grab
		Date:	09/21-22	09/22	09/21-22	09/22	09/21	09/21
		Time:	@	0915	@	1048	1010	1725
		Lab Log #:	398132	398133	398140	398141	398138	398139
TSS (mg/L)	Laboratory							
	Ecology		144 J	200 J	96 J	109 J		
	Medical Lake		149	195	93.3	92.7		
BOD5 (mg/L)	Ecology		207	196	44	39		
	Medical Lake		354	352	31	20.8		
Fecal Coliform (#/100 ml)	Ecology						3 U	3 U
	Medical Lake						20	40

@ 24 hour composite. Collection period: 0700 – 0700.
 Inf Influent samples.
 Ef STP effluent
 Comp composite sample
 grab/comp Grab composite sample

E Ecology Sample
 M Medical Lake Sample
 J The analyte was positively identified. The associated numerical value is an estimate.
 U The analyte was not detected at or above the reported result.

Table 5 - Detected VOAs, BNAs, PEST/PCBS, and METALS - Medical Lake, 1993

Parameters		Location:		Sludge-123		EPA Water Quality	
Type:	Date:	grab/comp	09/15	Criteria Summary		Acute	Chronic
Time:	Lab Log#:	1520	398148			Fresh	Fresh
VOA Compounds		ug/Kg - dry wt.		(ug/L)		(ug/L)	
Acetone		94					
Carbon Disulfide		72					
Benzene		20				5,300 *	
Toluene		22				17,500 *	
Total Xylenes		16 J					

Parameters		Location:		Sludge-123		EPA Water Quality	
Type:	Date:	grab/comp	09/15	Criteria Summary		Acute	Chronic
Time:	Lab Log#:	1520	398148			Fresh	Fresh
BNA Compounds		ug/Kg - dry wt.		(ug/L)		(ug/L)	
Bis(2-Ethylhexyl)Phthalate		12,000 J		940 *		3 *(i)	

Parameters		Location:		Matrix-3		EPA and Ecology	
Type:	Date:	grab/comp	09/21	Water Quality		Acute	Chronic
Time:	Lab Log#:	1520	398147	Criteria Summary		Fresh c	Fresh d
Metals		ug/L		mg/Kg - dry wt.		(ug/L)	
Hardness = 140							
Arsenic		3.77		4.07		360.0 c	190.0
Beryllium		0.26 P		0.34 P		130 *	5.3 *
Cadmium		4.59		3.03		5.0 +	1.3 +
Chromium		17.7		14.4			
Hexavalent Trivalent							
Copper		228		149		16	11
Lead		47.3		58.5		2,287 +	273 +
Mercury		2.98 P		0.994		21.0 +	13.6 +
Nickel		14.2		11.1		86 +	3.4 +
Selenium		2.6 P		2.1 P		2.4	0.012
Silver		6.5		1.5 P		1,791 +	199 +
Zinc		459		401		20.0	5.0

@ Composite sample period: 07:00-07:00
 Inf Influent Sample
 Ef Effluent Sample
 E Ecology Sample
 Sludge-2 Sediment sample from lagoon #2
 Sludge-3 Sediment sample from lagoon #3
 Matrix Composite of three sediment samples from lagoon #1
 Sludge-123 Combined sediment samples from lagoons 1, 2, & 3.
 Duplicate Blind duplicate of EF-E sample
 i Total Phthalate Esters
 B Analytes was found in the analytical methods blank, indicating the sample may have been contaminated.
 J The analyte was positively identified. The associated numerical result is an estimate.
 N The spike sample recovery was not within control limits.
 P The analyte was detected above the instrument detection level, but below the established minimum quantization limits.
 U The analyte was not detected at or above the reported result
 UU The analyte was not detected at or above the reported result
 * Parameters exceeding EPA and state water quality criteria
 † Insufficient data to develop criteria. The value presented is the LOEL - Lowest Observable Effects Level
 c A 1-hour average concentration not to be exceeded every three years on the average
 d A 4-day average concentration not to be exceeded every three years on the average
 ‡ Hardness dependent criteria (140 mg/L)
 § Water samples: Total Recoverable, Sludge samples & Hg: Total

Table 6 – EPA Metals Concentration Criteria for the Land Application of Municipal Sludge – Medical Lake, 1993

Parameter	Location: Type: Date: Time: Lab Log #:	Sludge-2	Sludge-3	Matrix-1	Matrix-2	Matrix-3	Sludge-123	EPA Standards for Disposal of Sewage Sludge	
		grab/comp 9/21 @ 398143	grab/comp 9/21/1993 @ 398144	grab 9/21 1415 398145	grab 9/21 1430 398146	grab 9/21 1450 398147	grab/comp 9/21/1993 1520 398148	Ceiling Concentrations *	Pollutant Concentrations **
		(mg/Kg-dry wt.)	(mg/Kg-dry wt.)	(mg/Kg-dry wt.)	(mg/Kg-dry wt.)	(mg/Kg-dry wt.)	(mg/Kg-dry wt.)	(mg/Kg-dry wt.)	(mg/Kg-dry wt.)
Metals									
Arsenic		4.17	3.29	4.68	4.96	4.07	3.77	75	41
Cadmium		4.62	1.7 P	3.44	4.35	3.03	4.59	85	39
Chromium		13.6	11.2	15	15.7	14.4	17.7	3000	1200
Copper		249	125	179	213	149	228	4300	1500
Lead		50.1	21.8	67.2	88.5	58.5	47.3	840	300
Mercury		3.09 P	0.443 P	1.20	1.02	0.994	0.298	57	17
Molybdenum								75	18
Nickel		11	12	12	12.7	11.1	14.2	420	420
Selenium		3.1 P	1.4 P	2 P	2.1 P	1.4 P	2.6 P	100	36
Zinc		496	221	444	542	401	459	7500	2800
Sludge -123	Composite sludge sample from all three lagoons				P				
Sludge-2	Sediment sample from Lagoon #2								
Sludge-3	Sediment sample from Lagoon #3								
Matrix	Sediment sample from Lagoon #1								
grab/comp	Grab -composite sample								
*	Ceiling concentration limit for bulk sewage sludge or for sewage sludge sold or given away in a bag or other container.								
**	Pollutant concentration limit of bulk sewage sludge if it is applied to agricultural land, forest land, a public contact site, or a reclamation site.								

Appendices

Appendix A - Sampling Stations Description - Medical Lake, 1993

Inf-E-1&2	Grab sample of influent wastewater collected from the headwork diverter box - Collected in both A.M. and P.M..
Inf-E	Ecology 24-hour composite sample of influent wastewater collected from the headwork's wetwell.
Inf-M	Medical lake grab sample of influent wastewater collected from the headwork diverter box.
Ef-pond-1	Grab sample of Lagoon #1 effluent taken from discharge pipe into lagoon# 2.
Ef-pond-2	Grab sample of Lagoon #2 effluent taken from transfer box at discharge into lagoon #3.
Ef-E-1&2	Grab sample of effluent from the weir overflow at the end of the chlorine contact chamber.
Ef-E-3&4	Fecal coliform grab sample of effluent from the weir overflow at the end of the chlorine contact chamber.
Ef-E	Ecology 24-hour composite sample collected from the weir overflow at the end of the chlorine contact chamber.
Ef-M	Medical Lake effluent grab sample collected from the weir overflow at the end of the chlorine contact chamber.
Out-E	Grab sample taken from the open channel to Deep Creek approximately 150 ft downstream from the weir overflow at the end of the chlorine contact chamber.
Sludge-2	Composite sample of bottom sludge collected from three locations in lagoon #2
Sludge-3	Composite sample of bottom sludge collected from three locations in lagoon #3
Matrix-#	Individual bottom sludge samples collected in a matrix pattern from lagoon #1
Sludge-123	Composite sample of bottom sludge collected from the centers of all three lagoons.
Duplicate	Duplicate of effluent sample for blind analysis.

Appendix B - Sample Schedule - Medical Lake Class II Inspection, 1993

Parameter	Location:	Inf-E-1	Inf-E-2	Inf-E	Inf-M	Ef-pond-1	Ef-pond-2	Ef-E-1 & Ef-E-3	Ef-E-2 & Ef-E-4	Ef-E	Ef-M	Out-E
Type:		grab	grab	comp	grab	grab	grab	grab	grab	comp	grab	grab
Date:		09/21	09/21	09/21-2	09/22	09/21	09/21	09/21	09/21	09/21-2	09/22	09/22
Time:		0935	1710	@	0915	1040	1045	1010	1725	@	1048	1115
Lab Log #:		398130	398131	398132	398133	398134	398135	398136 & 398138	398137 & 398139	398140	398141	398142

GENERAL CHEMISTRY

Conductivity	E	E	E	E	E	E	E	E	E	E	E	E
Alkalinity	E	E	E	E	E	E	E	E	E	E	E	E
Hardness	E	E	E	E	E	E	E	E	E	E	E	E
SOLIDS-4												
TS	E	E	E	E	E	E	E	E	E	E	E	E
TNVS	E	E	E	E	E	E	E	E	E	E	E	E
TSS	E	E	EM	EM	EM	E	E	E	E	EM	EM	E
TNVS	E	E	E	E	E	E	E	E	E	E	E	E
% Solids												
% Volatile Solids												

OXYGEN DEMAND PARAMETERS

BOD5	EM	EM	EM	EM	EM	EM	EM	EM	EM	EM	EM	EM
COD	E	E	E	E	E	E	E	E	E	E	E	E
TOC (water)	E	E	E	E	E	E	E	E	E	E	E	E
TOC (soil/seed)												

NUTRIENTS

Total Kjeldahl N												
NH3-N	E	E	E	E	E	E	E	E	E	E	E	E
NO2+NO3-N	E	E	E	E	E	E	E	E	E	E	E	E
Total-P	E	E	E	E	E	E	E	E	E	E	E	E

MISCELLANEOUS

Oil and Grease (water)	E	E	E	E	E	E	E	E	E	E	E	E
F - Coliform MF												
F - Coliform (soil/seed)												

ORGANICS

VOC (soil/seed)												
BNAs (soil/seed)												
METALS												
PP Metals (water)												
PP Metals (soil/seed)												

FIELD OBSERVATIONS

Temperature	E	E	E	E	E	E	E	E	E	E	E	E
Temp-cooled*+												
pH	E	E	E	E	E	E	E	E	E	E	E	E
Conductivity	E	E	E	E	E	E	E	E	E	E	E	E
Chlorine												

E Ecology analysis
M Medical Lake analysis
Inf Influent sample
Ef Effluent sample
grab Grab sample
comp Composite sample
grab/composite Grab - composite sample

Out Outfall into channel which flows to Deep Creek
Pond-1 Lagoon #1 effluent
Pond-2 Lagoon #2 effluent
@ 24-hour composite sample period: 07:00-07:00
*+ Refrigerated sample

Appendix B - Sample Schedule - Medical Lake Class II Inspection, 1993

Parameter II	Location	Sludge-2	Sludge-3	Matrix-1	Matrix-2	Matrix-3	Sludge-12	Duplicate
GENERAL CHEMISTRY								
Conductivity								E
Alkalinity								E
Hardness								E
SOLIDS-4								
TS								E
TSS								E
TNVS								E
% Solids		E	E	E	E	E	E	E
% Volatile Solids		E	E	E	E	E	E	E
OXYGEN DEMAND PARAMETERS								
BOD5								E
COD								E
TOC (water)								E
TOC (soil/sed)		E	E	E	E	E	E	E
NUTRIENTS								
Total Kjeldahl N		E	E	E	E	E	E	E
NH3-N		E	E	E	E	E	E	E
NO2+NO3-N		E	E	E	E	E	E	E
Total-P		E	E	E	E	E	E	E
MISCELLANEOUS								
Oil and Grease (water)								E
F - Coliform MF								E
F - Coliform (soil/sed)		E	E	E	E	E	E	E
ORGANICS								
VOC (soil/sed)								E
BNAs (soil/sed)								E
METALS								
PP Metals (water)								E
PP Metals (soil/sed)		E	E	E	E	E	E	E
FIELD OBSERVATIONS								
Temperature								E
Temp - cooled*+								E
pH								E
Conductivity								E
Chlorine								E

Sludge 2 Sludge composite sample from Lagoon #2 Duplicate Grab sample Duplicate of previous sample for blind analysis
 Sludge 3 Sludge composite sample from Lagoon #3 Sludge sample Composite sample
 Matrix Sludge samples from a matrix in pond #1 Composite sample
 Sludge-123 Composite sludge sample from all three lagoons 24-hour composite sample period: 07:00-07:00
 grab/composite Grab - composite sample
 *+ Refrigerated sample

Appendix C – Analytic Methods – Medical Lake, 1993

PARAMETER	MANCHESTER_METHODS	LAB USED
GENERAL CHEMISTRY		
Conductivity	EPA, Revised 1983: 120.1	Ecology
Alkalinity	EPA, Revised 1983: 310.1	Ecology
Hardness	EPA, Revised 1983: 130.2	Ecology
SOLIDS-4		
TS	EPA, Revised 1983: 160.3	Ecology
TNVS	EPA, Revised 1983: 160.3	Ecology
TSS	EPA, Revised 1983: 160.2	Ecology
TNVSS	EPA, Revised 1983: 160.2	Ecology
% Solids	APHA, 1989: 2540G.	Ecology
% Volatile Solids	EPA, Revised 1983: 160.4	Ecology
OXYGEN DEMAND PARAMETERS		
BOD5	EPA, Revised 1983: 405.1	Ecology
COD	EPA, Revised 1983: 410.1	Analytical Resources, Inc.
TOC (water)	EPA, Revised 1983: 415.1	Analytical Resources, Inc.
TOC (soil/sed)	EPA, Revised 1983: 415.1	Analytical Resources, Inc.
NUTRIENTS		
Total Kjeldahl N	EPA, Revised 1983: 351.3	Analytical Resources, Inc.
NH3-N	EPA, Revised 1983: 350.1	Analytical Resources, Inc.
NO2+NO3-N	EPA, Revised 1983: 353.2	Analytical Resources, Inc.
Total-P	EPA, Revised 1983: 365.3	Analytical Resources, Inc.
MISCELLANEOUS		
Oil and Grease (water)	EPA, Revised 1983: 413.1	Ecology
F-Coliform MF	APHA, 1989: 9222D.	Ecology
F-Coliform (soil/sed)	APHA, 1989: 9221A.	Ecology
ORGANICS		
VOC (soil/sed)	EPA, 1986: 8240	Analytical Resources, Inc.
BNAs (soil/sed)	EPA, 1986: 8270	Analytical Resources, Inc.
METALS		
PP Metals (water)	EPA, Revised 1983: 200-299	Ecology
PP Metals (soil/sed)	EPA, Revised 1983: 200-299	Ecology

METHOD BIBLIOGRAPHY

APHA-AWWA-WPCF, 1989. Standard Methods for the Examination of Water and Wastewater, 17th Edition.
 EPA, Revised 1983. Methods for Chemical Analysis of Water and Wastes, EPA-600/4-79-020 (Rev. March, 1983).
 EPA, 1986: SW846. Test methods for Evaluating Solid Waste Physical/Chemical Methods. SW-846, 3rd ed., November, 1986

Appendix D - Medical Lake Class II Inspection, 1993

Priority Pollutant Metal Cleaning Procedures for Wastewater Collection Equipment.

1. Wash with laboratory detergent
2. Rinse several times with tap water
3. Rinse with 10% HNO₃ solution
4. Rinse three (3) times with distilled/deionized water
5. Allow to dry and seal with aluminum foil

Priority Pollutant Cleaning Procedures for Sludge Collection Equipment.

1. Wash with laboratory detergent
2. Rinse several times with tap water
3. Rinse with 10% HNO₃ solution
4. Rinse three (3) times with distilled/deionized water
5. Rinse with high purity methylene chloride
6. Rinse with high purity acetone
7. Allow to dry and seal with aluminum foil

Specific QA/QC concerns

1. Water sample Procedural blanks detected the presence of arsenic and copper. The laboratory qualified these data with the "B" qualifier to indicate blank contamination when sample levels are less than ten times blank levels.
2. Sludge sample spike recoveries for antimony and thallium were outside of the CLP accepted limits. Antimony also exhibited a Relative Percent Difference (RPD) for precision and a Laboratory Control Sample (LCS) analysis outside the acceptable limits. Results for these elements are qualified with "N" or "J" depending on the severity of interferences found.
3. Semi-volatiles were extracted eight days past the SW-846 recommended holding times, but were analyzed within the 40 day extraction holding time. Detected results have been qualified with a "J" and non-detected analytes with a "UJ".
4. Semi-volatile analyses found matrix spike recovery for two compounds exceeded advisory QC limits. Results have already been qualified by "J" for holding time violations.
5. During the analyses of solids Manchester laboratory experienced a spill of phenol in their weighing room. This precluded the use of that room for weighing samples and weighing was done in a room without regulated humidity. This may have allowed some absorption of moisture during the weighing, slightly compromising the results. Consequently the lab has qualified all solids results with the "J" qualifier indicating that they are an estimate.

Appendix E - VOA and BNA Scan Results - Medical Lake, 1993.

Parameters	Location:	Sludge-123
	Type:	grab/comp
	Date:	09/21
	Time:	1520
	Lab Log#:	398148

VOA Compounds	ug/Kg-dry wt.
Chloromethane	32 U
Bromomethane	32 U
Vinyl Chloride	32 U
Chloroethane	32 U
Methylene Chloride	32 U
Acetone	94
Carbon Disulfide	72
1,1-Dichloroethene	16 U
1,1-Dichloroethane	16 U
trans-1,2-Dichloroethene	16 U
cis-1,2-Dichloroethene	16 U
Chloroform	16 U
1,2-Dichloroethane	16 U
2-Butanone (MEK)	81 U
1,1,1-Trichloroethane	16 U
Carbon Tetrachloride	16 U
Vinyl Acetate	16 U
Bromodichloromethane	16 U
1,2-Dichloropropane	16 U
cis-1,3-Dichloropropene	16 U
Trichloroethene	16 U
Dibromochloromethane	16 U
1,1,2-Trichloroethane	16 U
Benzene	20
trans-1,3-Dichloropropene	16 U
2-Chloroethylvinyl Ether	16 U
Bromoform	16 U
4-Methyl-2-Pentanone (MIBK)	81 U
2-Hexanone	81 U
Tetrachloroethene	16 U
1,1,2,2-Tetrachloroethane	16 U
Toluene	22
Chlorobenzene	16 U
Ethylbenzene	16 U
Styrene	16 U
Total Xylenes	16 J
Trichlorofluoromethane	32 U
1,1,2-Trichlorotrifluoroethane	32 U

U The analyte was not detected at or above the reported result.
 J The analyte was positively identified. The associated numerical result is an estimate.
 Sludge-123 Composite grab sample from each of the three lagoons.
 grab/comp Grab composite sample
 Detected Parameters

Appendix E - VOA and BNA Scan Results - Medical Lake, 1993.

Parameters	Location:	Sludge-123
	Type:	grab/comp
	Date:	09/21
	Time:	1520
	Lab Log#:	398148

BNA Compounds	ug/Kg-dry wt.
Phenol	13,000 UJ
Bis(2-Chloroethyl)Ether	13,000 UJ
2-Chlorophenol	13,000 UJ
1,3-Dichlorobenzene	13,000 UJ
1,4-Dichlorobenzene	13,000 UJ
Benzyl Alcohol	33,000 UJ
1,2-Dichlorobenzene	13,000 UJ
2-Methylphenol	13,000 UJ
Bis(2-Chloroisopropyl)Ether	13,000 UJ
4-Methylphenol	13,000 UJ
N-Nitroso-di-n-Propylamine	13,000 UJ
Hexachloroethane	13,000 UJ
Nitrobenzene	13,000 UJ
Isophorone	13,000 UJ
2-Nitrophenol	33,000 UJ
2,4-Dimethylphenol	13,000 UJ
Benzoic Acid	67,000 UJ
Bis(2-Chloroethoxy)Methane	13,000 UJ
2,4-Dichlorophenol	20,000 UJ
1,2,4-Trichlorobenzene	13,000 UJ
Naphthalene	13,000 UJ
4-Chloroaniline	20,000 UJ
Hexachlorobutadiene	13,000 UJ
4-Chloro-3-Methylphenol	13,000 UJ
2-Methylnaphthalene	13,000 UJ
Hexachlorocyclopentadiene	33,000 UJ
2,4,6-Trichlorophenol	33,000 UJ
2,4,5-Trichlorophenol	33,000 UJ
2-Chloronaphthalene	13,000 UJ
2-Nitroaniline	33,000 UJ
Dimethyl Phthalate	13,000 UJ
Acenaphthylene	13,000 UJ
3-Nitroaniline	33,000 UJ
Acenaphthene	13,000 UJ
2,4-Dinitrophenol	67,000 UJ
4-Nitrophenol	67,000 UJ
Dibenzofuran	13,000 UJ
2,6-Dinitrotoluene	33,000 UJ
2,4-Dinitrotoluene	33,000 UJ
Diethyl Phthalate	33,000 UJ

U The analyte was not detected at or above the reported result.

J The analyte was positively identified. The associated numerical result is an estimate.

Sludge-123 Composite grab sample from each of the three lagoons.

grab/comp Grab composite sample

Appendix E - VOA and BNA Scan Results - Medical Lake, 1993.

Parameters	Location:	Sludge-123
	Type:	grab/comp
	Date:	09/21
	Time:	1520
	Lab Log#:	398148

BNA Compounds	ug/Kg-dry wt.
4-Chlorophenyl Phenylether	13,000 UJ
Fluorene	13,000 UJ
4-Nitroaniline	33,000 UJ
4,6-Dinitro-2-Methylphenol	67,000 UJ
N-Nitrosodiphenylamine	13,000 UJ
4-Bromophenyl Phenylether	13,000 UJ
Hexachlorobenzene	13,000 UJ
Pentachlorophenol	33,000 UJ
Phenanthrene	13,000 UJ
Carbazole	13,000 UJ
Anthracene	13,000 UJ
Di-n-Butyl Phthalate	13,000 UJ
Fluoranthene	13,000 UJ
Pyrene	13,000 UJ
Butylbenzyl Phthalate	13,000 UJ
3,3'-Dichlorobenzidine	33,000 UJ
Benzo(a)Anthracene	13,000 UJ
Bis(2-Ethylhexyl)Phthalate	12,000 J
Chrysene	13,000 UJ
Di-n-Octyl Phthalate	13,000 UJ
Benzo(b)Fluoranthene	13,000 UJ
Benzo(k)Fluoranthene	13,000 UJ
Benzo(a)Pyrene	13,000 UJ
Indeno(1,2,3-cd)Pyrene	13,000 UJ
Dibenzo(a,h)Anthracene	13,000 UJ
Benzo(g,h,i)Perylene	13,000 UJ

U The analyte was not detected at or above the reported result.
 J The analyte was positively identified. The associated numerical result is an estimate.
 Sludge-123 Composite grab sample from each of the three lagoons.
 grab/comp Grab composite sample
 Detected Parameters

Appendix F - Metals Scan Results - Medical Lake, 1993

Parameters	Location	Inf-E	Ef-E	Duplicate	Sludge-2	Sludge-3	Matrix-1	Matrix-2	Matrix-3	Sludge-123
	Type:	comp	comp	comp	grab/comp	grab/comp	grab	grab	grab	grab/comp
	Date:	09/21-22	09/21-22	09/21-22	09/21	09/21	09/21	09/21	09/21	09/21
	Time:	@	@	@	1130	1330	1415	1430	1450	1520
Lab Log #		398132	398140	398149	398143	398144	398145	398146	398147	398148
	ug/L		ug/L	ug/L	mg/Kg-dry wt.	mg/Kg-dry wt.	mg/Kg-dry wt.	mg/Kg-dry wt.	mg/Kg-dry wt.	mg/Kg-dry wt.
Metals										
Antimony		30 U	30 U	30 U	3 U	3 UJ	3 UJ	3 UJ	3 UJ	3 UJ
Arsenic		2.2 PB	2.6 PB	1.5 PB	4.17	3.29	4.68	4.96	4.07	3.77
Beryllium		1 U	1 U	1 U	0.28 P	0.30 P	0.36 P	0.37 P	0.34 P	0.26 P
Cadmium		0.82 P	0.10 U	0.10 U	4.62	1.7 P	3.44	4.35	3.03	4.59
Chromium		5 U	5 U	5 U	13.6	11.2	15	15.7	14.4	17.7
Copper		43.3	7.6 PB	11 PB	249	125	179	213	149	228
Lead		3.9 P	1.0 U	1.0 U	50.1	21.8	67.2	88.5	58.5	47.3
Mercury		0.37 P	0.051 U	0.05 U	3.09 P	0.443 P	1.20	1.02	0.994	2.98 P
Nickel		10 U	10 U	10 U	11	12	12	12.7	11.1	14.2
Selenium		2.0 U	3.6 P	2.0 U	3.1 P	1.4 P	2.0 P	2.1 P	1.4 P	2.6 P
Silver		0.50 U	0.50 U	0.50 U	7.36	2 P	2.3 P	3.14	1.5 P	6.5
Thallium		2.5 U	2.5 U	2.5 U	0.50 UN	0.50 UN	0.05 UN	0.50 UN	0.05 UN	0.05 UN
Zinc		84.9	4.7	4 U	496	221	444	542	401	459

@ Composite sample period: 07:00-07:00
 Inf Influent Sample
 Ef Effluent Sample
 E Ecology Sample
 Sludge-2 Sediment sample from lagoon #2
 Sludge-3 Sediment sample from lagoon #3
 Matrix Composite sediment sample from lagoon #1
 Sludge-123 Combined sediment samples from lagoons 1, 2, & 3.
 Duplicate Blind duplicate of EF-E sample

B Analytes was found in the analytical methods blank, indicating the sample may have been contaminated.
 J The analyte was positively identified. The associated numerical result is an estimate.
 N The spike sample recovery was not within control limits.
 P The analyte was detected above the instrument detection level, but below the established minimum quantitation limits.
 U The analyte was not detected at or above the reported result
 UU The analyte was not detected at or above the reported estimated result.
 Detected parameters

Appendix G - Tentatively Identified Compounds - Medical Lake, 1993

Sample Location: Sludge-123
 Type: grab/comp
 Date: 9/21/93
 Time: 1520
 Sample ID: 398148

Volatile Organics:

Compound Name	Estimated Concentration ($\mu\text{g}/\text{Kg-dry wt.}$)	Qualifier
1. Unknown (b.p. m/e 207)	110	J
2. Silane Isomer (b.p. m/e 281)	150	JN
3. Unknown Hydrocarbon (b.p. m/e 57)	260	JN
4. Unknown Hydrocarbon (b.p. m/e 57)	440	JN
5. 7-Dimethyl-Undecane C13.H28 (b.p. m/e 57)	480	JN
6. Unknown Hydrocarbon (b.p. m/e 57)	710	JN
7. 1-Methyl-4-(1-Methylethenyl)-Cyclohexene C10.H16	290	JN
8. 8-Dimethyl-Undecane C13.H28 (b.p. m/e 57)	130	JN
9. Unknown Hydrocarbon (b.p. m/e 57)	270	JN
10. Trimethyl-Dodecane (b.p. m/e 57)	480	JN

Sample Location: Sludge-123
 Type: grab/comp
 Date: 9/21/93
 Time: 1520
 Sample ID: 398148

BNAs:

Compound Name	Estimated Concentration ($\mu\text{g}/\text{Kg-dry wt.}$)	Qualifier
1. 2,7,10-Trimethyl-Dodecane (b.p. m/e 57)	34000	JN
2. Unknown Hydrocarbon (b.p. m/e 57)	22000	JN
3. Unknown Hydrocarbon (b.p. m/e 69)	20000	JN
4. Unknown (b.p. m/e 69)	41000	J
5. Unknown (b.p. m/e 55)	100000	J
6. Unknown (b.p. m/e 43)	140000	J
7. Unknown (b.p. m/e 231)	39000	J
8. Unknown (b.p. m/e 43)	14000	J
9. Unknown (b.p. m/e 43)	15000	J
10. Unknown (b.p. m/e 43)	37000	J
11. Unknown (b.p. m/e 43)	39000	J
12. Unknown (b.p. m/e 43)	28000	J
13. 3,3-Thiobis-,Didodecyl Ester Propanoic Acid	340000	J

J The analyte was positively identified. The associated numerical result is an estimate.

JN The analyte was tentatively identified. The associated numerical result is an estimate

Appendix H - GLOSSARY

ABN	Acid base-neutral, semivolatile organics, see BNA
AED	Atomic Emission Detector
BNA	Base-neutral acids, semivolatiles, see ABN
BOD	Biological Oxygen Demand
CLP	Contract Laboratory Program
COD	Chemical Oxygen Demand
co-elutants	When two or more compounds have the same chromatographic retention time
CVAA	Cold Vapor Atomic Absorption
d-deuterium	An isotope of hydrogen
DL	Detection Limit
DOC	Dissolved Organic Carbon
DW	Dangerous Waste
ECD	Electron Capture Detector-Sensitive to halogen compounds - use: halogenated hydrocarbons
EHW	Extremely Hazardous Waste
ELD	Electrolytic Detector - Hall
EP TOX	Extraction Procedure Toxicity
Fatty Acid	Monobasic organic acids derived from hydrocarbons; include both saturated and unsaturated acids
FID	Flame Ionization Detector-Sensitive to carbon compounds, used in the determination of hydrocarbons
Flash Point	Minimum temperature that will enable combustion or explosions to take place
FTIR	Fourier Transform Infra-Red
GC	Gas Chromatography
GCMS	Gas Chromatography Mass Spectrometry, also GC/MS
HC	Hydrocarbon
HDPE	High Density Polyethylene
HH	Halogenated Hydrocarbon
HPLC	High Performance Liquid Chromatography
HSD	Halogen-Specific Detector - use: halogenated hydrocarbons
HW	Hazardous Waste
HWPAH	Hazardous Waste Polynuclear Aromatic Hydrocarbon
ICP	Inductively Coupled Plasma
ICP/MS	Inductively Coupled Plasma/Mass Spectrometry
IDL	Instrument Detection Limit
isomer	One of two or more substances which have the same elementary composition but differ in structure and hence in properties
isotope	One of two or more nuclides having the same atomic number, but differing in mass number

Appendix H - (continued)

Isotopically labelled	The substitution of one or more isotopes for elements in a compound
kg	kilogram (1 X 10 ³ grams)
L	Liter (1 X 10 ³ milliliters)
LC50	Concentration which is lethal to 50% of the test organisms
LOD	Limit of Detection
LOEC	Lowest Observable Effect Concentration
m ³	Cubic meter (1 X 10 ³ liters)
MBAS	Methylene Blue Active substances
metalloids	Elements that exhibit transitional characteristics between metals and non-metals, examples include silver, selenium, antimony
MF	Membrane Filter
mg	milligram (1 X 10 ⁻³ grams)
mL	Milliliter (1 X 10 ⁻³ liters)
MPN	Most Probable Number
ng	Nanogram (1 X 10 ⁻⁹ grams)
nm	Nanometer (1 X 10 ⁻⁹ meters)
NOEC	No Observable Effect Concentration
NPDES	National Pollution Discharge Elimination System
NPOC	Non-Purgeable Organic Carbon
NTU	Nephelometric Turbidity Unit
OSHA	Occupation Safety and Health Administration
OSW	Office of Solid Waste
PCB	Polychlorinated Biphenyl
PE	Polyethylene
pg	Picogram (1 X 10 ⁻¹² grams)
pH	Hydrogen Ion Concentration
PID	Photoionization Detector - use: aromatic hydrocarbons
PLM	Polarized Light Microscopy
POC	Purgeable Organic Carbon
Polyvalent	Capable of having more than one valance state
PP	Priority Pollutant
ppb	Parts per billion (1 X 10 ⁻⁹ ug/L or ug/kg)
ppm	Parts per million (1 X 10 ⁻⁶ ug/L or ug/kg)
ppt	Parts per thousand (1 X 10 ⁻³ ug/L or ug/kg)
PQL	Practical Quantitation Limit
PUF	Polyurethane Foam
SDWA	State Drinking Water Act
SOW	Statement of Work
SW	Solid Waste

Appendix H - (continued)

TC	Target Compounds or Total Carbon
TCD	Thermal Conductivity Detector
TCL	Target Compound List
TCLP	Toxicity Characteristic Leaching Procedure
TDS	Total Dissolved Solids
TIC	Total Inorganic Carbon or for GCMS Tentatively Identified Compound
TNVS	Total Non-Volatile Solids
TNVSS	Total Non-Volatile Suspended Solids
TOC	Total Organic Carbon
TP	Total Phosphorous
TPH	Total Petroleum Hydrocarbons
TS	Total Solids
TSS	Total Suspended Solids
TVS	Total Volatile Solids
ug	Microgram (1 X 10 ⁻⁶ grams)
ug/m ³	Microgram per cubic meter
VOA	Volatile Organic Analysis
VOC	Volatile Organic Carbon
ZHE	Zero Headspace Extractor