



Appendix N: Public Services and Utilities Resource Report

**For Programmatic Environmental Impact
Statement on Utility-Scale Solar Energy
Facilities in Washington State**

By

Environmental Science Associates

For the

Shorelands and Environmental Assistance Program

Washington State Department of Ecology

Olympia, Washington

September 2024

Table of Contents

Acronyms and Abbreviations List	iii
Executive Summary	iv
Crosswalk with Public Services and Utilities Resource Report for Utility-Scale Onshore Wind Energy	v
1 Introduction.....	1
1.1 Resource description.....	1
1.2 Regulatory context.....	1
2 Methodology	3
2.1 Study area	3
2.2 Technical approach	5
2.3 Impact assessment.....	6
2.3.1 Construction and decommissioning	6
2.3.2 Operation and maintenance.....	7
3 Technical Analysis and Results	8
3.1 Overview	8
3.2 Affected environment.....	8
3.2.1 Public services.....	8
3.2.2 Utilities.....	14
3.3 Potentially required permits	17
3.4 Small to medium utility-scale facilities of 20 MW to 600 MW (Alternative 1).....	17
3.4.1 Impacts from construction.....	17
3.4.2 Impacts from operation	20
3.4.3 Impacts from decommissioning.....	23
3.4.4 Actions to avoid and reduce impacts.....	24
3.4.5 Unavoidable significant adverse impacts.....	25
3.5 Large utility-scale solar facilities of 601 MW to 1,200 MW (Alternative 2)	26
3.5.1 Impacts from construction, operation, and decommissioning.....	26
3.5.2 Actions to avoid and reduce impacts.....	26
3.5.3 Unavoidable significant adverse impacts.....	26
3.6 Solar facility and co-located battery energy storage systems (Alternative 3).....	26
3.6.1 Impacts from construction, operation, and decommissioning.....	26
3.6.2 Actions to avoid and reduce impacts.....	27
3.6.3 Unavoidable significant adverse impacts.....	28
3.7 Solar facility combined with agricultural land use (agrivoltaics) (Alternative 4).....	28
3.7.1 Impacts from construction, operation, and decommissioning.....	28
3.7.2 Actions to avoid and reduce impacts.....	29
3.7.1 Unavoidable significant adverse impacts.....	29
3.8 No Action Alternative.....	29

4 References 30

List of Figures and Tables

Figures

Figure 1. Solar Energy Facilities PEIS – geographic scope of study 4
Figure 2. Fire response in the solar study area..... 9
Figure 3. Emergency medical response in the solar study area..... 10
Figure 4. Example of type of helicopter used to respond to wildfires 12
Figure 5. Example of aerial firefighting response 13

Table

Table 1. Applicable laws, plans, and policies 1

List of Attachments

Attachment 1. First Responders Guide to Lithium-Ion Battery Energy Storage System Incidents

Acronyms and Abbreviations List

BESS	battery energy storage system
BLM	Bureau of Land Management
BMP	best management practice
CFR	<i>Code of Federal Regulations</i>
DNR	Washington Department of Natural Resources
Ecology	Washington State Department of Ecology
EMT	Emergency Medical Technician
FAA	Federal Aviation Administration
FCC	Federal Communications Commission
gen-tie line	generation-tie transmission line
HAZMAT	Hazardous Materials Team
medevac	medical evacuation
MW	megawatt
NFPA	National Fire Protection Association
OSHA	Occupational Safety and Health Administration
PEIS	Programmatic Environmental Impact Statement
PUD	public utility district
PV	photovoltaic
RCW	Revised Code of Washington
USC	<i>United States Code</i>
USDA	U.S. Department of Agriculture
USFS	U.S. Forest Service
UW	University of Washington

Executive Summary

This resource report describes the public services and utilities conditions in the study area. It also describes the potential impacts and actions that could avoid or reduce impacts.

The impacts on public services and utilities identified in this resource report include those from the construction, operation, and decommissioning phases of the solar energy facilities considered in the Programmatic Environmental Impact Statement (PEIS). This impact assessment considers whether the solar energy facilities would result in a significantly increased demand for public services (e.g., fire and law enforcement response, emergency medical response, schools) such that the capacities of existing service providers would be exceeded. The assessment considers whether solar energy facilities would result in solid waste capacity exceedances or utility service interruptions and whether facility structures such as substations, meteorological towers, and generation-tie transmission lines (if overhead) may have the potential to obstruct or interfere with communications systems, aerial firefighting, or aerial medical evacuation capabilities.

A probable increase in the demand for emergency response public services would occur in the study area as utility-scale solar energy facilities would introduce new risks to remote areas during construction, operation, and decommissioning. Such facilities also likely require the construction of new facilities to connect the solar energy facilities to the energy grid. Construction and decommissioning of utility-scale solar energy facilities have the potential to result in service interruptions, which would require coordination and communication with local utility districts.

Findings for public services and utilities impacts described in this resource report are summarized below.

- Through compliance with laws and permits and with implementation of actions that could avoid and reduce impacts, most construction, operation, and decommissioning activities would likely result in **less than significant impacts** on public services and utilities.
- A facility would result in **potentially significant adverse impacts** to fire response if activities required a large fire response in remote locations with limited response capabilities or if there are other unique aspects of a facility site.

Construction, operation, and decommissioning of utility-scale solar facilities may result in a **potentially significant and unavoidable adverse impact** if activities require a large fire response in remote locations with limited response capabilities or if there are other unique aspects of a facility site that affect fire response. Determining if mitigation options would reduce or eliminate impacts below significance would be dependent on the specific project and site and local regulations and plans.

Crosswalk with Public Services and Utilities Resource Report for Utility-Scale Onshore Wind Energy

Two PEISs are being released at the same time, one for utility-scale solar energy facilities and one for utility-scale onshore wind energy facilities. This crosswalk identifies the areas with substantial differences between the public services and utilities resource reports for each PEIS.

Utility-Scale Solar Energy PEIS (this document)	Utility-Scale Onshore Wind Energy PEIS
<ul style="list-style-type: none">• Differences in specific impacts on public service and utility providers• Some differences in actions to avoid and reduce impacts	<ul style="list-style-type: none">• Potential for significant adverse impacts on fire response related to turbines• Potential for significant adverse impacts on solid waste and recycling during decommissioning or repowering• Some differences in actions to avoid and reduce impacts

1 Introduction

This resource report describes public services and utilities within the solar energy facility study area and assesses potential impacts associated with types of facilities (alternatives), including a No Action Alternative. Chapter 2 of the State Environmental Policy Act Programmatic Environmental Impact Statement (PEIS) provides a description of the types of facilities evaluated (alternatives). Where impacts are identified, the section identifies mitigation measures designed to reduce potential impacts.

This section provides an overview of the public services and utilities evaluated in the resource report and lists relevant regulations that contribute to the evaluation of potential impacts.

1.1 Resource description

Key features of public services described in this resource report consist of considerations for emergency response including fire prevention and response, security and law enforcement, emergency medical, and public schools in the study area as potentially affected by utility-scale solar energy facilities. Key features of utilities and service systems described in this resource report include natural gas, electrical and communications systems, water supply, wastewater, and solid waste management.

1.2 Regulatory context

Potentially applicable federal, state, and local regulations are listed in Table 1, which will contribute to the evaluation of potential public services and utilities impacts.

Table 1. Applicable laws, plans, and policies

Regulation, statute, guideline	Description
Federal	
42 <i>United States Code</i> (USC) 6901 et seq., Solid Waste Disposal Act	Applicable to solid waste generated during construction, decommissioning, and operation and maintenance phases.
36 <i>Code of Federal Regulations</i> (CFR) 251, Subpart B, U.S. Department of Agriculture (USDA) U.S. Forest Service (USFS)	Includes USFS-administered lands; the regulation stipulates that various plans, such as emergency action plans and site security plans, be implemented as conditions of approval.
43 USC 1701 et seq., Federal Land Policy and Management Act of 1976	Governs how the Department of the Interior's Bureau of Land Management (BLM) and USFS (under USDA) administer public lands, including grants of rights-of-way for the transmission lines associated with solar and wind facility development. See also the BLM Right-of-Way Regulations (43 CFR 2800).
29 CFR 1910.269, Occupational Safety and Health Act	Safe worker practices and training requirements are applicable to solar energy facilities and electrical systems.

Regulation, statute, guideline	Description
Solid Waste Disposal Act, as amended by the Resource Conservation and Recovery Act (42 USC 6901 et seq.) and the Hazardous Solid Waste Amendments of 1984	The regulations governing hazardous materials influence the destinations and process for solid waste reclamation.
47 USC 303(q) Antenna Tower Lighting and Marking Requirements; 47 CFR 17.21-17.58, Federal Aviation Administration (FAA) Advisory Circulars	Standards and specifications set forth in FAA advisory documents govern antenna tower lighting and marking requirements, which are mandatory under the Federal Communications Commission (FCC) rules. The FCC requirements for filing with FAA for proposed structures vary based on a number of factors including height, proximity to an airport, location, and frequencies emitted from the structure, etc. Depending on such factors, communication structures associated with the solar energy facilities may be subject to FAA standards.
National Electric Code, Article 690 Solar Electric Systems	Governs the safe installation and operation of photovoltaic solar systems, including solar panels, connections, inverters, battery storage, and connection to the grid.
National Electric Code, Article 705, Interconnected Power Systems	Includes requirements that make it easier for first responders to safely and effectively turn off a solar energy system.
National Fire Protection Association 855 Standards for Installation of Energy Storage Systems	Applies to facilities with co-located battery energy storage system (BESS) in Alternative 3. Provides the minimum requirements for mitigating the hazards associated with BESS.
State	
Revised Code of Washington (RCW) 36.70A.070, Washington State Growth Management Act	Requires cities and counties to include a utilities element in their comprehensive plans.
RCW 70A.510.010, Photovoltaic Module Stewardship and Takeback Program	Applicable to decommissioning of solar energy facilities.
RCW 70.95.010 et seq., Solid Waste Management – Reduction and Recycling	Applicable mostly to decommissioning of solar and wind energy facilities.
RCW 70.105.005 et seq., Hazardous Waste Management	Applies to storage, handling, transportation, use, and disposal of hazardous materials associated with the facilities.
RCW 70.118.010 et seq., On-site Sewage Disposal System	Applies to potential septic systems (as applicable) that may be proposed as part of a facility.
RCW 80.28.440, Wildfire mitigation plan—Review/revision	Requires wildfire mitigation plan for investor-owned utilities.
Local	
Comprehensive plan goals and objectives, and local codes and requirements pertaining to public services and utilities	A local planning effort by cities and counties that provides a vision for the community and identifies steps needed to meet that vision. Many counties and cities in Washington defer to the state regulations.

2 Methodology

2.1 Study area

The study area for public services and utilities is defined as the service territories of all relevant public services (emergency response, including law enforcement, fire prevention and response, emergency medical services and hospitals, and public schools) and utilities (communications, natural gas and electric, water and wastewater, and solid waste landfills and recycling) that provide service to areas within the overall solar energy facility PEIS geographic scope of study (Figure 1). The PEIS does not approve, authorize, limit, or exclude facilities on a site-specific basis. Future facility proponents would need to consider specific options available for public service and utility provision when considering potential facility siting.




Figure 1. Solar Energy Facilities PEIS – geographic scope of study

2.2 Technical approach

To evaluate the probable impacts on public services and utilities, existing providers in the study area were identified using information obtained through public websites, mapped sources, and personal communication. Impacts associated with construction, operation and maintenance, and decommissioning were qualitatively analyzed.

This nonproject evaluation of potential public services and utilities impacts associated with solar energy facilities considered siting and design parameters, regulatory requirements, and plans and procedures intended to reduce effects. For analysis purposes, it is assumed that the solar energy facilities would comply with existing regulations and that the requirements would be enforced by the applicable local, state, and/or federal jurisdictions.

The technical approach included a review of the typical siting criteria and assumptions for facilities considered in the PEIS. The desktop analysis used publicly available federal, state, and local planning documents and environmental impact statements from similar utility-scale solar energy projects in Washington.

The analysis assumed that facilities would be required to adhere to regulatory standards such as those for solid waste and fire safety. Standard measures and best management practices (BMPs) may be considered for integration as actions to avoid or reduce impacts. Geographic/regional variation would likely influence whether facility impacts on public services and utilities rise to the level where mitigation would be required. For example, fire risk is highly variable in Washington state, so public safety response would place variable demands on service providers depending on the facility location and associated risks. The analysis also included considerations of climate change and its influence with respect to wildfire risk as related to emergency response. The identified potential actions to avoid and reduce impacts are specific to impacts identified for public services and utilities, except where crossovers with other resource areas exist. In these cases, potential impacts and mitigation are cross-referenced from other PEIS resource reports. Additional details regarding public health and safety, including wildfire risk as it informs this analysis, are provided in the *Environmental Health and Safety Resource Report* (ESA 2024).

2.3 Impact assessment

The potential impacts on public services and utilities include those from the construction, operation and maintenance, and decommissioning phases of the solar energy facilities analyzed in the PEIS. This impact assessment considers if any phase would result in a significantly increased demand for public services (e.g., fire and law enforcement, emergency medical response, schools) such that the capacities of existing service providers would be exceeded. The assessment considers whether the solar energy facilities would result in the relocation or prolonged service interruptions of existing utilities or whether any phase of the solar energy facilities would require construction of new or modified utilities. The assessment also considers whether structures such as meteorological towers, substations, or generation-tie transmission lines (gen-tie lines) associated with the solar facilities would have the potential to impact aerial firefighting and aerial medical evacuation capabilities. Significant impacts would occur if a facility would result in the following:

- Significantly increased demand for public services during construction or decommissioning that would exceed existing capacities of public service providers
- Significantly increased demand for public services during operation such that unplanned new or physically altered governmental facilities would be needed to serve the facility
- Facility would propose or require the relocation or construction of new or modified utilities or service systems during construction, operations, or decommissioning
- Facility would result in the presence of structures with the potential to obstruct or otherwise impact aerial emergency response capabilities

2.3.1 Construction and decommissioning

The use of construction workers from outside of locations where the solar energy facilities are proposed may result in a temporary increase in demand for public services, including police, providers of emergency medical services, and local fire departments. However, construction and decommissioning of solar energy facilities is not expected to require a permanent workforce. The analysis assumes that workers hired to construct solar energy facilities within the study area would not take up residence or relocate their families to the region as a result of this temporary construction employment.

Decommissioning is expected to include dismantling and removing the solar array and other aboveground components such as the collector substation, buildings, battery energy storage system (BESS), and overhead lines. Foundations may be removed to a level of 3 feet or more below the ground surface. Facility roadways no longer needed to access the site are expected to be restored or naturally revegetated. Underground collection and communication cables may be disconnected and abandoned in place.

2.3.2 Operation and maintenance

The analysis assumes that solar energy facilities would not require permanent full-time, on-site staff for their operation or maintenance. Based on other utility-scale solar energy facilities, operation could utilize remotely monitored systems and site security. Maintenance would likely entail panel cleaning, vegetation control, and periodic repair/replacement of components. All these activities could be accomplished using part-time or contracted personnel.

3 Technical Analysis and Results

3.1 Overview

This section describes the public services and utilities conditions in the study area and provides an analysis of potential impacts that could occur in the study area for the utility-scale solar energy facility types analyzed in the PEIS. This section also evaluates actions that could avoid, minimize, or reduce the identified impacts and potential unavoidable significant adverse impacts.

3.2 Affected environment

The affected environment represents the conditions before any construction begins. The study area includes highly variable geography and public service and utility providers. For the purposes of the analysis, the temporal scope of affected environment considerations consists of 20 years within which potential solar energy facilities may be constructed and approximately 30 years of operation for each facility. The conditions described in this section include a high-level consideration of climate change over this time frame and its potential to alter conditions for public services and utilities in the study area.

3.2.1 Public services

The solar energy facility study area is served by a variety of public service providers, which are funded in part through public resources, such as business and sales tax revenue. Depending on the local conditions, public services may be provided by federal, Tribal, state, county, or local governments, as well as volunteer fire departments and other volunteer groups. Public services addressed in this section include fire protection, law enforcement, emergency or other medical services, and schools. The service areas for fire and emergency medical response providers in the study area are depicted in Figures 2 and 3, respectively.




Figure 2. Fire response in the solar study area

Data sources: DNR 2023; FAA 2024; WSGDP 2024a




Figure 3. Emergency medical response in the solar study area

Data sources: FAA 2024; WSGDP 2024b

3.2.1.1 Emergency response

Emergency response in the study area includes law enforcement, fire departments, and emergency medical services. Coordination and emergency alert communication are conveyed through subscriber-based text alerts via cell phone and email; radio and other media are used to communicate with the public about hazard conditions and natural disasters. Emergency management services are provided at the county level and consist of various divisions that carry out dispatch services to all law enforcement, fire, and emergency management and response services (including 9-1-1 response) through centers within their respective divisions. Lands within the study area under state and federal jurisdiction also have emergency communication and dispatch networks that operate through the Washington Department of Natural Resources (DNR), U.S. Forest Service (USFS), and Bureau of Land Management (BLM).

Law enforcement

Law enforcement in Washington is provided by various county, municipal, and state entities. Unincorporated areas of the state are served by local county sheriff's offices. All state routes are patrolled by the Washington State Patrol. The Washington State Patrol provides traffic enforcement on state highways, drug enforcement, Hazardous Materials Team (HAZMAT) oversight, and incident response. Washington State Department of Ecology (Ecology) also has a spill response team. Portions of the study area include federal lands under USFS or BLM jurisdiction, and these agencies have law enforcement capabilities. DNR also provides ranger patrol on properties it manages.

Fire prevention and response

Fire prevention and response for facilities in the study area would be under the control of local county fire departments with support from volunteer units and other response teams, depending on the jurisdiction. Counties and local jurisdictions coordinate proactive controls, such as promoting defensible space vegetation removal, prescribed burning, or invoking burn bans, as conditions warrant, to prevent the uncontrolled spread of wildfires. Although each jurisdiction maintains the primary responsibility for providing services within its boundaries, mutual aid response agreements exist among different fire jurisdictions and regions through which they assist each other in the event one jurisdiction or region is unable to contain a structure fire or another emergency situation using its own resources and personnel (WSF 2023). Figure 2 depicts fire response providers in the solar energy facility study area.

Wildfire response

Portions of the study area are not under local jurisdiction for fire response. Lands in or near national forests or BLM land are under USFS or BLM jurisdiction for fire response. At the state level, DNR provides fire protection on properties it manages. DNR works with other state, federal, and local agencies to respond to wildfires and offers local fire districts and volunteer units with support with fire protection and safety equipment requirements. DNR implements industrial fire precaution levels to limit certain activities as conditions warrant in lands under their jurisdiction.

DNR manages an aviation response and helitack program available for dispatch throughout Washington state. Crews are staged in multiple locations statewide during the fire season and respond to threats to human life, property, and natural resources. Helitack crews are teams of firefighters who are transported by helicopter to wildfires. Available for dispatch throughout all of Washington state, these small teams provide initial attack capacity to fires occurring in areas not easily reached by ground (Figure 4).



Figure 4. Example of type of helicopter used to respond to wildfires

Image source: DNR 2024

DNR Wildfire Aviation is a highly trained air-ground firefighting team available for initial attack rapid response to wildland fires (Figure 5). Wildfire Aviation has 10 UH-1H(M) Huey helicopters modified for water/suppressant delivery in remote locations with the capability to deliver helitack crews into otherwise unreachable terrain. The primary aviation bases are in Olympia and Yakima. Historically, DNR helitack program crews have been staged in Omak, Deer Park, Dallesport, Pomeroy, Wenatchee, Colville, and Olympia (DNR 2024).



Figure 5. Example of aerial firefighting response

Image source: DNR 2024

DNR implements industrial fire precaution levels to limit certain activities as conditions warrant in a given region. USFS and BLM also provide aerial fire response through aviation and helitack operations for lands under federal jurisdiction.

As discussed in the *Environmental Health and Safety Resource Report*, the combination of longer fire seasons, population growth, declining forest health, and other threats in recent years have made wildfire considerations a top priority in Washington. The *Washington State Wildland Fire Protection 10-Year Strategic Plan* recognizes the need for proactive management of the landscape, the importance of maintaining a highly capable fire response workforce, and the need to prepare for expected increases in wildland fires in future years (DNR 2019).

Climate change considerations for wildfire risk

The utility-scale solar PEIS considers facilities constructed in Washington from 2025 through 2045. Once constructed, the assumed operational life of the solar energy facilities is 30 years. The analysis in this report therefore includes consideration of climate change effects on wildfire risk over this extended time frame, as related to emergency response. Climate change is expected to impact multiple variables related to fire risk, including air temperature, precipitation, humidity, wind, solar radiation, and other interactive issues, such as forest health, invasive species (notably including mountain pine beetle infestations), and prolonged drought, all of which influence fire risk and associated emergency response.

As discussed in the *Environmental Health and Safety Resource Report*, the University of Washington (UW) has conducted climate resilience mapping to model wildfire risk across the

state through time. The map shows the projected increase in high fire-danger days¹ across the state compared to historical (1971 to 2000) averages. An increase in high fire-danger days indicates a greater potential for wildfire danger to damage infrastructure, interrupt businesses, and affect public health and wellbeing (UW 2024). Although the severity of fire risk is variable across the geography of the state, with a higher number of high fire-danger days in the eastern part of the state, it is notable that all counties show a significant increase in the projected number of high fire days between the years 2040 and 2069, roughly coinciding with the extended time frame of the solar energy facilities.

Emergency medical services

Fire departments throughout the state maintain a staff of paramedics to respond to medical emergencies. The Washington State Department of Health coordinates emergency medical services and trauma care in various regions throughout the state. Emergency Medical Technician (EMT) dispatch is handled through county Emergency Management divisions. Figure 3 depicts emergency response providers in the solar energy facility study area.

Hospitals and other medical facilities

At a local level, there are multiple healthcare facilities and hospitals throughout the state providing public health preparedness and response services. Local emergency planning efforts by hospitals, public health providers, and other community entities are integrated with county comprehensive planning. Medical evacuation (medevac) services are contracted through the public and private health facilities, and on state and federal lands with the support of agencies (such as DNR and USFS).

3.2.1.2 Public schools

A variety of public education school districts serve portions of the study area. These districts range in size from small, rural school districts to larger districts with numerous schools.

In Washington state, the number of school-age students increased an average of 11,300 per year between 2013 and 2023. Enrollment peaked at 1.1 million K–12 students in 2019, then leveled off during and following the Covid-19 pandemic. Enrollment increases are expected to be moderate as the growth in the school-age population is projected to ease after 2023 (OFM 2024).

3.2.2 Utilities

The study area includes utility service areas and areas without services. Utilities described in this section include communications, gas and electrical, water, wastewater, and solid waste management. Depending on the area, utilities may be provided by county, city, Tribal, or private suppliers. In general, utility infrastructure often correlates to the size of the population it serves. As a result, population levels, coupled with any topographic or other constraints on

¹ A high fire-danger day is defined by UW in the context of climate resilience mapping as a day in which 100-hour fuel moisture (i.e., the amount of water in fuel/vegetation available for combustion) is less than the historical 20th percentile.

where utilities can be provided, often dictate how well a community is served by utility systems.

3.2.2.1 Communications

Internet, broadband, and cell phone services are available in portions of the study area, generally aligning with the more populated regions. In the rural or unpopulated parts of the study area, cell phone and internet service is limited or unavailable. Public emergency alert systems report natural hazards (such as flooding or wildfire) through local radio stations, cell phones, and email notifications. The various counties in the study area provide emergency alert and notification systems allowing subscribers to access alerts in real time. In unpopulated or sparsely populated areas (where these cell service and internet systems are unavailable), these jurisdictions also utilize radio signals to broadcast alerts and communicate information pertaining to fire, police, severe weather, and other public hazards. There are stand-alone communication sites across the study area. These sites include cell towers, radio towers, and microwave towers, which serve to relay communication signals. Communications lines enabling internet or cellular signals can be mounted in a shared configuration (with electrical lines) on dual use poles or buried underground as cables or in conduits.

3.2.2.2 Gas and electric

Four natural gas companies operate in Washington state. The gas systems, including storage and distribution pipelines, are owned and managed by Avista Utilities, Cascade Natural Gas Corporation, Northwest Natural Gas Company, and Puget Sound Energy. Electrical utilities are provided in the State of Washington through public utility districts (PUDs) and three main corporations, including Avista Utilities, Pacific Power and Light, and Puget Sound Energy. There are 28 PUDs providing electric, water, sewer, communications, renewable natural gas, and renewable hydrogen (in some cases via retail service agreements) in the state. PUDs are not-for-profit community-owned entities governed by locally elected commissioners who live in the communities they serve (WPUDA 2024). With regulatory oversight from the Washington Utilities and Transportation Commission and the Federal Energy Regulatory Commission, these utilities maintain natural gas systems and energy transmission and distribution networks in various geographies throughout the state. Generally, solar facilities are unlikely to require gas service connections; however, locations of existing subsurface utilities including gas lines would need to be identified prior to construction to reduce potential ground-disturbance conflicts.

3.2.2.3 Water and wastewater

Water supply in the study area is provided through various sources, including groundwater wells, surface water, and other supplies depending on the geographic location. The Washington Departments of Health and Ecology share responsibilities under the state's Municipal Water Law under coordinated planning, engineering, and public health and safety agreements related to water resources and supply systems. Connecting to a public water system requires a service connection application to a PUD, municipal, or county system. Allocation and development of water supplies may be subject to restrictions depending on the location. Appropriation of groundwater and well construction, with limited exceptions, requires local permits. Such

activities near surface waters may need to demonstrate that the allocation will allow for the maintenance of instream flow requirements adequate to support fish habitats. Water resources are discussed in additional detail in the *Water Resources Report* (ESA and Anchor QEA 2024).

The analysis assumes that if septic or sanitary systems are employed as part of a solar facility, such systems would be required to conform to local permit design and installation requirements to protect public health and (surface and ground) water resources. Existing subsurface utilities (including wells and water lines) would also require identification prior to ground-disturbing construction and avoidance during operation and maintenance.

3.2.2.4 Solid waste landfills and recycling

Solid waste generated throughout the study area is collected and managed by the various cities, counties, and private waste management entities in the study area. There are nearly 1,000 solid waste handling facilities of various types throughout Washington. There are 14 municipal solid waste landfills operating in the state: 11 are publicly owned and 3 are privately owned. These landfills received 5.5 million tons of waste in 2019 and have an estimated capacity of 280 million tons, or about 40 years of capacity at current disposal rates. There is also one “Waste-to-Energy” facility in Spokane, which is the only incinerator in the state that burns municipal solid waste (Ecology 2021a). Ecology tracks and measures waste generation in Washington through review of submitted annual reports and recycling surveys from the regulated solid waste handling facilities in the state. Quantified waste generation activities include landfill disposal, incineration of mixed municipal solid waste, recycling, composting, anaerobic digestion, land application, and burning source-separated materials for energy. Other than municipal and commercial solid waste, by category, the largest quantities of solid waste generated in the state include construction and demolition debris, industrial waste, and cured concrete. In rural areas, where no collection systems are available, nonhazardous waste is removed by regulated providers and trucked to regional landfills.

Solid waste diversion incorporates a sustainable materials management approach intended to serve human needs by increasing productive reuse from the point of extraction to materials disposal (Ecology 2021b). Metals and other materials capable of reuse may be collected and sold for reuse, recycled, or otherwise managed separately consistent with state requirements.

A substantial portion of the materials that make up solar energy facilities are recyclable, such as steel, aluminum, glass, copper, and plastic. As noted in the regulatory setting (Table 1), the State of Washington has a photovoltaic (PV) Module Stewardship and Takeback Program, requiring manufacturers of PV modules to provide the public with a clean and environmentally sound way to recycle all modules purchased after July 1, 2017. The regulation includes provisions for funding, performance goals, and reporting. The program requires manufacturers to develop and submit a stewardship plan to Ecology with the intent to facilitate recycling and provide a mechanism to limit the release of hazardous substances into the environment. After January 1, 2021, PV manufacturers not participating in an approved stewardship plan may not sell their modules in or into Washington state (Ecology 2020).

3.3 Potentially required permits

The following permits related to public services and utilities could be required for construction, operation, or decommissioning of typical solar energy facilities and activities:

- **Right-of-way or lease (federal or state land manager):** Placement of facility infrastructure on lands under federal management jurisdiction would require approval from the federal or state land manager.
- **Federal Communications Commission (FCC):** Federal Aviation Administration (FAA) advisory documents govern antenna tower lighting and marking requirements, which are mandatory under the FCC rules. The FCC requirements for filing with FAA for proposed structures vary based on a number of factors, including height, proximity to an airport, location, and frequencies emitted from the structure. Depending on such factors, communication structures associated with solar energy facilities may be subject to FAA standards.
- **Conditional Use Permit (local county or municipality):** Operation of a utility-scale solar energy facility may require a use permit or a conditional use permit subject to review and approval by the jurisdiction (county or municipality) of its proposed operation. New or modified utilities proposed as part of a solar facility may require a conditional use permit; the use permit process would also include review of public service impacts.
- **Local permits (county or municipality):** Various construction activities and placement of new or modification of existing utilities proposed as part of a solar facility would be subject to local permits to ensure compliance with grading and drainage, stormwater management, building standards, etc.

3.4 Small to medium utility-scale facilities of 20 MW to 600 MW (Alternative 1)

3.4.1 Impacts from construction

Probable adverse impacts associated with the site characterization and construction of solar energy facilities could consist of those related to emergency response capacity exceedances, conflicts with other existing utilities, and potential prolonged service interruptions that may occur over portions of the facility construction period.

3.4.1.1 *Emergency response*

An impact during facility construction could occur if significantly increased demands were placed on emergency services providers that exceed response capacities. Construction of small- to medium-scale solar energy facilities would entail employment of a temporary workforce (estimated to range from 100 to 400 workers for a 150-megawatt [MW] facility) that could result in an increased demand for public services including law enforcement, fire departments, and emergency medical service response within and near the study area.

Law enforcement

Construction and site characterization activities would entail the use of equipment and presence of materials, which may increase the potential for theft, vandalism, trespass, fire, safety issues, and/or accidents requiring law enforcement or other emergency response services. Facilities are assumed to include provisions for site security, including a combination of fencing, lighting, security patrols, and/or security cameras and other electronic security monitoring systems as needed. Restricting access to the facility construction site is assumed to be achieved via perimeter fencing, locked gates, and “no trespassing” signs. Security fencing would likely consist of approximately 6- to 7-foot-high chain-link (or other wire) fencing; the top 1 foot may be composed of barbed wire strands. High-voltage electrical equipment within the solar facility would be separately fenced and access-controlled for safety and increased security. Lighting would likely be provided at construction trailers, substations, operations and maintenance buildings, and facility entrances as necessary for the safety and security of employees and the facilities. The presence of workers during the site characterization and construction phases may also deter incidents that would require a law enforcement response. Security patrols or cameras may also be used.

Fire prevention and response

Activities during site characterization and the development and construction of solar energy facilities could include welding, removal of vegetation, and use of vehicles and equipment and associated fuels, all of which introduce ignition risks during construction. Wildfire risks are discussed in the *Environmental Health and Safety Resource Report*. In remote locations with limited response capabilities, the fire response demand in the event of a construction-related fire at a solar facility could limit fire response resources needed to address other firefighting in the vicinity. The potential for increased fire response demand at construction of any particular facility would vary by facility and location.

Emergency medical services

As described under the law enforcement discussion, site characterization and construction of small to medium facilities would increase the potential for accidents and incidents requiring emergency medical response services. Solar energy facilities are frequently sited in remote locations, away from hospitals or other emergency treatment facilities. This can be a concern with regard to the provision of timely medical treatment if a worker falls, gets trapped, or is otherwise hurt. Winter conditions can further exacerbate medical response access considerations if, for example, snow, ice, or other weather conditions prevent a medevac landing or access roads are closed. Compliance with Occupational Safety and Health Administration (OSHA) requirements and appropriate site construction management would alleviate demand on local EMT response services and reduce such risks. Worker safety training and adherence to safety procedures during construction, for example, would limit potential emergency response demands. Consultation or early coordination with emergency response providers to ensure access and other proactive safety planning would also reduce such risks.

Emergency response impact summary

Through compliance with laws and permits and with implementation of actions that could avoid and reduce impacts, most construction activities would likely result in **less than significant impacts** on law enforcement, emergency medical response, and most fire response.

A facility would result in **potentially significant adverse impacts** to fire response if activities required a large fire response in remote locations with limited response capabilities or if there are other unique aspects of a facility site.

3.4.1.2 Public schools

The impact on local schools would be minor because few out-of-area construction workers would be likely to permanently relocate their families to the community where a solar energy facility is being developed. For this reason, construction-related impacts on local school enrollment are expected to be minor and temporary. Most workers are unlikely to be permanently relocated into the study area for long enough to require and obtain such services. Therefore, impacts on school enrollment during construction would be **less than significant**.

3.4.1.3 Communications systems

Solar energy facilities and their associated substations may include constructing communication systems or tall meteorological structures. An evaluation of specific potential communications conflicts would occur as part of the FCC review or during the conditional use permit/land use approval process. With appropriate siting and design, potentially signal interference impacts on low-wave radio and communications systems would be **less than significant**.

3.4.1.4 Gas and electric

Although new gas lines are not likely to be installed as part of a solar energy facility, conflicts with or damage to existing lines could occur through excavation or other ground-disturbing activities during site characterization and construction. It is anticipated that the siting and design for solar facilities would be informed by utility mark and locate activities prior to ground-disturbing work. In this way, most existing gas and electrical lines would be avoided. During construction, there would also be the potential for temporary service interruptions as electrical systems may require disengagement or rerouting to connect the solar energy facility's collection system to gen-tie lines and the electrical grid. Service providers require that line outages be scheduled during off-peak times, which would be coordinated to limit service disruptions. Notifications to residents and businesses for planned service interruptions would also likely be required. Occasional and temporary service interruptions could occur during construction. It is recommended that measures be implemented to reduce conflict with existing electrical systems, gas lines, and other existing or planned subsurface utilities. Through compliance with laws and permits and with implementation of actions that could avoid and reduce impacts, construction activities would likely result in **less than significant impacts** on gas and electrical systems.

3.4.1.5 Water and wastewater

Water demand during construction would consist of the supply needed for activities such as concrete mixing, dust control, fire control, or initial revegetation efforts. Water for non-potable uses may be accessed from reclaimed/recycled water supplies where available. Potable water would be needed for drinking water and could be supplied by a commercial supplier, on-site well, or a public or community water system.

Sanitation and wastewater could be managed through contracted portable systems or septic systems. The capacity of any in-ground septic tanks (if proposed as part of a solar facility) and the dimensions of any leach fields would be determined based on anticipated use and site-specific soil conditions among other factors, in conformance with local regulatory controls.

Additional discussion of water resources and potential impacts is provided in the *Water Resources Report*. Conflicts with existing subsurface water lines, wells, and wastewater lines could be addressed through utility mark and locate activities, which would be required prior to ground-disturbing work for site characterization and construction activities. Through compliance with laws and permits and with implementation of actions that could avoid and reduce impacts, construction activities would likely result in **less than significant impacts** on water and wastewater utilities.

3.4.1.6 Solid waste and recycling

During construction, the primary solid waste generated would consist of solid construction debris such as scrap metal, cable, wire, wood pallets, cardboard, packaging for construction materials, and a limited amount of waste associated with the construction workforce. A portion of this waste (e.g., scrap metal, cardboard) could be recycled; the remainder would be accumulated into receptacles and transported to a licensed transfer station or landfill. Based on the quantities generated by similar-sized solar energy facilities, it is estimated that approximately 22 cubic yards per week of solid waste (or slightly more than two average-sized dumpsters) may be generated during construction (ESA 2021). As noted previously, there are nearly 1,000 solid waste providers in the state and 14 landfills that could likely accommodate this level of waste. Through compliance with laws and permits and with implementation of actions that could avoid and reduce impacts, construction activities would likely result in **less than significant impacts** on solid waste and recycling.

3.4.2 Impacts from operation

3.4.2.1 Emergency response

Law enforcement

As with construction, solar energy facility operations could increase the demand for law enforcement services due to potential theft, accidents, vandalism, or trespassing. However, various security measures (e.g., fencing portions of the site to protect systems and equipment; employing site security personnel; providing motion-triggered lighting and facility monitoring systems) would typically be in place as part of normal operations to protect the facilities. Such measures would reduce demand for external security or law enforcement services.

Fire prevention and response

Fire risks associated with facility operations are described in the *Environmental Health and Safety Resource Report*. Fire risks during facility operation include those caused by solar energy facility operational activities and fires started outside of facilities that have altered behavior (i.e., spread, movement, or ability to be suppressed) due to the presence of a solar energy

facility. This analysis assumes that solar energy facilities would be regularly maintained and monitored to reduce these risks. However, accidents and fires could still occur.

Siting solar energy facilities in rural areas could have fencing and facility access restrictions that could delay emergency response if not proactively coordinated. Local and/or volunteer fire departments and responders may not be adequately trained and equipped to respond to wildfires that may occur on utility-scale solar energy facility sites. Specific facility access procedures, training, and coordination for response providers and volunteer units can help address concerns with local fire response capacity. The siting and height of structures such as substations, meteorological towers, and overhead gen-tie lines can also present risks to aerial firefighting. These should be addressed through early consultation with DNR or federal agencies to evaluate the siting and design for solar energy facilities.

Emergency medical services

Emergency medical services could be needed for employees. For example, periodic routine maintenance activities could involve a fire, electrical shock, or a medical emergency. The challenges of an emergency medical response could be exacerbated by winter conditions, distance of the facility site from medical services, and access to the site. However, the operational staffing for solar energy facilities would likely be small and not regularly on site. Additionally, facility operators would be expected to use appropriately trained technicians to operate and maintain the equipment. These considerations should result in a minimal increase in emergency medical service needs.

Emergency response impact summary

Through compliance with laws and permits and with implementation of actions that could avoid and reduce impacts, operations of a facility would likely result in **less than significant impacts** on law enforcement, emergency medical response, and most fire response.

A facility would result in **potentially significant adverse impacts** to fire response if activities required a large fire response in remote locations with limited response capabilities or if there are other unique aspects of a facility site.

3.4.2.2 Public schools

Small to medium facilities would not be expected to require full-time permanent staff for facility operation and maintenance. Operations could occur in tandem with remote facility (SCADA system) monitoring; periodic maintenance could occur through temporary or contracted staff. A small to medium facility would not increase the population such that new or modified public schools would be needed and impacts on local school enrollment during the operations phase would be **less than significant**.

3.4.2.3 Communications systems

Solar energy facilities and their associated substations may include communication systems or tall meteorological structures, the presence of which could impact existing communications systems or low-wave radio signals. An evaluation of specific potential communications conflicts would occur as part of the FCC review or during the conditional use permit/land use approval

process. With appropriate siting and design, potential signal interference impacts on low-wave radio and communications systems would be **less than significant**.

3.4.2.4 Gas and electric

Once operational, the solar facilities would not be anticipated to increase demand for gas or electricity services. New and modified electrical facilities (such as the facility substation systems, gen-tie lines, and interconnections) would be operated and maintained to connect, convert, and transmit the generated solar energy to the electrical grid; however, these systems would not increase demand such that new transmission lines or other electric systems would be required. Through compliance with laws and permits and with implementation of actions that could avoid and reduce impacts, operations of facilities would likely result in **less than significant impacts** on gas and electric services.

3.4.2.5 Water and wastewater

Once operational, water demand may include requirements for dust control, panel cleaning, potable water for facility personnel, irrigation of on-site vegetation, fire water supply, or plumbed facilities such as sinks or toilets. If water is used for solar panel washing, a small to medium facility would use approximately 3.3 million gallons per year, though this would vary based on panel size, soiling rates, and cleaning frequency. This water could come from a municipal supply, if water is available and approved by the utility. It could also be trucked in or from an on-site well, in which case a water right would be needed. If consistent with public health requirements and available supply, reclaimed water may supply some of such water demands.

Additional discussion of water supply considerations is provided in the *Water Resources Report*. As an alternative to washing solar panels with water, waterless cleaning methods, including use of soft brushes, may be feasible for removing particulates from panel surfaces. If consistent with public health requirements and available supply, reclaimed water may supply some of such water demands. Potable water also may be needed for on-site drinking water, which could be supplied by a well or trucked to the site.

If solar energy facilities include on-site septic systems during operation, such systems would conform to the state's siting and design requirements (Chapter 70.118.010 Revised Code of Washington et seq.) for the protection of water resources and public health. Septic systems or portable units, if utilized, would typically be maintained by a contracted licensed service provider. As discussed, the small number of operational staffing would limit impacts associated with wastewater.

Through compliance with laws and permits and with implementation of actions that could avoid and reduce impacts, construction activities would likely result in **less than significant impacts** on water and wastewater utilities.

3.4.2.6 Solid waste and recycling

A small amount of solid waste would be generated as part of normal operation and maintenance activities. Periodic replacement of PV solar panels would occur over the 30-year operational lifespan of solar facilities. These PV materials would be replaced in a manner consistent with state PV Module Stewardship and Takeback Program requirements. See Section 3.4.3.1 for details about the Takeback Program. Additional typical waste may include broken or rusted metal, defective or malfunctioning equipment, electrical materials, empty containers, miscellaneous solid waste, and typical refuse from operations and maintenance staff. Approximately 1 cubic yard of waste per week would be expected per solar facility, which would be collected by a commercial waste management service.

Through compliance with laws and permits and with implementation of actions that could avoid and reduce impacts, operation of facilities would likely result in **less than significant impacts** on solid waste and recycling.

3.4.3 Impacts from decommissioning

Decommissioning of solar energy facilities could generate similar impacts to most public services (law enforcement, emergency response, public schools, and healthcare) and utilities (gas and electric, and water supply and wastewater) as those identified in Section 3.4.1 for construction.

Additional considerations for solid waste and recycling during decommissioning are discussed below.

3.4.3.1 Solid waste and recycling

The regulatory control provided by the state PV Module Stewardship and Takeback Program (described in Section 3.2.2) would reduce the quantity of PV waste content that would reach area landfills during decommissioning.

Restoration or remediation of the substation and electrical sites could be necessary due to the use of oils and other hazardous materials during energy facility operation. The precise quantities and content of solid waste would vary depending on the facility size, and the actions associated with decommissioning would depend on construction materials used and specific site restoration actions needed based on the local environment. It is anticipated that decommissioning would involve removal of all aboveground components of the solar facilities and would generate more solid waste than the construction or operations phase. However, with PV takeback opportunities and requirements in place and the value of scrap metals and other materials for reuse or recycling, the quantity of solid waste generated in facility decommissioning is not anticipated to exceed the capacity of available solid waste management service providers.

3.4.3.2 Decommissioning impact summary

Through compliance with laws and permits and with implementation of actions that could avoid and reduce impacts, most decommissioning activities would likely result in **less than significant impacts** on public services and utilities.

A facility would result in **potentially significant adverse impacts** to fire response if activities required a large fire response in remote locations with limited response capabilities or if there are other unique aspects of a facility site.

3.4.4 Actions to avoid and reduce impacts

Site-specific mitigation actions would be developed during facility-specific reviews and permitting for each facility proposed in the future. Implementation of various plans designed to proactively address safety and hazards before they rise to emergency situations would alleviate impacts on public services and utilities.

An evaluation of potential facility-specific impacts on public services and utilities should consider the siting and design parameters, regulatory requirements, and plans and procedures intended to reduce impacts, and other mitigation measures identified in Sections 3.4.4.1 through 3.4.4.3.

3.4.4.1 Siting and design considerations

- Coordinate with the local fire district, emergency management departments, USFS, and/or DNR (as applicable, if facility siting is proposed on or near forests or wildlands) prior to and during construction and throughout the life cycle of the facility.
- Coordinate with the local fire district and DNR (as applicable, if the solar energy facility would be located in or near forests or wildlands) to ensure that adequate water supply is available for fighting fires. The facility proponent may also be able to demonstrate that adequate water supply is available for firefighting via an on-site well or other water storage.
- Design facilities to reduce risks to neighboring land uses from gen-tie lines or other solar facility components, including potential setbacks, to reduce the risk of ignitions in fire-prone environments.
- Determine appropriate setbacks in consultation with local, state, or federal land managers. Setback distances should consider proximity to residences, terrain, vegetation management clearance requirements for gen-tie lines, vegetation and natural communities on surrounding lands, and the need to maintain access for maintenance and emergency response, among other considerations.

3.4.4.2 Permits, plans, and best management practices

- Fire protection equipment must be consistent with the International and Washington State Fire Codes and OSHA and electrical code requirements.
- Apply appropriate site maintenance, including periodic mowing or vegetation control BMPs.

- A Fire Prevention and Response Plan, if required, would be site specific and outline procedures to reduce risks specific to the regions of proposed facility construction and operation.
- Hazardous Materials Management Plan
- Spill Prevention and Countermeasure Control Plan
- Decommissioning and Site Reclamation Restoration Plan
- Construction and Operational Site Security Plans
- Site-specific Medical Emergency Response Plan
- Implement measures recommended to reduce utility service interruptions and conflicts, including, but not limited to, the following:
 - Mark and locate all underground utilities within the construction footprint prior to ground-disturbing construction activities.
 - Consult and coordinate with utility providers about siting and design planning, specifying the extent and timing of proposed construction activities.
 - Provide prior notification to residents and businesses where service interruptions may occur because of construction.
- Develop a Traffic Management Plan to ensure that emergency ingress and egress are maintained during construction and operation. A Traffic Management Plan should specify how lane closures would occur and how evacuation procedures would be followed in the event of an emergency.

3.4.4.3 Additional mitigation measures

- Develop and implement a site-specific Fire Prevention and Response Plan. This plan would include specific measures for coordinating and training response personnel, such as guidelines for first responders to safely shut electrical systems down in the event of fire, management requirements to reduce ignition risks throughout the sites, and site management fire safety and awareness protocols including tracking fire conditions in the surrounding region, among others.
- Develop and implement a Decommissioning and Site Reclamation Restoration Plan to include fire prevention measures.

3.4.5 Unavoidable significant adverse impacts

Construction, operation, and decommissioning of small to medium utility-scale solar facilities may result in a **potentially significant and unavoidable adverse impact** if activities require a large fire response in remote locations with limited response capabilities or if there are other unique aspects of a facility site that affect fire response. Determining if mitigation options would reduce or eliminate impacts below significance would be dependent on the specific project and site and local regulations and plans.

3.5 Large utility-scale solar facilities of 601 MW to 1,200 MW (Alternative 2)

3.5.1 Impacts from construction, operation, and decommissioning

Large facilities would entail a larger-scale solar energy facility with an increased overall footprint compared to small to medium facilities. Impacts as described for small to medium facilities would be similar for large facilities but would be expected to occur at an increased scale. For this analysis, estimates for solid waste generated are assumed to be up to twice those estimated for small to medium facilities.

Through compliance with laws and permits and with implementation of actions that could avoid and reduce impacts, most construction, operation, and decommissioning activities would likely result in **less than significant impacts** on public services and utilities.

A facility would result in **potentially significant adverse impacts** to fire response if activities required a large fire response in remote locations with limited response capabilities or if there are other unique aspects of a facility site.

3.5.2 Actions to avoid and reduce impacts

Actions to avoid and reduce impacts would be the same as those identified in Section 3.4.4 for small to medium facilities. Although the scale of impacts would be proportionately increased for large facilities, there would be no change to the previously recommended mitigation measures.

3.5.3 Unavoidable significant adverse impacts

Construction, operation, and decommissioning of large utility-scale solar facilities may result in a **potentially significant and unavoidable adverse impact** if activities require a large fire response in remote locations with limited response capabilities or if there are other unique aspects of a facility site that affect fire response. Determining if mitigation options would reduce or eliminate impacts below significance would be dependent on the specific project and site and local regulations and plans.

3.6 Solar facility and co-located battery energy storage systems (Alternative 3)

3.6.1 Impacts from construction, operation, and decommissioning

Facilities with BESSs would include the same systems as those considered in Sections 3.4 and 3.5, with the addition of one or two co-located BESSs, each capable of storing up to 500 MW of energy. The site characterization, construction, operation, and decommissioning of a facility co-located with a BESS is anticipated to include the same impacts on public services and utilities as those described for facilities without BESSs.

Co-location of the BESSs introduces an additional fire risk management and emergency response consideration. The types of BESSs evaluated in this PEIS rarely start fires if properly installed and maintained. Flow batteries and zinc-bromide batteries are generally not flammable. BESSs come equipped with remote alarms for operations personnel and emergency response teams. Other protective measures include ventilation, overcurrent protection, battery controls to operate the batteries within designated parameters, temperature and humidity controls, smoke detection, and maintenance in accordance with manufacturers' guidelines.

Some battery types may contain hazardous materials that pose potential risks for environmental release if not handled correctly and could introduce hazards for first responders. BESS facilities could create extreme hazards for firefighters and emergency responders with the possibility of explosions, flammable gases, toxic fumes, water-reactive materials, electrical shock, corrosives, and chemical burns. Utility-scale energy storage requires specialized and reliable equipment to perform firefighting operations safely and effectively to the Washington Fire Code, National Fire Protection Association (NFPA), OSHA, and Underwriters Laboratories codes and standards, as discussed in the *Environmental Health and Safety Resource Report*, as well as the applicable county fire protection district codes and standards.

Specialized advanced planning and procedures for enhanced fire response training would be required to ensure that the solar energy facilities and co-located BESSs do not generate hazards that could interfere with or exceed emergency response capabilities. For additional details regarding emergency response procedures for BESSs, see Attachment 1, the *First Responders Guide to Lithium-Ion Battery Energy Storage System Incidents* (ACP 2023). The recommended approach from the American Clean Power guidance for firefighting is not to use water but allow the battery to burn in a controlled manner. This would result in air emissions that could be hazardous to emergency responders and would require protective gear.

Impacts to public services and utilities would be similar to findings for utility-scale solar facilities, with additional fire response considerations for BESSs.

A facility would result in **potentially significant adverse impacts** to fire response if activities required a large fire response in remote locations with limited response capabilities, or if there are other unique aspects of a facility site.

3.6.2 Actions to avoid and reduce impacts

Available actions for facilities with BESSs would be the same as those proposed for utility-scale facilities without BESSs, with additions noted below.

3.6.2.1 Permits, plans, and best management practices

- BESSs must comply with the latest Washington State Building Code Council regulations for batteries. This includes a requirement that where mixed systems are approved, the aggregate nameplate kilowatt-hour energy of all energy storage systems in a fire area cannot exceed the maximum quantity specified for any of the energy systems in the

code. A hazard mitigation analysis may also be required as part of this code to evaluate any potential adverse interaction between the various energy systems and technologies.

3.6.2.2 Additional mitigation measures

Additional mitigation measures to address potentially significant impacts specific to BESS safety training and emergency response are listed as follows:

- Develop and implement the fire protection, prevention, and detection measures and design features in accordance with NFPA C855 Standards for Installation of Energy Storage Facilities and the current Washington Fire Code, including requirements for providing redundant separate methods of BESS failure detection.
- Develop and implement an Emergency Action Plan in advance of construction to train local emergency response personnel on hazards specific to BESSs during development and operation of the facility.
- Develop and implement regular maintenance schedules and inspections for BESS components to ensure optimal performance and early detection of potential issues.

3.6.3 Unavoidable significant adverse impacts

Construction, operation, and decommissioning of utility-scale solar facilities with BESSs may result in a **potentially significant and unavoidable adverse impact** if activities require a large fire response in remote locations with limited response capabilities or if there are other unique aspects of a facility site that affect fire response. Determining if mitigation options would reduce or eliminate impacts below significance would be dependent on the specific project and site and local regulations and plans.

3.7 Solar facility combined with agricultural land use (agrivoltaics) (Alternative 4)

3.7.1 Impacts from construction, operation, and decommissioning

For a facility that includes agricultural land uses, any existing agricultural lands would be maintained, or new agricultural use could be co-located with the utility-scale solar facility. Agrivoltaic facilities may include raising or modifying the solar panels to allow for agricultural use. The scale of solar energy facilities with co-located agricultural uses is assumed to be similar to facilities without agricultural use; therefore, most potential impacts on public services and utilities would be similar. Impacts to most public services (law enforcement, schools, and healthcare) and utilities (gas and electric, water and wastewater, communications, and solid waste and recycling) from the construction, operation, or decommissioning of solar energy facilities with co-located agricultural uses would be similar to facilities without agricultural use.

Additional considerations for fire protection and emergency response are discussed below.

Fire protection and emergency response

Because these facilities would include active management of the vegetative landscape (e.g., grazing, irrigated crop production, and pollinator habitat) and provide a beneficial cooling effect to the land, fire risk for the agrivoltaics sites could generally be reduced compared to facilities without agricultural use. Emergency fire response demand may correspondingly decrease due to this type of land management.

Facilities with co-located agricultural uses could entail a different fencing design to potentially accommodate grazing or other agricultural activities, which could pose challenges for first responders if they were to need to access the site.

Through compliance with laws and permits and with implementation of actions that could avoid and reduce impacts, most construction, operation, and decommissioning activities would likely result in **less than significant impacts** on public services and utilities.

A facility would result in **potentially significant adverse impacts** to fire response, if activities required a large fire response in remote locations with limited response capabilities, or if there are other unique aspects of a facility site.

3.7.2 Actions to avoid and reduce impacts

The actions to avoid, reduce, and mitigate impacts for facilities with co-located agricultural uses would be the same as those identified in Section 3.4.4.

3.7.1 Unavoidable significant adverse impacts

Construction, operation, and decommissioning of utility-scale solar facilities with agricultural uses may result in a **potentially significant and unavoidable adverse impact** if activities require a large fire response in remote locations with limited response capabilities or if there are other unique aspects of a facility site that affect fire response. Determining if mitigation options would reduce or eliminate impacts below significance would be dependent on the specific project and site and local regulations and plans.

3.8 No Action Alternative

Under the No Action Alternative, the city, county, state, and federal agencies would continue to conduct environmental review and permitting on a facility-by-facility basis in accordance with existing laws, regulations, plans, and standards. The potential impacts from facilities developed under the No Action Alternative would be similar to the impacts for the types of facilities described previously for construction, operations, and decommissioning, depending on facility size and design, and would range from **less than significant** to **potentially significant adverse impacts**.

4 References

- ACP (American Clean Power Association), 2023. *First Responders Guide to Lithium-Ion Battery Energy Storage Incidents*. July 2023. Available at: <https://cleanpower.org/resources/first-responders-guide-to-bess-incidents/>.
- DNR (Washington Department of Natural Resources), 2019. *Washington State Wildland Fire Protection 10-Year Strategic Plan*. Available at: https://www.dnr.wa.gov/publications/rp_wildfire_strategic_plan.pdf.
- DNR, 2023. Washington Large Fires 1973–2022. Online geospatial dataset. Accessed February 28, 2024. Available at: https://gis.dnr.wa.gov/site3/rest/services/Public_Wildfire/WADNR_PUBLIC_WD_WildFire_Data/MapServer.
- DNR, 2024. “Programs and Services/Aviation.” Accessed March 1, 2024. Available at: <https://www.dnr.wa.gov/Aviation>.
- Ecology (Washington State Department of Ecology), 2020. *Manufacturer Plan Guidance for the Photovoltaic Module Stewardship Program*. July 2019 (revised 2020). Available at: <https://apps.ecology.wa.gov/publications/documents/1907014.pdf>.
- Ecology, 2021a. *State Solid and Hazardous Waste Plan*. Solid Waste Management Program. December. Publication 21-04-050. Available at: <https://apps.ecology.wa.gov/publications/documents/2104050.pdf>. Accessed April 15, 2024.
- Ecology, 2021b. *Measuring Waste Generation and Recovery in Washington Methodology 2017 and Beyond*. Solid Waste Management Program. Publication 21-07-025. July 2021. Available at: <https://apps.ecology.wa.gov/publications/documents/2107025.pdf>.
- ESA (Environmental Science Associates), 2021. *Luna Valley Solar Project Draft Environmental Impact Report No 7813; Conditional Use Permit No. 3671*. Prepared for Fresno County Division of Public Works and Planning. Available on Fresno County’s public website: Available at: <https://www.fresnocountyca.gov/Departments/Public-Works-and-Planning/divisions-of-public-works-and-planning/development-services-division/planning-and-land-use/environmental-impact-reports/eir-7813>.
- ESA, 2024. *Environmental Health and Safety Resource Report for Programmatic Environmental Impact Statement on Utility-Scale Solar Energy Facilities in Washington State*. Prepared for the Washington State Department of Ecology. September 2024.
- ESA and Anchor QEA (Environmental Science Associates; Anchor QEA), 2024. *Water Resources Report for Programmatic Environmental Impact Statement on Utility-Scale Solar Energy Facilities in Washington State*. Prepared for the Washington State Department of Ecology. September 2024.

- FAA (United States Federal Aviation Administration), 2024. Online geodataset: airports, helipad, and runways within 10 miles of scope. Accessed February 28, 2024. Available at: https://adds-faa.opendata.arcgis.com/datasets/e747ab91a11045e8b3f8a3efd093d3b5_0/explore?location=5.793434%2C-1.633886%2C2.18.
- OFM (State of Washington Office of Financial Management), 2024. Washington Data and Research. K–12 Enrollment. Available at: <https://ofm.wa.gov/washington-data-research/statewide-data/washington-trends/budget-drivers/kindergarten-through-grade-12-k-12-enrollment>.
- UW (University of Washington College of the Environment), 2024. Public web mapping tool: “Climate Mapping for a Resilient Washington.” Accessed March 1, 2024. Available at: <https://data.cig.uw.edu/climatemapping/>.
- WPUDA (Washington Public Utility Districts Association), 2024. “Frequently Asked Questions.” Accessed March 5, 2024. Available at: <https://www.wpuda.org/faqs>.
- WSF (Washington State Fire Marshal’s Office), 2023. *Washington State Fire Services Resource Mobilization Plan*. Revised May 2023. Available at: <https://www.wsp.wa.gov/wp-content/uploads/2023/06/2023-Mobilization-Plan-1.pdf>.
- WSGDP (Washington State Geospatial Data Portal), 2024a. Fire Services. Online geospatial dataset. Accessed February 28, 2024. Available at: <https://geo.wa.gov/maps/74981ffe7d1348f9b39f841143b8123e/about>.
- WSGDP, 2024b. Emergency Medical Services. Online geospatial dataset. Accessed February 28, 2024. Available at: <https://geo.wa.gov/maps/74981ffe7d1348f9b39f841143b8123e/about>.

**Attachment 1. First Responders Guide to
Lithium-Ion Battery Energy Storage System
Incidents**

First Responders Guide to Lithium-Ion Battery Energy Storage System Incidents

1 Introduction

This document provides guidance to first responders for incidents involving energy storage systems (ESS). The guidance is specific to ESS with lithium-ion (Li-ion) batteries, but some elements may apply to other technologies also. Hazards addressed include fire, explosion, arc flash, shock, and toxic chemicals. For the purposes of this guide, a facility is assumed to be subject to the 2023 revision of NFPA 855 [B8]¹ and to have a battery housed in a number of outdoor enclosures with total energy exceeding 600 kWh, thus triggering requirements for a hazard mitigation analysis (HMA), fire and explosion testing in accordance with UL 9540A [B14], emergency planning, and annual training. (The 2021 International Fire Code (IFC) [B2] has language that has been largely harmonized with NFPA 855, so the requirements are similar.)

This guide provides recommendations for pre-incident planning and incident response. Additional tutorial content is provided for each of the hazard categories. The Bibliography provides references to applicable codes and standards, and other documents of interest.

2 Abbreviations and acronyms

AHJ	authority having jurisdiction
BMS	battery management system
ERP	emergency response plan (designated in NFPA 855 as ‘emergency operations plan’)
ESS	energy storage system
HMA	hazard mitigation analysis
IDLH	immediately dangerous to life and health
LEL	lower explosive limit
LFL	lower flammable limit
LFP	lithium iron phosphate battery
Li-ion	lithium-ion
NCA	lithium nickel-cobalt-aluminum oxide
NFPA	National Fire Protection Association
NMC	lithium nickel-manganese-cobalt oxide
PPE	personal protective equipment
SCBA	self-contained breathing apparatus
SDS	safety data sheet
SME	subject-matter expert
UFL	upper flammable limit
UL	Underwriters Laboratories

¹ References in square brackets are to the Bibliography at the end of this guide.

3 Pre-incident planning

3.1 General

The pre-incident plan is used by first responders in effectively managing emergencies. It is required to be available to the incident commander during an event. The plan should be in accordance with the newly released NFPA 1660 [B9]. From the front matter of this new document: “The 2024 edition of NFPA 1660 integrates NFPA 1600, NFPA 1616, and NFPA 1620 into a single standard that establishes a common set of criteria for emergency management and business continuity programs; mass evacuation, sheltering, and re-entry programs; and the development of pre-incident plans for emergency response personnel.” Pre-incident planning, formerly in NFPA 1620, is in Chapters 17 through 23.

Additional ESS-specific guidance is provided in the NFPA Energy Storage Systems Safety Fact Sheet [B10]. NFPA 855 requires several submittals to the authority having jurisdiction (AHJ), all of which should be available to the pre-incident plan developer. These include:

- Results of fire and explosion testing conducted in accordance with UL 9540A
- Hazard mitigation analysis (HMA)
- Emergency response plan (ERP)

While the main document for development of the pre-incident plan is the ERP, the UL 9540A test results and HMA may provide useful additional information for the plan and associated training.

3.2 UL 9540A test results

Testing to UL 9540A provides information at a level of detail that may not be included in the ERP (see 3.4). Cell-level testing provides a breakdown of the composition of vented gas from cells in thermal runaway, including flammable gases and vapors. Potentially significant concentrations of highly toxic hydrogen fluoride may also be produced. Video recordings are made of testing at unit (rack) and installation levels (if the latter is performed). These test results and videos can be used in first-responder training (see 3.6) since they provide insight into system behavior in a thermal runaway event that cannot be gained from outside the enclosure.

3.3 HMA

While testing to UL 9540A is valuable, it involves initiation of thermal runaway in a limited number of cells. This method does not address larger-scale failures that could occur, for example, with a loss of insulation and subsequent arcing, or with mechanical damage potentially caused by vehicle impacts or flying debris. Such failures could result in a fire that consumes the entire enclosure. The HMA should address such an occurrence and should assess, at least by simulation or calculation, the maximum temperature rise of cells in adjacent enclosures. This information is used to justify limited spacing between enclosures and can also be used to determine whether first responders should intervene.

3.4 ERP

The ERP forms the basis for pre-incident planning. Among other information, the ERP should include details on the following:

- Site overview and ESS nameplate information
- Potential hazards
- Fire protection and safety systems
- Emergency response recommendations

- Emergency contacts, including subject-matter expert (SME)
- Safety data sheets (SDS)
- PPE

The firefighting philosophy should be outlined, whether that be to suppress the fire using built-in systems or to let it burn out safely (and in some cases, to make it burn. See 5.1.)

3.5 Availability of battery management system data

Access to battery management system (BMS) data is critical for informed incident response. Depending on the severity of the incident, it may be possible to observe the current conditions within the enclosure where the incident began, such as module temperatures and readings for any gas sensing systems that may be installed. If a fire is in progress, it is important to monitor module temperatures in adjacent enclosures, to determine whether additional actions should be taken.

BMS access may be direct, such as using a first responder's computer to access the local human-machine interface or a remote digital twin, or it may be indirect, such as through a voice connection to a network operations center or SME. Data may also be available on a screen local to each enclosure, but this should not be accessed if there is any danger of fire, explosion, or toxic emissions.

3.6 Training

NFPA 855 mandates initial and annual refresher training for facility staff (see section 4.3.2.2). First responders should be included in such training, either in person or via video recordings of the training sessions. Trainees should be familiar with the site layout, installed equipment, SDS contents, and emergency response recommendations of the ERP.

4 Incident response

4.1 General

An incident command system should be established immediately on arrival, and an appropriate incident command individual should have access to BMS data (see 3.5). Working with facility personnel, the scene should be assessed, and potential hazards should be communicated to all responders.

4.2 Personal protective equipment (PPE)

Full firefighter protective gear should be worn where there is any possibility of fire or explosion, including proper use of self-contained breathing apparatus (SCBA). If there is no risk of fire or explosion per the project incident command, protective clothing for arc-flash and shock hazards should be worn by anyone operating within the arc-flash boundary (see 4.5). Jewelry and other metallic items should be removed.

4.3 Fire

If a fire is in progress, flammable gases will be consumed as they are released, and an explosion is unlikely. The safest approach is to allow the enclosure to burn in a controlled manner, so that all fuel is consumed and the possibility of reignition is minimized. BMS data from adjacent enclosures should be monitored to verify that module temperatures remain at safe levels (typically up to around 80 °C/180 °F). Application of water should be limited to cooling and protecting nearby exposures (and adjacent enclosures if module temperatures are above thresholds identified in the ERP).

Once the fire has self-extinguished, there may be ongoing releases of flammable or toxic gases. Full protective gear and SCBA should continue to be used until releases (such as carbon monoxide) are measured to be at a safe level.

If an earlier fire has been extinguished by the enclosure's fire suppression system, there is a potential for ongoing release of flammable gases, with a corresponding explosion risk (see 4.4). See 5.1 for additional discussion of fire hazards.

4.4 Explosion

If system sensors (temperature, smoke, heat, and/or flammable gas) indicate that a thermal runaway event occurred, but there is no sign of fire, it should be assumed that an explosion risk is present. Personnel should be stationed outside the potential blast radius, at an angle to the doors, and upwind of the enclosure. The enclosure should be inspected from a distance using BMS data to determine the status of the system, including module temperatures, gas sensing, and ventilation systems for gas exhaust. If the BMS is not functioning because of system damage, thermal scanning may provide an indication of ongoing thermal issues. However, responders should be aware that enclosure insulation may make it difficult to make an accurate assessment of internal temperature.

If the enclosure has been vented by automatic door or panel opening and there is no indication of high temperatures, the enclosure may be approached by responders using continuous gas monitoring to warn of any residual atmospheric risk.

If the enclosure appears to be sealed – for example, if gas venting is accomplished through a magnetic flap or if there is no provision for gas venting – BMS data and external visual assessment should be reviewed with the SME before attempting to open the enclosure.

See 5.2 for additional discussion of explosion hazards.

4.5 Arc flash and electric shock

Even when disconnected from external circuits, batteries retain their stored energy and should be considered to be energized. A battery may be partially destroyed by fire yet retain stranded energy at hazardous levels. All batteries, whatever their visual condition, should be treated as fully charged with respect to arc flash and electric shock hazards.

Appropriate PPE should be worn by properly trained individuals when working within the arc flash boundary. See 5.3 for additional discussion of arc flash and shock hazards.

4.6 Toxic chemicals

Toxic chemicals, including hydrogen fluoride, hydrogen chloride, hydrogen cyanide, and carbon monoxide, may be released during an incident. Spraying water on smoke or vapor released from the battery, whether burning or not, may cause skin or lung irritation and contaminated run-off similar to plastic fires [B1]. This is one additional reason for allowing the battery to burn in a controlled manner. The site perimeter should be entered only by trained firefighters wearing full protective gear and using SCBA. See 5.4 for additional discussion of toxic chemical hazards.

5 Discussion of Li-ion hazards

5.1 Fire

There is ongoing debate in the energy storage industry over the merits of fire suppression in outdoor battery enclosures. On one hand, successful deployment of clean-agent fire suppression in response to a limited event (for example, an electrical fire or single-cell thermal runaway with no propagation) can limit damage to the system, which can then be expeditiously returned to service. On the other hand, actuation of the same system in response to a large event, such as a multicell arcing fault, may knock out or prevent a fire but allow ongoing release of flammable gases, thus creating an explosion hazard.

Some ESS designs employ a ‘make it burn’ strategy, in which a sparker ignites flammable gas when the lower flammable limit (LFL) is exceeded but before the lower explosive limit (LEL) is reached. Such designs do not include fire suppression, on the basis that the loss of an enclosure through controlled burning is preferable to increasing the risk of an explosion. This strategy can be effective for Li-ion technologies based on transition metal oxides, such as lithium nickel-cobalt-aluminum oxide (NCA) and lithium nickel-manganese-cobalt oxide (NMC) materials, which release oxygen during thermal runaway, thus maintaining a flammable gas mixture. The same arrangement would potentially be less effective for batteries using lithium iron phosphate (LFP) material, as discussed in 5.2.

There are pros and cons to each of the common fire-suppression media in use today, including clean agents, inert gases, aerosols, and water.

- Clean agents, such as Novec 1230®, and inert gases, such as nitrogen, will extinguish small fires without causing extensive damage within the enclosure; they also have a cooling effect, which can assist in limiting thermal runaway propagation. In a larger-scale event, such as a multi-cell arcing fault, their effect may be temporary and may result in ongoing propagation with the risk of reignition or explosion. Also, inert gases are oxygen-depleting and cannot be used in structures where personnel may be present.
- Aerosol devices, such as Stat-X®, can be self-actuating, releasing based on elevated temperature without the need for control systems. They are effective on small fires and can help to limit initiation of thermal runaway. The aerosol itself is typically alkaline and may damage BMS and other electronic components in the enclosure. These devices are unlikely to be effective in larger-scale events or when thermal runaway is freely propagating between cells or modules.
- Water is the most efficient medium for cooling cells below the level at which thermal runaway can occur. However, to be effective, the water must be able to reach cells that may be otherwise shielded within closely spaced modules. This means that directed spray across the top of each module is more likely to achieve full extinguishing and arresting of propagation than can be realized with ceiling-mounted sprinklers, and this precise coverage may not always be feasible to achieve. Liberal use of water may also serve as the initiator for electrical arcing that may cause thermal runaway in otherwise unaffected modules. Additionally, the combination of water and highly energized battery systems could electrolytically generate more explosive hydrogen gas. Finally, similar to plastics fires [B1] use of water for directly targeting a fire will also create contaminated run-off [B11], which must be contained and removed for treatment.

5.2 Explosion

Venting of all Li-ion cells results in the release of a gas mixture with high levels of hydrogen, carbon monoxide, and carbon dioxide. Depending on the circumstances, there may also be a fog of unreacted flammable organic compounds, and hydrogen fluoride (normally in trace amounts, but can be higher). The volume of gas released is typically orders of magnitude greater than the cell volume. In the absence of fire, this gas mixture poses an explosion risk.

NFPA 855 requires design provisions for either explosion prevention in compliance with NFPA 69 [B5], or explosion management according to NFPA 68 [B4]. However, systems only complying with NFPA 68 can present explosion hazards to first responders if the following conditions are met: 1) the atmosphere in the enclosure is above the upper flammable limit (UFL), 2) the system has no remote means to ventilate its contents, 3) and a door is opened. Caution and deliberation with the project SME should be taken in situations where gas has accumulated, and automatic ventilation is either not present or not functioning.

The 'make it burn' strategy for explosion prevention is discussed in 5.1. This approach may be less effective for batteries using LFP technology, from which minimal amounts of oxygen are released during thermal runaway. In a multi-cell arcing fault and in the absence of emergency ventilation with outside air, the available oxygen in the enclosure would be quickly consumed. Further cell venting would drive the gas concentration above the UFL, creating the same hazard described in the previous paragraph.

Ventilation for explosion prevention may be accomplished by the automatic opening of doors or other panels. While this measure is unlikely to meet the requirements of NFPA 69, it addresses the intent of the standard and can be important for protecting first responders. It should be noted that this procedure will reduce the effectiveness of airborne fire suppressants and is more compatible with a 'let it burn' philosophy.

5.3 Arc flash and shock

Battery strings in an enclosure involved in an incident should have been tripped by the BMS, but as detailed in 4.5, they can continue to present arc-flash and shock hazards. Many ESS designs now operate at dc voltages up to 1500 V, representing a significant risk to untrained personnel. At the time of preparing this guide, there is ongoing work on characterization of dc arc-flash hazards, and it is likely that this work will inform future changes to NFPA 70E [B7].

5.4 Toxic chemicals

Recommendations for first responders are detailed in 4.6. Emissions from battery fires vary by battery chemistry and state of charge. Toxicity issues are discussed at length in [B1], where it is stated that hydrogen chloride is the chemical that reaches its IDLH (immediately dangerous to life and health) value fastest. In terms of 30-minute average release rates as a function of IDLH, the greatest concern is with hydrogen fluoride, followed by hydrogen cyanide, hydrogen chloride, and carbon monoxide.

6 Bibliography

The following documents are discussed in this guide:

- [B1] DNV-GL, Considerations for ESS Fire Safety, Report for Consolidated Edison and NYSERDA, 2017
- [B2] International Fire Code (IFC), 2021, International Code Council, Inc.
- [B3] NFPA 1, Fire Code, 2021
- [B4] NFPA 68, Standard on Explosion Protection by Deflagration Venting, 2018
- [B5] NFPA 69, Standard on Explosion Prevention Systems, 2019
- [B6] NFPA 70, National Electrical Code, 2023
- [B7] NFPA 70E, Standard for Electrical Safety in the Workplace, 2021
- [B8] NFPA 855, Standard for the Installation of Stationary Energy Storage Systems, 2023
- [B9] NFPA 1660, Standard for Emergency, Continuity, and Crisis Management: Preparedness, Response, and Recovery, 2024
- [B10] NFPA Energy Storage Systems Safety Fact Sheet, available from the NFPA website
- [B11] Quant, M., Willstrand, O., Mallin, T., Hynynen, J., Ecotoxicity Evaluation of Fire-Extinguishing Water from Large-Scale Battery and Battery Electric Vehicle Fire Tests. *Environ. Sci. Technol.* <https://doi.org/10.1021/acs.est.2c08581>
- [B12] UL 1973 Ed. 3, ANSI/CAN/UL Batteries for Use in Stationary and Motive Auxiliary Power Applications, 2022
- [B13] UL 9540 Ed. 2, Energy Storage Systems and Equipment, 2020
- [B14] UL 9540A Ed. 4, ANSI/CAN/UL Standard for Test Method for Evaluating Thermal Runaway Fire Propagation in Battery Energy Storage Systems, 2019